



**Sharon W. Peavyhouse**  
H. B. Robinson Steam  
Electric Plant Unit 2  
Manager – Support Services

**Duke Energy Progress**  
3581 West Entrance Road  
Hartsville, SC 29550

O: 843 857 1584  
F: 843 857 1319

*Sharon.Peavyhouse@duke-energy.com*

10 CFR 72.44(d)(3)

Serial: RNP-RA/14-0027

**FEB 24 2014**

United States Nuclear Regulatory Commission  
Attn: Document Control Desk  
Director, Division of Spent Fuel Storage and Transportation  
Office of Nuclear Material Safety and Safeguards  
Washington, DC 20555-0001

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261/RENEWED LICENSE NO. DPR-23

INDEPENDENT SPENT FUEL STORAGE INSTALLATION  
DOCKET NO. 72-3/LICENSE NO. SNM-2502

INDEPENDENT SPENT FUEL STORAGE INSTALLATION  
DOCKET NO. 72-60

**INDEPENDENT SPENT FUEL STORAGE INSTALLATION  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT**

Ladies and Gentlemen:

In accordance with 10 CFR 72.44(d)(3), Duke Energy Progress, Inc. is providing the Annual Radioactive Effluent Release Report for the period January 1, 2013 through December 31, 2013 for the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, Independent Spent Fuel Storage Installations (ISFSIs).

The HBRSEP, Unit No. 2, site contains two ISFSI facilities. One facility operates under a site-specific license, which was originally issued in 1986 and was renewed in 2005. For that facility, this report is also submitted in accordance with License No. SNM-2502, Appendix C, Technical Specifications for Environmental Protection, Section 1.4.1. The second facility operates under a general license and began operation in 2005.

Both facilities employ the Transnuclear, Inc., NUHOMS® design. The design for both facilities includes seal welded storage canisters, such that there is no potential for gaseous or liquid radioactive effluents. Surveillances performed during the year confirm that the storage canisters are performing as designed. Hence, there were no gaseous or liquid radioactive effluents during 2013 for either facility.

There are no regulatory commitments made in this submittal. If you have any questions regarding this submittal, please contact Mr. R. Hightower at (843) 857-1329.


IE48  
HMS26

United States Nuclear Regulatory Commission

Serial: RNP-RA/14-0027

Page 2 of 2

Sincerely,

A handwritten signature in cursive script that reads "Sharon W. Peavyhouse".

Sharon W. Peavyhouse  
Manager – Support Services

SWP/msc

cc: Mr. V. M. McCree, NRC, Region II  
Mr. S. P. Lingam, NRC Project Manager, NRR  
Director, Spent Fuel Storage and Transportation  
NRC Resident Inspector, HBRSEP, Unit No. 2  
NRC Document Control Desk