



Ensuring Spent Fuel Pool Safety

Michael Weber
Deputy Executive Director for Operations
U.S. Nuclear Regulatory Commission

American Nuclear Society Meeting
June 28, 2011

Insights from Fukushima

- Nuclear emergency at Fukushima-Daiichi
 - 3 nuclear reactors
 - 4 reactor spent fuel pools
 - 1 common spent fuel pool



U.S. Spent Fuel Pools

- Spent fuel rods stored in spent fuel pools (SFPs) under at least 20 feet of water
- Typically ~1/4 to 1/3 of fuel in reactor replaced with fresh fuel every 18 to 24 months
- Spent fuel stored in pools minimum of 5 years

U.S. SFP Safety

- Spent Fuel Pools (SFP) originally designed for limited storage of spent fuel until removed off-site
- Safety of spent fuel in pools achieved primarily by maintaining water inventory, geometry, and soluble boron (PWRs)
- Drain down can lead to uncovered fuel, heat-up, and the release of radionuclides



Risk of Large Release

- SFP risk is low, due to the low frequency of events that could damage the thick reinforced pool walls
 - Frequency of fuel uncover; 6E-7 to 2E-6/yr. – NUREG-1738
 - Consequences have been assessed to be large due to the potential for heatup of all the fuel in the pool
 - Heatup of the fuel in the pool can lead to “zirconium fire” initiation and propagation
 - Large inventory of Cs-137

SFP Safety and Security


- NRC extensively reexamined pool safety and security after 9-11 attacks
 - Vulnerability to attack
 - Significantly improved analysis of fuel coolability / heatup
 - Assessment of mitigation measures to improve coolability of fuel
 - Improved fuel configuration within the pool achieves substantially greater passive cooling capability by natural convection

SFP Safety and Security


- Additional analyses of a spray system for spent fuel pool cooling
- NRC required spray capability for each site to improve active cooling capability
- Licensees performed site-specific assessments; NRC inspected
- Coolability of fuel within pools has been enhanced by measures identified and assessed as part of post-9/11 research
- Conducting research to confirm understanding and validate analytical modeling

Zirconium Fire Investigations During SFP Loss of Coolant Accident (LOCA)


- Prototypic full length 9×9 BWR hardware
 - Single pool rack cell
 - Upper & lower tie plates with seven spacers
 - Water tubes and channel box
 - 74 electric heater rods with Zr-2 cladding (eight partial length)
 - 5000 W simulating a 100 day old assembly
- Measurements
 - Temp profiles: Axial and radial
 - Induced flow: Effect of ignition on flow
 - O₂ concentration: Determine depletion
 - Nature of fire: Initiation location & axial burn rate



Zirc Fire Investigations During SFP LOCA – Postmortem



Full Length
Single
Assembly
Ignition
Melted




Removing Fuel from Pools

- NRC has considered benefits of removal of fuel from the pool and returning to a low density racking type configuration
- There are competing factors in such a consideration:
 - Storage in dry casks must be consistent with certificate
 - Discharging of fuel increases the risk of cask drops and worker doses
 - Removal of fuel will decrease the inventory of Cesium-137
 - Removal of fuel does not appreciably reduce decay heat (most of the decay heat is from recently discharged fuel)
 - Reduction in potential land contamination and economic impacts, if a large release occurred

Impact of Removing Assemblies

Reduction of pool thermal heat load



Comparative Consequence Study

- NRC is initiating an updated SFP study
- Estimate the change in accident consequences associated with removing older fuel from the SFP and placing it in dry storage
- Limited scope analysis (e.g., single SFP/operating cycle for low/high density racking)


Comparative Consequence Study for SFP

- Technical approach relies on realistic analysis using expedient but technically-defensible deterministic methods and assumptions.
- Elements of study include
 - Information gathering
 - Seismic and structural assessment
 - Accessibility, decay heat, and radionuclide inventory assessment
 - Accident progression (MELCOR) and offsite consequence analysis (MACCS2)
 - Emergency planning assessment

Conclusions

- No immediate safety concerns based on Fukushima nuclear emergency
- Confirmed the existing safety measures for SFPs
- Examining both the near-term and long-term reviews
- Spent fuel needs to be managed safely and securely

OK To Release
1



RESPONDING TO FUKUSHIMA-DAIICHI



Michael Weber

Deputy Executive Director for Materials, Waste, Research,
State, Tribal, and Compliance Programs
U.S. Nuclear Regulatory Commission

INMM – U.S. NIC Meeting
January 31, 2012

Overview

- Timeline
- Near-Term Task Force
- Enhancements
- Spent Fuel Safety
- Conclusions



Timeline



-
- December 16, 2011
Japan Announces Cold Shutdown Fukushima Units 1, 2, and 3
- October 18, 2011
Commission approved proceeding with high priority recommendations
- March 11, 2011
Earthquake, Tsunami, Nuclear Emergency
- TODAY**
Ongoing Stakeholder involvement as staff prepares to issue orders and requests for information
- December 15, 2011
Commission approved proceeding with next highest priority recommendations
- July 12, 2011
Near-Term Task Force Report




Current U.S. Plant Safety


- Similar sequence of events in the U.S. is unlikely
- Existing mitigation measures could reduce the likelihood of core damage and radiological releases
- No imminent risk from continued operation and licensing activities



Approach on Near Term Enhancements




- Commission approved implementation of specific recommendations
 - Issue orders, requests for information (50.54(f) letters), and new regulations
 - Seek stakeholder input in determining action on each recommendation



Enhancements without Delay




- Reevaluate external hazards, including seismic and flooding hazards
- Perform seismic and flooding hazard walkdowns
- Modify SBO rule to require enhanced capability to mitigate prolonged SBO



Enhancements without Delay (cont'd)


- Mitigation Strategies for Beyond Design Basis External Events
- Require reliable hardened vent designs in BWRs with Mark I and II containments
- Enhancement of spent fuel pool instrumentation




Enhancements without Delay (cont'd)




- Strengthen and integrate onsite emergency response capabilities
- Rapidly staffing and communications equipment to respond to multiunit events and prolonged SBO



Recommendations for Other Actions




- Tier 2 Recommendations – Could not be initiated in the near term due to resources or critical skill set limitations
- Tier 3 Recommendations – Requiring further staff study to support a regulatory action




Additional Issues




- Filtration of Containment Vents
- Seismic Monitoring Instruments
- Emergency Planning Zone Size
- KI Beyond 10 Miles
- Dry Cask Storage
- Loss of Ultimate Heat Sink



Schedule



- FY2012 Appropriations – Accelerate schedule
- NRC goal is to issue Tier 1 Orders and 50.54(f) letters by March 11th
- Planning to submit to the Commission by February 17; Commission will direct the staff
- Overall Goal – Complete enhancements in 5 years



NRC Follow-up





- Review and assess licensee responses
- Establish necessary regulatory framework
- Inspect to ensure compliance with all new regulatory requirements
- Consider implications for other nuclear facilities



U.S. Spent Fuel Pools

- Spent fuel rods stored in spent fuel pools (SFPs) under at least 20 feet of water
- Typically ~1/4 to 1/3 of fuel in reactor replaced with fresh fuel every 18 to 24 months
- Spent fuel stored in pools minimum of 5 years





Spent Fuel Safety

- Spent Fuel Pools (SFP) originally designed for limited storage of spent fuel until removed off-site
- Safety achieved primarily by maintaining water inventory, geometry, and soluble boron (PWRs)
- Drain down can lead to un-covered fuel, heat-up, and the release of radionuclides



Risk of Large Release

- SFP risk is low, due to the very low likelihood of events that could damage the thick reinforced pool walls
 - Likelihood of fuel uncover is low; 6E-7 to 2E-6/yr (NUREG-1738)
 - Potential consequences may be large due to heatup of the fuel in the pool
 - Heatup of the fuel in the pool can lead to “zirconium fire” initiation and propagation
 - Large inventory of ^{137}Cs available for release



Spent Fuel Safety and Security

- NRC extensively reexamined pool safety and security after 9-11 attacks
 - Low vulnerability to attack
 - Significantly improved analysis of fuel coolability / heatup
 - Mitigation measures include the
coolability of fuel
 - Improved fuel cooling design
achieves substantially greater passive cooling
capability by natural convection


Spent Fuel Safety and Security

- NRC required spray capability for each site to improve active cooling capability
- Licensees performed site-specific assessments; NRC inspected
- Coolability of fuel within pools has been enhanced by measures identified and discussed as part of post-9/11 measures
- Conducting research to confirm understanding and validate analytical modeling





Zirconium Fire Investigations During SFP Loss of Coolant Accident (LOCA)

- Prototypic full length 9 × 9 BWR hardware
 - Single pool rack cell
 - Upper & lower tie plates with seven spaces
 - Water tubes and channel box
 - 74 electric heater rods with Zr-2 cladding (eight partial length)
 - 5000 W simulating a 100 day old assembly
- Measurements
 - Temp profiles: Axial and radial
 - Induced flow: Effect of ignition on flow
 - O₂ concentration: Determine depletion
 - Nature of fire: Initiation location & axial burn rate



Zirc Fire Investigations During SFP LOCA – Post-test





Removing Fuel from Pools

- NRC has considered benefits of removal of fuel from the pool and returning to a low density packing type configuration
- There are competing factors in such a consideration
 - Storage in dry casks must be consistent with cask design
 - Discharging of fuel increases the risk of cask drops and increases worker doses
 - Removal of fuel will decrease the inventory of Cesium-137
 - Removal of fuel does not appreciably reduce decay heat (most of the decay heat is from recently discharged fuel)
 - Reduction in potential land contamination and economic impacts, if a large release occurred




Impact of Removing Assemblies

Reduction of pool thermal heat load




Spent Fuel Pool Scoping Study

- NRC has initiated an updated SFP study
- Estimate the change in accident consequences associated with removing older fuel from the SFP and placing it in dry storage
- Limited scope analysis (e.g., single SFP per cooling cycle for low/high density rods/stack)
- Does not comprehensively consider competing factors (e.g., impact of waste fuel moves)



Comparative Consequences

- Technical approach relies on realistic analysis using expedient and technically-defensible deterministic methods and assumptions
- Elements of study include
 - Information gathering
 - Seismic and structural assessment
 - Accessibility, decay heat, and radionuclide inventory assessment
 - Accident progression (MELCOR) and offsite consequence analysis (MACCS2)
 - Emergency planning assessment



Conclusions

- No immediate safety concerns based on Fukushima nuclear emergency
- Confirmed the existing safety measures for nuclear power plants, including SFPs
- Moving forward with nuclear power plant enhancements
- Examining additional near-term and long-term reviews
- Spent fuel must be managed safely and securely

