RTL-001-CALC-ST-0403 Rev 4_Redacted

é in a					CALC.	NO. RTL-0	01-CALC-ST-0403		
EBF	ENERCON CALCULATION COVER SHEET REV. 4								
					PAGE	10. 10	f 16		
Title:	Pin Puncture Evaluation	n		Client:	Robate	l Technolog	ies, LLC		
	Project: RTL-001								
ltem		Cover Sheet Ite	ms			Yes	No		
1	Does this calculation co (If YES , Identify the ass	ontain any open assum sumptions)	ptions that requi	ire confirm	ation?		\boxtimes		
2	Does this calculation serve as an "Alternate Calculation"? (If YES, Identify the design verified calculation.) Design Verified Calculation No.								
3	Does this calculation S superseded calculation Superseded Calculati	upersede an existing C .) on No	alculation? (If Y	ES, identif	y the				
Revisio N/A	on Impact on Results:								
					⊠				
	Sat	fety-Related 🔯	Non-Safety	Related			<u> </u>		
		(Print	t Name and Sig	n)			· ···		
Origina	tor: David Hartmangru	iber paves Hart	rematule	2	Date:	01/03/201	4		
Design	Verifier: Curt Lindner	WON #	e U	4	Date:	01/03/201	4		
Approv	er: Nand Lambha	-10	MAMS	10	Date:	01/03/201	14		

.

.

	CALC. NO.	RTL-001-CALC-ST-0403					
CALCULATION REVISION STATUS SHEET		4					
		2 of 16					
CALCULATION REVISION STATUS							
<u><u></u></u>	ESCRIPTION						
Initial Issue							
Updated material all	owables based	on RAI responses					
Incorporat	ed customer co	omments					
Updated calculation and drawing references							
Updated calculation and drawing references							
EVISION STATUS							
PAGE NO.		REVISION					
	CULATION STATUS SHEET	CULATION STATUS SHEET CALC. NO. REV. PAGE NO. NREVISION STATUS DESCRIPTION Initial Issue Updated material allowables based Incorporated customer co Updated calculation and drawi Updated calculation and drawi					

APPENDIX REVISION STATUS							
APPENDIX NO.	PAGE NO.	REVISION NO.	APPENDIX NO.	PAGE NO.	REVISION NO.		
1	1-3	3					
2	1-1	3					
3	1-3	3					

	CALCULATION	CALC. NO. RTL-001-CALC-S
	Excellence—Every project. Every day	
	PLAN AND SUMMARY SHEET	PAGE NO. 3 of 16
Calculation Design Verification	Plan:	
Calculation to be reviewed for corr accuracy.	ectness of inputs, design criteria, analytical	methods, acceptance criteria and nu
Stated objectives and conclusions	shall be confirmed to be reasonable and va	ilid.
Any assumptions shall be clearly oprinciples and practices.	documented and confirmed to be appropriat	e and verified based on sound engine
(Print	Name and Sign for Approval – mark "N/A	" if not required)
	MILLAUN M.O	
Approver: Nand Lambha	MM UMASUL	Date: 01/03/2014
Calculation Design Verification	Summary:	
Calculation has been designated a	as Safety Related as noted on the cover sh	eet.
Calculation has been verified to be assumptions, analytical methods,	e mathematically correct and performed in a design criteria and acceptance criteria.	ccordance with appropriate design in
Calculation has been verified to be assumptions, analytical methods, The conclusions developed in the	e mathematically correct and performed in a design criteria and acceptance criteria. calculation are reasonable, valid and consistent of the second sec	ccordance with appropriate design in stent with the purpose and scope.
Calculation has been verified to be assumptions, analytical methods, The conclusions developed in the Assumptions are appropriate and	e mathematically correct and performed in a design criteria and acceptance criteria. calculation are reasonable, valid and consis correct.	ccordance with appropriate design in stent with the purpose and scope.
Calculation has been verified to be assumptions, analytical methods, The conclusions developed in the Assumptions are appropriate and	e mathematically correct and performed in a design criteria and acceptance criteria. calculation are reasonable, valid and consis correct.	ccordance with appropriate design in stent with the purpose and scope.
Calculation has been verified to be assumptions, analytical methods, The conclusions developed in the Assumptions are appropriate and	e mathematically correct and performed in a design criteria and acceptance criteria. calculation are reasonable, valid and consis correct.	ccordance with appropriate design in stent with the purpose and scope.
Calculation has been verified to be assumptions, analytical methods, The conclusions developed in the Assumptions are appropriate and	e mathematically correct and performed in a design criteria and acceptance criteria. calculation are reasonable, valid and consis correct.	ccordance with appropriate design in
Calculation has been verified to be assumptions, analytical methods, The conclusions developed in the Assumptions are appropriate and	e mathematically correct and performed in a design criteria and acceptance criteria. calculation are reasonable, valid and consis correct.	ccordance with appropriate design in
Calculation has been verified to be assumptions, analytical methods, The conclusions developed in the Assumptions are appropriate and	e mathematically correct and performed in a design criteria and acceptance criteria. calculation are reasonable, valid and consis correct.	ccordance with appropriate design in
Calculation has been verified to be assumptions, analytical methods, The conclusions developed in the Assumptions are appropriate and	e mathematically correct and performed in a design criteria and acceptance criteria. calculation are reasonable, valid and consis correct.	ccordance with appropriate design in
Calculation has been verified to be assumptions, analytical methods, The conclusions developed in the Assumptions are appropriate and Based On The Above Summary	e mathematically correct and performed in a design criteria and acceptance criteria. calculation are reasonable, valid and consis correct.	ccordance with appropriate design in stent with the purpose and scope.
Calculation has been verified to be assumptions, analytical methods, The conclusions developed in the Assumptions are appropriate and Based On The Above Summary	e mathematically correct and performed in a design criteria and acceptance criteria. calculation are reasonable, valid and consis correct. , The Calculation Is Determined To Be Ac (Print Name and Sign)	ccordance with appropriate design in stent with the purpose and scope.
Calculation has been verified to be assumptions, analytical methods, The conclusions developed in the Assumptions are appropriate and Based On The Above Summary Design Verifier: Curt Lindner	e mathematically correct and performed in a design criteria and acceptance criteria. calculation are reasonable, valid and consis correct. , The Calculation Is Determined To Be Ac (Print Name and Sign)	ccordance with appropriate design in stent with the purpose and scope. cceptable. Date: 01/03/2014

		CALCULATION		C. NO.	RTL-001-CALC-ST-0403		
ÉA E	ENERCON	DESIGN VERIFICATION	REV.		4		
	Excellence—Every project. Every day.	CHECKLIST	PAG	E NO.	4 of 16		
ltem		CHECKLIST ITEMS		Yes	No	N/A	
1	Design Inputs - Were the (latest revision), consistent calculation?	ne design inputs correctly selected, referenced ant with the design basis, and incorporated in t	he	x			
2	Assumptions - Were th described, justified and/		x				
3	Quality Assurance - W requirements assigned t	ere the appropriate QA classification and other calculation?		x	-		
4	Codes, Standards, and codes, standards, and re addenda, properly identi	Regulatory Requirements - Were the applic egulatory requirements, including issue and fied and their requirements satisfied?	able	x			
5	Construction and Oper and operating experience	rating Experience - Have applicable construct e been considered?	tion			х	
6	Interfaces - Have the de including interactions with	esign-interface requirements been satisfied, th other calculations?		х			
7	Methods - Was the calc applied to satisfy the cal		х				
8	Design Outputs - Was it correspond directly wit compared to the inputs?	the conclusion of the calculation clearly stated h the objectives, and are the results reasonab	, did le	х			
9	Radiation Exposure - Has the calculation properly considered radiation exposure to the public and plant personnel?					x	
10	Acceptance Criteria - A calculation sufficient to a been satisfactorily accor	Are the acceptance criteria incorporated in the allow verification that the design requirements nplished?	have	x			
11	Computer Software- Is are the requirements of	a computer program or software used, and if s CSP 3.02 met?	so,	x			
COMME	ENTS						
-		(Print Name and Sign)					
Design V	/erifier: Curt Lindner	MAR	Date	e: 01/03	/2014		
Others:		0	Date	e:			



PAGE NO. 5 of 16

4

REV.

Table of Contents

Calcula	ation Cover Sheet	1
Calcula	ation Revision Status Sheet	2
Calcula	ation Design Verification Plan and Summary Sheet	3
Calcula	ation Design Verification Checklist	4
1.0	Purpose and Scope	6
2.0	Summary of Results and Conclusions	7
3.0	References	8
4.0	Assumptions	9
5.0	Design Inputs	9
6.0	Methodology	9
7.0	Calculation1	3
APPEN	NDIX 1—Figures	1
APPEN	NDIX 2—Input and Output File Organization	1
APPE	NDIX 3—Output File Listing	1

	CALCULATION CONTROL SHEET	CALC. NO. RTL- 001-CALC-ST-0403		
E E N E R C O N		REV.	4	
encenence every project every buy		PAGE I	NO. 6 of 16	

1.0 Purpose and Scope

The purpose of this report is to document the Robatel Technologies RT-100 cask body analyses and show that the design meets the requirements of 10 CFR Part 71 (1). Specifically, the evaluation addresses the loads associated with Part 71.73(c)(3) hypothetical accident condition (HAC) puncture. The puncture load includes:

"A free drop of the specimen through a distance of 1 m (40 in) in a position for which maximum damage is expected, onto the upper end of a solid, vertical, cylindrical, mild steel bar mounted on an essentially unyielding, horizontal surface. The bar must be 15 cm (6 in) in diameter, with the top horizontal and its edge rounded to a radius of not more than 6 mm (0.25 in), and of a length as to cause maximum damage to the package, but not less than 20 cm (8 in) long. The long axis of the bar must be vertical. Two thermal conditions are evaluated, a hot and cold case. The hot case represents 38°C (100°F) ambient temperature and maximum insolance and heat load. The cold case represents -40°C (-40°F) with maximum heat load."

The pin puncture evaluation includes classic calculations and finite elements analyses to show the RT-100 cask meets the pin puncture load requirements. The finite element analysis results of the lid pin puncture analysis is presented pictorially in stress intensity contour plots as well as in table form, with the corresponding safety factors in each component of the cask body.

Proprietary Information Content Withheld Under 10 CFR 2.390

	CALCULATION CONTROL SHEET	CALC. NO. RTL- 001-CALC-ST-0403			
		REV.	4		
Excenence revery project every day		PAGE NO . 7 of 16			

2.0 Summary of Results and Conclusions

Structural analyses were performed for the Robatel Technologies RT-100 cask for hypothetical accident conditions pin puncture. To evaluate the RT-100 cask, classical calculations and a 3-D ANSYS model are used to analyze the governing puncture cases. All structural members have a positive margin of safety under worst case loading conditions. It is concluded that the RT-100 cask is structurally adequate for the HAC pin puncture loading conditions. The requirements of 10 CFR 71 covered by this calculation have been satisfied.

	CALCULATION CONTROL SHEET	CALC. NO. RTL- 001-CALC-ST-0403			
		REV. 4			
		PAGE NO. 8 of 16			

3.0 References

- 1. NRC. "Title 10, Part 71—Packaging and Transportation of Radioactive Material". 10 CFR 71.
- 2. Baumeister T. and Marks, L.S. "Standard Handbook for Mechanical Engineers, 7th Edition". New York : McGraw-Hill Book Co., 1967.
- Shappert, L.B. "The Radioactive Materials Packaging Handbook". Oak Ridge, Tennessee : Oak Ridge National Laboratory, 1988. ORNL/M-5003.
- 4. NAC. "SAR UMS Transport Cask". Docket No. 71-9270.
- 5. ENERCON. "RT-100 Cask Weight and Center of Gravity Calculation". RTL-001-CALC-ST-0101, Rev. 0.
- 6. —. "RT-100 Cask Body Analysis". RTL-001-CALC-ST-0402, Rev. 4.
- 7. ASME. "2007 & 2010 ASME Boiler & Pressure Vessel Code, Section II, Part D, Properties (Metric) Materials.
- 8. Rack, H.J., Knorovsky, G.A. "An Assessment of Stress-Strain Data Suitable for Finite-Element Elastic Plastic Analysis of Shipping Containers". 1978. NUREG/CR-0481.
- 9. Baumeister T. and Marks, L.S. "Standard Handbook for Mechanical Engineers, 9th Edition". New York : McGraw-Hill Book Co., 1987.
- 10. ANSYS®. Mecahnical, Revision 14. s.l. : ANSYS, Inc.
- 11. Roark, Raymond J. "Roark's Formulas for Stress & Strain". 5th Edition. New York : McGraw-Hill, 1975.
- 12. Robatel. "ROBATEL Transport Package RT100 General Assy", Drawing RT100 PE 1001 Sht. 1 & 2 Rev. H.

	CALCULATION CONTROL SHEET	CALC. NO. RTL- 001-CALC-ST-0403		
ELENERCON		REV. 4		
excenence: -rvery project every buy		PAGE NO. 9 of 16		

4.0 Assumptions

- 4.1 The weight of the cask for the analytical evaluation of the hypothetical accident is considered as the total weight of the cask and the maximum payload. The damage sustained by the cask and the impact limiters during the free drop evaluations does not result in any significant reduction in load, so no reduction is considered. **Basis:** This is a conservative assumption without further evaluation required.
- 4.2 For the drop in the vertical orientation, the mild steel bar/pin is assumed to impact directly at the center cask lid. **Basis:** This loading configuration imposes the worst case prying force in the lid and closure bolts.
- 4.3 The flow stress for the mild steel pin used in this evaluation is 324 MPa (approximately 47,000 psi) per Chapter 5 of Reference (2) and Reference (3). **Basis:** Standard equation used to evaluate the puncture response of a cask.
- 4.4 For the end puncture case, the total load is limited by the flow stress of the puncture probe. **Basis:** Previous designs submitted to the NRC successfully adopted this methodology per Reference (4).

5.0 Design Inputs

- 5.1 The maximum payload weight is 6,804 kg (15,000 lb) (5).
- 5.2 The material properties used for the cask shell, the lead shielding and the lid bolts are given in Tables 6-1 through 6-3 of Section 6.0.
- 5.3 Cask performance criteria 10 CFR 71. 73 (1).
- 5.4 A value of 9.81 m/s² will be used for the gravitational acceleration.
- 5.5 Robatel Drawings:
 - RT100-NM-1000, Rev. F, RT-100 Bill of Materials
 - RT100-PE-1001-1, Rev. H, RT-100 General Assembly, Sheet 1
 - RT100-PE-1001-2, Rev. H, RT-100 General Assembly, Sheet 2
 - RT100-PRS-1011, Rev. E, RT-100 Cask Body Weld Map
 - RT100-PRS-1013, Rev. C, RT-100 Secondary Lid Weld Map
 - RT100-PRS-1031, Rev. D, RT-100 Lower Impact Limiter Weld Map
 - RT100-PRS-1032, Rev. D, RT-100 Upper Impact Limiter Weld Map

6.0 Methodology

To evaluate the puncture impact of the RT-100 cask, a combination of classic calculations and finite element analyses are used. For the finite element portion of the evaluation, refer to the cask body analysis calculation for explanation of modeling methodology and load combinations in Reference (6).

Ê	Ε	Ν	Ε	R	С	0	N	CALC
		EXCEP	enre	Ever	γ ριο _ι ε	PCI EVP	ry day	

*

Т

 CALC. NO. RTL- 001-CALC-ST-0403

 REV.
 4

TROE NO. TO OF TO	PAGE	NO.	10	of	16
-------------------	------	-----	----	----	----

Property*	Value									
Temperature (°C)	-40	21	38	93	149	204	260	343	427	482
Ultimate strength, S _u (MPa)	517.1	517.1	517.1	489.5	456.4	441.3	437.1	437.1	433.0	419.2
Yield strength, S _y (MPa)	206.8	206.8	206.8	172.4	154.4	142.7	133.8	124.1	116.5	111.7
Design Stress Intensity, S _m (MPa)	137.9	137.9	137.9	137.9	137.9	128.2	120.7	111.7	104.8	100.7
Modulus of Elasticity, E (GPa)	198.6	195.1	194.0	190.3	186.2	182.7	177.9	173.1	166.2	162.0
Coefficient of Thermal Expansion, α (×10 ⁻⁵ m/m/°C)	1.4634	1.5300	1.5480	1.6020	1.6560	1.7100	1.7460	1.7820	1.8180	1.8360
Thermal Conductivity, k (W/m•°C)	_	15.164	15.410	16.217	17.025	_	_	—	_	—
Specific Heat, (J/kg•°C)	_	6.977	4.916	2.510	1.706	_	_	_	_	_
Poisson's Ratio	0.31									
Density (kg/m³)		8027.2								

Table 6-1 – Properties of SA-240, Type 304/304L (dual certified), Stainless Steel per Reference (7)

SA-182, Type 304 stainless steel may be substituted for SA-240 Type 304 stainless steel provided that the SA-182 material yield and ultimate strengths are equal to or greater than those of the SA-240 material. The SA-182 forging material and the SA-240 plate material are both Type 304 austenitic stainless steels. Austenitic stainless steels do not experience a ductile-to-brittle transition for the range of temperatures considered in this Safety Analysis Report. Therefore, fracture toughness is not a concern.

		CALC. NO. RTL- 001-CALC-ST-0403
BENERCON	CALCULATION CONTROL SHEET	REV. 4
Excenence—Every project Every boy		PAGE NO. 11 of 16

Table 6-2 – Properties of SA-354, Grade BD, Carbon Steel Per Reference (7)

Property*		Value								
Temperature (°C)	-40	21	38	93	149	204	260	343	427	482
Ultimate strength, S _u (MPa)	1034.2	1034.2	1034.2	1034.2	1034.2	1034.2	1034.2	1034.2	946.7	767.4
Yield strength, S _y (MPa)	896.3	896.3	896.3	821.2	792.9	765.3	730.2	663.3	599.8	564.7
Modulus of Elasticity, E (GPa)	206.7	202.7	201.7	198.6	195.1	192.4	188.2	178. 9	-	-
Coefficient of Thermal Expansion, α (×10 ⁻⁵ m/m/°C)	1.1214	1.1520	1.1647	1.2060	1.2420	1.2780	1.3140	1.3140	_	_
Thermal Conductivity, k (W/m•°C)		60.405	60.054	58.327	55.904	—	_		_	-
Specific Heat, (J/kg•°C)	_	16.270	16.751	17.998	18.822	_	-	-		1
Poisson's Ratio	0.3									
Density (kg/m³)		8220.9								

.			CALC. N	NO. RTL- 001-CALC-ST-0403
E	ENERCON	CALCULATION CONTROL SHEET	REV.	4
	excenenceevery project every bay			0 10 110

PAGE NO. 12 of 16

Table 6-3 – Lead Properties

Property*	Value									
Temperature (°C)	-40	-29	20	21	27	70	77	93	149	316
Modulus of Elasticity, E (GPa) (8)	16.9	16.7		15.7	—	_	_	14.2	13.4	10.3
Coefficient of Thermal Expansion, α (×10 ⁻⁵ m/m/°C) (8)	2.8080	2.8260	—	2.8980	—	_	_	2.9880	3.0960	3.6360
Thermal Conductivity, k (W/m•°C) (8)	I	—	35.335	_	35.246	34.655	34.565	_		_
Specific Heat, (J/kg•°C) (8)		—	127.70	—	128.12	129.79	130.21	_	_	_
Poisson's Ratio (2)	0.4									
Density (kg/m ³) (2)		11340								

		CALC. NO. RTL- 001-CALC-ST-0403
ENERCON Excellence - Every project Every day	CALCULATION CONTROL SHEET	REV . 4
		PAGE NO. 13 of 16

7.0 Calculation

The RT-100 cask inner shell, shield annulus and outer shell are designed to provide required shielding with minimum weight. A benefit of this configuration is that the outer shell provides protection from pin puncture so that the inner shell is not deformed. Therefore, the lead layer acts as a shock-absorbing medium distributing the puncture impact energy, which propagates inward from the outer shell.

7.1 Lid Puncture

Finite element analysis methods are used to perform the stress evaluation of the RT-100 Cask for the end puncture conditions. The end puncture is analyzed using a three-dimensional finite element model using the computational modeling software ANSYS as described in Reference (10). The end puncture model description is provided in Reference (6). To simplify the pin puncture analysis, only the upper end of the cask is considered for this evaluation. Figure 7-1 shows the pin puncture model.

7.1.1 Lid Puncture—Boundary conditions

The puncture load is applied to a 152 mm (6 in) diameter region which corresponds to a 152 mm diameter pin. The load is simulated with an evenly distributed pressure load equal to the dynamic flow stress of the pin, which is taken to be 324 MPa (47,000 psi) as specified in Reference (2). As discussed in the cask body analysis, the preload generated from the torque of the closure bolts is included as an initial condition. In addition, the maximum normal operating pressure of 241 KPa (35 psig) is applied to the interior surface of the cask.

7.1.2 Lid Puncture—Results

Stress results for the 1-meter pin puncture combined loading conditions are documented in Table 7-1. The table documents the primary membrane (P_m), primary membrane plus primary bending (P_m+P_b) stresses in accordance with the criteria presented in Regulatory Guide 7.6. Stresses are linearized across critical sections to determine the membrane and bending stresses which are compared with allowable stress intensities.

As shown in Table 7-1, the margins of safety when compared to the stress intensity for each category are positive. The most critically stressed component in the system is the flange, which is due to bending as a result of the pin puncture probe striking the center of the lid. The minimum margin of safety is found to be +0.2 for primary membrane plus bending stress intensity. The locations of the critical sections correspond to the maximum stress location shown in Figure 7-2.

Stress State	Location	S1	S2	S3	SINT	Allowable Stress	Margin of Safety
INNER LID		MPa	MPa	MPa	MPa	MPa	
Pm		-108.6	-109.8	-191.5	82.9	331	3.0
Pm + Pb	Inside	383.4	382.9	-37.7	421.1	485	0.2
	Center	-108.6	-109.8	-191.5	82.9	485	4.9
	Outside	-342.9	-602.3	-603.3	260.4	485	0.9

Table 7-1. HAC Pin Puncture Stress Summary

ENERCON Excellencetwery project Every day		CALC. N	O . RTL- 001-CALC-ST-0403
	CALCULATION CONTROL SHEET	REV.	4
		PAGE NO	D. 14 of 16

7.2 Puncture—Cask Side Puncture

7.2.1 Minimum Wall Thickness

A series of pin puncture tests performed at Oak Ridge National Laboratory were used to develop an empirical equation for the stress in the outer wall of a multi wall cask as a function of the mass of the cask and the thickness of the cask outer wall material (3). This equation (Nelm's equation) applies to steel-lead-steel cask wall construction and is used to demonstrate-pin puncture adequacy for casks with stainless steel walls, and this equation has been the basis for the puncture analysis of several licensed casks. Solving Nelm's equation for the RT-100 outer shell:

t =
$$\left(\frac{w}{s}\right)^{0.71}$$
 = 1.16 in (29 mm) < 35 mm

where

W = 92,594 lb (42,000 kg), maximum gross weight of the package

S = 75,000 psi (517.1 MPa), ultimate tensile strength of the outer shell.

Nelm's equation shows that the cask outer shell is sufficient to resist puncture.

7.2.2 Cask Sidewall Bending Stresses

When the cask sidewall impacts the puncture pin, the bending force is:

$$\sigma_{b} = \frac{M \times c}{I} = 15.3 \text{ MPa}$$

Conservatively assuming the compressive and tensile stresses occur at the same location, the stress intensity is doubled to 30.6 MPa. Therefore, the factor of safety is:

$$FS = \frac{517.1}{30.6} = 15.7 > 1$$

where

Fixm = 1589.2 kN-m, moment due to impact force М = 1.16 m, moment arm resulting from impact = m L = $h_{tot} - h_u - h_L = 2.32$ m, sidewall length = 3312.8 mm, cask total height h_{tot} hυ = 498 mm, upper impact limiter height h = 494 mm, lower impact limiter height Fi = $K_s \times A_i$ = 5478.2 kN, impact force Ks = 324 MPa, dynamic flow stress for mild steel (3) $= \frac{\pi}{2} \times d_p^2 = 0.0177 \text{ m}^2$, puncture probe area Ai = 0.15 m, puncture probe diameter dP

Therefore, the RT-100 cask sidewall successfully resists the regulatory puncture drop.

-	ENERCON Excellence – Every project Every day		CALC. N	O. RTL- 001-CALC-ST-0403
E3		CALCULATION CONTROL SHEET	REV.	4
			PAGE N	I O. 15 of 16

7.3 Puncture—Lead Deformation during Side Puncture

Following the postulated side puncture of The RT-100 cask, the cask may experience localized deformation of the outer shell. Behind this localized deformation a slight flattening may occur, which results in shielding loss. To quantify this loss, the local stiffness of the cask wall is determined to calculate the energy absorbed by the package. To calculate the total deformation of the lead shield, it is conservatively assumed that the available potential energy of the 1 meter puncture drop is converted to strain energy.

The maximum deformation occurs during postulated puncture event when the cask strikes the puncture probe approximately mid-span on the cask outer shell. For the purposes of this evaluation, the cask is considered a closed cylinder subjected to a concentrated load at the mid-span. The deformation is obtained from Roark's, Table 31, Case 9 (10). The deflection of the outer shell due to the applied load is:

where

 $y = \frac{P}{Et} \left[0.48 \times \left(\frac{L}{R}\right)^{0.5} \times \left(\frac{R}{t}\right)^{1.22} \right]$

L = length of the cylinder

R = mean radius of the shell

P = applied load

Solving for the stiffness:

$$\mathbf{k} \quad = \quad \frac{\mathbf{P}}{\mathbf{y}} = \frac{\mathbf{Et}}{\left[0.48 \times \left(\frac{\mathbf{L}}{\mathbf{R}}\right)^{0.5} \times \left(\frac{\mathbf{R}}{\mathbf{t}}\right)^{1.22}\right]}$$

The RT-100 is considered a composite cylinder comprised of an outer shell, lead shield, and inner shell. The resulting stiffness of each component is:

7.3.1 Outer Shell Stiffness

$$k_{1} = \frac{1.989 \times 10^{10} \times 3.505 \times 10^{-2}}{\left[0.48 \times \left(\frac{1.946}{1.003}\right)^{0.5} \times \left(\frac{1.003}{3.505 \times 10^{-2}}\right)^{1.22}\right]} = 1.743 \times 10^{7} \text{ N/m}$$

$$L = 1.946 \text{ m}$$

$$R = 1.003 \text{ m}$$

$$t = 3.505 \times 10^{-2} \text{ m}$$

$$P = 6.972 \times 10^{8} \text{ N}$$

$$E = 1.989 \times 10^{10} \text{ Pa}$$

7.3.2 Lead Stiffness

$$k_2 = \frac{1.602 \times 10^9 \times 8.992 \times 10^{-2}}{\left[0.48 \times \left(\frac{1.946}{9.401 \times 10^{-1}}\right)^{0.5} \times \left(\frac{9.401 \times 10^{-1}}{8.992 \times 10^{-2}}\right)^{1.22}\right]} = 1.191 \times 10^7 \text{ N/m}$$



ENERCON		CALC. NO	D. RTL- 001-CALC-ST-0403
	CALCULATION CONTROL SHEET	REV.	4
encerrence every project every our		PAGE NC) . 16 of 16

where

where

L = 1.946 mR = $9.401 \times 10^{-1} \text{ m}$ t = $8.992 \times 10^{-2} \text{ m}$ P = $1.441 \times 10^8 \text{ N}$ E = $1.602 \times 10^9 \text{ Pa}$

7.3.3 Inner Shell Stiffness

$$k_{3} = \frac{1.989 \times 10^{10} \times 1.905 \times 10^{-2}}{\left[0.48 \times \left(\frac{1.946}{8.801 \times 10^{-1}}\right)^{0.5} \times \left(\frac{6.801 \times 10^{-1}}{1.905 \times 10^{-2}}\right)^{1.22}\right]} = 4.945 \times 10^{6} \text{ N/m}$$

$$L = 1.946 \text{ m}$$

$$R = 8.801 \times 10^{-1} \text{ m}$$

$$t = 1.905 \times 10^{-2} \text{ m}$$

$$P = 3.789 \times 10^{8} \text{ N}$$

$$E = 1.989 \times 10^{10} Pa$$

7.3.4 Lead Deformation due to Puncture Load

The effective stiffness of the composite section of the cask is:

$$k_{eff} = k_1 + k_2 + k_3 = 3.428 \times 10^7 \text{ N/m}$$

The energy absorbed during impact is:

 $U = \frac{1}{2} k_{eff} \times \delta^2$

Assuming the energy absorbed is equal to the total potential energy, the potential energy is calculated as:

$$P.E. = W \times h$$

Setting the energy absorbed during impact equal to the total potential energy the outer shell deformation is:

$$\frac{1}{2} k_{eff} \times \delta^2 = W \times h \implies \delta = \sqrt{\frac{2(W \times h)}{k_{eff}}} = 0.050 \text{ m}$$

where

The deformation of the lead is calculated from the ratio of the effective stiffness and lead stiffness:

$$\delta_{\text{lead}} = \delta \times \frac{k_2}{k_{\text{eff}}} = 0.017 \text{ m}$$

Even though the deformation is comprised of and elastic and inelastic component, the entire deformation is conservatively assumed to be permanent.

ENERCON		CALC. NO. RTL- 001-CALC-ST-0403				
	CALCULATION CONTROL SHEET (APPENDIX 1)	REV.	3			
Excenence Every pro,ect Every day	(= ·),	PAGE N	O. 1 of 3			

APPENDIX 1—Figures

ENERCON		CALC. NO. RTL- 001-CALC-ST-040		
	CALCULATION CONTROL SHEET (APPENDIX 1)	REV. 3		
Excellence — Every project Every day	(PAGE NO. 2 of 3		



Figure 7-1. RT-100 ANSYS Puncture Model.

		CALC. NO. RTL- 001-CALC-ST-0403		
ENERCON	CALCULATION CONTROL SHEET	REV.	3	
Excenence — Every project Every day	()	PAGE N	IO. 3 of 3	
			(MPa) 0.15 30.51 60.86 91.22 121.58 151.93 182.29 212.64 243.00 273.36 303.71 334.07 364.43 394.78 217.25 455.49	

Figure 7-2. RT-100 Pin Puncture Stress Intensity Results.

ENERCON	CALCULATION CONTROL SHEET (APPENDIX 2)	CALC. NO. RTL- 001-CALC-ST-0403	
		REV.	3
excenence - Every project Every bay		PAGE N	NO . 1 of 1

APPENDIX 2—Input and Output File Organization

The following table shows the call sequence and which files are created during the ANSYS solution process.

Input File	Output File
RT100_puncture.inp	stress_pin_puncture.txt

	CALCULATION CONTROL SHEET (APPENDIX 3)	CALC. NO. RTL- 001-CALC-ST-0403	
FJENERCON		REV.	3
Excenerate "Every project Every duy		PAGE N	IO. 1 of 3

APPENDIX 3—Output File Listing

ENERCON	CALCULATION CONTROL SHEET (APPENDIX 3)	CALC. NO. RTL- 001-CALC-ST-0403	
		REV. 3	
excenence · every project every day		PAGE NO. 2 of 3	

Stress_pin_puncture.txt

**********	**********	***** Sectio	n l *******	******	*****
**** INSIDE	* POST1 LINEA E NODE =10000	ARIZED STRESS 000 OUTSI	LISTING *** DE NODE =100	•• 0001	
LOAD STEP TIME= 1.00	1 SUBSTEP=	= 1 LOAD CASE= 0			
THE FOLLOWING	X,Y,Z STRESS	SES ARE IN TH	E GLOBAL COO	RDINATE SYST	ΈΜ.
	* MEMBRANE *				
-0.1591E+05 →0	SY).2758E+05 -(SZ).1596E+05 -	5X1 738.4 -	SYZ 1332. (SX2 0.3287E-01
S1 −0.1575E+05 −(S2).1593E+05 −0	S3).2778E+05 0	STNT .1203E+05 0	SEQV .1194E+05	
	** BENDING **	I=INSIDE C	=CENTER O=OU	TSIDE	
SX	SY	SZ	SXY	SYZ	SXZ
I 0.7144E+05	0.2218E+05	0.7152E+05	-137.5	-428.3	-32.39
C 0.000	0.000	0.000	0.000	0.000	0.000
9 -0.7144E105 S1	-0.2216E/00	-U.7152E105	STNT	420.0 SEOV	02.09
T 0.7153E+05	0.7143E+05	0.2217E+05	0.4936E+05	0.4931E+05	
C 0.000	0.000	0.000	0.000	0.000	
O -0.2217E+05	-0.7143E+05	-0.7153E+05	0.4936E+05	0.4931E+05	
	** MEMBRANE I	LUS BENDING	** I=INSIDE	C=CENTER O=	-OUTSIDE
SX	SY	SZ	SXY	SYZ	SXZ
I 0.5552E+05	-5408.	0.5556E+05	-875.9	-1760.	-32.35
C -0.1591E+05	-0.2758E+05	-0.1596E+05	-738.4	-1332.	0.3287E-01
0 -0.8735E+05	-0.4976E+05	-0.8748E+05	-600.8	-903.2	32.42
S1	S2	S3	SINT	SEQV	
1 0.5561E+05	0.55536+05	-54/2.	0.6108E+05	0.6105E+05	
O -0.4973E+05	-0.1593E+05	-0.2778E+05	0.1203E+05 0.3777E+05	0.1194E+05 0.3770E+05	
	** PEAK ** 1	[=INSIDE C=CE	NTER O=OUTSI	DE	
SX	SY	SZ	SXY	SYZ	SXZ
I -0.5286E+05	774.2	-0.5283E+05	712.2	1451.	29.13
C 2443.	-1657.	2503.	-394.4	-670.7	25.24
O 0.7940E+05	0.5142E+05	0.8562E+05	-346.9	827.9	-229.0
S1	S2	S3	SINT	SEQV	
1 822.8	-0.528/E+05	-0.5292E+05	0.53/4E+05	0.5372E+05	
0 0.8565E+05	0.7939E+05	0.5140E+05	0.3425E+05	4345. 0.3159E+05	
	** TOTAL **	I=INSIDE C=C	ENTER OFOUTS	TDF.	
SX	SY	SZ	SXY	SYZ	SXZ
I 2665.	-4634.	2682.	-163.7	-309.3	-3.218
C -0.1347E+05	-0.2924E+05	-0.1346E+05	-1133.	-2002.	25.27
0 -7950.	1660.	-1860.	-947.8	-75.33	-196.6
S1	52	S3	SINT	SEQV	TEMP
I 2695.	2068.	-4651.	7346.	7333.	0.000
C -0.1311E+05	-0.13495+05	-0.2957E+05	0.1646E+05	0.1627E+05	0.000
0 1753.	-1854.	-8049.	9803.	8388.	0.000
**** PATH VA	RIABLE SUMMAN	<u>RY</u> ****			
S	PATH1				
0.0000	7346.3				
0.19685	58692.				
0.39370	51326.				
0.59056	44808.				

			CALC. N	CALC. NO. RTL- 001-CALC-ST-0403	
		CALCULATION CONTROL SHEET	REV.	3	
			PAGE N	PAGE NO. 3 of 3	
0.78741	39861.				
0.98426	34944.				
1.1811	31080.				
1.3780	27295.				
1.5748	23621.				
1.7717	20052.				
1.9685	16460.				
2.1654	12213.				
2.3622	8121.2				
2.5591	4025.5				
2.7559	5132.6				
2.9528	10449.				
3.1496	18097.				
3.3465	25875.				
3.5433	34741.				
3.7402	44514.				
3 9370	9802.9				

LOAD STEP 1 SUBSTEP 1 CUMULATIVE ITERATION 1 TIME - 1.00000 TIME INCREMENT - 1.00000 NUMBER OF EQUILIBRIUM ITERATIONS = 1 CONVERGENCE INDICATOR = 0 MAXIMUM DEGREE OF FREEDOM VALUE = -0.914944E-01 RESPONSE FREQUENCY FOR 2ND ORDER SYSTEMS = 0.00000 DESCENT PARAMETER = 0.00000 FORCE CONVERGENCE VALUE = 0.00000 DISPLACEMENT CONVERGENCE VALUE = 0.00000 ROTATION CONVERGENCE VALUE = 0.00000 NUMBER OF NONCONVERGED 2D CONTACT ELEMENTS = 0

NUMBER	OF	WARNING	MESSAGES	ENCOUNTERED=	388
NUMBER	ΟF	ERROR	MESSAGES	ENCOUNTERED-	0