

BAW-2259  
January 1996

**EVALUATION OF RT<sub>NOT</sub>, USE, AND CHEMICAL COMPOSITION  
OF CORE REGION ELECTROSLAG WELDS  
FOR QUAD CITIES UNITS 1 AND 2**

by

C.A. Campbell

FTI Document No. 77-2259-00

(See Section 4.0 for document signatures.)

Prepared for

Commonwealth Edison Company

Prepared by

Framatome Technologies, Inc.  
P.O. Box 10935  
Lynchburg, VA 24506-0935

## **ABSTRACT**

This document contains FTI's best estimate of the initial  $RT_{NDT}$ , initial Charpy V-notch upper-shelf energy (CvUSE), and chemical composition (copper, nickel and phosphorus) values for the longitudinal electroslag welds within the core region of Quad Cities Units 1 and 2. Based on a review of existing weld procedure qualifications (PQs) and surveillance weld data, initial  $RT_{NDT}$  is estimated to be 23.1°F, with a standard deviation of 13.0°F. The initial CvUSE for the electroslag welds is estimated to be 105.4 ft-lbs, with a standard deviation of 16.1 ft-lbs. The electroslag welds are estimated to contain 0.190 weight percent (w/o) copper, 0.311 w/o nickel, and 0.013 w/o phosphorus (with standard deviations of 0.048, 0.051, and 0.003 w/o, respectively). A chemistry factor of 114.43 is calculated based on the copper and nickel contents for the electroslag welds at Quad Cities Units 1 and 2.

## CONTENTS

	Page
1. INTRODUCTION .....	1-1
2. FABRICATION HISTORY .....	2-1
3. RT <sub>NDT</sub> , CvUSE, AND CHEMICAL COMPOSITION .....	3-1
3.1. RT <sub>NDT</sub> Determination .....	3-1
3.2. CvUSE Determination .....	3-4
3.3. Weld Compositions (Cu, Ni, and P) .....	3-4
4. CERTIFICATION .....	4-1
5. REFERENCES .....	5-1
APPENDIX .....	A-1

## List of Tables

	Page
2-1. Quad Cities Unit 1 Plate and Weld Identification for MK-57 Shell Course .....	2-3
2-2. Quad Cities Unit 1 Plate and Weld Identification for MK-58 Shell Course .....	2-4
2-3. Quad Cities Unit 2 Plate and Weld Identification for MK-57 Shell Course .....	2-5
2-4. Quad Cities Unit 2 Plate and Weld Identification for MK-58 Shell Course .....	2-6

## List of Figures

	Page
1-1. Quad Cities Reactor Vessel Shell Course Arrangement in Core Region .....	1-2
2-1. Quad Cities Unit 1 Plate and Weld Layout for MK-57 Shell Course .....	2-3
2-2. Quad Cities Unit 1 Plate and Weld Layout for MK-58 Shell Course .....	2-4
2-3. Quad Cities Unit 2 Plate and Weld Layout for MK-57 Shell Course .....	2-5
2-4. Quad Cities Unit 2 Plate and Weld Layout for MK-58 Shell Course .....	2-6

## 1. INTRODUCTION

This document presents FTI's (Framatome Technologies, Inc.) best assessment of the initial (i.e., beginning of life) reference temperature ( $RT_{NDT}$ ) value, the initial Charpy V-notch upper-shelf energy (CvUSE) value, and the chemical composition of electroslag welds in the Quad Cities Units 1 and 2 reactor vessels. In particular, the electroslag welds of interest are longitudinal welds among the plates comprising the Mark 57 (Mk-57) and Mk-58 shell courses. The Mk-57 and Mk-58 shell courses are within the core region. Figure 1-1 illustrates the arrangement of these shell courses in the reactor vessels of Quad Cities Units 1 and 2.


This assessment is a result of the collection and compilation of weld PQs and other data pertinent to the fabrication of the Quad Cities reactor vessels, as well as other boiling water reactor (BWR) vessels fabricated in the same time frame. This document does not include information with regard to chemical composition or Charpy impact data on specific shell courses or non-electroslag welds.

The following list identifies the number of electroslag (ES) welds in each of the two shell courses of the Quad Cities Units 1 and 2 reactor vessels.

<u>Unit ID</u>	<u>Shell Course</u>	<u>No. of ES welds</u>
Quad Cities 1	Mk-57	4
	Mk-58	4
Quad Cities 2	Mk-57	3
	Mk-58	3

All longitudinal welds within the individual shell courses of Units 1 and 2 are electroslag welds. [Note: The Mk-57 and Mk-58 shell courses of the Quad Cities Unit 1 reactor vessel were fabricated using three individual plates, one of which was initially in two sections; thus, each of these two shell courses has four longitudinal welds.]

FIGURE 1-1.  
QUAD CITIES REACTOR VESSEL  
SHELL COURSE ARRANGEMENT IN CORE REGION



## 2. FABRICATION HISTORY

The plate material supplied for fabrication of the Quad Cities Units 1 and 2 reactor vessels was ASME SA-302, Grade B<sup>1</sup> high strength alloy carbon steel (modified to Code Case 1339<sup>2</sup>) provided by Lukens Steel. During fabrication, the individual plates in each shell course were rolled to contour; then, the plates were welded together with longitudinal seams using electroslag and submerged arc welding processes. Figures 2-1 and 2-2 and Figures 2-3 and 2-4 illustrate the plate and weld layouts for the Mk-57 and Mk-58 shell courses of Quad Cities Units 1 and 2, respectively. All electroslag welds of interest were made using Hi-Mn-Mo filler wire with Linde #124 flux.

Following assembly of each shell section, the following heat treatment was performed:

- Heat to 1675-1725°F, hold for 6.5 hours; brine quench
- Heat to 1600-1650°F, hold for 6.5 hours; brine quench
- Heat to 1175-1225°F, hold for 6.5 hours; liquid quench

The two core region shell courses (Mk-57 and -58) were fabricated by Babcock & Wilcox (B&W) for Quad Cities Unit 1 and Unit 2. The circumferential weld joining the Mk-57 shell course to the Mk-58 shell course of the Quad Cities Unit 1 reactor vessel was completed by B&W; the circumferential weld for the Quad Cities Unit 2 reactor vessel was completed by Chicago Bridge & Iron, Company (CB&I).

Although an extensive records search was completed,\* very little information could be located with regard to either the specific weld materials or test results for the ES weld consumables used on the longitudinal weld seams of the core region shell courses of the Quad Cities reactor vessels. Therefore, applicable test data for weld PQs -- performed in the general time frame that the electroslag longitudinal welds in both Quad Cities units were fabricated -- have

---

\* Records were searched at the FTI facilities in Lynchburg, Virginia, as well as the Babcock & Wilcox facilities in Mt. Vernon, Indiana, and Barberton, Ohio, to locate all available documentation.

been included as one source of typical RT<sub>NDT</sub> data for this type of weld. Copies of the weld PQs of interest are included in the Appendix. It is believed that the weld PQs included in the Appendix are the only weld PQs that are applicable to the core region shell courses welded by the electroslag welding process for the two Quad Cities units.

FIGURE 2-1.

QUAD CITIES UNIT 1  
PLATE AND WELD LAYOUT FOR MK-57 SHELL COURSE




TABLE 2-1.

QUAD CITIES UNIT 1  
PLATE AND WELD IDENTIFICATION FOR MK-57 SHELL COURSE

<u>ID</u>	<u>Location</u>	<u>Wire or Plate Heat No.</u>	<u>Flux Lot No.</u>	<u>Fab.'d by</u>
Long. seam 1 (ES)	55°	U'	U'	B&W
Long. seam 2 (ES)	77°	U'	U'	B&W
Long. seam 3 (ES)	197°	U'	U'	B&W
Long. seam 4 (ES)	317°	U'	U'	B&W
6-122-1	--	B5524-1	--	---
6-122-2	--	A0610-1	--	---
6-122-11	--	C1485-2	--	---
Mk-57 to Mk-58	--	72445	8688	B&W
circ. weld (SA)		406L44	8688	

ES: Electroslag weld

SA: Submerged arc weld

U: Unidentified

\*: Records indicated that the electroslag welds for Mk-57 were performed using the following weld wire/flux lot combinations: 0L0794/8467, 37C065/8445, 35A320/3496, and 36A168/3496. However, data for specific longitudinal seams are not identified.

FIGURE 2-2.

QUAD CITIES UNIT 1  
PLATE AND WELD LAYOUT FOR MK-58 SHELL COURSE




TABLE 2-2.

QUAD CITIES UNIT 1  
PLATE AND WELD IDENTIFICATION FOR MK-58 SHELL COURSE

<u>ID</u>	<u>Location</u>	<u>Wire or Plate</u> <u>Heat No.</u>	<u>Flux</u> <u>Lot No.</u>	<u>Fab.'d</u> <u>by</u>
Long. seam 1 (ES)	22°	U'	U'	B&W
Long. seam 2 (ES)	141°	U'	U'	B&W
Long. seam 3 (ES)	261°	U'	U'	B&W
Long. seam 4 (ES)	323°	U'	U'	B&W
6-122-4	--	C1505-2	--	---
6-122-6	--	C1498-2	--	---
6-122-13	--	A0931-1	--	---
Mk-57 to Mk-58	--	72445	8688	B&W
circ. weld (SA)		406L44	8688	


ES: Electroslag weld

SA: Submerged arc weld

U: Unidentified

\*: Records indicated that the electroslag welds for Mk-57 were performed using the following weld wire/flux lot combinations: 0L0794/8467, 37C065/8445, 35A320/3496, and 36A168/3496. However, data for specific longitudinal seams are not identified.

**FIGURE 2-3.**  
**QUAD CITIES UNIT 2**  
**PLATE AND WELD LAYOUT FOR MK-57 SHELL COURSE**



**TABLE 2-3.**  
**QUAD CITIES UNIT 2**  
**PLATE AND WELD IDENTIFICATION FOR MK-57 SHELL COURSE**

<u>ID</u>	<u>Location</u>	<u>Wire or Plate Heat No.</u>	<u>Flux Lot No.</u>	<u>Fab'd by</u>
Long. seam 1 (ES)	77°	U	U	B&W
Long. seam 2 (ES)	197°	U	U	B&W
Long. seam 3 (ES)	317°	U	U	B&W
6-122-8	--	C1516-2	--	---
6-122-10	--	C1501-2	--	---
6-122-14	--	C1722-2	--	---
Mk-57 to Mk-58 circ. weld (SA)	--	S-3986	3870	CB&I

ES: Electroslag weld

SA: Submerged arc weld

U: Unidentified

FIGURE 2-4.  
**QUAD CITIES UNIT 2  
 PLATE AND WELD LAYOUT FOR MK-58 SHELL COURSE**




TABLE 2-4.  
**QUAD CITIES UNIT 2  
 PLATE AND WELD IDENTIFICATION FOR MK-58 SHELL COURSE**

<u>ID</u>	<u>Location</u>	<u>Wire or Plate Heat No.</u>	<u>Flux Lot No.</u>	<u>Fab.'d by</u>
Long. seam 1 (ES)	22°	U	U	B&W
Long. seam 2 (ES)	142°	U	U	B&W
Long. seam 3 (ES)	262°	U	U	B&W
6-139-16	--	C2753-2	--	---
6-139-22	--	C2868-1	--	---
6-139-25	--	C3307-2	--	---
Mk-57 to Mk-58 circ. weld (SA)	--	S-3986	3870	CB&I

ES: Electroslag weld

SA: Submerged arc weld

U: Unidentified

### 3. RT<sub>NDT</sub>, CvUSE, AND CHEMICAL COMPOSITION

Both mechanical property and chemical composition data are lacking on electroslag welds for Quad Cities Units 1 and 2. For this reason, the available data discussed in this report are based primarily on weld PQs and known weld wire chemistry data. Weld PQs contain mechanical properties and, usually, chemical composition data as well. While this data cannot represent actual reactor vessel welds exactly, the procedures, consumables (i.e., weld wire and flux), and thickness of the welded plates are similar to the actual welds. Generally, weld amperage, voltage, and oscillation speeds are equivalent or similar for the PQs. Although the welding procedures are similar, an accumulated thermal history is not available for the beltline reactor vessel welds at Quad Cities Unit 1. For Unit 2, however, CB&I has reported that the Mk-57 and Mk-58 shell courses received the following accumulated post weld heat treatment:<sup>4</sup>

Mk-57	27 hours, 56 minutes
Mk-58	44 hours, 22 minutes.

Stress relief heat treatments were completed at temperatures in the range of 1100 to 1150°F.

#### 3.1 RT<sub>NDT</sub> Determination

The electroslag weld PQs included in this document contain Charpy impact data as well as respective stress relief times implemented for each weld PQ. As shown by the data in Table I below, stress relief heat treatments were typically performed for either 18 or 30 hours; one weld PQ had a stress relief time of 42 hours. The weld PQs for the electroslag welds in Quad Cities Units 1 and 2 used a RACO (Reid Avery Company) Hi-Mn-Mo weld wire and a Linde #124 flux; therefore, only data from weld PQs using this same RACO wire/flux combination are included. The Charpy V-notch impact data are reported for tests completed at 10°F using a load of 240 ft-lbs.

---

\* As reported in Attachment B to the CECO response to Generic Letter 92-01 for Dresden Units 2 and 3 and Quad Cities Units 1 and 2.<sup>5</sup>

TABLE I  
Charpy V-Notch Impact Data for Electroslag Weld PQs

<u>Weld PQ</u>	<u>Charpy Data</u>	<u>Drop Wt. T<sub>NDT</sub> (°F)</u>	<u>Stress Relief Time</u>
PQ-1092-C	38 33 41	--	18
PQ-1138-A	52 30 50 (Surf) 30 53 36 (1/4T)	-- 10	18
PQ-1300	39 42 43	--	30
PQ-1309-A	60 50 35	--	18
PQ-1309-B	58 36 44	--	18
PQ-1667	47 39 27	--	30
PQ-1822	36 70 42 64 45	30	30
PQ-1851	84 71 57	10	30
PQ-1928	30 33 33	25	30
PQ-1929	80 40 55	50	30
PQ-1930	10 72 70 75 16 14 39	30	30
PQ-1931	47 24 33 57 50	20	30
PQ-2563	59 47 49 (Surf) 27 34 32 (1/4T)	-- 10	42

From a statistical standpoint, the above Charpy data are sufficiently close with regard to Charpy impact behavior that the values can be considered as one group of data. Therefore, all drop weight data identified above are equally weighted in the calculation for initial RT<sub>NDT</sub> discussed below.

No drop weight specimens were tested for the Quad Cities Units 1 and 2 surveillance electroslag weld metals, nor were any tested for the electroslag welds at other plants fabricated using the same RACO weld/flux combination as the Quad Cities units. The surveillance electroslag weld Charpy impact data that are available, however, are shown below in Table IIA.

TABLE IIA

Charpy V-Notch Data for Surveillance Electroslag Weld Metal<sup>4-11</sup>

<u>Plant ID</u>	<u>T<sub>CV30</sub></u>	<u>T<sub>CV50</sub></u>	<u>T<sub>35MLE</sub></u>	<u>USE</u>
Quad Cities Unit 1	10°F	35°F	25°F	>100 ft-lbs
Quad Cities Unit 2	-30°F	20°F	- 5°F	125 ft-lbs
Browns Ferry Unit 1	8°F	33°F	20°F	93 ft-lbs
Browns Ferry Unit 2	-10°F	10°F	- 2°F	116 ft-lbs
Browns Ferry Unit 3	-31°F	-21°F	-27°F	124 ft-lbs
Dresden Unit 2	-10°F	40°F	5°F	101 ft-lbs
Dresden Unit 3	40°F	110°F	65°F	70 ft-lbs
Peach Bottom Unit 2	4°F	43°F	27°F	110 ft-lbs
Peach Bottom Unit 3	2°F	47°F	34°F	110 ft-lbs

[\* Conservatively estimated based on data from Capsule No. 8,<sup>9</sup> since value was not determined for unirradiated ESW surveillance material.]

The following Charpy impact data are also available for electroslag welds tested for the Peach Bottom Unit 2 surveillance program to determine an initial RT<sub>NDT</sub> value representative of the electroslag welds:

TABLE IIB

Electroslag Weld Test Data<sup>10</sup>

<u>Test Weld ID</u>	<u>T<sub>CV50</sub></u>	<u>Test Weld ID</u>	<u>T<sub>CV50</sub></u>
1	18.8	6	-20.7
2	3.0	7	15.9
3	31.7	8	12.5
4	32.1	9	18.9
5	26.7		

As defined in the ASME Code, Paragraph NB-2331,<sup>12</sup> the RT<sub>NDT</sub> is established in accordance with the following requirements:

1. Determine a temperature, T<sub>NDT</sub>, that is at or above the nil-ductility transition temperature by drop weight tests.

2. At a temperature not greater than  $T_{NDT} + 60^{\circ}\text{F}$ , each Charpy specimen shall exhibit at least 50 ft-lbs absorbed energy and at least 35 mils lateral expansion. If these requirements are met,  $T_{NDT}$  is the  $RT_{NDT}$ .
3. If the requirements of 2. are not met, additional Charpy tests shall be performed (in groups of three specimens) to determine the temperature,  $T_{cv}$ , at which they are met. Then,  $RT_{NDT}$  is  $(T_{cv} - 60^{\circ}\text{F})$ .  $RT_{NDT}$  is the greater of  $T_{NDT}$  and  $(T_{cv} - 60^{\circ}\text{F})$ .
4. When a Charpy test has not been performed at  $T_{NDT} + 60^{\circ}\text{F}$ , or when a Charpy test is performed at  $T_{NDT} + 60^{\circ}\text{F}$  and the specimens do not exhibit a minimum of 50 ft-lb absorbed energy and 35 mils lateral expansion, a temperature representing these minimum requirements may be obtained from a full Charpy curve developed from the minimum of Charpy data of all tests performed.

Using the weld PQ  $T_{NDT}$  data and the available surveillance Charpy impact data for the electroslag welds, the  $RT_{NDT}$  is controlled by the  $T_{NDT}$  requirement. Based on these data, the initial  $RT_{NDT}$  for the electroslag welds in Quad Cities Units 1 and 2 is calculated using the  $T_{NDT}$  data reported in the weld PQs. The  $T_{NDT}$  values range from 10 to 50 $^{\circ}\text{F}$ . Taking the mean of these values results in an estimated initial  $RT_{NDT}$  value of 23.1 $^{\circ}\text{F}$  for the electroslag welds, with a standard deviation ( $\sigma_i$ ) of 13.0 $^{\circ}\text{F}$ .

### 3.2 CvUSE Determination

The initial CvUSE data for electroslag welds were obtained from available surveillance data and are presented in Table IIA. The unirradiated CvUSE values range from 70 to 125 ft-lbs. Taking the mean of these values results in an estimated initial CvUSE value of 105.4 ft-lbs for the electroslag welds, with a standard deviation of 16.1 ft-lbs.

### 3.3 Weld Compositions (Cu, Ni, and P)

Electroslag weld chemical composition data (in weight percent [w/o]) are available from three different sources: weld PQs, weld wire compositions, and surveillance capsule specimens.

As shown in Tables III through VI, each group is similar in its own respect. In evaluating the data, the average weld compositions (and standard deviations) were calculated using only the data from the weld PQs and surveillance capsule specimens since this weld data is believed to be more representative of the actual (longitudinal) electroslag welds located in the reactor vessel shell courses. The weld wire composition data were not included in these calculations.

TABLE III

Procedure Qualification Chemical Composition Data

<u>Weld PQ</u>	<u>C</u>	<u>Mn</u>	<u>P</u>	<u>S</u>	<u>Si</u>	<u>Cr</u>	<u>Ni</u>	<u>Mo</u>	<u>Cu</u>
PQ-1092-C	0.20	1.28	0.017	0.018	0.18	0.08	0.31	0.53	0.24
PQ-1138-A	0.19	1.50	0.017	0.027	0.19	0.09	0.35	0.55	0.25
PQ-1300	0.18	1.26	0.015	0.017	0.16	0.11	0.33	0.51	0.30
PQ-1309-A	0.18	1.34	0.012	0.017	0.14	0.10	0.30	0.47	0.22
PQ-1309-B	0.17	1.31	0.015	0.015	0.14	0.12	0.29	0.51	0.23
PQ-1667	0.19	1.41	0.019	0.015	0.07	0.06	0.25	0.57	0.20
PQ-1822	0.19	1.40	0.015	0.015	0.14	0.09	0.27	0.54	0.23
PQ-1851	0.18	1.49	0.014	0.011	0.15	0.06	0.36	0.49	0.18
PQ-1928	0.19	1.49	0.016	0.014	0.16	0.06	0.38	0.55	0.19
PQ-1929	0.18	1.50	0.016	0.013	0.17	0.08	0.30	0.48	0.20
PQ-1930	0.16	1.52	0.012	0.014	0.15	0.07	0.26	0.51	0.20
PQ-1931	0.20	1.52	0.015	0.021	0.12	0.05	0.38	0.59	0.19

TABLE IV

Weld Consumables Chemical Composition Data

<u>Wire ID</u>	<u>C</u>	<u>Mn</u>	<u>P</u>	<u>S</u>	<u>Si</u>	<u>Cr</u>	<u>Ni</u>	<u>Mo</u>	<u>Cu</u>
W-8349	0.14	1.79	0.010	0.012	0.04	--	--	0.47	--
34A167	0.14	1.76	0.010	0.014	0.04	--	--	0.49	--
36A168	0.12	1.70	0.010	0.019	0.03	--	--	0.52	--

TABLE V  
Surveillance and Beltline Weld Chemical Composition Data<sup>13-17</sup>

<u>Specimen &amp; Plant ID</u>	<u>C</u>	<u>Mn</u>	<u>P</u>	<u>S</u>	<u>Si</u>	<u>Cr</u>	<u>Ni</u>	<u>Mo</u>	<u>Cu</u>
MA1 QC1 <sup>a,13*</sup>	0.17	1.56	0.011	0.017	0.19	0.06	0.28	0.45	0.17
TD1 QC2 <sup>b,13</sup>	0.18	1.75	0.011	0.013	0.17	0.09	0.20	0.49	0.18
MA4 QC1 <sup>a,14</sup>	0.158	--	0.012	0.006	0.05	0.063	0.25	0.45	0.136
	--	--	--	--	--	--	0.26	--	0.19
MAD QC1 <sup>a,14</sup>	0.236	--	0.012	0.004	0.08	0.063	0.26	0.45	0.138
	--	--	--	--	--	--	0.38	--	0.19
M7L QC1 <sup>a,14</sup>	--	--	--	--	--	--	0.30	--	0.20
MBU QC1 <sup>a,14</sup>	--	--	--	--	--	--	0.33	--	0.24
M6D QC1 <sup>a,14</sup>	--	--	--	--	--	--	0.39	--	0.16
MDC QC1 <sup>a,14</sup>	--	--	--	--	--	--	0.40	--	0.21
MD4 QC1 <sup>a,14</sup>	--	--	--	--	--	--	0.33	--	0.19
MBY QC1 <sup>a,14</sup>	--	--	--	--	--	--	0.40	--	0.21
TAE QC2 <sup>b,15</sup>	0.209	--	0.008	0.017	0.115	0.079	0.313	0.503	0.129
							0.32		0.14
TAT QC2 <sup>b,15</sup>	0.216	--	0.008	0.018	0.126	0.091	0.359	0.522	0.122
							0.33		0.16
TBP QC2 <sup>b,15</sup>	--	--	--	--	--	--	0.34	--	0.16
TB1 QC2 <sup>b,15</sup>	--	--	--	--	--	--	0.37	--	0.17
T6K QC2 <sup>b,15</sup>	--	--	--	--	--	--	0.39	--	0.17
TBM QC2 <sup>b,15</sup>	--	--	--	--	--	--	0.37	--	0.17
T7Z QC2 <sup>b,15</sup>	--	--	--	--	--	--	0.41	--	0.20
TAP QC2 <sup>b,15</sup>	--	--	--	--	--	--	0.32	--	0.12

\* Number designates reference from which data was taken.

TABLE V (cont.)

<u>Specimen &amp; Plant ID</u>	<u>C</u>	<u>Mn</u>	<u>P</u>	<u>S</u>	<u>Si</u>	<u>Cr</u>	<u>Ni</u>	<u>Mo</u>	<u>Cu</u>
ESW Weld D3 <sup>c,18</sup>	0.21	1.78	0.011	0.015	0.32	0.07	0.30	0.51	0.20
KAE D3 <sup>c,17</sup>	0.220	—	0.009	0.016	0.176	0.064	0.332	0.550	0.191
—	—	—	—	—	—	—	—	—	0.29
KAL D3 <sup>c,17</sup>	0.197	—	0.008	0.019	0.144	0.056	0.282	0.520	0.171
—	—	—	—	—	—	—	0.33	—	0.18
K6L D3 <sup>c,17</sup>	—	—	—	—	—	—	0.41	—	0.24
K6A D3 <sup>c,17</sup>	—	—	—	—	—	—	0.38	—	0.23
KBM D3 <sup>c,17</sup>	—	—	—	—	—	—	0.36	—	0.22
K6T D3 <sup>c,17</sup>	—	—	—	—	—	—	0.38	—	0.19
KAJ D3 <sup>c,17</sup>	—	—	—	—	—	—	0.34	—	0.21
KAD D3 <sup>c,17</sup>	—	—	—	—	—	—	0.34	—	0.21
Peach Bottom 2,3 <sup>d,e</sup>	0.17	1.41	0.015	0.013	0.09	0.05	0.21	0.53	0.21

<sup>a</sup> Quad Cities Unit 1<sup>b</sup> Quad Cities Unit 2<sup>c</sup> Dresden Unit 3.<sup>d</sup> Beltline weld data<sup>e</sup> Based on nine electroslag weld prolongations from the Peach Bottom Unit 2 reactor vessel; all were made from the same weld heat.

It should be noted that the data taken from References 14, 15, and 17 were not included in these calculations as individual data points; instead, the mean values of these data were determined and included in the calculations for Quad Cities Units 1 and 2. Additional data is listed below for the surveillance electroslag welds for Browns Ferry Units 1, 2, and 3 and Peach Bottom Units 2 and 3.

TABLE VI

Surveillance Electroslag Weld Data<sup>6,10,11</sup>

<u>Plant ID</u>	<u>C</u>	<u>Mn</u>	<u>P</u>	<u>S</u>	<u>Si</u>	<u>Cr</u>	<u>Ni</u>	<u>Mo</u>	<u>Cu</u>
Browns Ferry 1	—	—	0.012	—	—	—	0.30	—	0.10
Browns Ferry 2	—	—	0.010	—	—	—	0.33	—	0.20
Browns Ferry 3	—	—	0.011	—	—	—	0.28	—	0.11
Peach Bottom 2	—	1.43	0.010	—	—	0.08	0.32	0.49	0.09
Peach Bottom 3	—	1.46	0.012	—	—	0.08	0.32	0.49	0.10
Peach Bottom 3	—	1.55	0.009	—	0.19	—	0.40	0.50	0.11
Peach Bottom 3	—	1.57	0.009	—	0.19	—	0.41	0.51	0.11

The compositional data for the weld PQs; the surveillance weld data for Dresden Unit 3 and Quad Cities Units 1 and 2; and the beltline and surveillance weld data for the Browns Ferry and Peach Bottom units were averaged to determine estimated values for copper, nickel, and phosphorus contents for the ES welds at Quad Cities Units 1 and 2. The results are as follows:

<u>Element</u>	<u>Content (w/o)</u>	<u>Std. Deviation w/o</u>
Copper	0.190	0.048
Nickel	0.311	0.051
Phosphorus	0.013	0.003


Applying these best estimate chemistry values to the Position C.1 procedures of Regulatory Guide 1.99, Revision 2,<sup>18</sup> a chemistry factor of 114.43 is calculated for the Quad Cities Units 1 and 2 longitudinal electroslag welds.

#### 4. CERTIFICATION


This report provides justifiable estimates for initial RT<sub>NDT</sub> and chemical composition (copper, nickel, and phosphorus) for the longitudinal electroslag welds in the core region of the Quad Cities Units 1 and 2 reactor vessels.

 1/10/96  
C.A. Campbell Date  
Materials and Structural Analysis


This report was reviewed and was found to be an accurate assessment of the work reported.

 1/15/96  
M.J. DeVan Date  
Materials and Structural Analysis

Verification of independent review.

 1-15-96  
K.E. Moore, Manager Date  
Materials and Structural Analysis

The document has been approved for release.

 1/15/96  
D.L. Howell, Program Manager Date

## 5. REFERENCES

1. American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section II, "Material Specifications, Part A: Ferrous Materials," American Society of Mechanical Engineers, New York, New York.
2. ASME Boiler and Pressure Vessel Code, "Code Cases," American Society of Mechanical Engineers, New York, New York.
3. Letter and Attachments from Marcia A. Jackson, Commonwealth Edison Company, to Dr. Thomas E. Murley, U.S.NRC, Subject: Dresden Station Units 2 and 3, NRC Docket Numbers 50-237/249; Quad Cities Station Units 1 and 2, NRC Docket Numbers 50-254/265; LaSalle County Station Units 1 and 2, NRC Docket Numbers 50-373/374. (Response to Generic Letter 92-01.) Dated July 1, 1992.
4. Yanichko, S.E., et al., "Analysis of the Third Capsule from the Commonwealth Edison Company Quad Cities Unit 1 Nuclear Plant Reactor Vessel Radiation Surveillance Program," WCAP-9920, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, August 1981.
5. Perrin, J.S., et al., "Quad Cities Nuclear Plant Unit No. 2 Reactor Pressure Vessel Surveillance Program: Capsule Basket No. 12 and Capsule Basket No. 13, Battelle Columbus Laboratories, Columbus, Ohio, September 19, 1975.
6. "Browns Ferry Core Region Materials Information (Units 1, 2, and 3)," BAW-1845, Babcock & Wilcox Utility Power Generation Division, Lynchburg, Virginia, August 1984.<sup>\*</sup>
7. Rieger, G.F., and G.H. Henderson, "Dresden Nuclear Power Station Unit One and Unit Two Mechanical Properties of Irradiated Reactor Vessel Material Surveillance

---

\* Report available from Framatome Technologies, Inc., Lynchburg, Virginia.

Specimens," NEDC 12585, Vallecitos Nuclear Center, General Electric Company, Pleasanton, California, May 1975.

8. Perrin, J.S., et al., "Dresden Nuclear Plant Reactor Pressure Vessel Surveillance Program: Unit No. 2 Neutron Dosimeter Monitor, Unit No. 2 Capsule Basket Assembly No. 2, and Unit No. 3 Capsule Basket Assembly No. 12," BCL-585-3, Battelle Columbus Laboratories, Columbus, Ohio, September 15, 1977.
9. Norris, E.B., "Dresden Nuclear Power Station Unit 2 Reactor Vessel Irradiation Surveillance Program Analysis of Capsule No. 8," SwRI Project No. 06-6901-002, Southwest Research Institute, San Antonio, Texas, March 1983.
10. Branlund, B.J., "Peach Bottom Atomic Power Station Unit 2 Vessel Surveillance Materials Testing and Fracture Toughness Analysis," SASR 88-24, DRF B13-01445-1 Rev. 1, General Electric, December 1991.
11. Caine, T.A., "Peach Bottom Atomic Power Station, Unit 3 Vessel Surveillance Materials Testing and Fracture Toughness Analysis," SASR 90-50, DRF B11-00494, General Electric, June 1990.
12. ASME Boiler and Pressure Vessel Code, Section III, "Nuclear Power Plant Components," Division 1 -- Subsection NB, American Society of Mechanical Engineers, New York, New York.
13. Perrin, J.S., and L.M. Lowry, "Quad Cities Nuclear Plant Unit No. 1 and Unit No. 2 Reactor Pressure Vessel Surveillance Programs: Unirradiated Mechanical Properties," Battelle Columbus Laboratories, Columbus, Ohio, February 15, 1975.
14. Norris, E.B., "Quad Cities Nuclear Power Station Unit 1 Reactor Vessel Irradiation Surveillance Program -- Analysis of Capsule No. 8," SwRI-7857, Southwest Research Institute, San Antonio, Texas, August 1984.
15. Norris, E.B., "Quad Cities Nuclear Power Station Unit 2 Reactor Vessel Irradiation Surveillance Program -- Analysis of Capsule No. 18," SwRI-7484-002/1, Southwest Research Institute, San Antonio, Texas, March 1984.
16. Yanichko, S.E., et al., "Analysis of the Fourth Capsule From the Commonwealth Edison Company Dresden Unit 3 Nuclear Plant Reactor Vessel Radiation Surveillance

Program," WCAP-10030, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, January 1982.

17. Norris, E.B., "Dresden Nuclear Power Station Unit 3 Reactor Vessel Irradiation Surveillance Program Analysis of Capsule No. 18," SwRI-7484-003/1, Southwest Research Institute, San Antonio, Texas, February 1984.
18. U.S. Nuclear Regulatory Commission, Radiation Damage to Reactor Vessel Material, Regulatory Guide 1.99, Revision 2, May 1988.

**APPENDIX**  
**Electroslag Procedure**  
**Qualifications**

THE BABCOCK & WILCOX COMPANY  
BARBERTON, OHIO

## RECORD OF PROCEDURE OR OPERATOR QUALIFICATION TEST QCD 2E4-122

JOB NO. <u>610-098 Initial Application</u>	DATE <u>10-14-65</u>	PROCEDURE NO. <u>PQ-1092C-2</u>	W-182-3 <u>WS-40</u>
WELDING PROCESS <u>Electroslag</u>	SINGLE PASS <u>X Double Electrode</u>	MULTIPLE PASS	MULTIPLE ARC
MATERIAL SPECIFICATION <u>P-3 (A-302-B Mod)</u>			

PLATE <u>X</u>	PIPE	METAL THICKNESS <u>6-1/4"</u>	FILLER METAL GROUP NO. <u>Reid Avery Hi-Mn-Mo</u>	WELD CLASSIFICATION NO. <u>Pressure</u>
BACKING STRIP USED <input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO	PRE HEAT TEMPERATURE <u>70°F Min.</u>	INTER PASS TEMPERATURE <u>Not Applicable</u>	FLUX NAME OR COMPOSITION <u>Linde #124 20 X 150</u>

WELD CHARACTERISTICS (VDA) (A.C. OR D.C.) <u>Alternating Current</u>	48-52 Volts	600 Amps	
WELD FLOW RATE <u>Not Applicable</u>	POSITION OF PLATE OR PIPE <u>Vertical</u>	ULTRASONIC TEST <u>Acceptable/No Defects</u>	LIQUID PENETRANT <u>Not Applicable</u>
IONIZING PARTICLE <u>Acceptable/No Defects</u>	RADIOGRAPH <u>No Acceptable/Defects</u>	MACRO EXAMINATION <u>Not Required</u>	MICRO EXAMINATION <u>Not Required</u>
SIZE OF ELECTRODE <u>1/8" Dia.</u>	INERT GAS COMPOSITION <u>Not Applicable</u>		POST HEAT TREATMENT <u>See Attached Sketch</u>
			TRAVEL SPEED INCHES PER MIN. <u>Oscillation Speed 48"/Min. Dwell Time 5 Sec</u>

WELDER'S NAME <u>R. Reese</u>	CLOCK NO. <u>6136</u>	SYMBOL <u>None</u>
----------------------------------	--------------------------	-----------------------

REMARKS Procedure qualification for welding P-3 material in the vertical position by electroslag process using 1/8" Dia. (RACO) Hi-Mn-Mo filler wire with Linde #124 Flux.

(Groove Configuration Attached)

## WELD CHEMICAL ANALYSIS

MN	SI	P	S	CR	NI	MO	CU
				Not Required			

## REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STRENGTH PSI	FRACTURE OR LOCATION
	WIDTH	THICK.				
			<u>See Attached Sketch</u>			

SIDE BEND TEST		FREE BEND TEST	
<u>Our Side Bonds - Acceptable (No Defects)</u>		<u>Not Required</u>	

## ALL WELD METAL TENSILE

SPECIMEN NO.	DIA.	AREA SQ. IN.	YIELD POINT PSI.	TENS. STR. PSI	ELONG % IN 2"	RED AREA %
			Not Required			

HARPY IMPACT TESTS SPECIMEN NO.	TYPE FT. LBS.	OR	FT. LBS. ENERGY LOAD SPECIMEN NO.
	<u>See Attached Sketch</u>		

WE CERTIFY THAT THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED, AND TESTED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME, U.S.C.G., ABS, USN MIL-STD-270 OR NAVSHIPS 250-1500-1.

DATE 10-28-65 SIGNED


WITNESSED C. Zanon, D.C.A.S.O.

PQ-1092C-2

BABCOCK & WILCOX COMPANY

BY Paul E. Campbell

Code #235



ELECTROSLAG DOUBLE ELECTRODE WELD A.C.  
48-52 VOLTS 600 AMPS OSCILLATION SPEED 48" MIN. Dwell Time 5S.  
1/8 DIA. (RACO) HI-MN-MO FILLERWIRE - LINDE #1EA FLUX

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN No	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS	ULT. TENSILE STRENGTH PSI	FRACTURE
	WIDTH	THICK				
PQ1092C-2	1.000"	3.000"	3.060"	284,300	92,960	WELD
PQ1092C-2	1.000"	2.732"	2.732	251,000	91,880	WELD
PQ1092C-2	1.007"	2.629"	2.648	266,000	93,400	WELD
PQ1092C-2	1.006"	3.092"	3.092	285,000	92,170	WELD

CHARPY V-NOTCH IMPACTS @ +10°F 240 FT LBS

LOCATION	FT LBS	FT LBS	FT LBS
BASE METAL	60.0	70.0	63.0
HEAT AFFECTED ZONE	40.0	52.0	70.0
WELD METAL	38.0	33.0	41.0

HEAT TREATMENT

PRELIMINARY QUENCH 6 1/2 HOURS @ 1675°-1725°F BRINE QUENCH  
 FINAL QUENCH 6 1/2 HOURS @ 1600°-1650°F BRINE QUENCH  
 TEMPER 6 1/2 HOURS @ 1175°F-1225°F WATER QUENCH  
 STRESS RELIEF 18 HRS @ 1100°-1150°F FURNACE COOL.

PQ 1092 C-2  
 WELDED IN VERTICAL POSITION.  
 DATE 11-2-65

1-30356

## CORD OF TEST RESULTS

THE BABCOCK & WILCOX COMPANY  
BARBERTON, OHIO

JECT	CUSTOMER General Electric Atomic Power Equipment Department	
ADMN Code Weld Test Plate (Electro Slag)	CUSTOMER ORDER NO. 205-55501	
IT NO.	ASSOCIATED PROCESS QUALIFICATION NO.	B&W CONTRACT NO.
W-1138-A	PQ-1092 C-2	610-0098

SCRIPTION OF TEST Postweld - Heat Treatment - Preliminary Quench 1750-1800°F. HOLD 6-1/2 hours. Quench to below 400°F. Final Quench 1600-1650°F. HOLD 6-1/2 hours. Brine Quench to below 400°F. Temper 1175-1225°F. HOLD 6-1/2 hours. Water Quench to below 400°F. Stress Relieve 1150-1180°F. HOLD 18 hours. Furnace cool to below 600°F.

## WELD CHEMICAL ANALYSIS

C	MN	SI	P	S	CR	NI	MO	CU	ALLOY
1.50	.19	.017	.027	.09	.35	.55	.25	.25	1020

## BASE METAL CHEMICAL ANALYSIS

C	MN	SI	P	S	CR	NI	MO	CU	ALLOY
1.37	.28	.015	.020	.14	.69	.51	.24	.24	1020

ND TEST: TYPE Side NUMBER 4 RESULTS Satisfactory

## DUCTED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMAN NO.	WIDTH	THICKNESS	AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STRENGTH PSI	LOCATION OF FRACTURE
W-1138-A	1.001"	2.934"	2.936 sq "	252,000	85,820	Weld
W-1138-A	1.001"	2.944"	2.947 sq "	262,000	88,900	Weld
W-1138-A	1.000"	2.682"	2.662 sq "	244,500	91,160	Weld
W-1138-A	1.000"	2.850"	2.850 sq "	250,000	87,700	Weld

## WELD METAL TENSILE

SPECIMAN NO.	DIAMETER	AREA SQ. IN.	YIELD POINT PSI	TENSILE STRENGTH PSI	E LONG % IN. 2"	RED. AREA
W-1138-A	.505"	.2 sq in	66,500	87,500	25.0	60.6
W-1138-A	.504"	.2 sq in	66,500	87,000	25.5	60.7

## HARD IMPACT TESTS

LOCATION	TYPE	V-Notch	AT	+10 °F	240 FT. LBS.	LATERAL EXPANSION	ENERGY LOAD.
Weld Surface				52.0, 30.0, 50.0		.044, .031, .041	
Weld 1/4 T				30.0, 53.0, 38.0		.023, .046, .029	
1/4 T Base Metal				64.0, 55.0, 70.0		.042, .041, .053	
1/4 T HAZ				76.0, 65.0, 76.0		.052, .047, .051	

## DROP WEIGHT IMPACT TESTS

LOCATION	HEIGHT	WEIGHT	TEMPERATURE °F	+20	+10	0	-20	-40	-50	-60	-70	-80
Weld	1/4"	60#	+20	F	F	F						
Weld 1/4 T	1/4"	60#	+10	NF	NF	NF	F					
Weld	1/4"	60#	0	NF	NF	NF	F	NF	NF	F	NF	

F = FAILURE

NF = NO FAILURE

DATE January 24, 1966 WITNESSED

BY

Paul F. Campbell  
THE BABCOCK & WILCOX COMPANY

THE BABCOCK & WILCOX COMPANY  
BARBERTON, OHIO

## RECORD OF PROCEDURE OR OPERATOR QUALIFICATION TEST QCD 2E4-122

JOB NO. 610-0111 INITIAL APPLICATION		DATE 5-26-66	PROCEDURE NO. PQ-1300	WS-40
WELDING PROCESS Electroslag		SINGLE PASS <input checked="" type="checkbox"/> Double Arc	MULTIPLE PASS <input type="checkbox"/>	MULTIPLE ARC <input type="checkbox"/>

## MATERIAL SPECIFICATION

P-3 (SA-302, Grade B)

PLATE <input checked="" type="checkbox"/>	PIPE <input type="checkbox"/>	METAL THICKNESS 6-3/8"	FILLER METAL GROUP NO. RACO Hi-Mn-Mo	WELD CLASSIFICATION NO Pressure
IS BACKING STRIP USED <input type="checkbox"/> YES		PRE HEAT TEMPERATURE 70°F. MIN.	INTER PASS TEMPERATURE Not Applicable	FLUX NAME OR COMPOSITION LINDE #124

## WELD CHARACTERISTICS (VSA) (A.C. OR D.C.)

Alternating Current 48-52 Volts 575-625 Amps

GAS FLOW RATE Not Applicable	POSITION OF PLATE OR PIPE Vertical	ULTRASONIC TEST Acceptable/No Defects	LIQUID PENETRANT Not Applicable
MAGNETIC PARTICLE Acceptable/No Defects	RADIOGRAPH No Acceptable/Defects	MACRO EXAMINATION Acceptable	POST HEAT TREATMENT See Reverse Side
SIZE OF ELECTRODE 1/8" Diameter	INERT GAS COMPOSITION Not Applicable	TRAVEL SPEED INCHES PER MIN. Not Applicable Oscillation 48"/MIN. Dwell Time 5 sec	

## WELDERS NAME

R. Reese

## CLOCK NO.

## SYMBOL

REMARKS Procedure qualification for welding P-3 material in the vertical position by Electroslag process using 1/8" Dia. (RACO Hi-Mn-Mo Filler Wire with LINDE #124 Flux. See Reverse Side for Groove Configuration.

## WELD CHEMICAL ANALYSIS

	MN	SI	P	S	CR	NI	MO	CU	
	1.26	.16	.015	.017	.11	.33	.51	.30	

## REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STRENGTH PSI	FRACTURE OR LOCAT.
	WIDTH	THICK.				
		See Reverse Side				

## SIDE BEND TEST

Four Side Bends - Acceptable/No Defects

## FREE BEND TEST

Not Applicable

## ALL WELD METAL TENSILE

SPECIMEN NO.	DIA.	AREA-SQ. IN.	YIELD POINT PSI.	TENS. STR. PSI	ELONG % IN 2"	RED AREA %
			Not Required			

CHARPY IMPACT TESTS	TYPE V-NOTCH	10 OF 240	FT. LBS. ENERGY LOAD
LOCATION	FT. LBS.	LOCATION	FT. LBS.
Heat Affected Zone	104.0, 76.0, 114.0	Weld Metal	39.0, 42.0, 43.0
Base Metal	94.0, 76.0, 82.0		

WE CERTIFY THAT THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED, AND TESTED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME, U.S.C.G.: ABS; USN MIL-STD-278 OR NAVSHIPS 250-1500-1.


October 17, 1966 SIGNED

WITNESSED R. Remark, D. C. A. S. O.

PQ-1300  
235

BABCOCK &amp; WILCOX COMPANY

BY Paul E Campbell



ELECTROSLAG WELD A.C. 48-52 VOLTS 575-625 AMPS  
 48"/MIN OSCILLATION SPEED 5 SEC DWELL TIME  
 $\frac{1}{8}$  DIA(RACO) HI-MN-MO FILLER WIRE WITH LINDE #124 FLUX

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STR. P.S.I.	FRACTURE
	WIDTH	THICK.				
PQ 1300	1.007"	3.175"	3.197"	266,000	83,200	WELD
PQ 1300	1.001"	2.785"	2.788"	237,000	84,980	WELD
PQ 1300	.992"	2.956"	2.932"	236,000	80,500	WELD
PQ 1300	1.008"	3.937"	3.968"	332,000	83,660	WELD

HEAT TREATMENT  
 $\frac{1}{2}$  HRS @ 1675°-1725°F - BRINE QUENCH  
 $\frac{1}{2}$  HRS @ 1600°-1650°F - BRINE QUENCH  
 $\frac{1}{2}$  HRS @ 1175°-1225°F - LIQUID QUENCH  
 30 HRS @ 1100°-1150°F - FURNACE COOL

PQ 1300  
 WELD IN VERTICAL POSITION  
 10-22-CG

## RECORD OF PROCEDURE OR OPERATOR QUALIFICATION TEST QCD 2E4-122

ASSEMBLY TEST JOB NO. 610-0098 INITIAL APPLICATION	DATE 6-7-66	PROCEDURE NO. PQ-1309-A
WELDING PROCESS Electroslag and Automatic Submerged Arc	SINGLE PASS <input checked="" type="checkbox"/> Double Arc	MULTIPLE PASS <input type="checkbox"/>
MULTIPLE ARC <input type="checkbox"/>		

## MATERIAL SPECIFICATION

## P-3 (A-302-B)

PLATE <input checked="" type="checkbox"/>	PIPE <input type="checkbox"/>	METAL THICKNESS 6-1/4"	FILLER METAL GROUP NO. RACO Hi-Mn-Mo & ASW Mn-Mo-Ni	WELD CLASSIFICATION NO Pressure
IS BACKING STRIP USED <input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO	PRE HEAT TEMPERATURE ES 70°F MIN-ASA 300°F MIN.	INTER PASS TEMPERATURE ASA - Not Applicable	FLUX NAME OR COMPOSITION Electroslag LINDE #
		ASA - 300°F MAX.		Auto Sub Arc LINDE #
WELD CHARACTERISTICS (VBA) (A.C. OR D.C.)		Alternating Current	Electroslag 48-52 Volts 600 Amps	
Automatic Submerged Arc		30-34 Volts 450-500 Amps		
GAS FLOW RATE Not Applicable	POSITION OF PLATE OR PIPE ES-Vertical ASA-Flat		ULTRASONIC TEST Acceptable/No Defects	LIQUID PENETRANT Not Applicable
MAGNETIC PARTICLE Acceptable/No Defects	RADIOGRAPH Acceptable/Defects	No	MACRO EXAMINATION Not Required	MICRO EXAMINATION Not Required
SIZE OF ELECTRODE 1/8" Diameter	INERT GAS COMPOSITION Not Applicable		Travel Speed Inches Per Min. ASA - 10" - 12" /MIN.	POST HEAT TREATMENT See Reverse Side
			ES Oscillation 48"/MIN. Dwell Time 5 sec.	
WELDERS NAME R. Reese - T. Starnes - V. Clonts	CLOCK NO. 6136 - 6376 - 6149		SYMBOL None - YS - U-11	
REMARKS Procedure qualification for welding P-3 material by Combination Electroslag and Automatic Submerged Arc process. Electroslag weld in the vertical position using 1/8"Dia. (RACO)Hi-Mn-Mo Filler Wire with LINDE #124 Flux. Auto Sub Arc in the flat position using 1/8"Dia. (ASW)Mn-Mo-Ni Filler with LINDE #80 Flux.				
WELD CHEMICAL ANALYSIS See Reverse Side-Groove Configuration				
C	MN	SI	P	S CR NI MO CU
See Reverse Side				

## REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STRENGTH PSI	FRACTURE LOCATI
	WIDTH	THICK.				
See Reverse Side						

SIDE BEND TEST			FREE BEND TEST		
Four Side Bends - Acceptable/No Defects			Not Required		

## ALL WELD METAL TENSILE

SPECIMEN NO.	DIA.	AREA SQ. IN.	YIELD POINT PSI.	TENS. STR. PSI	ELONG % IN 2"	RED AREA
Not Required						

CHARPY IMPACT TESTS		TYPE V-Notch	+10	OF 240	FT. LBS. ENERGY LOAD
SPECIMEN NO.		FT. LBS.	SPECIMEN NO.		FT. LBS.
See Reverse Side					

WE CERTIFY THAT THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED, AND TESTED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME, U.S.C.G., ABS, USN MIL-STD-278 OR NAVSHIPS 250-1500-1.

PQ-1309-A

275


June 23, 1966 SIGNED

WITNESSED R. Y. Brown, G. E. APED


BABCOCK &amp; WILCOX COMPANY

BY Paul E Campbell

COMBINATION ELECTROSLAG & AUTO SUB ARC WELD



DOUBLE ARC ELECTROSLAG WELD  
A.C. 48-52 VOLTS 600 AMPS  
OSCILLATION SPEED 48"/MIN DWELL TIME 5 SEC  
 $\frac{1}{8}$ " DIA (RACO) HI-MN-MO FILLER WIRE  
LINDE #124 FLUX



AUTOMATIC SUBMERGED ARC WELD  
A.C. 30-34 VOLTS 450-500 AMPS 10"-12"/MIN TRAVEL SPEED  
 $\frac{1}{8}$ " DIA (AMERICAN STEEL & WIRE) MN-MO-NI FILLER WIRE-LINDE #80 FLUX

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT TENSILE STRENGTH R.S.I.	FRACTURE
	WIDTH	THICK				
PQ1309A	1.000"	2.980"	2.980	253,000	84,900	SLAG WELD
PQ1309A	1.000"	2.510"	2.510	217,500	86,660	SLAG WELD
PQ1309A	1.001"	3.009"	3.010	255,000	84,720	SLAG WELD
PQ1309A	.998"	2.506"	2.501	220,000	87,960	SLAG WELD

CHARPY U-NOTCH IMPACTS @ +10°F 240 FT. LBS. ENERGY LOAD

LOCATION	FT. LBS.	FT. LBS.	FT. LBS.
AUTO SUB ARC WELD HEAT AFFECTED ZONE OF SUBARC IN ELECTROSLAG WELD	33.0	42.0	34.0
	93.0	90.0	87.0
BASE METAL	89.0	80.0	95.0
ELECTROSLAG WELD	60.0	50.0	35.0

CHEMICAL ANALYSIS

	C.	MN.	P.	S.	SI.	CR.	Ni.	Mo.	CU.
ELECTROSLAG WELD	.18	1.34	.012	.017	.14	.10	.30	.47	.22
BASE METAL	.18	1.14	.012	.018	.25	.15	.57	.48	.20
AUTO SUBARC WELD	.08	1.65	.015	.016	.46	.07	.48	.43	.19

HEAT TREATMENT PRIOR TO SUBARC WELD 1HR/IN @ 1675°-1725°F BRINE QUENCH  
HEAT TREATMENT PRIOR TO SUBARC WELD 1HR/IN @ 1600°-1650°F BRINE QUENCH  
HEAT TREATMENT PRIOR TO SUBARC WELD 1HR/IN @ 1175°-1200°F LIQUID QUENCH  
FINAL STRESS RELIEF, AFTER WELDING 18 HRS @ 1100°-1150°F FURNACE COOL

PQ 1309A  
ELECTROSLAG WELD IN VERTICAL POSITION  
AUTO SUBARC WELD IN FLAT POSITION  
DATE 6-29-66 CHEMISTRY REVISED 7-22-66

## F ORDER OF PROCEDURE OR OPERATOR QUALIFICATION TEST OQD 2E4-122

ASSESS JOB NO. 610-0098 INITIAL APPLICATION	DATE 6-8-66	PROCEDURE NO. PQ-1309-B
WELDING PROCESS Electroslag and Manual Metal Arc	SINGLE <input type="checkbox"/>	MULTIPLE PASS <input checked="" type="checkbox"/> X MULTIPLE ARC <input type="checkbox"/>
MATERIAL SPECIFICATION		

## P-3 (A-302-B)

PLATE <input checked="" type="checkbox"/> X	PIPE <input type="checkbox"/>	METAL THICKNESS 6-1/4"	FILLER METAL GROUP NO. RACO Hi-Mn-Mo & B&W 8015	WELD CLASSIFICATION NO. Friction
IS BACKING STRIP USED <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	PRE HEAT TEMPERATURE Electroslag 700° F MIN. M.M.A. 300° F MIN.	INTER PASS TEMPERATURE Electroslag Not Applicable M.M.A. 500° F MAX.	FLUX NAME OR COMPOSITION E.S. LINDE #124	
WELD CHARACTERISTICS Electroslag-Alternating Current 48-52 Volts 600 Amps Manual Metal Arc-Direct Current Reverse Polarity 22-26 Volts 185-265 Amps (See Reverse Side)				
GAS FLOW RATE Not Applicable	POSITION OF PLATE OR PIPE Vertical	ULTRASONIC TEST Acceptable/No Defects	LIQUID PENETRANT Not Applicable	
MAGNETIC PARTICLE Acceptable/No Defects	RADIOGRAPH No Acceptable/Defects	MACRO EXAMINATION Not Required	MICRO EXAMINATION Not Required	POST HEAT TREATMENT See Reverse Side
SIZE OF ELECTRODE 1/8", 5/32", & 3/16"Dia	INERT GAS COMPOSITION Not Applicable	TRAVEL SPEED INCHES PER MIN. E.S. Oscillation 48"/MIN Wall Time		
WELDERS NAME R. Reese - E. Sylvester D. Sinnott - U. Palinkas - G. Thompson	CLOCK NO. 6136 - 6188 6125 - 6092 - 6276	SYMBOL None - RU HU - EZ - UR		
REMARKS Procedure qualification for welding P-3 material by combination Electroslag and Manual M-Arc process in the vertical position. Electroslag using 1/8"Dia. (RACO)Hi-Mn-Mo Filler Wire with LINDE #124 Flux. Manual Metal Arc using 5/32" & 3/16"Dia. (B&W)8015 Electrodes. See Reverse Side above Configuration.				
WELD CHEMICAL ANALYSIS				
MN	SI	P	S	Cr Ni Mo Cu
See Reverse Side				

## REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STRENGTH PSI	FRACTURE OR LOCAT
	WIDTH	THICK.				
	See Reverse Side					

SIDE BEND TEST Four Side Bends - Acceptable/No Defects		FREE BEND TEST Not Required
---	--	--------------------------------

## ALL WELD METAL TENSILE

SPECIMEN NO.	DIA.	AREA SQ. IN.	YIELD POINT PSI.	TENS. STR. PSI	ELONG % IN 2"	RED AREA
			Not Required			

CHARPY IMPACT TESTS	TYPE V-Notch	+10° OF 240° FT. LBS. ENERGY LOAD	
SPECIMEN NO.	FT. LBS.	SPECIMEN NO.	FT. LBS.
	See Reverse Side		

WE CERTIFY THAT THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED, AND TESTED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME, U.S.C.G., ABS, USN MIL-STD-278 OR NAVSHIPS 250-1500-1.


PQ-1309-B

275


BABCOCK &amp; WILCOX COMPANY

WITNESSED W. J. Titterington, Sr., G.E.BY Paul E Campbell

**COMBINATION ELECTROSLAG + MANUAL METAL ARC WELD**



**DOUBLE ARC ELECTROSLAG WELD**  
**A.C. 48-52 VOLTS 600 AMPS**  
**OSCILLATION SPEED 48"/MIN DWELL TIME 5 SEC**  
**1/8 DIA (RACO) HI-MN-MO FILLER WIRE**  
**LINDE #124 FLUX**



**MANUAL METAL ARC DCRP**  
**5/32" DIA (B&W) 8015 ELECTRODES 22-24 VOLTS 185-195 AMPS**  
**7/16" DIA (B&W) 8015 ELECTRODES 24-26 VOLTS 250-265 AMPS**

**REDUCED SECTION TENSILE (TRANSVERSE TO WELD)**

SPECIMEN NO.	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT TENSILE STRENGTH P.S.I.	FRACTURE
	WIDTH	THICK.				
PQ1309B	1.000"	3.010"	3.010	249,000	82,720	M.M.A. WELD
PQ1309B	1.002"	2.783"	2.788	230,000	82,500	SLAG WELD
PQ1309B	1.002"	2.736"	2.742	228,000	83,150	SLAG WELD
PQ1309B	1.003"	2.784"	2.793	228,000	81,640	SLAG WELD

LOCATION	CHARPY V-NOTCH IMPACTS @ +10°F 240 FT. LBS. ENERGY LOAD		
	FT. LBS.	FT. LBS.	FT. LBS.
MANUAL METAL ARC WELD HEAT AFFECTED ZONE OF M.M.A. IN ELECTROSLAG WELD	97.0	91.0	96.0
BASE METAL	47.0	95.0	74.0
ELECTROSLAG WELD	98.0	53.0	95.0
	58.0	36.0	44.0

**CHEMICAL ANALYSIS**

	C	MN	P	S	SI	CR	NL	MO	CU
ELECTROSLAG WELD	.17	1.31	.015	.015	.14	.12	.29	.51	.23
MANUAL METAL ARC WELD	.06	.94	.011	.020	.27	.04	.73	.59	.01
BASE PLATE	.19	1.12	.011	.016	.23	.15	.57	.48	.20

HEAT TREATMENT PRIOR TO M.M.A. WELD 1HR/IN @ 1675°-1725°F BRINE QUENCH  
 HEAT TREATMENT PRIOR TO M.M.A. WELD 1HR/IN @ 1600°-1650°F BRINE QUENCH  
 HEAT TREATMENT PRIOR TO M.M.A. WELD 1HR/IN @ 1175°-1200°F LIQUID QUENCH  
 FINAL STRESS RELIEF 18 HRS @ 1100°-1150°F FURNACE COOL  
 (AFTER WELDING)

**PQ 1309B**  
**WELDED IN VERTICAL POSITION**  
**DATE 7-8-66**

THE BABCOCK & WILCOX COMPANY  
BARBERTON, OHIO

CONTRACT NO. A.S.M.E.  
SPECIFICATION NO. \_\_\_\_\_

OF PROCEDURE AND/OR OPERATOR QUALIFICATION TEST-QC 2E4-122

NAME/SHIPS 250-1500-1	ASME SECTION 3 <input checked="" type="checkbox"/>	ASME SECTION 1 & 8 <input checked="" type="checkbox"/>	OTHER <input type="checkbox"/>	PLATE <input checked="" type="checkbox"/>	PIPE <input type="checkbox"/>	SINGLE PASS <input checked="" type="checkbox"/>	MULTIPLY <input checked="" type="checkbox"/>
WELDING PROCESS Double Electroslag		QUALIFICATION POSITION Vertical			METAL THICKNESS 6 $\frac{1}{4}$ IN.	SINGLE LAYER N.R.	MULTIPLY N.A.
MATERIAL SPECIFICATION P-3 (SA-302-B) and electroslag weld metal		{ Mn-Mo base material plus Mn-Mo filler metal }			SINGLE ARC <input checked="" type="checkbox"/>	MULTIPLY <input checked="" type="checkbox"/>	2
HEAT TREATMENT See reverse side					MACRO. EXAM. N.R.	MICRO. EX. N.R.	
FLUX NAME OR COMPOSITION Linde #124	PREHEAT TEMPERATURE NONE	INTERPASS TEMPERATURE NONE	WELDER Cissna SYMBOL CLOCK NO. 1071			McFarland 1072	
TYPE OF BACKUP (STRIP OR GAS) AND COMPOSITION N.A.		FILLER METAL GROUP NO. RACO - H1-Mn-Mo	SHIELDING GAS		CUP SIZE N.A.	TORCH GAS FLOW RATE N.L.	

Alternating current - 48-52 Volts 580-600 Amps

**Alternating current - 40-52 Volts 500-600 Amps**

SIZE OF ELECTRODE, IN. DIA.	ELECTRODE EXT. BEYOND CUP IN.	TRAVEL SPEED IPM	WIRE FEED IPM	OSCILLATION TIME	DWELL TIME
SIZE OF FILLER WIRE, IN. DIA. 1/8 .	N.A.	N.A.	N.A.	48	1pm 1sec
LIQUID PENETRANT	MAGNETIC PARTICLE	RADIOGRAPH		ULTRASONIC TEST	
N.A.	Acceptable	Acceptable		Acceptable	

**REMARKS:** Procedure Qualification for welding P-3 material in the vertical position by the electroslag process using 1/8" dia. (RACO) H1-Mn-Mo filler wire with Linde #124 flux. See reverse side for groove configuration.

CHEMICAL ANALYSIS = S.E. NO. 59703

**REDUCED SECTION TENSILE (TRANSVERSE TO WELD)**

SPECIMEN NO.	DIMENSIONS, INCHES		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULTIMATE TENSILE STRENGTH PSI	FRACTURE LOCATION
	WIDTH	THICKNESS				
P-1667	.995	2.465	2.453	221,000	90,100	Weld
P-1667	1.000	2.342	2.342	208,500	89,020	Weld
P-1667	.995	2.590	2.577	228,000	88,470	Weld
P-1667	1.000	2.660	2.660	233,000	87,600	Weld

Four side bends - Acceptable (No defects)

**ALL WELD METAL TENSILE**

SPECIMEN NO.	DIA. IN.	AREA SQ. IN.	YIELD POINT PSI	TENSILE STR. PSI	ELONG % IN 2"	REC AREA %
			N.B.			

---

**TYPE CHARPY V-NOTCH**

---

**IMPACT TEST AT**

10

340 FT. LBS. ENERGY LOAD

USE METAL	57.	69.	77	FT.LBS.			FT.
ELE. METAL	47.	39.	27	FT.LBS.			FT.
EAT. AFFECTED ZONE	44.	44.	35	FT.LBS.			FT.

WE CERTIFY THAT TO THE BEST OF OUR KNOWLEDGE THE STATEMENTS MADE IN  
T-1'S RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED,  
AND TESTED IN ACCORDANCE WITH THE APPLICABLE SPECIFICATIONS.

**N.R. = NOT REQUIRED      N.A. = NOT APPLICABLE**

MTV-8  
1667


**WITNESSED**

A-11

DATE Sept. 22, 1967

BY Paul E Campbell  
BABCOCK & WILCOX COMPANY

## DOUBLE ELECTROSLAG (A.C.)



1/8" DIA (RACO) HI-MN-MO FILLER WIRE

LINDE #124 FLUX

48-52 VOLTS 590-600 AMPS

48 IPM OSCILLATION 5 SEC. DWELL TIME

HEAT TREATMENT AFTER WELDING

6 1/2 HRS @ 1675°-1725°F - BRINE QUENCH

6 1/2 HRS @ 1600°-1650°F - BRINE QUENCH

6 1/2 HRS @ 1180°-1200°F - WATER QUENCH

30 HRS @ 1100°-1150°F - FURNACE COOL

PQ 1667

MTV-9

WELDED IN VERTICAL POSITION

DATE 10-18-67

A-12

THE BABCOCK & WILCOX COMPANY  
BARBERTON, OHIO

CONTRACT NO. 847-008136-02  
SPECIFICATION NO. WS-40

501-4

ITEMS	ASME SECTION 3	ASME SECTION 8	OTHER	PLATE	PIPE	SINGLE PASS	MULTIPLE PASS
I-1500-1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
WELDING PROCESS	QUALIFICATION POSITION			METAL THICKNESS		SINGLE LAYER	MULTIPLE LAYER
Electroslag	Vertical			6-3/8 IN.		NA	NA
ITEM SPECIFICATION						SINGLE ARC.	MULTIPLE ARC.
P-3 (SA-302-B)						<input type="checkbox"/>	* 2
AT TREATMENT						MACRO. EXAM.	MICRO. EXAM.
See reverse side						**	NR
UX NAME OR COMPOSITION	PREHEAT TEMPERATURE		INTERPASS TEMPERATURE		WELDER SYMBOL	Pierson 5702	Miller 5701
Linde 124	60 °F MIN.		NA °F MAX.		CLOCK NO.		
PE OF BACKUP (STRIP OR GAS) AND COMPOSITION	FILLER METAL GROUP NO.			SHIELDING GAS		CUP SIZE	TORCH GAS FLOW RATE
None	A-2			NA		NA	NA C
PS. VOLTS, CURRENT, POLARITY	46-48 volts,			550-600 amps			
ZE OF ELECTRODE, IN. DIA.	ELECTRODE EXT. BEYOND CUP IN.			TRAVEL SPEED IPM	WIRE FEED IPM	DEPOLARIZATION TIME CY/PM SEC.	DWELL TIME SEC.
ZE OF FILLER WIRE, IN. DIA.	NA			NA	NA	4-5	
QUID PENETRANT	MAGNETIC PARTICLE			RADIOGRAPH		ULTRASONIC TEST	
NA	Acceptable			Acceptable		Acceptable	
MARKS: Procedure qualification for welding P-3 material in the vertical position by the electroslag process using 1/8" dia. (RACO) Hi-Mn-Mo fillerwire with Linde 124 flux. See reverse for additional information & groove configuration.							

CHEMICAL ANALYSIS - S E NO. 65179

LOCATION	C	NH	P	S	SI	CR	NI	MO	FE	CU	CB	CO	TA	TI	UN
Weld	.19	1.40	.015	.015	.14	.09	.27	.54		.23					
Base	.24	1.26	.016	.019	.23	.14	.69	.51		.16					

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS, INCHES		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULTIMATE TENSILE STRENGTH PSI	FRACTURE LOCATION
	WIDTH	THICKNESS				
PQ-1822	.993	2.895	2.875	255,000	88,690	Weld
PQ-1822	.993	2.802	2.782	249,000	89,510	Weld

BEND TEST

Four side bends (split into 20) - Acceptable (No defects)

ALL WELD METAL TENSILE

SPECIMEN NO.	DIAMETER, IN.	AREA SQ. IN.	YIELD POINT PSI	TENSILE STR. PSI	ELONG % IN 2"	RED AREA %
Q-1822 (T)	.504		66,000	88,000	25.0	64.6
Q-1822 (T)	.504		66,000	85,500	26.5	64.1
Q-1822 (T)	.505		65,000	85,500	27.0	67.0
Q-1822 (T)	.505		63,750	85,500	29.0	67.9

TYPE CHARPY IMPACT TEST AT

°F

FT. LBS. ENERGY LOAD

SE METAL	FT. LBS.	FT. LBS.	FT. LBS.
LD METAL	See Reverse Side	FT. LBS.	FT. LBS.
AT AFFECTED ZONE	FT. LBS.		FT. LBS.

WE CERTIFY THAT TO THE BEST OF OUR KNOWLEDGE THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED AND TESTED IN ACCORDANCE WITH THE APPLICABLE SPECIFICATIONS.

N.R. = NOT REQUIRED N.A. = NOT APPLICABLE

\* Electrode spacing 4"

\*\* One transverse & one longitudinal macro - Acceptable


PQ 1822

WITNESSED

A-13

DATE July 30, 1968

By *J. Muffet*  
BABCOCK & WILCOX COMPANY



HEAT TREATMENT

6½ HRS. @ 1675°-1725°F — BRINE QUENCH

6½ HRS. @ 1600°-1650°F — BRINE QUENCH

6½ HRS. @ 1175°-1225°F — LIQUID QUENCH

30 HRS. @ 1100°-1150°F — FURANCE COOL

DROP WEIGHTS

TEMP.	WELD	BASE	HEAT AFFECTED ZONE
+50°	NF NF		
+40°	NF NF		
+30°	NF F F		NF NF
+20°	F	NF NF	F NF
-10°		NF NF	
-20°		NF F	
-30°		F	
-40°	F		

CHARPY V-NOTCH IMPACTS —  $\frac{1}{4}$  T

TEMP.	WELD FT. LBS.	BASE FT. LBS.	HEAT AFFECTED ZONE FT. LBS.
+10	36, 70, 42, 64, 45	56, 56, 56	66, 77, 60
+40	66, 56, 65		
-20	25, 36, 43		
-50	8, 35	32	

THE BABCOCK & WILCOX COMPANY  
BARBERTON, OHIO

CONTRACT NO. 610-0127  
SPECIFICATION NO. W-57

SDM 57-4

**RECORD OF PROCEDURE AND/OR OPERATOR QUALIFICATION TEST-OC 2E4-122**

NAVSHP'S 150-1500-1	ASME SECTION 5	ASME SECTION 8	OTHER	PLATE <input checked="" type="checkbox"/> PIPE <input type="checkbox"/>	SINGLE PASS <input checked="" type="checkbox"/>	MULTIPLE PASS <input type="checkbox"/>
WELDING PROCESS Electroslag				QUALIFICATION POSITION Vertical	METAL THICKNESS 6-3/8 in.	SINGLE LAYER <input type="checkbox"/> MULTIPLE LAY <input type="checkbox"/>
MATERIAL SPECIFICATION P-3 (SA-302-B)					SINGLE ARC <input type="checkbox"/>	MULTIPLE ARC <input checked="" type="checkbox"/>
HEAT TREATMENT See reverse side					MACRO. EXAM. <u>5-Acceptable</u>	MICRO. EXAM. NR
FLUX NAME OR COMPOSITION Linde 124		PREHEAT TEMPERATURE 70 ° MIN.	INTERPASS TEMPERATURE NA ° MAX.	WELDER SYMBOL CLOCK NO. Pierson 5702	MILLER 570	
TYPE OF BACKUP (STRIP OR GAS) AND COMPOSITION None			FILLER METAL GROUP NO. A-2	SHIELDING GAS NA	CUP SIZE NA	TORCH GAS FLOW RATE NA cfm
AMPS. VOLTS. CURRENT. POLARITY Alternating current 48 volts,		550-600 amps				
SIZE OF ELECTRODE, IN. DIA. 1/8		ELECTRODE EXT. BEYOND CUP IN. NA	TRAVEL SPEED IPM NA	WIRE FEED IPM NA	OSCILLATION 40 II /PM SEC	DWELL TIME SEC
LIQUID PENETRANT NA		MAGNETIC PARTICLE Acceptable *	RADIOGRAPH Acceptable	ULTRASONIC TEST Acceptable		
REMARKS: Procedure qualification for welding P-3 material in the vertical position by the electroslag process using 1/8" dia. (Raco) Ni-Mn-Mo filler wire with Linde 124 flux. See reverse side for groove configuration.						

CHMICAL ANALYSIS - S E NO. 65705

LOCATION	C	MN	P	S	SI	CR	Ni	MO	FE	CU	CD	CO	TA	TI	AL
r d	.18	1.49	.014	.011	.15	.06	.36	.49		.18					
base	.23	1.35	.013	.019	.25	.09	.62	.51		.08					

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS, INCHES		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULTIMATE TENSILE STRENGTH PSI	FRACTURE LOCATION
	WIDTH	THICKNESS				
PQ-1851	.878	2.765	2.428	206,500	85,050	Weld
PQ-1851	.871	3.122	2.719	224,500	82,560	Weld
PQ-1851	1.004	2.995	3.007	251,000	83,460	Weld
PQ-1851	1.006	2.852	2.859	240,000	83,940	Weld

END TEST

Four side bends (split into 16) - Acceptable (No defects)

ALL WELD METAL TENSILE

SPECIMEN NO.	DIAMETER, IN.	AREA SQ. IN.	YIELD POINT PSI	TENSILE STR. PSI	ELONG % IN 2"	RED AREA %
PQ-1851	.505		61,750	83,000	30.0	65.6
PQ-1851	.505		63,000	83,500	30.0	69.7
PQ-1851	.505		60,000	82,000	29.0	69.0
PQ-1851	.505		59,500	81,250	29.0	67.9

TYPE CHARPY

IMPACT TEST AT °F FT. LBS. ENERGY LOAD

BASE METAL	FT. LBS.	FT. LBS.
WELD METAL	See reverse side	FT. LBS.
HEAT AFFECTED ZONE	FT. LBS.	FT. LBS.

WE CERTIFY THAT TO THE BEST OF OUR KNOWLEDGE THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WEI "D" AND TESTED IN ACCORDANCE WITH THE APPLICABLE SPECIFICATIONS.

N.R. = NOT REQUIRED N.A. = NOT APPLICABLE

\* Final surfaces


PQ 1851

WITNESSED \_\_\_\_\_

A-15

DATE Oct. 15, 1968

BY Paul F Campbell  
BABCOCK & WILCOX COMPANY CN 23



HEAT TREATMENT AFTER WELDING

6½ HRS. @ 1675°-1725°F — BRINE QUENCH  
 6½ HRS. @ 1600°-1650°F — BRINE QUENCH  
 6½ HRS. @ 1175°-1225°F — LIQUID QUENCH  
 30 HRS. @ 1100°-1150°F — FURNACE COOL

CHARPY V-NOTCH IMPACTS @ 240 FT. LBS.

LOCATION	0°F	+10°F	+40°F	-20°F	-30°F	-40°F
WELD METAL ( $\pm T$ )	55	84, 71, 57	79, 72, 81, 83	59, 39, 35	44	21
BASE METAL ( $\pm T$ )		74, 84, 81		55		
HEAT AFFECTED ZONE ( $\pm T$ )		79, 96, 64		64		

DROP WEIGHTS @ 3 FT./100 LBS.

HEAT AFFECTED ZONE ( $\pm T$ )	
+20°F	NF
0°F	NF
-20°F	F
-10°F	NF
-10°F	NF
-20°F	F
-20°F	NF
-20°F	NF

WELD METAL ( $\pm T$ )	
-20°F	F
-10°F	F
0°F	F
+10°F	F
+20°F	NF
+20°F	NF
-10°F	NF
-30°F	F

BASE METAL ( $\pm T$ )	
0°F	NF
0°F	F
+20°F	NF
+10°F	NF
+10°F	NF

PQ 1051

DATE: 10-15-68

THE BABCOCK & WILCOX COMPANY  
BARBERTON, OHIO

CONTRACT NO. A-17  
SPECIFICATION NO. V-32

Form 901-4

D OF PROCEDURE AND/OR OPERATOR QUALIFICATION TEST-QC 2E4-122

NAVSHP'S 250-1500-1	ASME SECTION 8 <input checked="" type="checkbox"/>	ASME SECTION 8 <input checked="" type="checkbox"/>	OTHER <input type="checkbox"/>	PLATE <input checked="" type="checkbox"/>	PIPE <input type="checkbox"/>	SINGLE PASS <input checked="" type="checkbox"/>	MULTIPLE <input type="checkbox"/>
WELDING PROCESS Electroslag	QUALIFICATION POSITION Vertical				METAL THICKNESS 6-3/8 IN.	SINGLE LAYER NA	MULTIPLE NA
MATERIAL SPECIFICATION P-3 (SA-302-B)						SINGLE ARC <input type="checkbox"/>	MULTIPLE A <input type="checkbox"/>
HEAT TREATMENT See Reverse Side						MACRO. EXAM. NR	MICRO. EXAM. NR
FLUX NAME OR COMPOSITION Linde 124	PREHEAT TEMPERATURE 70° MIN.	INTERPASS TEMPERATURE NA °F MAX.	WELDER SIGNATURE SYMBOL CLOCK NO.	E.I. SISON Miller 5702	SHIELDING GAS None	CUP SIZE NA	TORCH GAS FLOW RATE NA C
TYPE OF BACKUP (STRIP OR GAS) AND COMPOSITION None	FILLER METAL GROUP NO. A-2						
AMPS, VOLTS, CURRENT, POLARITY Alternating Current 46-48 Volts	590-600 Amps						
SIZE OF ELECTRODE, IN. DIA. SIZE OF FILLER WIRE, IN. DIA. 1/8	ELECTRODE EXT. BEYOND CUP IN. NA	TRAVEL SPEED IPM NA	WIRE FEED IPM NA	OSCILLATION IN 45° SWEEP SEC	DWELL TIME SEC		
LIQUID PENETRANT NA	MAGNETIC PARTICLE Acceptable **	RADIOGRAPH Acceptable		ULTRASONIC TEST Acceptable			

REMARKS: Procedure qualification for welding P-3 mat'l in the vertical position by the electroslag process using 1/8" Dia (Raco) HiMnMo filler wire with Linde 124 flux. See reverse side for groove configuration.

CHEMICAL ANALYSIS - S E NO. 67501

LOCATION	C	MN	P	S	SI	CR	NI	MO	FR	CU	CB	CO	TA	TI
Weld	.19	1.49	.016	.014	.16	.06	.38	.55		.19				
Base	.22	1.34	.013	.018	.25	.07	.52	.53		.11				

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS, INCHES		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULTIMATE TENSILE STRENGTH PSI	FRACTURE LOCATION
	WIDTH	THICKNESS				
PQ-1928	.995	3.141	3.125	290,500	83,350	Weld
PQ-1928	.995	3.150	3.134	242,000	83,500	Weld
PQ-1928	.996	2.790	2.779	242,500	87,270	Weld
PQ-1928	1.005	2.697	2.713	235,500	85,800	Weld

BEND TEST

Four side bends (split into 16) - Acceptable (No Defects)

ALL WELD METAL TENSILE

SPECIMEN NO.	DIAMETER, IN.	AREA SQ. IN.	YIELD POINT PSI	TENSILE STR. PSI	ELONG % IN 2"	RED AREA

TYPE CHARPY	IMPACT TEST AT °F	FT. LBS. ENERGY LOAD
BASE METAL	FT. LBS.	FT. LBS.
WELD METAL	See Reverse Side FT. LBS.	FT. LBS.
HEAT AFFECTED ZONE	FT. LBS.	FT. LBS.

WE CERTIFY THAT TO THE BEST OF OUR KNOWLEDGE THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED AND TESTED IN ACCORDANCE WITH THE APPLICABLE SPECIFICATIONS.

N.R. = NOT REQUIRED N.A. = NOT APPLICABLE

\* 4" Electrode spacing  
\*\* Final surface

PQ 1928


WITNESSED

A-17

DATE Dec. 10, 1968

BY J. J. Muffet  
BABCOCK & WILCOX COMPANY

CN 235



HEAT TREATMENT AFTER WELDING

6 1/2 HRS. @ 1675°-1725°F — BRINE QUENCH  
 6 1/2 HRS. @ 1600°-1650°F — BRINE QUENCH  
 6 1/2 HRS. @ 1175°-1225°F — LIQUID QUENCH  
 30 HRS. @ 1100°-1150°F — FURNACE COOL

CHARPY V-NOTCH IMPACTS 240 FT. LBS. ENERGY LOAD

WELD METAL ( $\frac{1}{8}T$ )	
+10°F	30
+10°F	33
+10°F	33
0°F	18
0°F	26

BASE METAL ( $\frac{1}{8}T$ )	
-10°F	57
-10°F	39
-10°F	27
-20°F	52
-20°F	30
-20°F	38

HEAT AFFECTED ZONE ( $\frac{1}{8}T$ )	
+10°F	81
+10°F	81
+10°F	62
-20°F	41
-20°F	58
-20°F	35

DROP WEIGHTS

WELD METAL ( $\frac{1}{8}T$ )	
+20°F	NF
+20°F	F
+30°F	NF
+30°F	NF
+25°F	F
+25°F	NF
+25°F	F

BASE METAL ( $\frac{1}{8}T$ )	
+20°F	NF
+20°F	NF
+10°F	NF
+10°F	NF
-10°F	F
0°F	NF
0°F	NF
-10°F	F

HEAT AFFECTED ZONE ( $\frac{1}{8}T$ )	
+20°F	F
+30°F	NF
+30°F	NF
+25°F	NF
+25°F	F

PQ 1928  
 DATE: 12-10-68

THE BABCOCK & WILCOX COMPANY  
BARBERTON, OHIO

CONTRACT NO. ASME  
SPECIFICATION NO. E-34,

ADM 501-4

FORM OF PROCEDURE AND/OR OPERATOR QUALIFICATION TEST-QC 2E4-122

NAVSHIPS 250-1800-1	ASME SECTION 5	X	ASME SECTION	V	OTHER	PLATE	PIPE	SINGLE PASS	MULTIP. E
WELDING PROCESS Electroslag			QUALIFICATION POSITION Vertical			METAL THICKNESS 6-3/8 IN.		SINGLE LAYER	MULTIPLE
MATERIAL SPECIFICATION P-3 (SA-302-B)								SINGLE ARC	MULTIPLE
HEAT TREATMENT See reverse side								MACRO. EXAM.	MICRO. E
FLUX NAME OR COMPOSITION Linde 124		PREHEAT TEMPERATURE 70 °F MIN.		INTERPASS TEMPERATURE NA °F MAX.		WELDER SYMBOL CLOCK NO.	Pierson 5702	Miller 5701	
TYPE OF BACKUP (STRIP OR GAS) AND COMPOSITION NA			FILLER METAL GROUP NO. A-2			SHIELDING GAS NA		CUP SIZE NA	TORCH GAS FLOW RATE NA

AMPS, VOLTS, CURRENT, POLARITY

Alternating current 48 volts, 600-650 amps

SIZE OF ELECTRODE, IN. DIA.	ELECTRODE EXT. BEYOND CUP IN.	TRAVEL SPEED IPM	WIRE FEED RPM	Oscillation TIME
SIZE OF FILLER WIRE, IN. DIA. 1/8	NA*	NA	NA	48" PM

LIQUID PENETRANT NA	MAGNETIC PARTICLE Acceptable **	RADIOGRAPH Acceptable	ULTRASONIC TEST Acceptable
------------------------	------------------------------------	--------------------------	-------------------------------

REMARKS: Procedure qualification for welding P-3 material in the vertical position by the electroslag process using 1/8" dia. (Eaco) Ni-Mn-Mo fillerwire with Linde 124 flux. See reverse side for groove configuration.

CHEMICAL ANALYSIS - S.E. NO. CCC-1

LOCATION	C	MN	P	S	SI	CR	NI	MO	FE	CU	CR	CD	TA	TI
base	.22	1.37	.013	.014	.27	.11	.51	.49		.09				
Weld	.18	1.50	.016	.013	.17	.03	.30	.43		.20				

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS, INCHES		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULTIMATE TENSILE STRENGTH PSI	FRACTURE LOCA
	WIDTH	THICKNESS				
PQ-1929	.990	3.105	3.153	274,000	44,900	Weld
PQ-1929	1.015	3.119	3.165	275,000	86,890	Weld
PQ-1929	.995	2.721	2.707	232,500	55,880	Weld
PQ-1929	1.002	2.735	2.741	237,500	57,570	Weld

BEND TEST

Four side bends (Split into 16) - Acceptable (No defects)

ALL WELD METAL TENSILE

SPECIMEN NO.	DIAMETER, IN.	AREA SQ. IN.	YIELD POINT PSI	TENSILE STR. PSI	ELONG % IN 2"	RED AREA
			214			

TYPE CHARPY	IMPACT TEST AT	OF	FT. LBS. ENERGY LOAD
BASE METAL		FT. LBS.	
WELD METAL	See reverse side	FT. LBS.	
HEAT AFFECTED ZONE		FT. LBS.	

WE CERTIFY THAT TO THE BEST OF OUR KNOWLEDGE THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, COOLED AND TESTED IN ACCORDANCE WITH THE APPLICABLE SPECIFICATIONS.

N.R. = NOT REQUIRED N.A. = NOT APPLIC

\* 4" electrode spacing


\*\* Final surface

PO 1929

WITNESSED \_\_\_\_\_

BY John Muffet  
BABCOCK & WILCOX COMPANY

DATE Dec. 10, 1968



#### HEAT TREATMENT AFTER WELDING

6½ HRS. @ 1675°-1725°F — BRINE QUENCH  
 6½ HRS. @ 1600°-1650°F — BRINE QUENCH  
 6½ HRS. @ 1175°-1225°F — LIQUID QUENCH  
 30 HRS. @ 1100°-1150°F — FURNACE COOL

#### CHARPY V-NOTCH IMPACTS @ 240 FT. LBS. ENERGY LOAD

BASE METAL #T	
+10°F	18
+10°F	21
+10°F	30
0°F	24
0°F	25
0°F	20

WELD METAL #T	
+10°F	80
+10°F	40
+10°F	55

HEAT AFFECTED ZONE #T	
+10°F	33
+10°F	41
+10°F	31
0°F	36
0°F	13
0°F	25

#### DROP WEIGHTS

BASE METAL #T	
+20°F	F
+20°F	F
+30°F	F
+40°F	F
+80°F	NF
+70°F	NF
+60°F	NF
+60°F	NF

WELD METAL #T	
+20°F	F
+20°F	F
+30°F	F
+40°F	F
+50°F	F
+70°F	NF
+70°F	NF
+60°F	NF

HEAT AFFECTED ZONE #T	
+20°F	F
+20°F	F
+30°F	NF
+30°F	NF
+25°F	F
+25°F	F

PQ 1929

DATE: 12-10-68

THE BABCOCK & WILCOX COMPANY  
BARBERTON, OHIO.

CONTRACT NO. 2-118

SPECIFICATION NO. S-24, V-5

W 401-4

RD OF PROCEDURE AND/OR OPERATOR QUALIFICATION TEST-QC 2E4-122

NAVSHP'S 250-1500-1	ASME SECTION 9	ASME SECTION	<input checked="" type="checkbox"/> OTHER	PLATE	PIPE	SINGLE PASS	MULTIPLE PASSES
WELDING PROCESS Electroslag		QUALIFICATION POSITION Vertical			METAL THICKNESS 6-3/8 IN.	SINGLE LAYER	MULTIPLE LAYER NR
MATERIAL SPECIFICATION P-3 (SA-302-B)						SINGLE ARC	MULTIPLE ARC 2
HEAT TREATMENT See reverse side						MACRO. EXAM. NR	MICRO. EXAM. NR
FLUX NAME OR COMPOSITION Linde 124		PREHEAT TEMPERATURE 70 °F MIN.	INTERPASS TEMPERATURE NR °F MAX.	WELDER Symbol Clock No.	Fierbor 5702	MILLER 5701	
TYPE OF BACKUP (STRIP OR GASS) AND COMPOSITION NA		FILLER METAL GROUP NO. A-2		SHIELDING GAS NA		CUP SIZE NA	TORCH GAS FLOW RATE NA CFM
AMPS, VOLTS, CURRENT, POLARITY Alternating current		50 volts, 590-600 amperes					
SIZE OF ELECTRODE, IN. DIA. SIZE OF FILLER WIRE, IN. DIA.	1/8	ELECTRODE EXT. BEYOND CUP IN. NR	TRAVEL SPEED IPM NR	WIRE FEED IPM NR	Oscillation 24.5 IPH	Dwell Time SEC	
LIQUID PENETRANT NA		MAGNETIC PARTICLE Acceptable	RADIOGRAPH Acceptable	ULTRASONIC TEST Acceptable			
REMARKS: Procedure qualification for welding P-3 material in the vertical position by the electroslag process using 1/8" dia. (Raco) Ni-Mn-Mo filler wire with Linde 124 flux. See reverse side for groove configuration.							

CHEMICAL ANALYSIS - S E NO. 65581

LOCATION	f	MM	"	IN	CR	SI	IN	MM	SI	CR	IN	MM	SI	IN	MM	SI
Base	.19	1.38	.012	.020	.28	.11	.50	.49	.19	.51	.20	.16	.51	.19	.51	.19
Jld	.16	1.52	.012	.014	.15	.07	.26	.51	.20	.51	.20	.16	.51	.19	.51	.19

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS, INCHES		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULTIMATE TENSILE STRENGTH, PSI	FRACTURE LOCATION
	BIRTH	THICKNESS				
PQ-1930	1.000	2.862	2.862	241,000	84,220	Weld
PQ-1930	1.000	3.080	3.050	260,500	94,580	Weld
PQ-1930	1.000	2.462	2.462	210,500	55,500	Weld
PQ-1930	1.000	3.230	3.230	271,000	33,900	Weld

BOND TEST

Four side bends (Split into 16) - Acceptable (No defects)

ALL WELD METAL TENSILE

SPECIMEN NO.	DIAMETER, IN.	AREA SQ. IN.	YIELD POINT PSI	TENSILE STR. PSI	ELONG % IN "	RED AREA %
			N.R.			

TYPE CHARPY	IMPACT TEST AT	FT. LBS.	FT. LBS.	FT. LBS.
BASE METAL	See reverse side	FT.LBS.		FT.LBS.
WELD METAL		FT.LBS.		FT.LBS.
HEAT AFFECTED ZONE		FT.LBS.		FT.LBS.

WE CERTIFY THAT TO THE BEST OF OUR KNOWLEDGE THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED AND TESTED IN ACCORDANCE WITH THE APPLICABLE SPECIFICATIONS.

N.R. = NOT REQUIRED N.A. = NOT APPLICABLE

\* 2-3/4" electrode spacing


\*\* Final surfaces

PQ 1930

WITNESSED

BY F.J. Miffet  
BABCOCK & WILCOX COMPANY

DATE 1-1-1968



#### HEAT TREATMENT AFTER WELDING

6½ HRS. @ 1675°-1725°F — BRINE QUENCH  
 6½ HRS. @ 1600°-1650°F — BRINE QUENCH  
 6½ HRS. @ 1175°-1225°F — LIQUID QUENCH  
 30 HRS. @ 1100°-1150°F — FURNACE COOL

#### CHARPY-V NOTCH IMPACTS @ 290 FT. LBS.

BASE METAL (#T)	WELD METAL (#T)			HEAT AFFECTED ZONE (#T)
+10°F 44	+10°F 10	+20°F 78		+10°F 65
+10°F 52	+10°F 72	+40°F 62		+10°F 52
+10°F 15	+10°F 70	+40°F 94		+10°F 54
+10°F 32	+10°F 75	+30°F 89		-10°F 10
+10°F 50	+10°F 16	+20°F 72		-10°F 65
+10°F 44	+10°F 14	+10°F 39		-10°F 30
	+40°F 90	0°F 45		
	-20°F 31	-10°F 67		

#### DROP WEIGHTS

BASE METAL (#T)	WELD METAL (#T)	HEAT AFFECTED ZONE (#T)
+20°F F	+20°F F	+20°F F
+20°F F	+20°F F	+20°F F
+10°F F	+10°F F	+10°F F
+30°F NF	+30°F F	+30°F NF
+30°F F	+40°F NF	+30°F F
+40°F NF	+40°F NF	+40°F NF
+40°F NF	+30°F NF	+40°F NF
+35°F F	+30°F F	+40°F NF

PQ 1930  
DATE: 10-10-68

80-30356  
RECORD OF TEST RESULTS

THE BABCOCK & WILCOX COMPANY  
BARBERTON, OHIO

Base Metal: 6-3/8" thk  
SA-302-B  
Parallel weld groove  
side walls 1-3/8" + 1/8" apart

CT		ASME Code Weld Test Plate (Electroslag WS-40)		CUSTOMER General Electric				
TEST NO.		ASSOCIATED PROCESS QUALIFICATION NO.		CUSTOMER ORDER NO.				
PQ-1931				BBW CONTRACT NO.				
DESCRIPTION OF TEST			Heat treatment 6-1/2 hrs @ 1675-1725°F - Brine quench after welding: 6-1/2 hrs @ 1600-1650°F - Brine quench 6-1/2 hrs @ 1175-1225°F - Liquid quench 30 hrs. @ 1100-1150°F - Furnace cool					
C	Mn	Si	P	S	Cr	Ni	Mo	Cu
.20	1.52	.12	.015	.021	.05	.38	.59	.19
BASE METAL CHEMICAL ANALYSIS E-66319								
C	Mn	Si	P	S	Cr	Ni	Mo	Cu
.21	1.32	.18	.015	.034	.04	.60	.55	.10

BEND TEST:	TYPE	NUMBER	RESULTS
Four side bends (split into 16) - Acceptable (No defects)			

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	WIDTH	THICKNESS	AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STRENGTH PSI	LOCATION OF FRACTURE
PQ-1931	1.009	2.769	2.794	236,000	84,470	Weld
PQ-1931	.883	2.854	2.520	211,000	83,740	Weld
PQ-1931	1.000	3.056	3.056	256,500	83,940	Weld
PQ-1931	1.001	2.945	2.947	243,500	82,620	Weld

WELD METAL TENSILE	SPECIMAN NO.	DIAMETER	AREA SQ. IN.	YIELD POINT PSI	TENSILE STRENGTH PSI	E LONG % IN. 2"	RED AREA %
				NR			

HARPY IMPACT TESTS

TYPE	AT	OF	FT. LBS. ENERGY LOAD.
LOCATION	FT. LBS.	LOCATION	FT. LBS.
	See reverse side		

TOP WEIGHT IMPACT TESTS	LOCATION	HEIGHT	WEIGHT	TEMPERATURE °F
See reverse side				

F = FAILURE

NF = NO FAILURE

235

Nov. 1, 1968 WITNESSED

A-23

BY *Paul F. Campbell*

### CHARPY V-NOTCH IMPACTS

LOCATION	TEMP. °F.	FT. LBS.
T WELD	+10	47
"	+10	24
"	+10	33
"	+10	57
"	+10	50

LOCATION	TEMP. °F.	FT. LBS.
1/2 T HAZ	+10	36
" "	+10	30
" "	+10	75
" "	-20	29
" "	-20	24
" "	-20	16

LOCATION	TEMP. °F.	FT. LBS.
1/2 T BASE	+10	82
" "	+10	56
" "	+10	74
" "	-20	39
" "	-20	30
" "	-20	50

### DROP WEIGHTS

LOCATION	TEMP. °F.	RESULTS
1/2 T WELD	+20	F
" "	+20	F
" "	+30	NF
" "	+30	NF
" "	+20	F

LOCATION	TEMP. °F.	RESULTS
1/2 T HAZ	+20	F
" "	+20	F
" "	+30	NF
" "	+30	NF
" "	+20	F

LOCATION	TEMP. °F.	RESULTS
1/2 T BASE	+20	NF
" "	+20	NF
" "	0	NF
" "	-20	F
" "	-10	NF
" "	-10	NF
" "	-20	F
" "	-20	F

PQ 1931

DATE: 11-1-68

WELDERS

PIERSON — 5702

MILLER — 5701

## THE BABCOCK &amp; WILCOX COMPANY

MT. VERNON, INDIANA

CONTRACT NO. 610-0122  
SPECIFICATION NO. WS-40

## 1-6 OF PROCEDURE AND/OR OPERATOR QUALIFICATION TEST-QC 2E4-122 Code No. 235\*

NAVSHP'S 290-190G-1	<input type="checkbox"/>	ASME SECTION 2	<input checked="" type="checkbox"/>	ASME SECTION I & II	<input checked="" type="checkbox"/> OTHER A.S.M.E. <input checked="" type="checkbox"/> Sect. IV	PLATE	PIPE	<input type="checkbox"/>	SINGLE PASS	MULTIPLE P.				
WELDING PROCESS Electroslag				QUALIFICATION POSITION Vertical				METAL THICKNESS 6 $\frac{1}{2}$ " IN.	SINGLE LAYER	MULTIPLE L.				
MATERIAL SPECIFICATION P-3 (SA-302 Gr. B. Mod.)									<input type="checkbox"/>	<input type="checkbox"/>				
HEAT TREATMENT See Reverse Side									SINGLE ARC	MULTIPLE AR				
FLUX NAME OR COMPOSITION Linde #124		PREHEAT TEMPERATURE 70 °F MIN.		INTERPASS TEMPERATURE N.A. °F MAX.		WELDER SYMBOL NO. 1068	IRVIN							
TYPE OF BACKUP (STRIP) OR GASKET AND COMPOSITION N.A.				FILLER METAL GROUP NO. Raco Hi-Mn-Mo(A-2)				SHIELDING GAS N.A.	CUP SIZE N.A.	TORCH GAS FLOW RATE N.A.				
AMPS, VOLTS, CURRENT, POLARITY Alternating Current				48-52 Volts				575-625 Amps						
SIZE OF ELECTRODE, IN. DIA. 1/8"				ELECTRODE EXT. BEYOND CUP IN. N.A.		TRAVEL SPEED IPM N.A.		WIRE FEED IPM N.A.		OSCILLATION $\frac{1}{2}$ SEC. See Reverse Side 1/2 CYC/SEC.				
LIQUID PENETRANT N.A.				VISUAL INSPECTION Acceptable				ULTRASONIC TEST						
MAGNETIC PARTICLE Acceptable/No Defects				RADIOGRAPH Acceptable/No Defects				Acceptable/No Defects						
REMARKS: Procedure Qualification for welding P-3 material in the vertical position by the Electroslag Process using 1/8" Dia. (RACO) Hi-Mn-Mo Filler Wire with Linde #124 Flux. See Reverse Side for Groove Configuration.														
CHEMICAL ANALYSIS - % E.W.O.														
LOCATION	C	MN	P	S	SI	CR	Ni	Mo	Fe	CU	CB	CD	TI	TD
REDUCED SECTION TENSILE (TRANSVERSE TO WELD)														
SPECIMEN NO.	DIMENSIONS, INCHES			AREA SQ. IN.	ULTIMATE LOAD LBS.	ULTIMATE TENSILE STRENGTH PSI	FRACTURE LOCA							
	WIDTH	THICKNESS												
T1A	.962	2.895	2.785	248,500	89,250	Weld								
T1B	.978	3.193	3.123	278,250	89,100	Weld								
T10A	.890	3.095	2.755	244,000	88,600	Weld								
T10B	.965	2.969	2.865	255,250	89,100	Weld								
BEND TEST														
(4) Side Bends Split into 16 - Acceptable/No Defects														
ALL WELD METAL TENSILE														
SPECIMEN NO.	DIAMETER, IN.	AREA SQ. IN.	YIELD POINT PSI	TENSILE STR. PSI	ELONG % IN 2	DUCTILITY								
TYPE CHARPY V-Notch				IMPACT TEST AT +10 °F @ 240	FT. LBS. ENERGY LOAD									
AS2 METAL	WT	79, 34, 69	FT. LBS.				FT.							
ELD METAL Surface		59, 47, 49	FT. LBS.	Weld Metal @ +T =	27, 34, 32		FT.							
EAT Affected Zone	WT	84, 80, 76	FT. LBS.				FT.							

CERTIFY THAT TO THE BEST OF MY KNOWLEDGE THE STATEMENTS MADE IN  
THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED,  
WELDED AND TESTED IN ACCORDANCE WITH THE APPLICABLE SPECIFICATIONS.

N.R. = NOT REQUIRED N.A. = NOT APPL

\*Revised 1/26/71.W.L.W.

WITNESSED Hartford (ASME)


DATE 5/22/70

BY D. V. Collins  
BABCOCK & WILCOX

235

PG 2563

MTV-1



#### HEAT TREATMENT

6 $\frac{1}{2}$  HRS @ 1675° - 1725°F - BRINE QUENCH  
 6 $\frac{1}{2}$  HRS @ 1600° - 1650°F - BRINE QUENCH  
 6 $\frac{1}{2}$  HRS @ 1175° - 1225°F - BRINE QUENCH  
 42 HRS @ 1100° - 1150°F - FURNACE COOL

#### DROP WEIGHT TESTS PER ASTM-E208

BASE METAL HAZ	
-10°F	NF
-20°F	NF, NF
-30°F	NF, F
-40°F	F

WELD METAL HAZ	
+20°F	NF, NF
+10°F	F

HAZ H. T	
-10°F	NF, NF
-20°F	NF, F
-30°F	F
-40°F	F

$$\begin{aligned}
 \underline{N.D.T.T.} = & \quad \text{WELD} \quad + 10°F \\
 & \text{HAZ} \quad - 20°F \\
 & \text{B.M.} \quad - 30°F
 \end{aligned}$$

Revised 1/26/71 W.L.W.

P.O. 2563  
MTV-148  
DATE-5/22/70