DRESDEN NUCLEAR POWER STATION

RADIOACTIVE WASTE, ENVIRONMENTAL MONITORING AND OCCUPATIONAL PERSONNEL RADIATION EXPOSURE

JULY THROUGH DECEMBER 1976

Ravid Black The 2/28/19

FEBRUARY 1977

TABLE OF CONTENTS

			PAGE
Intro	ductio	n	1
Summa	ry		2
1.0	Efflu	ents	
	1.1 1.2	GaseousLiquid	
2.0	Solid	Waste	3
3.0	Dose	To Man	
	3.1 3.2	Gaseous Effluent PathwaysLiquid Effluent Pathways	
4.0	Site	Meteorology	27
5.0	Envir	onmental Monitoring	
	5.1 5.2 5.3 5.4 5.5 5.6 5.7 5.8	Gamma Radiation	38 38 40 40 40 40
6.0	Analy	tical Procedures	41
7.0	Occup	ational Personnel Radiation Exposure	41
8.0	Addit	ional Environmental Data for the period January - June 1976	41
9.0	Errat	a to January - June 1976 Report	42
Appen	dix I		
		Tables - Readings and Analyses July through December, 1975	43
Appen	dix II		
	Meteo	prological Data	80
Appen	dix II	I	
	Occup	oational Personnel Radiation Exposure - January through December, 1976	95

INTRODUCTION

The Dresden Nuclear Power Station is located approximately twelve miles southwest of Joliet, Illinois, at the confluence of the Des Plaines and Kankakee Rivers where they form the Illinois River. This station uses three boiling water reactors (GE design) to generate electricity. Unit 1 began operating in 1960 and has a rated power output of 200 megawatts electrical (MWe). Units 2 and 3 began operating in 1970 and 1971, respectively, each with a rated power output of 800 MWe. The General Electric Morris Operation Plant (GEMO) is located adjacent to Dresden.

Liquid effluents from Dresden are released to the Illinois River in controlled batches after radioassay of each batch. Gaseous effluents are released to the atmosphere after delay to permit decay of short half-life gases. Releases to the atmosphere are calculated on the basis of analyses of daily grab samples of noble gases and continuously collected composite samples of iodine and particulate matter. The results of effluent analyses are summarized on a monthly basis and reported semiannually to the Nuclear Regulatory Commission as required per Technical Specifications. Airborne concentrations of noble gases, I-131 and particulate radioactivity in offsite areas are calculated using effluent and meteorological data and data on isotopic composition of effluents.

Environmental monitoring is conducted by sampling at indicator and reference (background) stations in the vicinity of the Dresden plant to measure changes in radiation or radioactivity levels that may be attributable to plant operation. If significant changes attributable to Dresden are measured, these changes are correlated with effluent releases. External gamma radiation exposure from noble gases and I-131 in milk are the most probable pathways at this site; however, a comprehensive environmental monitoring program is conducted which includes many other pathways of less importance.

Radiation dose to individuals and to population groups is calculated when effluent and environmental monitoring data for the six month period indicate a likelihood of public intakes in excess of those that could result from continuous exposure to concentration values listed in Appendix B, Table II, Part 20, Title 10, Code of Federal Regulations (10CFR20).

SUMMARY

Gaseous and liquid effluents for the period remained below the Technical Specification limits. Calculations of environmental concentrations based on effluent, Illinois River flow, and meteorological data for the period indicate that consumption by the public of radioactive materials attributable to the plant are unlikely to exceed one percent of intake that could result from continuous exposure to the concentration value listed in Appendix B, Table II of 10CRF20. Gamma radiation exposure from noble gases released to the atmosphere represented the critical pathway for the period with a maximum individual dose estimated to be 4.6 mrem for the six-month period, and 8.6 mrem for the year, when a shielding and occupancy factor of two is assumed. Environmental monitoring results confirm that dose via other pathways was not significant.

1.0 EFFLUENTS

1.1 GASEOUS EFFLUENTS TO THE ATMOSPHERE

Measured concentrations and isotopic composition of noble gases, radioiodine, and particulate radioactivity released to the atmosphere during the period 1 July through 31 December 1976, are listed in Table 1.1-1 and 1.1-2. A six-month total of 2.7 E+05 curies of noble gases was released during the period with a maximum release rate during any one-hour period of 5.4 E+04 μ Ci/sec.

A total of 0.88 curies of I-131 was released during the six-month period.

A six-month total of 2.9 curies of beta-gamma emitters and non-detectable amounts of alpha emitters was released as airborne particulate matter.

1.2 LIQUIDS RELEASED TO ILLINOIS RIVER

A total of 1.8 E+06 liters of radioactive liquid wastes containing 0.3 curies (excluding tritium) were discharged from the station. These wastes were released at a maximum monthly average concentration of 2.1 E-08 μ Ci/ml from Unit 1 and 2.6 E-08 μ Ci/ml from Units 2 and 3 which is 21% and 26% respectively of the Technical Specification release limits for unidentified radioactivity. During the same period, 4.7 curies of tritium and 0.01 curies of alpha radioactivity were released. Monthly release estimates and principal radionuclides in liquid effluents are given in Table 1.2-1 and 1.2-2.

2.0 SOLID RADIOACTIVE WASTE

Solid radioactive wastes were shipped to Nuclear Engineering Company, Sheffield, Illinois or Moorehead, Kentucky, and Barnwell Nuclear Center, South Carolina. The record of waste shipments is summarized in Table 2.0-1.

TABLE 1.1-1

POOR ORIGINAL

REPORT OT RADIOACTIVE EFFLUENTS

FACILITY: DRESDET NUCLEAR POWER STATICK - UNIT 1

DOCKET NOS.: 50 - 10

I. Garecus Effluents	UNITS	CATA	AUGUST	SEPTETE	COMOBEL	.NUVEYELE	DE CLUBELL	6 MO. TOTAL	TECH. SPEC. REF.
l. Gross Radioactivity Releases a) Total Release	curies	5.1E+0 <u>'</u> ,	&.2E+04	2.6E+04	6.0E+04	3.2E+Qi	1.7E+04	2.7E05	
b) Maximum Release Rate	uCi/sec	3.3E+04	5.4E+04	2.8E+04	4.5E+04	3.15+04	1.0E+04	5.4E+04	
c) Isctopes Released			<u></u>						
Kr-25m	curies	1.3E03	2.1E03	6.2E02	9.6E02	9.0E02	8.6E03	1.4E04	
Kr-87	curies	_4.3E03	6.6E03	1.7E03	4.4E03	2.7E03	2.4E03	2.2E04	
Kr-88	curies	3.8E03	5.6E03	2.0E03	3.5E03	2.8E03	1.5E03	1.9E04	
Xe-133	curies	1.8E03	3.0E03	7.3E02	1.4E03	1.2E03	1.2E03	9.3E03	
Xe-135	curies	9.8E03	1.6E04	5.4E03	6.1E03	5.1E03	4.1E02	4.3E94	···-
Xe-135m	curies	9.8E03	1.5E04	5.1E03	9.6E03	4.5E03	2.4E03	4.6E04	
Xe-138	curies	2.0E04	3.3E04	1.0E04	3.4E04	1.5E04	5.1E02	1.1E05	
d) Percent of Chimney Limit	Z	3.4	5.he	1.80	4.0	2.17	1.12	3.0	
e) kvorage Rolesse Rate	uCi/sec	1.9E+04	3.1E+04	1.06+04	2.2E+O4	1.22+04	6.3E+03	2.6E+04	
2. Iodine Releases									
a) Isotopes Released			<u> </u>						
I-131	curies	4.25-02	7.1E-02	1.1E-01	1.4E-02	1.95-02	8.1E-03	2.6E-01	·
I-133	curies	1.0E-01	1.1E-01	5.9E-01	4.4E-02	5.7E-02	5.5E-02	1.0	·
I-135	curies	1.0E-01	1.2E-01	2.2E-02	5.2E-02	6.1E-02	7.7E-02	4.3E-01	
b) Percent of Chimney Limit	%	0.65	1.11	1.81	0.22	0.30	0.13	0.70	
c) Average Release Rate	uCi/sec	1.6E-02	2.7E-02	4.35-02	5.3E-03	7.2E-03	3.0E-03	1.7E-02	
		l	<u> </u>						



TABLE 1.1-1 (Cont'd)

REPORT OF RADIOACTIVE EFFLUENTS

FACILITY: DRESDEN NUCLEAR POWER STATION - UNIT 1 DOCKET NOS.: 50-10

		,_ 		,				,	
I. Gaseous Effluents (continued)	UNITS	JUIN	AUGUUS T	SEPTEMBER	COTOBLE	HOVEMBER	DUOTREER	6 MO. TOTAL	TECH. SPEC. REF.
3. Particulate Releases a) Gross Radioactivity (ダップ)	curies	3.15-00	3.0E-02	3.4E-02	2.5E-02	3.02-02	4.1E-02	1.9E-01	·
b) Gross Alpha Radioactivity	curies								
c) Isotopes Released - Ce-141	curies						9.0E-05	9.0E-05	
Cr-51	curies						<u> </u>		
Co-60	curies	3.6E-04	3.2E-04	1.1E-03	1.8E-05	3.0E-04	1.1E-03	3.2E-03	~
Sr-89	curies	2.5E-02	2.4E-02	2.3E-02	2.2E-02	2.4E-02	3.3E-02	1.5E-01	
Sr-90	curies	1.2E-05	1.5E-05	3.1E-05	5.0E-06	6.0E-06	8.2E-06	7.7E-05	
Ko-99	curies						i		·
I-131	curies	7.1E-04	5.9E-04	1.0E-03	1.1E-03	2.0E-03	2.2E-04	5.6E-03	
Cs-134	curies	6.5E-05	3.4E-04	3.4E-04		1.3E-04	1.1E-04	9.9E-04	
C3-137	curies	5.3E-04	1.6E-03	1.0E-03	2.9E-04	3.2E-04		3.7E-03	
Ba-140	curies	4.4E-03	3.5E-03	6.9E-03	1.5E-03	2.65-03	5.5E-03	2.4E-02	
La-140	curies								
Np-239	curies								·
Tc-99m	curies								
So 53	curies	3.0E-04		6.6E-04	4.8E-05	2.4E-04	1.2E-03	2.4E-03	
lin 5lı .	curies	7-11			1.3E-06			1.3E-06	
d) Porcent of Chimney Limit	*	0.48	0.47	0.55	0.38	0.47	0.63	0.50	•
e) Average Release	uCi/sec	1.25-02	1.1E-02	1.3E-02	9.2E-03	1.15-02	1.5E-02	1.2E-02	
2. Sum of Iodines & Farticulates									
a) Percent of Chimney Limit	1%	1.13	1.50	2.36	0.61	0.77	0.76	1.20	
. Gaseous Tritium									
e) Total Release	curies	2.8E+01	6.3E+00	3.2E-01	8.5E+00	7.2E+00	2.4E+00	5.3E+01	
b) Average Release Ante	uC1/sec	1.0E+01	2.4E+00	1.3E-01	3.2E+00	2.8E+00	9.0E-01	3.2E+00	

TABLE 1.1-2

REPORT OF RADIOACTIVE EFFLUENTS

FACILITY: Dresden Nuclear Power Station-Units 2/3

DOCKET NOS.: 50-237, 50-249

I. Gasecus Effluents	UNITS	JULY	1 SUEUN	SEPTEMBER	OCTOBER	: CAESERFE	DLOEMBER	6 MO. TOTAL	TECH. SPEC. REF.
1. Gross Radioactivity Releases a) Total Release	curios	2.1E+03	9.1E+02	4.6E+02	1.3E+02	1.29+03	5.6E02	5.4E+03	6.6D.1.f.(1)
b) Maximum Release Rate	uCi/coc	1.45+04	6.1E+03	3.1E+03	6.8E+01	5.52+03	4.6E+03	1.4E+04	6.6D.l.f (2)
c) Iscropes Released									6.6D.1(4)
	curies	1.5E02	8.8E01	5.6E01	8.5	9.2E02	4.3E01	1.3E03	
Kr-87	curies	6.0E01						6.0E01	
Kr-68	curies	2.0E02	1.3E01				6.1	2.2E02	
	curies	7.3E02	7.8E02	3.7E02	1.2E02	1.8E02	5.0E02	2.7E03	
Ye-135	curies	9.1E02	3.1F01	2.6E01		1.3E01	1.2E01	9.9E02	
Ке-135m	curies								
Xe-138	curies					`			
			,		-				
d) Percent of Chimney Limit	%	0.09	0.04	0.02	.01	.05	0.02	.03	6.65.1.f.(3)
e) Percent of Vent Stack Limit	95						L		6.6D.1.f.(3)
f) Average Release Rate	uCi/sec	7.82+02	3.LE+02	1.8E+02	5.0E+01	4.5E+02	2.1E+02	3.4E+02	
2. Chirney Iodine Releases									6.6D.1.T.(1)
a) Isotopes Released					·				
I-131	curies	8.22-02	8.1E-02	1.58-01	2.4E-02	6.9E-02	1.5E-01	5.6E-01	•
I-133	curies	4.1E-01	4.5E-01	7.6E-01	5.2E-02	4.2E-01	6.4E-01	2.7	
I-135	curies	6.3E-01	7.4E-01	9.1E-01	5.9E-01	6.0E-01	8.1E-01	4.3	
b) Percent of Chimney Limit	1 %	0.71	0.73	1.45	0.25	0.64	1.30	0.85	6.6D.1.f.(3)
c) Average Release Rate	uC1/sec	3.1E-02	3.0E-02	5.6E-02	8.9E-03	2.73-02	5.6E-02	2.1E-01	



TABLE 1.1-2 (Cont'd)

REPORT OF RADIOACTIVE EFFLUENTS

FACILITY: Dresden Nuclear Power Station - Unit 2/3

DOCKET NOS.: 50-237, 50-249

T Commun Efficients (continued)	UNITS	JULY	AUGUST	SEPTEMBER	0070ಚಿಟ್	NOVEMBER:	DEMOTABER	6 MO. TOTAL	TECH. SPEC. REP.
I. Gaseous Effluents(continued)	5.0115	0022	- Ac ded :	dia mana	60,65.2.	100000	1	0 110. TOTAL	Teon. Stee. Ret.
3. Chimney Particulate Release a) Gross Radioactivity(β-γ)	ouries	4.63-01	l+-8E-01	3.1E-01	5.8E-02	3.55-01	7.3E-01	2.4E+00	6.6D.l.f.(1)
b) Gross Alpha Radioactivity	curies								
c) Isclopes Released - Mn-54	curies	3.7E-04			5.9E-04		2.2E-03	3.2E-03	6.6D.1.s.(1)
Cr-51	curies								
Co-60	curies			8.1E-04	1.3E-03	1.2E-02	2.1E-02	3.5E-02	
Sr-69	curies	2.4E-01	2.6E-01	1.9E-01	2.5E-02	2.3E-02	5.5E-02	7.9E-01	
Sr-90	curies	6.0E-04	5.8E-04	4.0E-04	2.3E-05	3.5E-05	7.3E-05	1.7E-03	
Mo-99	curies								
I-131	curies	1.5E-02	3.8E-02	1.5E-02	1.1E-03	1.4E-01	5.5E-02	2.6E-01	
Cs-134	curies	7.8E-04						7.8E-04	
Cs-137	curies	3.5E-03	2.4E-03	2.0E-03			8.2E-03	1.6E-02	
Ba-140	curies	2.0E-01	1.8E-01	9.8E-02	3.0E-02	1.8E-01	5.6E-01	1.2E00	
Ia-140	curies								
Np-239	curies								
Tc-95m	curies								
Ce-144 Ce-141	curies curies	2.3E-03		8: {E=83		3.6E-03	2: ZE=02 2: 8E=03	3:5E-83	
d) Percent of Chirney Limit	25	4.0	4.18	2.81	0.62	3.3	6.35	3.54	6.6D.1.f.(3)
G) Average Release Rate	uCi/sec	1.7E-01	1.8E-01	1.18E-01	2.2E-02	1.35-01	2.7E-01	8.9E-01	
L. Vent Stack Icdine Release									6.6D.1.f.(1)
a) Isotopes Noleaced									•
I-131	curies	9.75-03	1.LE-02	1.4E-02	1.5E-02	6.2E-03	5.4E-03	6.4E-02	
I-133	curies	4.0E-02	7.0E-02	4.9E-02	1.7E-02	2.3E-02	2.2E-02	2.3E-01	
I-135	curies	4.6E-02	1.2E-01	5.4E-02		2.1E-02	2.4E-02	2.7E-01	
b) Percent of Vent Stack Limit	8	3.04	4.38	2يا. يا	4.76	2.0	1.7	3.38	6.6D.1.f.(3)
c) Average Release Rate	uCi/sec	3.62-03	5.3E-03	5.3E-03	5.7E-03	03-ئىيا، 2	2.0E-03	4.1E-03	

REPORT OF KADIOACTIVE EFFLUENTS

FACILITY: Dresden Nuclear Power Station - Unit 2/3

DOCKET NOS.: 50-237, 50-249

I. Gaseous Effluents (Continued)	UNITS	JULY	AUCU3 T	SEPTATIBLE	COTOBLE	VE.453R	DUCEMBER	6 MO. TOTAL	TECH. SPEC. REF.
5. Vent Stack Particulate Release (a) Gross Radioactivity (B-γ)	curies	135-02	4.92-02	3.6E-02	3.9E-02	6.1E-02	3.4E-02	2.6E-01	•
(b) Gross Alpha Radioactivity	caries								6.6D.1.r.(1)
(c) Isotopes Released					}				
Cr~51	curies	3.5E-03	5.4E-03	4.2E-03	5.2E-03	8.7E-03		2.7E-02	6.6D.1.f(1)
co_60	curies	5.6E-03	1.3E-02	4.8E-03	1.7E-02	1.3E-02	8.8E-03	6.3E-02	
89	curies	4.0E-03	5.5E-03	3.1E-03	1.1E-03	2.4E-03	5.2E-03	2.2E-02	
Sr90	curies	4.6E-05	5.7E-05	2.7E-05	7.4E-05	2.6E-04	2.0E-04	6.6E-04	
Mo-99	curies	5.0E-03		3.1E-03				8.1E-03	
1-131	curies	6.8E-03	8.9E-03	6.1E-03	2.0E-03	1.5E-02	7.3E-03	4.6E-02	
Cs-134	curies	2.6E-04	2.7E-04	2.5E-04	7.1E-04	7.2E-04	5.7E-04	2.8E-03	
Cs-137	curies	4.4E-04	6.9E-04	4.7E-04	1.2E-03	2.0E-03	2.5E-03	7.3E-03	
Ba-140	curies	5.5E-03	6.9E-03	3.7E-03	3.0E-03	5.9E-03	4.1E-03	2.9E-02	
La-140	curies	6.4E-03	7.6E-03	4.1E-03	3.5E-03	2.3E-03	4.1E-03	2.8E-02	
Np-239	curies								
Tc-99m (continued on next sheet)	curies	5.5E-03		3.4E-03				8.9E-03	
(d) Fercent Vent Stack Limit	56	13.6	15.3	11.53	12.23	19.56	10.73	13.83	6.6D.1.f.(3)
(e) Average Reloase Rate	uCi/sec	1.62-02	1.8E-02	1.4E-02	1.5E-02	2.35-02	1.3E-02	1.7E-02	
6. Sum of Iodine and Particulate									
a) Fercent of Chimney Limit	4,	4.71	4.9	4.26	0.87	3.94	7.65	4.39	6.6D.l.f.(3)
b) Fercent of Vent Stack Limit	%	16.60	19.7	15.94	16.99	21.56	12.39	17.20	
1. Jugobus Dyitimu									
4) Release	curies	2.8E+01	6.3E+J0	3.2E-01	8.5E+00	7.2E+00	2.4E+00	5.3E+01	
t) Average Relieuse Nate	uCi/sec	3.4E+00	3.3E+00	1.5E+01	4.02E+00	4.8E-03	4.7E+00	5.1E+00	
c) Fercent Joan Spec Limit									
									

TABLE 1.1-2 (Cont'd)

REPORT OF KADIOACTIVE EFFLUENTS

FACILITY: Dresden Nuclear Power Station - Unit 2/3 DOCKET NOS.: 50-237, 50-249

•							_		
I. Gaseous Effluents (continued)	UNITS	JULY	AUGUST	SEPTEMBER	OCTOBER	NOVEMBER	DECEMBER	6 MO. TOTAL	TECH. SPEC. REF.
5. Isotopes Released (continued)	Curies								
Mn-54 .	curies	2.7E-04	7.6E-04	5.1E-04	1.9E-03	2.6E-03	3.8E-04	6.3E-03	6.6D.1.f(1)
Co-58	curies	1.2E-04	5.3E-05	4.3E-04	1.2E-03	1.7E-03	2.4E-04	3.8E-03	
Fc-59	curies			2.4E-04	4.6E-04	7.3E-04		1.4E-03	
Zn-65	curies			8.8E-05	3.8E-04			4.7E-04	•
Zr-95	curies			2.5E-04	3.3E-04	7.1E-04	1.4E-04	1.4E-03	
Nb-95	curies			2.1E-04	7.6E-04	1.2E-03	3.5E-04	2.5E-03	
Ce-144	curies				3.1E-04	1.4E-03		1.7E-03	
Ce-141	curies	1.1E-04	2.5E-04	1.7E-04	5.9E-04	7.1E-04	2.1E-04	2.1E-03	
Ru-103	curies			2.3E-04	3.5E-04	6.6E-04	2.2E-05	1.3E-03	
				,					
		;							
			1						
							ļ		•
						1			
						 			
									•
			 			 			
									
· · · · · · · · · · · · · · · · · · ·		<u>_</u>				 -			
	 			l		 			

TABLE 1.2-1

REPORT OF RADIOACTIVE EFFLUENTS

FACILITY: DRESDEN MUCLEAR POWER STATION - UNIT 1 DOCKET NOS.: 50-10 YEAR: 1976

I. Liquid Effluents	UNITS	JULY	AUGUSC	OURTHWEAK	OCYOBER	LOVERBER	DOORDER.	6 MO. TOTAL	TECH. SPEC. REP
1. Gross Radioactivity (B-J)									
a) Total Release		1.55-02	2.0E-02	3.5E-02	7.0E-02	2.95-02	1.0E-02	1.8E-01 1.2E-09	((>) () ()
b) Average Concentration Released	uci/ml	5.5E-10	7.2E-10	1.4E-09	2.6E-09	1.1 _E -02	4.7E-10		6.6D.l.e.(1) 6.6D.l.e.(4)
c) Maximum Concentration Released	uci/ml	2.7E-08	3.7E-08	3.8E-08	4.7E-08	3.3E-08	2.1E-08	2.1E-08	
d) Percent of Tech Spec Limit	*		-	 			ļ		6.6D.l.e.(5)
					ļ		<u> </u>	<u> </u>	6.6D.l.e.(6)
2. Tritiun			ļ. <u></u>						
a) Total Release	Curies	7.6E-04	4.0E-04	8.0E-04	8.1E-04	1.1E-02	4-2E-04	1.4E-02	6.6D.l.e.(8)
L Average Concentration Released	uci/ml	2.8E-11	1.5E-11	3.2E-11	3.0E-11	5.3E-10	1.9E-11	1.1E-10	
c) Percent of Tech Spec Limit	%								
3. Dissolved Noble Gases			-						
a) Total Release	Curies								
b) Average Concentration Released	uci/ml								
c) Fercent of Tech Spec Limit	Z								
4. Gross Alpha Radioactivity									
a) Total Release	Curies	6.72-06	5.1E-04	5.1E-05	7.95-05	2 -0E -04	1.0E-02	1.1E-02	
b) Average Concentration Released	uci/ml	2.52-13	1.92-11	2.0E-12	2.9E-12	9-3E-12	4.7E-10	8.4E-11	
5. Volume of Liquid Waste to			 			<u> </u>			•
Discharge Canal	Liters	8.7E+0li	6.5%+04	1.6E+05	2.7E+05	1.55+05	1.0E+05	6.9E+05	6.6D.l.e.(2)
6. Volume of Dilution Water	Liters	2.7E+10	2.7E+10	2.5E+10	2.7E+10	2.15+10	2.2E+10	1.5E+11	6.6D.l.e.(3)
		·						<u> </u>	
							·		· · · · · · · · · · · · · · · · · · ·

TABLE 1.2-1 (Cont'd)

REPORT OF KADIOACTIVE EFFLUENTS

PACILITY: Dresden Nuclear Power Station
Unit 1 Laundry Drain Tanks

DOCKET NOS .:

50 ~ 10

Unit 1 Laundry Drain Tanks											
I. Liquid Effluents (continued)	UNITS	JULY	AUGUST	SEPTEMBER	OCTOBER	NOVEMBER	DECEMBER	6 HO. TOTAL	TECH. SPEC. REF.		
7. Isotopes Released	Curies	A		٠.							
Mn-54	curies	4.6E-04	5.7E-04	3.0E-03	4.9E-03	2.8E-03	9.2E-04	1.3E-02			
Co-58	curies	5.5E-04		7.2E-04	3.1E-03	1.4E-03	1.1E-04	5.9E-03	·		
Co-60	curies	7.7E-03	1.2E-02	2.9E-02	5.2E-02	1.8E-02	8.6E-03	1.3E-01			
Sr-89	curies	4.1E-03	8.3E-04	1.8E-04	1.3E-04	1.3E-04	6.8E-05	5.4E-03	,		
Sr-90	curies	3.9E-05	5.4E-05	7.1E-06 '	2.8E-05	2.9E-05	1.5E-05	1.7E-04			
Cs-134	curies	5.7E-04	1.5E-03	7.8E-04	2.4E-04	2.1E-04	9.9E-05	3.4E-03			
Cs-137	curies	1.5E-03	5.3E-03	2.0E-03	1.0E-03	1.0E-03	4.7E-04	1.1E-02			
Fe-59	curies				2.2E-03	9.6E-04		3.2E-03			
Nb-95	curies				2.0E-03	9.4E-04		2.9E-03			
Ru-103	curies				2.7E-03	8.7E-04		3.6E-03			
Ce-141	curies				1.6E-03	7.0E-04		2.3E-03			
2r-95	curies	·			~	7.8E-04		7.8E-04			
Ce-144	curies				~	1.6E-03		1.6E-03			
									······································		
								1			
									<u> </u>		
						1			,		
					-						

TABLE 1.2-2

REPORT OF RADIOACTIVE EFFLUENTS

FACILITY: DRESDMI NUCLEAR POWER STATION - UNIT 2/3 DOCKET NOS.: 50-237, 50-249 YEAR: 1976

II. Liquid Effluents	units	JULY	AUGUST	Slptember	CCTOBLE	HERENO::	DECEMBER	6 MO. TOTAL	TECH.	SPEC. RE	<u></u>
l. Gross Radioactivity (ゟ゚-゚゚゚) a) Total Release	Curies	5.5E-03	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE	1.OE-01	5.4E-04	1.1E-01			
b) Average Concentration Released	uci/ml	3.2E-11	THIS MONTH	THIS MONTH	THIS MONTH	1.SE-09	6.4E-11	3.2E-10			
c) Maximum Concentration Released	uci/ml	5.6E-09				2.62-08	1.9E-08	2.6E-08			
d) Percent of Tech Spec Limit	Z										
2. Tritium			·								
Total Release	Curies	4.4E-02				4.6E+00	8.9E-02	4.7E+00			
b) Average Concentration Released	uci/ml	2.6E-10				8.2E-08	1.1E-08	1.6E-08			
c) Percent of Tech Spec Limit	L										
3. Dissolved Noble Gases											
a) Total Release	Curies										
b) Average Concentration Released	uci/ml										
c) Percent of Tech Spec Limit	%					-					
L. Cross Alpha Radioactivity			-							 -	
a) Total Release	Curies	_0				5.1E-04	4.1E-06	5.1E-04			
b) Average Concentration Released	uci/ml	0	<u>-</u>			9.12-12	4.8E-13	1.6E-12			
5. Volume of Liquid Waste to	Liters	1.0E+C!.	·			1.lE+06	1.2E+04	1.1E+06		•	
5. Volume of Dilution Water	Liters	1.72+11				5.62+10	8.4E+09	2.3E+11			_
									 _		

12

TABLE 1.2-2 (Cont'd)

REPORT OF RADIOACTIVE EFFLUENTS

PACILITY: Dresden Nuclear Power Station
D 2/3 Waste Sample Tanks

DOCKET NOS.: 50-237, 50-249

TEAR: 1976

II. Liquid Effluents (continued)	UNITS	JULY	AUGUST	SEPTEMBER	OCTOBER	NOVEMBER	DECEMBER	6 NO. TOTAL	TECH. SPEC. MEP.
7. Isotopes Released	Curles					•			
Mn-54	curies	2.0E-04	NO	NO	NO	6.1E-03		6.3E-03	
Co-58	curies	8.2E-04	DISCHARGE	DISCHARGE	DISCHARGE	5.3E-03		1.1E-03	
Co-60	curies	1.7E-08		•		4.8E-02	1.4E-04	4.8E-02	
Sr-89	curies	1.1E-04				2.1E-04	1.2E-05	3.3E-04	
Sr-90	curies	1.7E-05		1		3.1E-05	1.7E-06	5:0E-05	
I-131	curies	2.4E-03					2.5E-04	2.7E-03	
Cs-134	curies	1.3E-03					1.7E-05	1.3E-03	
Cs-137	curies	6.4E-04					1.2E-04	7.6E-04	
2r-95	curies					1.1E-02		1.1E-02	
Nb-95	curies					1.8E-02		1.8E-02	
Ru-103	curies					7.5E-03		7.5E-03	
Ce-141	curies	÷				6.7E-03		6.7E-03	
				à					
					,				
· ·									·
									•
								·	
						,			
				-					

SOLID WASTE SHIPMENTS, JULY-DECEMBER, 1976

FACULTY: Dresden Nuclear Power Station

DOCKET NOS .: 50-10, 50-237, 50-549

I. Solid Waste Shipped Offsite For		ı		,	· 	γ	1	γ	
Burial or Disposal	UNITS	JULY	AUGUST	SEPTEMBER	OCTOBER	NOVEMBER	DECEMBER	6 MO. TOTAL	TECH. SPEC. REP.
1. Spont Resins, Filter Sludges, Evaporator Bottoms, etc.							:	·	
a) Quantity Shipped	cubic motors	2.0E+02	1.4E+02	1.3E+02	6.1E+01	9.7E+01	5.8E+01	6.9E+02	6.5.D.g.(1)
b) Radioactivity	curies	1.3E+02	2.5E+02	14.14E+02	5.4E+02	1.9E+03	4.6E+02	3.7E+03	6.5.D.g.(2)
2. Dry compressible waste,	 						-		
contaminated equipment, etc.				í			:		
a) Quantity Shipped	cubic meters	1.l ₄ E+01	2.LE+01	1.6E+01	1.9E+02	1.5E+02	1.9E+01	4.1E+02	6.5.D.g.(1)
h' Radioactivity	ouries	1.1E+00	1.2E+00	2.5E-01	2.0E+00	2.35+00	1.4E+00	8.3E+00	6.5.D.g.(2)
II. Solid Waste Shipped Offsite For Purial or Disposal (Processed by									
contractor)					·			-	
1. Spent Resins, Filter Sludges,									
evaporator bottoms, etc. a) Quantity Shipped	cubic meters	7.4E+00	0	0	0	4.9E+0G	0	1.2E+01	6.5.D.g.(1)
b) Radioactivity	curies	9.5E-02	. 0	0	0	2.7E+00	0	2.3E+00	6.5.D.g.(2)
2. Dry Compressible Waste,	-								
contaminated equipment, etc.	-					ļ	 		·
a) Quantity	cubic moters	1.6E+02	3.6E+02	5.5E+01	1.1E+03	1.2E+03	0	2.9E+03	6.5.D.g.(1)
b) Radioactivity	curios	2.9E-02	4.7E-01	2.3E-01	8.8E-01	1.6E+00	0	3.2E+00	6.5.D.g.(2)
	-								
						•			

DRESIEN NUCLEAR POWER STATION

SOLID WASTE DISPOSITION

YEAR 1976

HONTH	NUMBER OF SHIPMENTS	•	MODE OF TRANSPORTATION	DESTINATION
JULY	1 .7	•	Motor Freight (Exclusive use Only)	Sheffield Nuclear Conter
AUGUST	62		Motor Freight (Exclusive use Only)	Sheffield Nuclear Center
SEPTEMBER	36	1	Motor Freight (Exclusive use Only)	Sheffield Nuclear Center
OCTOBER	75 '		Motor Freight (Exclusive use Only)	Sheffield Nuclear Center
OCTOBER	53		Motor Freight (Exclusive use Only)	Barnwell South Carolina
NOVEMBER	96	•	Motor Freight (Esclusive use Only)	Sheffield Nuclear Center
NO VEMBER	63		Motor Freight (Exclusive use Only)	Barnwell South Carolina
DECEMBER .	24		Motor Freight (Exclusive use (Only)	Sheffield Nuclear Center

3.0 DOSE TO MAN

3.1 GASEOUS EFFLUENT PATHWAYS

3.1.1 GAMMA DOSE RATES

Gamma dose rates off-site were calculated based on measured release rates, isotopic composition of the noble gases, and meteorological data for the period (Table 3.1-1). Isodose contours are shown in Figure 3.1-1 for the report period, and in Figure 3.1-2 for the year. Based on measured effluents and meteorological data, the maximum dose to an individual at that location would be 4.6 mrem during the six-month period and 8.6 mrem for the year, with an occupancy or sheilding factor of two included.

3.1.1.2 BETA AIR DOSE RATES

The range of beta particles in air is relatively small (on the order of a few meters or less); consequently, plumes of gaseous effluents may be considered "infinite" for purpose of calculating the dose from beta radiation incident on the skin. The surface dose, i.e., beta air dose, from beta emitters in the infinite cloud can be approximated; however, the actual dose to sensitive skin tissues is difficult to calculate because this depends on the beta particle energies, thickness of inert skin, and clothing covering sensitive tissues. For purposes of this report the surface dose only is given.

The air concentrations of radioactive noble gases at the off-site receptor locations are given in Figures 3.1-3 and 3.1-4. The Laximum off-site beta air dose for the six-month period was 9.4 mrad; that for the year was 12.1 mrad.

3.1.2 RADIOACTIVE IODINE

The human thyroid exhibits a significant capacity to concentrate ingested or inhaled iodine, and some of the radioiodines, especially I-131 and I-133, released during routine operation of the plant may be made available to man thus resulting in a dose to the thyroid. Studies of environmental radioiodine show that the pathways of interest are inhalations of airborne iodine, and ingestion of iodine in milk or on leafy vegetation.

TABLE 3.1-1

DRESDEN NUCLEAR POWER STATION MONTH ENDED DECEMBER, 1976

	MAXIMUM DOSE (1)							
TYPE	UNITS	THIS MONTH	LAST 3 MONTHS	LAST 6 MONTHS	JANUARY TO DATE			
WHOLE BODY (2)	MREM	2.628E-01_	2.15.0E+0.0	4.583E+00	8.645E+00			
SKIN	MRFM	1.452E-01	4.156E+00	9.414E+00	1.213E+01			
INFANTS THYROID (3)	MREM	3.088E-03	1.150E-02	7.732E-01	1.060E+00			
_ADULTS_THYROID_(4)	MREM	2.547E-03_	2.614E-02	9.680E-02	1.076E-01			
POPULATION (5)	PERSON-REM	3.835E+00	2.063E+01	1.627E+02	1.953E+02(6)			

- (1) DOSES CALCULATED IN ACCORDANCE WITH PROPOSED A.L.A.P. REGULATORY GUIDES AA AND OD.
- _(2) INCLUDES SHIELDING AND OCCUPANCY FACTOR OF 2.
- (3) INCLUDES INHALATION DOSE FOR EACH MONTH AND DOSE RECEIVED VIA MILK PATHWAY FROM APRIL THRU SEPTEMBER ONLY.
- (5) POPULATION DOSE IS DETERMINED BY MULTIPLYING THE POPULATION IN EACH SECTOR AND BAND WIDTH BY THE DOSE AT THE MID-POINT OF THE AREA. THE DOSE INTEGRATION EXTENDS TO 50 MILES.

 INCLUDES SHIELDING AND OCCUPANCY FACTOR OF 2.
- (6) THE EQUIVALENT AVERAGE POPULATION DOSE IS 3.180E-05 REM.

FIGURE 3.1-1

Estimated Cumulative Gamma Dose (mrem) from DNPS for the period July-December 1976.

Esopleth Labels:

Small Figure - Multiply by 10⁰
Large Figure - Multiply by 10⁻¹

SCALE


15

POOR ORIGINAL FIGURE 3.1-2

Estimated Cumulative Gamma Dose (mrem) from DNPS for the period January-December 1976.

Isopleth Labels:

Small Figure - Multiply by 10^{0} Large Figure - Multiply by 10^{-1}








FIGURE 3.1-3

Estimated Total Concentration (pCi $/m^3$) of Noble Gases from DNPS for the period July-December 1976.

Isopleth Labels:

Small Figure - Multiply by 10^{+3} Large Figure - Multiply by 10^{+2}







Estimated Total Concentration (pCi $/m^3$) of Noble Gases from DNPS for the period January-December 1976.

Isopleth Labels:

Small Figure - Multiply by 10^{+4} Large Figure - Multiply by 10^{+3}





3.1.2.1 <u>IODINE-131 CONCENTRATION IN AIR</u>

The calculated concentration contours for I-131 in air are shown in Figures 3.1-5 and 3.1-6. Included in these calculations is an iodine cloud depletion factor which accounts for the phenomenon of elemental iodine deposition on the ground. The maximum off-site six-month average concentration is estimated to be 0.8 pCi/m^3 ; that for the year is estimated to be 1.0 pCi/m^3 .

3.1.2.2 DOSE TO INFANTS THYROID

The hypothetical thyroid dose to an infant living near the plant via inhalation and ingestion of milk was calculated. The radionuclides considered were I-131 and I-133 and the source of milk was taken to be the nearest dairy farm with the cows pastured from April to September. The infant was assumed to live at the point of maximum off-site concentrations of airborne iodine. Under these conditions the maximum infant's thyroid dose was 0.8 mrem during the six-month reporting period, and 1.1 mrem during the year. (Table 3.1-1) The measured I-131 in milk (Section 5.4), most of which is believed to be fallout, results in a child's thyroid dose of less than 1 mrem.

3.1.2.3 DOSE TO ADULT'S THYROID

The thyroid dose via inhalation and ingestion of leafy vegetation to an adult living and working nearby was calculated to be 0.1 mrem during the report period and 0.1 mrem for the year. The radionuclides considered are I-131 and I-133 and the source of the leafy vegetables, such as lettuce, harvested during August, September and October, is taken to be a hypothetical farm existing at the point of maximum X/O. (Table 3.1-1)

3.1.3 CONCENTRATION OF "PARTICULATES" IN AIR

Concentration contours of radioactive airborne particulates are shown in Figures 3.1-7 and 3.1-8. The maximum off-site average level for the six months and the year is estimated to be 0.07 and 0.7 pCi/m^3 , respectively, at the site boundry.

3.1.4 SUMMARY OF DOSES

Table 3.1-1 summarizes the doses resulting from releases of airborne radioactivity via the different exposure pathways.

3.2 LIQUID EFFLUENT PATHWAYS

The five principal pathways through the aquatic environment for potential doses to man from liquid waste are drinking water, eating aquatic foods, immersion in water and exposure while boating or walking on the shoreline. Not all of these pathways are applicable at a given time or station but a reasonable approximation of the dose can be made by adjusting the dose formula for season of the year or type and degree of use of the aquatic environment. NRC* developed equations were used to calculate the doses to the whole body, lower GI tract, thyroid, bone and skin; specific parameters for use in


*Nuclear Regulatory Commission, Proposed A.L.A.P. Regulatory Guides AA through DD, February 1974.

FIGURE 3.1-5

Estimated Total Concentration (pCi $/m^3$) of lodine from DNPS for the period July - December 1976.

Isopleth Labels:

Small Figure - Multiply by 10^{-2} Large Figure - Multiply by 10^{-3}







FIGURE 3.1-6


POOR ORIGINAL

Estimated Total Concentration (pCi/ $\rm m^3)$ of Iodine from DNPS for the period January - December 1976.

Isopleth Labels:

Small Figure - Multiply by 10^{-2} Large Figure - Multiply by 10^{-3}






Estimated Total Concentration (pCi/m 3) of Particulate Matter from DNPS for the period July-December 1976.

Isopleth Labels:

Small Figure - Multiply by 10^{-2} Large Figure - Multiply by 10^{-3}








FIGURE 3.1-8

Estimated Total Concentration (pCi/m 3) of Particulate Matter from DNPS for the period January-December 1976.

Isopleth Labels:

Small Figure - Multiply by 10^{-2} Large Figure - Multiply by 10^{-3}





3.2 LIQUID EFFLUENT PATHWAYS (Cont'd)

the equations are given in Table 3.2-1. In general the values of the parameters used were taken from HERMES*, a report which summarizes the living habits of persons in the North Central U.S. These doses are summarized in Tables 3.2-2 and 3.2-3. No organ dose exceeded 0.04 mrem for the year.

4.0 SITE METEOROLOGY

A summary of the site meteorological measurements taken during each calendar quarter of the six-month report period is given in Appendix II. The data are presented as cumulative joint frequency distributions of 35' level wind direction and wind speed class by atmospheric stability class determined from the temperature difference between the 150' and 35' levels. Data recovery for these measurements was 95.8%.

^{*}J. F. Fletcher and W. L. Dotson (compilers), "HERMES-A digital Computer Code for Estimating Regional Radiological Effects from the Nuclear Power Industry," USAEC Report HEDL-TME-71-168, Hanford Engineering Development Laboratory, 1971.

TABLE 3.2-1

VALUES OF PARAMETERS USED TO MAKE DOSE ESTIMATES
RESULTING FROM DRESDEN LIQUID WASTE DISCHARGES

Pathway	Parameter	<u>Unit</u>	Value or Source
Potable Water	M _p /F M _p /F F F Up Qi Dipr λi	unitless CFS-1 CFS 1/m 1/m Ci/m mrem/pCi hr-1	1/1.37 x 10 ⁴ (a) 1.34 x 10 ⁻⁸ F ¹ Station Report 36.6 Station Report Regulatory Guide Table of Isotopes or Other Sources 106 (b)
Aquatic Food	Mp F1 Up Qi,DiprAi Bip tp	unitless CFS 1/m kg/m 1/kg hr	1/4 1.34 x 10 ⁻⁸ F ¹ Station Report 0.1 (c) See Potable Water Regulatory Guide 72 (d)
Shoreline Deposits	$\begin{smallmatrix} M_{p},F,Q_{1},\lambda_{1} \\ U_{p} \\ T_{1} \\ W \\ t_{p} \\ t \end{smallmatrix}$	hr/m d unitless hr hr	See Aquatic Food 16.6 (e) (.693/ λ_1) x 1/24 d/hr 0.2 0 (8.76 x 10 ³ (hr/y) x 30y = 2.63 x 10 ⁵
Swimming	M _p ,F,Q _i ,\(\lambda_i\) U _p D _{ipr} t _p K _p	hr/m mrem/hr/pCi/l hr unitless	See Aquatic Foods 0 (f) Regulatory Guide 0 1
Boating	M _p ,F,Q _i ,λ _i U _p D _{ipr} t _p K _p	 hr/m mrem/hr/pCi/l hr unitless	See Aquatic Foods O, Nov. to March:47, April to Oct.(g) Regulatory Guide 0 2

⁽a) For potable water pathway it is assumed that total mixing in the river has occurred by the time the radioactivity reaches Peoria, 106 miles downstream.

⁽b) A river flow of 1 mph is assumed; hence t = 106 miles + 1 mph

⁽c) Based on data from HERMES, pg. 41

⁽d) HERMES, pg. 118 (e) HERMES, pg. 144

⁽f) No swimming in Illinois River

⁽g) HERMES, pg. 144. 29 hr/m = \rightarrow 330 hr/yr. 330 hr of boating from April to October is 47 hr/m.

TABLE 3.2-2

DRESDEN-1 NUCLEAR POWER STATION DOSES RESULTING FROM EXPOSURE

TO RADIOACTIVITY DISCHARGED IN LIQUID WASTE DECEMBER 1976 AND JANUARY TO DECEMBER 1976

PERIOD	INGEST		DOSE BY PATHWAY (MRFM) ON SHORELINE			SWIMMING		BOATING	
						WHOLE BODY			WHOLE BODY
THIS MONTH			0.000	000	0.0.0		0.000	0.000	0.000-
LAST 3 MONTHS	•000	.002	0.000	.000	.000	.000	0.000	0.000	.000
LAST 6 MONTHS	.002	-002	0.000	.002	.001	.001	0.000	0.000	.000
SINCE JANUARY			0.0.0.0	004		• 0 0 2	0 • 0 0 0 -	0 • 0 D.D	-000

ORGAN.	TOTAL ORGAN TOTAL DOSE	DOSE SINCE JANUARY MAXIMUM ALLOWABLE	PERCENT OF MAXIMUM
WHOLE BODY GI-LLI THYROID	•006 •003	500 1500 1500	•001 •000
BONE SKIN	•004 •002	500 3000	.001 .000

DRESDEN-2/3 NUCLEAR POWER STATION

DOSES RESULTING FROM EXPOSURE TO RADIOACTIVITY DISCHARGED IN LIQUID WASTE DECEMBER 1976 AND JANUARY TO DECEMBER 1976

PERIOD	DOSE E INGESTION				ATHWAY (MREM) SHORELINE		SWIMMING		BOATING	
			· · · · · ·		SKIN	WHOLE BODY	SKIN	WHOLE BODY	WHOLE BODY	
THIS MONTH	.000	.005	.000	.000	.000	.000	0.000	0.000	9.000	
LAST 6 MONTHS SINCE JANUARY	.000	•005 	4 4	•000		.000			.000	

	ORGAN		DOSE SINCE JANUARY , MAXIMUM ALLOWABLE	PERCENT OF MAXIMUM	
	WHOLE BODY GI-LLI	.010	500 1500	.002	
- Company and the second secon	BONE SKIN	• 005 • 003	1500 500 3000	• 001 • 000	

5.0 ENVIRONMENTAL MONITORING

Table 5.0-1 provides a summary of the radiological environmental monitoring program as required in the Technical Specifications. Monitoring locations are shown in Figure 5.0-1. The analytical results for each type of measurement and each medium are discussed in the following sections, and listed in Appendix I. Average values for radioactivity in the environment are given in Tables 5.0-2 and 5.0-3.

Nuclear explosions were detonated at the Lop Nor test site in the People's Republic of China on 26 September 1976 and 17 October 1976. Fallout from the first of these events was detected in the Eastern U. S. at considerably above normal levels a few days after the explosion. Radioactive debris was detected in samples collected from the midwestern U. S. in samples collected ten days to two weeks after the event. Since sampled media represent integral collections the debris could have arrived with air masses considerably before the actual collection date.

Major effects of the first explosion were seen in concentrations of radioactivity in air particulates which increased significantly in mid-October and were only returning to the levels normally measured during the late fall months by the end of December.

Effects of the second detonation were either masked by those from the first explosion or not detected at sensitivities employed in this program. Global meteorological processes, device yields, and injection altitudes all effect the temporal and spacial distribution of debris from these events and additional longer lived nuclides may be detected at some later time.

Specific findings for various environmental media are discussed below.

5.1 GAMMA RADIATION

External radiation dose from on-site sources and noble gases released to the atmosphere was measured at eight indicator and nine reference (back-ground) locations using 10 mR ionization (ion) chambers and solid lithium fluoride thermoluminescent dosimeters (TLD). Ion chamber readings are used to provide a weekly indication of variations in exposure rates. Interpretation of these measurements in complicated by changes in background radiation due to snow cover, soil moisture and other natural phenomena. Also the ion chamber readings are affected by temperature, atmospheric pressure, humidity and charge leakage. The ion chambers are not shielded and some of the ion chamber response may not represent total body (penetrating) dose. For these reasons, the TLD readings are considered to provide the best documentation of total body dose for the period. Quarterly TLD readings are given in Table 5.1-1 and weekly ion chamber readings are given in Tables 5.1-2 through 5.1-11 in Appendix I.

A comparison of the TLD results for reference stations with on-site and off-site indicator stations is included in Table 5.1-1. Although a slight difference between the average on-site and off-site values was measured this is mainly due to a higher value from one station (On-Site 2) and not a generally elevated level throughout the site. With the exception of this one station, the small changes which may be due to plant operations are difficult to distinguish from natural background variations. The greatest dose measured at an off-site indicator station was 4.3 mrem with a shielding and occupancy factor of two included.

Air Sampling and Station Gamma Radiation

R - Surface Water W - Well Water M - Milk




FIGURE 5.0-1 Location of Dresden/MFRP Environmental Monitoring Stations

TABLE 5.0-1 SUMMARY OF RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM* January through June 1976

Medium	Number of Locations	Number of Samples	No. of Unusual(a) Readings	Radiation Attributable to Plant Operation
Direct Radiation	35	731	8	6
Airborne Particulate	17	456	See Section 5.0	0
Airborne I-131	17	235.	12	0
Milk	3	73	12(b)	0
Grass	4 .	59	0	0
Cattle Feed	3	30	0	0 .
Precipitation	4	28	4(b)	0
Soil	4	26	0	0
Water	22	133-	2 (c),(d)	0
Fish	1	4	0	0
Sediment	3	6	0	. 0
Other Aquatic Biota	6	9	0	0

^{*}Exclusive of special collections reported in Tables of Section 5.8

⁽a) Does not include on-site stations or ion chamber readings.

⁽b) Refer to Section 5.0, 5.4 or 5.5.

^{&#}x27;(c) High solid content and/or possible fresh fallout (see Section 5.0)

⁽d) I-131 found in inlet and discharge samples on 11/26/76.

TABLE 5.0-2

REPORTING OF RADIOACTIVITY IN THE ENVIRONS

Docket No. 50-10, 50-237, 50-249

Facility: DRESDEN

B Lisbon

B Coal City B Channahon Reporting Period: Third Quarter 1976

mR/Week mR/Ouarter

	Sampling/Location	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Units
1.0	Water	Gross a (W/G)	Gross B (W/G)	Sr-89 (Q/C')	Sr-90 (0/C')	H-3 (Q/C')	I-131 (W/C')	10 ⁻⁹ µCi/ml
1a	Station Cooling Water							
	I Discharge Canal-1	2	7	< 5 < 5	< 2	360	< 4	
	I Discharge Canal-2/3	1	9 9	< 5 < 5	· < 2 < 2	380 210	< 4 < 4	
	B Inlet Canal-1	1	9	()	ν 2	210	\ 4	
1ь	Surface							
	I Illinois River at EJ&E		10					
	RR Bridge	2	10 10		0	///	< 4	
	I Illinois River at Morris	NR .	6	< 5 < 5	2 < 1	440 190	NR	
	I Dresden Lock & Dam	NR	6	< 5	< 1	280	NR NR	
	I Dresden Lake (Pond)	NR	O	\)	\ 1	200	NK	
lc	Well	•	Gross B (Q/G)			H-3 (0/G)		
	I Dresden Lock & Dam		21			NR		
	I Dresden Well #1		22			< 100		
	I Dresden Well #2		22	•		< 100		
	I Thorsen Farm		8			< 100		
	I Anderson Farm		16 15			NR NR		
	B Bennitt Farm B Hansel		24			NR NR		
	B Breen		35			NR NR		
	B Olson		20			NR.		
	B GE-MO-Well		30			< 200		
	B Drinking Fountain		18			NR		
· 1d	Precipitation		Gross β (M/C)	•		H-3 (M/C)		
	I On-Site #2		58			290		
	B Davidson Farm		29			225		
	B Mather Farm		40			415		
	B Brandon Lock & Dam		18			270		
2.0	Air		culate					
		Gross a (M/C)	Gross B (W/C)			GeLi (M/C')	I-131 (B/C)	10-14 cc
	I Bennitt Farm	< 0.5	4			< 1	< 3	
	I Clay Products	< 0.5	. 4			< 1	< 3	
	I On-Site #1	NR	5			< 1	< 3	
	I On-Site #2	NR	5			< 1	< 3	
	T On-Site #3	< 0.2	5 5			< 1 < 1	< 3 < 3	
	I Pheasant Trail	< 0.5 0.2	<u>ح</u> ۸			< 1	< 3	
	I Collins Road	NR	4 6			< 1	< 3	
	I Prairie Park	NR NR	Ž			< 1	₹3	
	B Elwood B Joliet	0.2	4			< 1	₹ 3	
	B Wilmington	NR	4 .			< ī	< 3	
	B Morris	0.3	4	·		< 1	< 3	
	D Id-box	NR	4			< 1	< 3	


	B Minooka	0.2	4		< 1 < 1	〈
	B Goose Lake Village	< 0.5	4		· -	
3.0	Gamma Background	Ion Ch	ambers	TLD		
		Gamma (W/I)	Gamma (Q/I)	Gamma (Q/I)		
	I Bennitt Farm	1.9	25	25		
	I Clay Products	1.7	22	20		
	I On-Site #1	2.0	26	25		
	I On-Site #2 Unshielded	3.0	39	38		
	I On-Site #3 Shielded	2.4	31	-		
	I On-Site #3	2.0	26	31		
	I Pheasant Trail	1.9	25	22		
	I Prairie Park	1.9	25	21	•	
	I Collins Road	1.8	23	23		
	B Elwood	1.9	25	16	•	
	B Joliet	2.1	27	18		
	B Wilmington	1.6	21	19		
	B Morris	1.7	22	16		
	B Lisbon	1.7	22	16		
	B Coal City	1.6	21	16		
	B Channahon	1.8	23	22		
	B Minooka	1.8	23	20		
	B Goose Lake Village	1.7	22	19		

⁽¹⁾ Frequency: W-Weekly, M-Monthly, Q-Quarterly, T-Thrice Annually, S-Semi-Annual, A-Annual Type: G-Grab, C-Continuous, P-Proportional, C'-Composite, I-Integrating.

I-Indicator Stations or Levels. B - Background Stations or Levels.

0.2

If all data for a given medium are "<", average is listed as "<" the least sensitive measurement. Where "<" values and finite measurements occur within a series, "<" data are averaged as if they were measured quantities.



REPORTING OF RADIOACTIVITY IN THE ENVIRONS

Docket No. 50-10, 50-237, 50-249

Facility: DRESDEN

Reporting Period: Third Quarter 1976

	Sampling/Location	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) . Results	Entity (Freq/Type)(1) Results	Units
4.0	Milk I Davidson Farm I Dorin Farm B Mather Farm		Sr-89 (M/C') < 5 < 5 < 5	Sr-90 (M/C') 5 5 5 5	Cs-137 (M/C¹)	H-3 (S/G) 240 350 200	I-131 (W/G) < 0.5 < 0.5 < 0.5	10 ⁻⁹ uCi/ml
5.0	Sediment I Dresden Lock & Dam B kankakee River B DesPlaines River	Gross β (Q/C) 3 1 3	Sr-89 (S/G) < 2 < 2 < 2 < 2 < 2	Sr-90 (0/G) < 1 < 1 < 1 < 1		GeLi (S/G) < 1 < 1 < 1		10-3 µC1/kg
6.0	Periphyton I Dresden Lock & Dam B Kankakee River B DesPlaines River	Gross <u>B</u> (T/G) 52 42 65				GeLi (S/G) < 1 < 1 < 1		
7.0	Fish I Dresden Lock & Dam	Gross β (S/G)	Sr-89 (T/G) < 2	Sr-90 (T/G)		GeLi (T/G) < 0.1		
8.0	Davidson Farm prin Farm ather Farm	Gross β (M/G) 8 8 10	Sr-89 (M/G) <pre></pre>	Sr-90 (M/G) < 1 < 1 < 1		GeL1 (M/G) < 1 < 1 < 1		
9.0	Cattle Feed & Hay I Davidson Farm I Dorin Farm B Mather Farm	Gross β (M/S) 4 7 4	Sr-89 (M/S) < 2 < 2 < 2 < 2 < 2	Sr-90 (M/S) <pre>< 1</pre>			I-131 (A/G) < 1 < 1 < 1	10 ⁻³ µC1/kg
10.0	Vegetables Glasscock Girot Phillips Rousonellis	Gross β (M/G) 2 2 2 2 3	Sr-89 (A/G) <pre></pre>	Sr-90 (A/G) <pre></pre>		GeL1 (A/G) < 1 < 1 < 1 < 1 < 1 < 1		
11.0	Soil I Davidson Farm I Thorsen Farm I Mather Farm I Dorin Farm	Gross β (Q/G) 4 9 4 4	Sr-89 (Q/G)	Sr-90 (Q/G)		GeLi (A/G) < 1 < 1 < 1 < 1 < 1 < 1	·	
12.0	Aquatic Plants I Discharge Canal-1 B Inlet Canal I Discharge Canal-2/3	Gross β (Q/G) 6 4 30	<u>Sr-89 (Q/G)</u>	<u>sr-90 (0/G)</u> < 1		GeLi (S/G) < 1 < 1 See Discussion		

⁽¹⁾ Frequency: W-Weekly, B-Bi-Weekly, M-Monthly, Q-Quarterly, T-Thrice Annually, S-Semi-Annual, A-Annual Type: G-Grab, C-Continuous, P-Proportional, C'-Composite, I-Integrating

I - Indicator Stations or Levels.B round Stations or Levels.

If alreadta for a given medium are "<", average is listed as "<" the least sensitive measurement. Where "<" values and finite measurements occur within a series, "<" data are averaged as if they were measured quantities.

TABLE 5.0-3

REPORTING OF RADIOACTIVITY IN THE ENVIRONS

Docket No. 50-10, 50-237, 50-249

Facility: DRESDEN

B Goose Lake Village

Reporting Period: Fourth Quarter, 1976

Facil	lity: DRESDEN					Reporting Perio	deporting Period: Fourth Quarter, 1976			
	Sampling/Location	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Entity (Freg/Type)(1) Results	Fntity (Freq/Type)(1) Results	Units		
1.0	Water	Cross a (W/G)	Gross B (W/G)	Sr-89 (Q/C')	Sr-90 (Q/C')	H-3 (0/C')	I-131 (W/C')	10 ⁻⁹ uC1/ml		
la	Station Cooling Water I Discharge Canal-1	1	7	< 5	< 2	470	< 4			
	I Discharge Canal-1	3	8	₹ 5	< 2	590	< 4			
	B Inlet Canal-1	2	7	< 5	< 2	360	< 4			
1ъ	Surface I Illinois River at EJ&E RR Bridge I Illinois River at Morris I Dresden Lock & Dam I Dresden Lake (Pond)	3 NR NR NR	7 8 6 10	< 5 NR < 5 NR	< 2 NR < 2 NR	720 NR NR < 240	< 4 NR NR NR			
1c	Well		Gross β (Q/G)			H-3 (0/G)				
	I Dresden Lock & Dam		22							
	I Dresden Well #1		25			200				
	I Dresden Well #2 I Thorsen Farm		38 4	•		< 200 360				
	I Anderson Farm		23			NR				
	B Bennitt Farm		9			NR				
	B Hansel		13			NR				
	B Breen		16 20	•		NR NR				
	B Olson B GE-MO-Well		22			< 200				
	B Drinking Fountain		27			NR				
ld	Precipitation		Gross β (M/C)	•		H-3 (M/C)				
	I On-Site #2		284			160				
	B Davidson Farm		231			190				
	B Mather Farm		67 61			200 190				
	B Brandon Lock & Dam		01			190				
2.0	Air	Parti Gross a (M/C)	culate Gross β (W/C)			GeLi (M/C')	<u>1-131</u> (B/C)	10 /cc		
	I Bennitt Farm	0.2	13			<u> </u>	< 3			
	I Clay Products	0.4	13	1		< 1	< 3			
	I On-Site #1	NR NR	16			< 1	< 3			
	I On-Site #2 I On-Site #3	NR 0.8	18 12			< 1 < 1	< 3			
	I Pheasant Trail	0.3	14			< 1	< 3 . < 3			
	I Collins Road	0.2	12			< 1	₹ 3			
	I Prairie Park	NR	14			< 1	< 3			
	B Elwood	NR 0.4	14 14			< 1	< 3			
	B Joliet B Wilmington	NR	14			< 1 < 1	< 3 < 3			
	B Morris	0.3	12	•		< 1	₹3			
	B Lisbon	NR	12			< 1	< 3			
	B Coal City	0.2 NR	12			< 1	⟨ 3			
	B Channahon	0.2	13 15			< 1 < 1	< 3 < 3			
	B Minooka B Goose Lake Village	0.2	14			< 1	< 3			
3.0	Gamma Background	Ion Cha	mhara	TLD				mt /Ho als		
J. 0	•	Gamma (W/I)	Gamma (Q/I)	Gamma (Q/I)				mR/Week mR/Ouarter		
	I Bennitt Farm	1.9	25	18						
	I Clay Products I On-Site #1	2.0 2.3	26 30	16 17						
	I On-Site #1 I On-Site #2 Unshielded	2.3	30 33	17 23						
	I On-Site #2 Shielded	2.2	29	-						
	I On-Site #3	2.0	26	23						
	I Pheasant Trail I Prairie Park	1.9 1.9	25 25	22		•				
	I Prairie Park I Collins Road	1.9	25 25	17 18						
	B Elwood	2.1	27	14						
	B Joliet	2.2	29	. 16						
	B Wilmington	2.0	26	17						
	B Morris B Lisbon	1.8 1.8	23 23	15 15						
	B Coal City	1.7	22	15						
	B Channahon	1.9	25	17						
	B Minooka	1.8	23	16						
	R Goose Lake Village	1.8	23	17				_		

^{1.8} (1) Frequency: W-Weekly, M-Monthly, Q-Quarterly, T-Thrice Annually, S-Semi-Annual, A-Annual Type: G-Grab, C-Continuous, P-Proportional, C'-Composite, I-Integrating. I-Indicator Stations or Levels. B - Background Stations or Levels.

17

23

If all data for a given medium are "<", average is listed as "<" the least sensitive measurement. Where "<" values and finite measurements occur within a series, "<" data are averaged as if they were measured quantities.

TABLE 5.0-3 (Cont'd)

REPORTING OF RADIOACTIVITY IN THE ENVIRONS

Docket No. 50-10, 50-237, 50-249

Facility: DRESDEN

Reporting Period: Fourth Quarter 1976

	Sampling/Location	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Entity (Freq/Type)(1) Results	Units
4.0	Milk I Davidson Farm I Dorin Farm B Mather Farm		Sr-89 (M/C') < 5 < 5 < 5 < 5	<u>Sr-90 (M/C¹)</u> 2 6 4	Cs-137 (M/C¹) < 5 < 5 < 5 < 5	H-3 (S/G) NR NR NR	I-131 (W/G) See Discussion "	10 ⁻⁹ uC1/ml
5.0	Sediment I Dresden Lock & Dam B kankakee River B DesPlaines River	Gross β (Q/C) 6 < 1 3	Sr-89 (S/G) <pre></pre>	<u>Sr-90 (∩/G)</u>		GeLi (S/G) <pre></pre>		10 ⁻³ µCi/kg
6.0	Periphyton I Dresden Lock & Dam B Kankakee River B DesPlaines River	Gross β (T/C) 6 15 14				GeL1 (S/G) NR NR NR		
7.0	Fish 1 Dresden Lock & Dam	Gross B (S/G)	Sr-89 (T/G) NOT REQUIRED	Sr-90 (T/G) THIS PERIOD		GeLi (T/G)		
8.0	Grass I Davidson Farm I Dorin Farm B Mather Farm	Gross β (M/G) 15 7 6	Sr-89 (M/G) < 2 < 2 < 2 < 2	<u>Sr-90 (M/G)</u>		GeL1 (M/G) < 1 < 1 < 1		
9	ottle Feed & Hay Davidson Farm I Dorin Farm B Mather Farm	Cross β (M/S) 7 9 4	Sr-89 (M/S) < 2 < 2 < 2 < 2 < 2	<u>sr-90 (M/s)</u>		GeL1 (M/C)	<u>1-131 (A/G)</u>	10-3 µC1/kg
10.0	Vegetables Glasscock Girot Phillips Dorin Rousonellis	Gross ß (M/G)	11 11	Sr-90 (A/G) IRED THIS PERIOD " " "		GeLi (A/G)		
11.0	Soil I Davidson Farm I Thorsen Farm I Mather Farm I Dorin Farm	Gross β (Q/G) 5 8 6 5	Sr-89 (Q/G) < 2 < 2 < 2 < 2 < 2 < 2	<u>sr-90 (Q/G)</u>		GeLi (Q/G) <pre></pre>		
12.0	Aquatic Plants I Discharge Canal-1 B Inlet Canal I Discharge Canal-2/3	Gross β (Q/G)	n	Sr-90 (O/G) IRED THIS PERIOD """"		GeL1 (S/G)		

^{·(1)} Frequency: W-Weekly, B-Bi-Weekly, M-Monthly, Q-Quarterly, T-Thrice Annually, S-Semi-Annual, A-Annual Type: G-Grab, C-Continuous, P-Proportional, C'-Composite, I-Integrating

I - Indicator Stations or Levels.B - Background Stations or Levels.

If all data for a given medium are "<", average is listed as "<" the least sensitive measurement. Where "<" values and finite measurements occur within a, "<" data are averaged as if they were measured quantities.

5.2 AIRBORNE I-131 AND PARTICULATE RADIOACTIVITY

Concentrations of airborne I-131 and particulate radioactivity at monitoring locations are listed in Tables 5.2-1 through 5.2-8 (Appendix I). The locations of these air samplers are the same as for direct radiation measurements, shown in Figure 5.0-1. Airborne I-131 remained below 0.03 pCi/m^3 .

Concentrations of gross alpha radioactivity associated with airborne particulate matter (after decay of natural radon daughters) remained below $0.01~\rm pCi/m^3$. Beta radioactivity in air particulate samples ranged from about $0.02~\rm to~0.08~\rm pCi/m^3$, which is the usual range for late summer – early winter samples, until debris from the Chinese nuclear explosions was detected in mid-October (see above). From mid-October through mid-November gross beta concentrations in air particulates increased to measurements as high as $0.66~\rm pCi/m^3$ and then began to decrease to an average of around $0.1~\rm pCi/m^3$ in filters collected during the end of the year.

An unusual effect observed here and other stations throughout the midwest was the wide range of concentrations of beta emitters in samples for the same time interval at different stations. This phenomenon is attributed to the presence of relatively large particles of radioactive debris from the first test. The validity of the measurements and this observation has been confirmed by individual nuclide measurements of individual filters at other stations.

The weekly average gross beta concentrations in air are plotted in Figure 5.2-1. Plotted are averages where the three on-site stations are considered as one group, stations 0 to 5 miles from the plant as another group, and stations more than five miles distant as a third group. No contribution from plant operation was measured. Gamma isotopic analyses of composites of air particulate filters indicated the presence only of naturally occurring Be-7 at concentrations above the sensitivity requirements of the program for both indicator and background stations. The October, November and December composites for both groups of samples contained gamma emitters, chiefly Ce-141, Ru-103, Rh-102, Zr-Nb-95, in concentrations below program sensitivities and not further quantified. These nuclides are characteristic of the debris from the above mentioned tests. Radioactivity listed in Tables 5.2-7 and 5.2-8, Appendix I.

5.3 AQUATIC RADIOACTIVITY

Surface water samples were collected daily and composited for analysis weekly for the Unit 1 Inlet Canal, Unit 1 Discharge Canal and Units 2 and 3 Discharge Canal. Weekly grab samples were taken from Dresden Lake and the Illinois River at the EJ and E Railroad Bridge. A twice per month composite sample made from daily aliquots of Illinois River water was collected at Morris, Illinois. A quarterly grab sample was taken from the Corps of Engineers Goose Lake Pumping Station on the Kankakee River. For gross alpha and gross beta analysis a 250 ml sample is processed. High dissolved solids in a sample require that a smaller volume be analyzed to minimize self-absorption problems in counting. Analytical results for gross alpha, gross beta, I-131, tritium, gamma emitters, Sr-89 and Sr-90 shown in Tables 5.3-1 through 5.3-3 do not indicate any measurable radioactivity attributable to plant operation.

No activity attributable to plant operations was detected in sediment of aquatic biota samples. The results of analyses are shown on Tables 5.3-6 through 5.3-9.




FIGURE 5.2-1 GROSS BETA IN WEEKLY AIR PARTICULATE FILTERS.

5.4 MILK, GRASS AND CATTLEFEED

Milk samples were collected weekly from the Davidson Farm located five miles northeast of Dresden, the Dorin Farm located about 10 miles south of the station and the Mather Farm (background station) located more than 10 miles N.E. of Dresden. I-131 was determined for each sample by gamma spectrometry or chemical separation of I- and beta counting. Gamma emitters were measured by gamma spectrometry (GeLi). For I-131 analysis a four liter sample is processed; for Sr-89, Sr-90 one liter is used, and three liters are analyzed for gamma emitters. Sr-89 and Sr-90 were determined by radiochemistry and low background beta counting, and Cs-137 by radiochemical separation and/or gamma (GeLi) spectrometry. The analytical results are given in Table 5.4-1 and 5.4-2. Elevated concentrations of I-131 in milk were measured from early October through early November. This activity is attributed to debris from the Chinese nuclear tests (See section 5.0) and agrees in temporal distribution with similar observations throughout the midwest. There was no radioactivity attributable to plant operations. The only radionuclides present in measurable amounts were Sr-90 from worldwide fallout and natural K-40. The concentrations of Sr-90 were within expected ranges and are not attributable to plant operation.

5.4 MILK, GRASS AND CATTLEFEED (Cont'd)

When milk cows were on pasture, grass samples were collected weekly from the same dairy farms that supply the milk samples. During the winter months, cattlefeed samples were collected instead of pasture grass. These grass and cattlefeed samples were analyzed for gross beta, Sr-90, Sr-89 and gamma emitters (spectrometry by GeLi). Because fallout Sr-90 and Cs-137 are present, the best indicator radionuclides are Sr-89, I-131, Cs-134 and Ba-140. These radionuclides were not detected in any of the samples. The results are given in Tables 5.4-3 and 5.4-4.

5.5 <u>TERRESTRIAL DEPOSITION</u> (Rainwater and Soil)

Radioactivity deposited on the surface of the ground was sampled using 6-inch diameter collectors for precipitation and dry deposition. These samples are analyzed for gross beta. The results are summarized in Table 5.5-1. Slightly elevated concentrations attributable to fallout (See 5.0) were measured in October and November samples. Radioactivity in soil given in Table 5.5-2, does not indicate a significant difference in the results for indicator and background stations, and except for traces of fallout materials, only naturally occurring radionuclides were detected.

5.6 VEGETABLES

Vegetables were collected from farms between 2 and 12 miles of the station. Analytical data listed in Table 5.6-1 (Appendix I), indicate the presence of no radioactivity due to station operations.

5.7 GROUND WATER

Well water samples, collected monthly from the Dresden Lock and Dam drinking fountain and quarterly from other wells, showed no indication of increases in radioactivity attributable to operation of the Dresden Station. The well water data are given in Table 5.7-1.

5.8 SPECIAL COLLECTIONS

5.8-1 On July 25 to July 31, 1976; August 22 to 25, 1976; September 12 to 15, 1976; October 7 to 9, 1976; November 11 to 17, 1976; December 9 to 14, 1976, airborne radioiodine plus particulate effluents exceeded 33%, but not 100% of the limits in Technical Specification section 3.8.A.a. Special collections of grass and soil were made on August 7, 1976; September 11, 1976; September 25, 1976; December 4, 1976; December 24, 1976. The special collection on December 4, 1976 was snow rather than grass because a recent snowfall covered the ground. Gross beta and gamma isotopic analysis of these special collections did not reveal the presence of radioactivity attributable to station operations (Table 5.8-1). Routine samples (air particulate filters, ion chamber readings, surface water, etc.) collected shortly thereafter also revealed normal concentrations of natural and weapons testing fallout radioactivity.

5.8 SPECIAL COLLECTIONS (Cont'd)

5.8-2 On July 31, 1975, a 30 ft. well was installed in bore 1 drilled on the east side of the Unit 1 Radwaste Facility (see Figure 5.8-1). A special sampling program was established to monitor the elevation of ground water and concentration of radioactivity in the water taken from the area around the T-112, T-113 resin vaults. The results of the samples are shown in Table 5.8-2. To date, the results are not conclusive, but it does appear that most activity is on suspended material and is thus not readily migratable. "Organics" in the water are complicating the analytical efforts. The measurement of ground water elevation has been discontinued. Measurements of radioactivity in quarterly samples will continue for an indefinite period.

5.8-3 Following soil excavation for the new D-1 HPCI and Waste Treatment Facilities radiation surveys of the sandstone bedrock within the restricted area indicated that radioactivity contamination was present. Consequently, approximately 50,000 ft³ of soil containing 1.2 Ci were removed from this area and shipped to Barnwell, S. C. The activity, the composition of which is Cs-137 43%, Co-60 46%, Cs-134 10% and Mn-54 1%, in the remaining soil and sandstone is estimated to be approximately 0.1 Ci. Radiological decay will reduce this to 0.02 Ci in 30 years. (See table 5.8-3, Appendix I).

6.0 ANALYTICAL PROCEDURES

A summary of the procedures used for analyzing radioactivity in environmental samples is given in Appendix III of the report for the period January through June 1975. Procedures used during the period covered by this report remain unchanged.

7.0 OCCUPATIONAL PERSONNEL RADIATION EXPOSURE

Occupational personnel radiation exposure data for the January - December period are given in Appendix III.

8.0 ADDITIONAL ENVIRONMENTAL DATA FOR THE PERIOD JANUARY - JUNE 1976

See Table 8.0-1, Appendix I

9.0 ERRATA TO JANUARY THROUGH JUNE 1976 REPORT

Month		Reported	Should Be
January	U-1 I. Gaseous effluents 1. a) total release*	2.8 E+02	2.0 E+03
January	 Iodine releases a) Isotope I-131* 	2.7 E-03	2.2 E-04
April	 Particulate releases a) Gross Radioactivity Six-Month total 	6.9 E-02 2.8 E-01	5.7 E-02 2.7 E-01
	Solid Waste Shipped	Off-Site	
January April		6.2 E+00 3.6 E+00 2.2 E+01	3.9 E+00 3.6 E+01 5.2 E+01

^{*}Six-month total not effected.

APPENDIX I
ANALYTICAL DATA

GAMMA RADIATION

Average mR/week Using Thermoluminescent Dosimeters

			Six-Month Average	
	3rd Quarter	4th Quarter	July - December	<u>Annual</u>
Date Annealed:	07/07/76	10/05/76	NA	02/06/76
Date Read:	10/11/76	1/05/77	NA	01/04/77
Location				
On-Site Indicator Stations				
D-16 On-Site 1 A	1.91 ± .46(a)	$1.32 \pm .14(a)$	1.61 ± 0.30	1.08 ± 0.26
D-17 On-Site 2 B	$2.92 \pm .37(a)$	$1.79 \pm .37(a)$	2.35 ± 0.37	1.74 ± 0.15
D-18 On-Site 3 C	$2.39 \pm .29(a)$	1.76 ± .14(a)	2.07 ± 0.28	1.40 ± 0.19
D-46 Collins Road CR	$1.78 \pm .21(a)$	$1.42 \pm .10(a)$	1.60 ± 0.15	1.17 ± 0.09
Average	$2.25 \pm .33$	$1.57 \pm .18$	$\overline{1.91 \pm 0.28}$	1.35 ± 0.17
Off-Site Indicator Stations		113, 1 110	1.71 - 0.20	1.33 = 0.17
D-09 Bennitt Farm BE	$1.93 \pm .29(b)$	$1.40 \pm .35(b)$	1.66 ± 0.32	1.14 ± 0.10
D-15 Clay Products J21	$1.53 \pm .48(b)$	1,22 ± ,25	1.37 ± 0.36	0.98 ± 0.14
D-45 Pheasant Trail PT	$1.68 \pm .07(b)$	$1.67 \pm .29(b)$	1.67 ± 0.18	0.99 ± 0.15
D-47 Prairie Park PP	$1.58 \pm .16$ (b)	$1.29 \pm .23$	1.39 ± 0.19	0.93 ± 0.09
Average	$1.68 \pm .25$	$1.40 \pm .28$	1.52 ± 0.26	1.01 ± 0.12
Background Stations				
D-02 Elwood J15	$1.23 \pm .13$	$1.04 \pm .16$	1.13 ± 0.26	0.91 ± 0.05
D-03 Joliet Brandon Rd.J48	$1.39 \pm .09$	$1.26 \pm .10$	1.32 ± 0.09	0.91 ± 0.04
D-04 Wilmington 464	$1.43 \pm .19$	1.27 ± .24	1.35 ± 0.21	0.85 ± 0.10
D-06 Morris J16	$1.23 \pm .18$	1.18 ± .09	1.20 ± 0.13	0.79 ± 0.09
D-07 Lisbon J24	$1.25 \pm .12$	1.15 ± .19	1.20 ± 0.15	0.78 ± 0.08
D-08 Coal City J68	$1.22 \pm .16$	1.12 ± .18	1.17 ± 0.17	0.72 ± 0.12
D-11 Channahon CH	$1.67 \pm .12(c)$	$1.28 \pm .17$	1.47 ± 0.14	0.82 ± 0.08
D-14 Minooka J27	1.51 ± .19(c)	$1.20 \pm .18$	1.35 ± 0.18	1.03 ± 0.06
D-44 Goose Lake Village GLV	$1.46 \pm .30$	$1.33 \pm .29$	1.39 ± 0.29	1.01 ± 0.15
Average	1.37 ± .16	1.20 ± .18	1.29 ± 0.18	0.87 ± 0.09

⁽a) Unusual reading due to station operation.

⁽b) Unusual reading possibly due to station operation.

⁽c) Unusual reading not thought to be due to station operation.



	D-09		BENNITT F	ARM	BE	1	D-15	_	CLAY PROD	UCTS	J21
Week	Serial		Serial			3	Serial		Serial		
Ending	Number	mR	Number	mR_	mR/Week]	Number	mR	Number	mR	mR/Week
07/03/76	2458	(a)	2557	(a)	_	_	2728	(a)	2734	(a)	-
07/10/76	11	(a)	11	(a)	- .		11	(a)	11	(a)	_
07/17/76	11	4.5	11	5.0	1.5		**	4.5	11	4.6	1.5
07/24/76	11	2.0	**	2.0	2.0		11	1.5	11	1.4	1.4
07/31/76	. 11	1.8	17	1.9	1.8		11	1.7	11	1.8	1.7
08/07/76	11	2.1	11	2.5	2.1		11	1.7	11	2.0	1.7
08/13/76	11	1.8	11	1.9	2.1		11	1.4	11	1.5	1.6
08/21/76	11	2.2	**	2.5	1.9		11	2.0	11	2.0	1.8
08/29/76	11	2.5	**	2.3	2.0		11	2.0	***	2.0	1.8
09/04/76	11	1.4	11	1.5	1.6		11	1.5	11	1.7	1.7
09/11/76	11	1.9	11	1.8	1.8		11	2.0	11	2.0	2.0
09/18/76	11	(a)	**	(a)	**		11	(a)	11	(a)	_
09/25/76	11	(b)	11	(b)	-		11	(b)	11	(b)	_
10/03/76	11	6.1	17	6.2	2.0	•	11	5.5	11	5.8	1.8
10/09/76	11	1.5	**	1.4	1.6		11	2.0	11	2.0	2.3
10/16/76	11	1.8	11	2.0	1.8		11	1.6	11	1.7	1.6
10/23/76	11	(b)	11	(b)	_		11	(b)	11	(b)	_
10/30/76	11	(b)	11	(b)	_		11	(b)	11	(b)	_
11/07/76	11	6.1	**	5.8	1.8		1111	5.8	11	6.0	1.8
11/13/76	11	1.5	11	4.6	1.7		11	1.8	11	1.8	2.1
11/21/76	11	(b)	11	(b)	_		11	(b)	11	(b)	
11/27/76	11	4.5	11	4.7	2.2		11	3.7	11	3.7	1.9
12/04/76	11	(a)	11	(a)	_		***	(a)	***	(a)	_
12/11/76	rr .	4.5	11	4.6	2.1		f	4.5	**	4.6	2.1
12/18/76	11	2.0	11	2.0	2.0		11	2.0	**	2.3	2.0
12/24/76	11	(a)	"	(a)	-		11	(a)	11	(a)	_
12/31/76	11	(a)	ff	(a)	-		11	(a)	**	(a)	_

⁽a) No reading due to minometer problems.

⁽b) No reading due to weather conditions.

	D-16	ON	-SITE STAT	ION #1	A		D-18	ON-	SITE STATI	ON #3	C
Week	Serial		Serial				Serial		Serial		
Ending	Number	mR	Number	mR	mR/Week		Number	mR_	Number	mR	mR/Week
07/03/76	2613	(a)	2530	(a)	_		2472	(a)	2436	(a)	_
07/10/76	**	(a)	**	(a)	_		11	(a)	11	(a)	_
07/17/76	11	5.1	**	5.0	1.7		**	5.0	**	5.0	1.7
07/24/76	11	1.8	11	1.8	1.8		**	1.5	71	1.5	1.5
07/31/76	11	2.5	11	2.5	2.5		**	1.9	**	2.0	1.9
08/07/76	11	2.0	tt	2.3	2.0		11	2.0	11	2.3	2.0
08/13/76	11	1.7	**	1.6	1.9		**	1.9	**	1.9	2.2
08/21/76	11	3.0	11	3.0	2.6	•	11	3.0	11	3.2	2.6
08/29/76	71	2.3	11	2.3	2.0		**	3.0	***	2.7	2.4
09/04/76	11	1.7	11	1.7	2.0		11	1.7	11	3.0	2.0
09/11/76	11	1.9	11	1.9	1.9		11	2.0	11	1.9	1.9
09/18/76	11	(a)	11	(a)	_		11	(a)	11	(a)	-
09/25/76	11	(b)	11	(b)	_		*1	(b)	11	(b)	_
10/03/76	**	6.5	11	7.8	2.2	-	11	7.6	tt	7.7	2.5
10/09/76	***	1.7	11	1.7	2.0		11	2.5	11	2.5	2.9
10/16/76	11	2.6	11	2.7	2.6		11	2.0	11	2.2	2.0
10/23/76	11	(b)	11	(b)	.		11	(b)	11	(b)	-
10/30/76	**	(b)	. 11	(b)	_		ri,	(b)	11	(b)	-
11/07/76	11	7.0	11	6.5	2.0		11	8.2	11	8.2	2.6
11/13/76	***	1.6	11	4.0	1.9		11	1.7	11	1.8	2.0
11/21/76	11	(b)	11	(b)	_		11	(b)	11	(b)	_
11/27/76	11	5.0	11	5.5	2.5		11	4.7	11	4.5	2.3
12/04/76	11	(a)	11	(a)	_		11	' (a)	17	(a)	_
12/11/76	11	7.0	11	7.0	3.3		11	4.5	11	4.5	2.1
12/11/76	11	2.0	17	2.0	2.0		11	2.0	f1	2.1	2.0
12/24/76	**	(a)	11	(a)			11	(a)	11	(a)	-
12/31/76	11	(a)	11	(a)	_		11	(a)	11	(a)	<u>-</u> ·

⁽a) No reading due to minometer problems.

⁽b) No reading due to weather conditions.



			(SHIELDE	•		(UNSHIELDED)				
	D-17	ON-	-SITE STAT	ION #2	В	<u>D-17</u>	ON-	-SITE STAT	TION #2	<u>B</u>
Week	Serial		Serial			Serial		Serial		
Ending	Number	mR	Number	mR	mR/Week	Number	mR	Number	mR	mR/Week
07/03/76	2628	(a)	2553	(a)	-	2535	(a)	2479	(a)	-
07/10/76	**	(a)	**	(a)	-	n	(a)	11	(a)	-
07/17/76	11	6.0	11	6.0	2.0	11	6.0	11	6.0	2.0
07/24/76	**	3.2	17	4.0	3.2	11	4.0	**	4.0	4.0
07/31/76	**	1.9	17	2.0	1.9	11	2.2	**	2.2	2.2
08/07/76	11	3.0	**	3.0	3.0	***	4.0	***	4.0	4.0
08/13/76	11	3.0	11	2.6	3.0	11	3.5	11	3.3	3.8
08/21/76	***	2.6	11	2.6	2.3	11	3.2	**	3.2	2.8
08/29/76	11	3.5	11	3.3	2.9	11	4.6	11	4.7	4.0
09/04/76	11	1.5	11	1.6	1.7	11	1.6	11	1.6	1.9
09/11/76	11	1.7	**	2.8	1.7	11	1.9	*1	1.9	1.9
09/18/76	11	(a)	11	(a)	-	11	(a)	**	(a)	-
09/25/76	11	(b)	11	(b)	-	11	(b)	"	(b)	-
10/03/76	11	7.0	11	7.2	2.3	11	9.0	11	9.5	3.0
10/09/76	11	2.0	**	2.0	2.3	11	2.0	11	2.0	2.3
10/16/76	11	2.6	***	2.8	2.6	11	3.4	11	3.5	3.4
10/23/76	11	(b)	11	(b)	_	tf	(b)	11	. (b)	-
10/30/76	11	(b)	11	(b)	_	**	(b)	11	(b)	_
11/07/76	11	7.5	11	7.5	2.3	11	8.5	11	9.5	2.7
11/13/76	11	1.8	**	2.3	2.1	11	1.8	11	7.0	2.1
11/21/76	11	(b)	**	(b)	-	11	(b)	11	(b)	_
11/27/76	11	4.5	11	4.5	2.3	11	5.1	11	5.2	2.6
12/04/76	11	(a)	11	(a)	_	11	(a)	11	(a)	-
12/11/76	11	3.6	11	6.0	1.7	*1	4.0	11	4.1	1.9
12/18/76	11	2.2	11	2.2	2.2	11	2.3	**	2.5	2.3
12/24/76	11	(a)	11	(a)	_	11	(a)	11	(a)	_
12/31/76	11	(a)	11	(a)	-	**	(a).	***	(a)	-

- (a) No reading due to minometer problems.
- (b) No reading due to weather conditions.

	D-45		PHEASANT 3	TRAIL	PT	D-46		COLLINS RO	AD	CR
Week	Serial		Serial			Serial		Serial		
Ending	Number	mR	Number	mR	mR/Week	Number	mR_	Number	mR_	mR/Week
07/03/76	2474	(a)	2455	(a)	-	0775	(a)	2431	(a)	-
07/10/76	11	(a)	**	(a)	-	11	(a)	11	(a)	-
07/17/76	11	5.1	11	5.2	1.7	11	4.3	11	4.3	1.4
07/24/76	11	1.8	11	1.9	1.8	11	1.8	11	1.9	1.8
07/31/76	11	2.0	11	2.0	2.0	11	1.8	11	1.8	1.8
08/07/76	#1	2.2	***	2.1	2.1	11	2.0	11	2.0	2.0
08/13/76	11	1.5	11	1.5	1.7	11	1.5	11	1.6	1.7
08/21/76	11	2.6	11	2.6	2.3	11	3.0	77	3.0	2.6
08/29/76	tt	2.2	11	2.1	1.8	11	2.6	11	2.4	2.1
09/04/76	11	1.6	11	1.6	1.9	11	1.7	11	1.7	2.0
09/11/76	11	1.9	11	2.0	1.9	††	1.9	11	1.9	1.9
09/18/76	**	(a)	11	(a)	_	11	(a)	**	(a)	-
09/25/76	11	(b)	11	(b)	-	11	(b)	11	(b)	-
10/03/76	11	6.5	11	6.5	2.2	**	5.5	11	5.5	1.8
10/09/76	11	1.9	**	2.0	2.2	11	1.6	11	1.6	1.9
10/16/76	11	2.5	**	2.6	2.5	11	1.6	11	2.4	1.6
10/23/76	**	(b)	. 11	(b)	-	11	(b)	11	(b)	_
10/30/76	11	(b)	11	(b)	-	11	(b)	11	(b)	_
11/07/76	11	7.5	11	8.0	2.3	11	6.0	11	5.8	1.8
11/13/76	H	1.9	11	2.0	2.2	***	1.6	17	1.8	1.8
11/21/76	11	(b)	11	(b)	-	Ħ	(b)	11	(b)	-
11/27/76	11	4.3	11	4.3	2.2	11	3.5	11	3.5	1.8
12/04/76	11	(a)	**	(a)	-	11	(a)	11	(a)	_
12/11/76	11	4.2	**	4.2	2.0	11	5.0	11	5.2	2.3
12/18/76	11	2.1	11	2.2	2.1	11	2.0	11	2.0	2.0
12/24/76	11	(a)	**	(a)	_	11	(a)	**	(a)	-
12/31/76	11	(a)	***	(a)	-	11	(a)	11	(a)	_

- (a) No reading due to minometer problems.(b) No reading due to weather problems.

TABLE 5.1-6

	D-47		PP		
Week	Serial		Serial		
Ending	Number	mR_	Number	mR	mR/Week
07/03/76	2422	(a)	2567	(a)	
07/10/76	11	(a)	11	(a)	_
07/17/76	***	5.1	**	4.5	1.5
07/24/76	11	1.8	11	2.0	1.8
07/31/76	11	1.8	11	1.9	1.8
08/07/76	11	1.7	11	2.0	1.7
08/13/76	Ħ	1.5	11	1.5	1.7
08/21/76	11	1.9	11	1.9	1.7
08/29/76	11	2.2	11	2.3	1.9
09/04/76	FF .	1.7	11	1.7	2.0
09/11/76	**	2.0	11	1.8	1.8
09/18/76	t t	(a)	11	(a)	_
09/25/76	**	(b)	11	(b)	_
10/03/76	H	5.5	11	5.5	1.8
10/09/76	f1	1.6	11	1.8	1.9
10/16/76	11	1.8	11	1.9	1.8
10/23/76	7.5	(b)	11	(b)	_
10/30/76	11	(b)	11	(b)	_
11/07/76	11	6.0	11	5.5	1.7
11/13/76	11	1.5	*1	1.6	1.7
11/21/76	11	(b)	11	(b)	_
11/27/76	11	4.0	11	4.0	2.0
12/04/76	11	(a)	11	(a)	-
12/11/76	11	4.5	11	4.6	2.1
12/18/76	11	1.9	**	2.2	1.9
12/24/76	11	(a)	11	(a)	_
12/31/76	11	(a)	11	(a)	-

⁽a) No reading due to minometer problems.

⁽b) No reading due to weather conditions.

IONIZATION CHAMBER READINGS Background Stations

	D-02 ELWOOD		ELWOOD			D-03			LIET, BRANDON RD.	
Week	Serial		Serial	•		Serial		Serial		
Ending	Number	mR	Number	mR	mR/Week	Number	mR	Number	mR	mR/Week
07/03/76	2467	(a)	2466	(a)	_	2405	(a)	2554	(a)	
07/10/76	11	(a)	11	(a)	-	11	(a)	11	(a)	-
07/17/76	11	4.3	11	4.4	1.4	17	5.2	11	5.3	1.7
07/24/76	11	1.9	17	1.9	1.9	11	1.9	71	2.2	1.9
07/31/76	11	1.7	11	1.8	1.7	11	1.8	**	1.9	1.8
08/07/76	11	1.8	11	2.0	1.8	11	2.3	**	2.3	2.3
08/13/76	11	1.6	11	1.7	1.9	11	2.0	**	2.0	2.3
08/21/76	11	2.1	11	2.2	1.8	11	2.8	11	3.0	2.5
08/29/76	11	2.1	11	2.5	1.8	11	2.7	**	2.4	2.1
09/04/76	11	1.8	**	1.8	2.1	11	2.0	11	2.2	2.3
09/11/76	11	2.5	11	2.5	2.5	11	2.3	11	2.2	2.2
09/18/76	11	(a)	11	(a)	-	11	(a)	**	(a)	_
09/25/76	11	(b)	**	(b)	_	11	(b)	**	(b)	_
10/03/76	11	6.5	11	6.8	2.2	11	6.5	11	6.5	2.2
10/09/76	11	2.0	11	2.0	2.3	11	2.0	11	2.2	2.3
10/16/76	***	2.5	11	2.6	2.5	11	2.5	11	2.3	2.3
10/23/76	11	(b)	11	(b)	-	11	(b)	***	(b)	_
10/30/76	11	(b)	11	(b)	-	11	(b)	11	(b)	-
11/07/76	11	6.0	**	5.5	1.7	11	7.5	11	7.0	2.2
11/13/76	ti	2.0	11	2.3	2.3	11	2.2	11	2.3	2.5
11/21/76	11	(b)	. 11	(b)	-	***	(b)	11	(b)	_
11/27/76	**	4.0	11	4.0	2.0	11	4.5	**	4.5	2.3
12/04/76	11	(a)	*1	(a)	_	11	(a)	11	(a)	-
12/11/76	**	4.0	**	4.0	1.9	11	4.2	11	4.5	2.0
12/18/76	tt	1.9	*1	2.0	1.9	**	2.2	11	2.2	2.2
12/24/76	11	(a)	11	(a)	_	11	(a)	11	(a)	_
12/31/76	H	(a)	*1	(a)	-	11	(a)	11	(a)	-

⁽a) No reading due to minometer problems.(b) No reading due to weather conditions.



	D-04		WILMINGTO	N	464	D-06		MORRIS		J16
Week	Serial		Serial			Serial		Serial		
Ending	Number	<u>mR</u>	Number	mR	mR/Week	Number	mR	Number	mR	mR/Week
07/03/76	2537	(a)	2642	(a)	_	2411	(a)	2457	(a)	-
07/10/76	**	(a)	11	(a)	_	11	(a)	11	(a)	-
07/17/76	11	4.5	11	4.5	1.5	11	4.3	11	4.5	1.4
07/24/76	**	1.5	11	4.0	1.5	11	1.8	71	1.8	1.8
07/31/76	**	1.5	11	1.6	1.5	11	1.6	11	1.8	1.6
08/07/76	11	1.5	11	1.6	1.5	. 11	2.2	11	2.0	2.0
08/13/76	11	1.5	11	1.4	1.6	11	1.6	11	1.5	1.7
08/21/76	11	2.6	11	2.7	2.3	11	2.0	11	2.2	1.8
08/29/76	11	1.8	11	1.8	1.6	11	F.S.	11	F.S.	F.S.(b)
09/04/76	11	1.5	11	1.5	1.7	11	1.5	11	1.6	1.7
09/11/76	**	1.7	Ħ	1.8	1.7	11	2.0	11	1.8	1.8
09/18/76	11	(a)	11	(a)	_	11	(a)	11	(a)	_
09/25/76	11	(c)	11	(c)	_	11	(c)	11	(c)	_
10/03/76	11	5.3	11	5.5	1.8	11	5.0	11	5.5	1.7
10/09/76	tt	1.5	11	1.5	1.8	11	1.5	11	1.5	1.8
10/16/76	11	2.0	11	2.0	2.0	*1	1.6	11	1.8	1.6
10/23/76	11	(c)	11	(c)	_	11	(c)	11	(c)	-
10/30/76	11	(c)	11	(c)	-	11	(c)	77	(c)	-
11/07/76	11	7.0	tr	7.0	2.2	11	4.4	11	4.9	1.4
11/13/76	11	1.7	11	1.7	1.9	**	1.4	11	1.4	1.6
11/21/76	H	(c)	11	(c)	-	11	(c)	TT .	(c)	
11/27/76	11	3.5	11	3.5	1.8	*1	3.4	11	3.3	1.7
12/04/76	ti	(a)	11	(a)	_	11	(a)	11	(a)	_
12/11/76	11	3.6	11	3.6	1.7	11	ŝ.ó	11	5.0	2.3
12/18/76	11	1.8	11	1.8	1.8	11	1.9	11	2.0	1.9
12/24/76	11	(a)	11	(a)	_	11	(a)	11	(a)	-
12/31/76	***	(a)	11	(a)	_	11	(a)	11	(a)	-

⁽a) No reading due to minometer problems.

⁽b) FS = Full Scale. Apparently anomalous reading.

⁽c) No reading due to weather conditions.

IONIZATION CHAMBER READINGS Background Stations

•	D-07		LISBON		J24	D-08		COAL CITY		J68
Week	Serial		Serial			Serial		Seria1		
Ending	Number	mR	Number	mR	mR/Week	Number	mR	Number	mR	mR/Week
07/03/76	2694	(a)	0274	(a)	_	2582	(a)	0973	(a)	-
07/10/76	11	(a)	11	(a)	-	11	(a)	**	(a)	-
07/17/76	11	4.3	11	4.2	1.4	11	4.8	**	4.8	1.6
07/24/76	11	1.4	11	1.5	1.4	17	1.8	**	1.9	1.8
07/31/76	11	1.5	17	1.8	1.5	11	1.5	**	1.4	1.4
08/07/76	11	1.8	11	1.7	1.7	11	1.7	11	1.5	1.5
08/13/76	11	1.4	11	1.4	1.6	17	1.3	*11	1.3	1.5
08/21/76	11	2.0	11	2.5	1.8	11	2.0	**	2.0	1.8
08/29/76	11	2.0	11	2.0	1.8	11	2.0	***	1.9	1.7
09/04/76	11	2.0	11	2.2	2.3	Ħ	1.5	11	1.7	1.7
09/11/76	11	1.8	**	1.8	1.8	11	1.5	**	1.8	1.5
09/18/76	11	(a)	11	(a)	_	11	(a)	**	(a)	-
09/25/76	11	(b)	11	(b)	_	11	(b)	11	(b)	_
10/03/76	11	5.5	11	5.5	1.8	11	4.6	11	5.0	1.5
10/09/76	11	1.5	11	1.5	1.8	11	1.5	11	1.5	1.8
10/16/76	11	1.8	11	1.8	1.8	11	1.6	*1	1.6	1.6
10/23/76	11	(Ъ)	11	(b)	_	11	(b)	11	(b)	_
10/30/76	Ħ	(b)	11	(b)	_	II	(b)	11	(b)	_
11/07/76	**	5.2	**	5.2	1.6	11	5.5	**	5.0	1.5
11/13/76	11	1.2	11	1.3	1.5	**	1.8	11	1.7	1.9
11/21/76	11	(b)	11	(b)	_	11	(b)	11	(b)	_
11/27/76	11	4.0	11	3.7	1.9	. 11	3.5	11	3.5	1.8
12/04/76	11	(a)	11	(a)	_	11	(a)	11	(a)	-
12/11/76	11	4.2	11	4.3	2.0	**	4.2	11	4.5	2.0
12/18/76	**	1.8	11	1.9	1.8	**	1.7	11	1.8	1.7
12/24/76	11	(a)	11	(a)	-	f1	(a)	11	(a)	-
12/31/76	11	(a)	11	(a)	-	11	(a)	11	(a)	-

⁽a) No reading due to minometer problems.(b) No reading due to weather conditions.

TABLE_5.1-10 IONIZATION CHAMBER READINGS

Background Stations

	D-11	,	CHANNAHON		СН	D-14		MINOOKA		J27
Week Ending	Serial [.] Number	mR	Serial Number	mR	mR/Week	Serial Number	mR	Serial Number	mR	mR/Week
07/03/76	0775	(a)	2543	(a)	-	2610	(a)	2397	(a)	_
27/10/76	**	7-5	11	(-)		11	(0)	11	(2)	_

WCCIC	OCLIAI		DCLLGI			1702 244		O C L L C L		
Ending	Number	mR	Number	mR	mR/Week	Number	mR	Number	mR	mR/Week
07/03/76	0775	(a)	2543	(a)	-	2610	(a)	2397	(a)	-
07/10/76	71	(a)	11	(a)	-	11	(a)	**	(a)	_
07/17/76	**	4.5	**	4.5	1.5	11	4.7	***	4.5	1.5
07/24/76	11	1.8	**	1.9	1.8	††	1.8	**	1.8	1.8
07/31/76	**	1.8	**	1.8	1.8	T I	1.5	**	1.8	1.5
08/07/76	11	1.8	11	2.1	1.8	11	2.5	11	2.6	2.5
08/13/76	11	2.0	11	2.0	2.3	11	1.5	11	1.6	1.7
08/21/76	11	2.2	11	1.7	1.5	11	2.0	11	2.5	1.8
08/29/76	11	2.0	11	2.0	1.8	11	2.0	11	2.0	1.8
09/04/76	11	1.4	11	1.4	1.6	11	1.5	11	2.5	1.7
09/11/76	11	1.8	11	1.8	1.8	11	1.7	11	1.8	1.7
09/18/76	11	(a)	11	(a)	_	11	(a)	11	(a)	-
09/25/76	11	(b)	11	(b)	-	11	(b)	11	(b)	-
10/03/76	**	5.6	11	6.0	1.9	11	5.5	11	6.0	1.8
10/09/76	11	1.5	11	1.3	1.5	11	1.6	**	1.6	1.9
10/16/76	11	1.8	11	2.1	1.8	11	1.8	**	2.0	1.8
10/23/76	11	(b)	11	(b)	-	11	(b)	11	(b)	-
10/30/76	11	(b)	11	(b)	_	17	(b)	11	(b)	-
11/07/76	11	6.0	11	6.0	1.9	**	5.5	11	5.5	1.7
11/13/76	11	1.8	11	4.0	2.1	11	1.5	**	1.6	1.7
11/21/76	11	(b)	11	(b)	-	t1	(b)	*1	(b)	_
11/27/76	**	4.3	11	4.3	2.2	11	4.0	11	4.0	2.0
12/04/76	11	(a)	11	(a)	-	11	(a)	11	(a)	-
12/11/76	11	4.2	11	4.5	2.0	l†	4.2	11	4.3	2.0
12/18/76	11	2.0	11	2.1	2.0	**	1.9	11	2.0	1.9
12/24/76	11	(a)	**	(a)	-	11	(a)	11	(a)	_
12/31/76	77	(a)	11	(a)	-	11	(a)	***	(a)	-

⁽a) No reading due to minometer problems.(b) No reading due to weather conditions.

TABLE 5.1-11

IONIZATION CHAMBER READINGS Background Station

	D-44	G00	SE LAKE VI	LLAGE	GLV
Week	Serial		Serial		
Ending	Number	mR	Number	_mR_	mR/Week
07/03/76	2525	(a)	2724	(a)	
07/10/76	11	(a)	**	(a)	
07/17/76	**	4.8	**	5.0	1.6
07/24/76	*1	1.6	11	1.6	1.6
07/31/76	**	1.8	**	1.9	1.8
08/07/76	**	1.9	11	1.9	1.9
08/13/76	**	1.5	**	1.5	1.7
08/21/76	**	2.0	*1	2.0	1.8
08/29/76	11	F.S.	*11	F.S.	F.S.(b)
09/04/76	11	1.5	**	1.5	1.7
09/11/76	11	1.6	11	1.6	1.6
09/18/76	11	(a)	**	(a)	_
09/25/76	11	(c)	**	(c)	-
10/03/76	**	5.0	**	5.0	1.7
10/09/76	**	1.5	11	1.5	1.8
10/16/76	11	1.6	11	1.6	1.6
10/23/76	**	(c)	#1	(c)	-
10/30/76	11	(c)	11	(c)	_
11/07/76	11	5.0	11	5.0	1.5
11/13/76	11	1.4	11	1.4	1.6
11/21/76	T1	(c)	11	(c)	_
11/27/76	11	4.0	11	4.0	2.0
12/04/76	11	(a)	11	(a)	_
12/11/76	TŤ	Š.Ó	11	4.8	2.2
12/18/76	11	1.9	11	2.2	1.9
12/24/76	11	(a)	11	(a)	_
12/31/76	11	(a)	11	(a)	_

⁽a) No reading due to minometer problems.

FS = Full Scale. Apparently anomalous reading No reading due to weather conditions.

TA 5.2-1

AIRBORNE IODINE-131* AND GROSS ALPHA AND BETA IN AIR PARTICULATES Indicator Stations

	D-09	BENNIT	в ВЕ	D-15	CLAY PROD	UCTS J21
Week	Volume	Gross a	Gross β	Volume	Gross a	Gross β
Ending	(m ³)	$(10^{-3} \text{ pCi/m}^3)$	$(10^{-2} \text{ pCi/m}^3)$	<u>(m³)</u>	$(10^{-3} \text{ pCi/m}^3)$	$(10^{-2} \text{ pCi/m}^3)$
07/03/76	295	< 1	3 ± 1	29 5	< 1	3 ± 1
07/10/76	285	-	4 ± 1	285	-	3 ± 1
07/17/76	285	_	5 ± 1	280	- ·	3 ± 1
07/24/76	285	-	5 ± 1	285	-	4 ± 1
07/31/76	280	-	4 ± 1	180	-	4 ± 1
08/07/76	290	< 5	4 ± 1	(a)	-	_
08/13/76	240	-	4 ± 1	95	_	< 12(b)
08/21/76	330	-	7 ± 1	330	-	5 ± 1
08/29/76	330	-	6 ± 1	325	-	5 ± 1
09/04/76	245	< 5	3 ± 1	245	< 5	4 ± 1
09/11/76	285	-	4 ± 1	285	-	4 ± 1
09/18/76	280	-	4 ± 1	280	-	3 ± 1
09/25/76	290	_	4 ± 1	290	-	5 ± 1
10/03/76	325	2 ± 1	7 ± 1	325	4 ± 2	5 ± 1
10/09/76	245	-	3 ± 2	245	-	3 ± 1
10/16/76	285		25 ± 3(c)	285	-	16 ± 2(c)
10/23/76	290	-	8 ± 2	290	-	7 ± 1
10/30/76	285	-	26 ± 4(c)	285	-	$25 \pm 4(c)$
11/07/76	300	< 5	$13 \pm 1(c)$	330	< 5	14 ± 1(c)
11/13/76	235	_	$19 \pm 3(c)$	235	•	$24 \pm 3(c)$
11/21/76	335	_	$16 \pm 3(c)$	335	-	$14 \pm 2(c)$
11/27/76	240	_	$12 \pm 2(c)$	240	-	7 ± 1
12/04/76	285	< 5	$12 \pm 2(c)$	285	< 5	$15 \pm 2(c)$
12/11/76	285	-	16 ± 2(c)	285	-	18 ± 3(c)
12/18/76	285	-	$11 \pm 2(c)$	285	-	$11 \pm 2(c)$
12/24/76	245	_	8 ± 2	245	-	7 ± 2
12/31/76	290	-	$10 \pm 2(c)$	290	- .	12 ± 2(c)

*Iodine-131 is sampled alternate weeks. Activity is <.03 pCi/m³ unless otherwise specified.

Data reported as "<" are at the 99% confidence level. All other data are at the 95% confidence level, all based on counting errors.

- (a) Lost in transit.
- (b) Low sensitivity due to sample size.
- (c) Unusual reading; refer to Section 5.0.

AIRBORNE IODINE-131* AND GROSS ALPHA AND BETA IN AIR PARTICULATES
Indicator Stations

TABLE 5.2-2

		ON-SITE	· ·	ON-SITE			
	D-16	STATION #1 A	D-17	STATION #2 B	D-18	ON-SITE STATIO	N #3 C
Week	Volume	Gross β	Volume	Gross β	Volume	Gross a	Gross β
Ending	(m ³)	$(10^{-2} \text{ pCi/m}^3)$	<u>(m³)</u>	$(10^{-2} \text{ pCi/m}^3)$	(m^3)	$(10^{-3} \text{ pCi/m}^3)$	$(10^{-2} \text{ pCi/m}^3)$
07/03/76	285	2 ± 1	285	2 ± 1	285	2 ± 1	4 ± 1
07/10/76	285	4 ± 1	290	5 ± 1	290	-	6 ± 1
07/17/76	280	6 ± 1	280	6 ± 1	280	-	5 ± 1
07/24/76	285	5 ± 1	🎅 285	8 ± 1	285	_	6 ± 1
07/31/76	280	4 ± 1	285 285	4 ± 1	285	_	5 ± 1
08/07/76	(a)	(a)	290	3 ± 1	290	< 5	8 ± 1
08/13/76	240	4 ± 1	290 240 330	6 ± 1	240	- .	5 ± 1
08/21/76	230	6 ± 1	330	6 ± 1	330	-	7 ± 1
08/29/76	325	7 ± 1	325	6 ± 1	325	_	7 ± 1
09/04/76	245	4 ± 1	250	4 ± 1	250	< 5	4 ± 1
09/11/76	265	5 ± 1	280	5 ± 1	280	-	5 ± 1
09/18/76	280	4 ± 1	280	4 ± 1	280	-	4 ± 1
09/25/76	290	5 ± 1	290	5 ± 1	290	-	5 ± 1
10/03-76	325	6 ± 1	320	6 ± 1	325	8 ± 3	6 ± 1
10/09/76	240	4 ± 1	245	1 ± 1	245	- .	4 ± 1
10/16/76	285	$18 \pm 2(b)$	285	51 ± 5(b)	285	-	$10 \pm 1(b)$
10/23/76	290	$14 \pm 3(b)$	290	$14 \pm 3(b)$	290	_	7 ± 1
10/30/76	285	$35 \pm 5(b)$	[*] 285	$31 \pm 5(b)$	285	-	$23 \pm 3(b)$
11/07/76	330	25 ± 1(b)	335	$16 \pm 1(b)$	335	< 5	$15 \pm 1(b)$
11/13/76	240	20 ± 3(b) .	240	$28 \pm 3(b)$	240	_ `	$16 \pm 3(b)$
11/21/76	335	16 ± 3(b)	330	$15 \pm 2(b)$	330	_	$14 \pm 2(b)$
11/27/76	240	17 ± 2(b)	240	15 ± 2(b)	240	_	$13 \pm 2 (b)$
12/04/76	275	15 ± 2(b)	285	$15 \pm 2(b)$	285	< 5	$10 \pm 2 (b)$
12/11/76	275	$18 \pm 3(b)$	280	$19 \pm 3(b)$	285		19 ± 3 (b)
12/18/76	285	$12 \pm 2(b)$	285	$14 \pm 2(b)$	285	- .	$10 \pm 2 (b)$
12/24/76	245	$12 \pm 3(b)$	245	$12 \pm 3(b)$	245	_	9 ± 2
12/31/76	290	$12 \pm 2(b)$	290	$12 \pm 2(b)$	290	-	9 ± 2

*Iodine-131 is sampled alternate weeks. Activity is <.03 pCi/ m^3 unless otherwise specified. Data reported as "<" are at the 99% confidence level. All other data are at the 95% confidence level, all based on counting errors.

⁽a) Lost in transit. (b) Unusual reading; refer to Section 5.0.

TA 5.2-3

AIRBORNE IODINE-131* AND GROSS ALPHA AND BETA IN AIR PARTICULATES Indicator Stations

		D-45	PHEASANT T	RAIL PT	D-46	COLLINS	ROAD CR	D-47 P	RAIRIE PARK PP
	Week	Volume	Gross a	Gross β	Volume	Gross a	Gross β	Volume	Gross β
	Ending	(m ³)	$(10^{-3} \text{ pCi/m}^3)$	$(10^{-2} \text{ pCi/m}^3)$	(m ³)	$(10^{-3} \text{ pCi/m}^3)$	$(10^{-2} \text{ pCi/m}^3)$	(m^3)	$(10^{-2} \text{ pCi/m}^3)$
	07/03/76	285	< 1	4 ± 1	285	2 ± 1	2 ± 1	295	2 ± 1
	07/10/76	290	-	3 ± 1	285	-	4 ± 1	275	4 ± 1
	07/17/76	280	_	4 ± 1	280	-	3 ± 1	280	3 ± 1
	07/24/76	285	-	6 ± 1	285		4 ± 1	285	5 ± 1
	07/31/76	285	_	5 ± 1	285	-	4 ± 1	285	4 ± 1
	08/07/76	295	< 5	5 ± 1	290	< 5	4 ± 1	275	5 ± 1
	08/13/76	235	-	5 ± 1	240	-	4 ± 1	240	5 ± 1
	08/21/76	330	_	5 ± 1	330	-	7 ± 1	330	6 ± 1
	08/29/76	325	-	5 ± 1	325	-	6 ± 1	320	5 ± 1
	09/04/76	250	< 5	4 ± 1	245	< 5	4 ± 1	245	3 ± 1
	09/11/76	280	_	5 ± 1	285	-	4 ± 1	285	4 ± 1
	09/18/76	245	-	5 ± 1	280	-	4 ± 1	280	4 ± 1
	09/25/76	290	-	4 ± 1	290	-	4 ± 1	290	5 ± 1
57	10/03/76	325	3 ± 1	6 ± 1	325	2 ± 1	6 ± 1	325	6 ± 1
_	10/09/76	245	-	4 ± 1	245	-	2 ± 1	245	3 ± 1
	10/16/76	285	-	15 ± 2+	285	-	12 ± 2+	285	14 ± 1 ⁺
	10/23/76	290	-	14 ± 2+	290	-	10 ± 2 ⁺	290	8 ± 2
	10/30/76	280	-	26 ± 4 ⁺	285	-	38 ± 6 ⁺	280	39 ± 6 ⁺
	11/07/76	335	< 5	21 ± 1 ⁺	330	< 5	11 ± 1 ⁺	330	16 ± 1 ⁺
	11/13/76	240	-	24 ± 3 ⁺	240	-	21 ± 3 ⁺	235	22 ± 3 ⁺
	11/21/76	330	-	17 ± 3 ⁺	335	-	16 ± 3	335	20 ± 2 ⁺
	11/27/76	240	-	11 ± 2 ⁺	240	-	$13 \pm 2^{+}$	240	10 ± 2 ⁺
	12/04/76	290	< 5	15 ± 2 ⁺	285	< 5	9 ± 2,	285	$14 \pm 2^{+}$
	12/11/76	280**	-	16 ± 2 ⁺	280**	-	$13 \pm 2^{+}$	280**	17 ± 3 ⁺
	12/18/76	285	-	$12 \pm 2^{+}$	285	-	8 ± 2	285	$10 \pm 2^{+}$
	12/24/76	245	-	8 ± 2.	245	-	8 ± 2	245	8 ± 2 ₁
	12/31/76	290	-	10 ± 2 ⁺	290	-	9 ± 2	290	$10 \pm 2^{+}$

*Iodine-131 is sampled alternate weeks. Activity is <.03 pCi/m³ unless otherwise specified. Data reported as "<" are at the 99% confidence level. All other data are at the 95% confidence level, all based on counting errors. **Estimated volume. +Unusual reading; refer to Section 5.0.

AIRBORNE IODINE-131* AND GROSS ALPHA AND BETA IN AIR PARTICULATES
Background Stations

TABLE 5.2-4

	D-02	ELWOOD J15	D-03	JOLIET, BRANDO	N ROAD J48	D-04 W	ILMINGTON 464
Week	Volume	Gross β	Volume	Gross a	Gross β	Volume	Gross β
Ending	(m ³)	$(10^{-2} \text{ pCi/m}^3)$	(m ³)	$(10^{-3} \text{ pCi/m}^3)$	$(10^{-2} \text{ pCi/m}^3)$	(m^3)	$(10^{-2} \text{ pCi/m}^3)$
07/03/76	290	2 ± 1	290	2 ± 1	2 ± 1	290	3 ± 1
07/10/76	285	4 ± 1	280		4 ± 1	280	5 ± 1
07/17/76	280	4 ± 1	280	~	3 ± 1	270	3 ± 1
07/24/76	285	5 ± 1	285	-	4 ± 1	285	4 ± 1
07/31/76	285	5 ± 1	285	-	4 ± 1	285	4 ± 1
08/07/76	295	5 ± 1	295	< 5	4 ± 1	295	5 ± 1
08/13/76	235	6 ± 1	235	~	5 ± 1	235	5 ± 1
08/21/76	330	4 ± 1	330	~	5 ± 1	330	5 ± 1
08/29/76	325	6 ± 1	325	~	5 ± 1	325	6 ± 1
09/04/76	250	4 ± 1	250	< 5	4 ± 1	250	3 ± 1
09/11/76	280	4 ± 1	280	~	4 ± 1	280	4 ± 1
09/18/76	280	4 ± 1	35	-	< 4**	280	4 ± 1
09/25/76	290	4 ± 1	290	-	4 ± 1	290	4 ± 1
10/03/76	325	6 ± 1	325	4 ± 2	6 ± 1	325	6 ± 1
10/09/76	245	3 ± 1	245	~	3 ± 1	245	$3 \pm 1_{+}$
10/16/76	285	18 ± 1 ⁺	280	~	16 ± 1 ⁺	280	17 ± 1
10/23/76	290	19 ± 4 ⁺	290	~	13 ± 3 ⁺	290	7 ± 1
10/30/76	285	$23 \pm 3^{+}$	285	~	27 ± 4 ⁺	285	33 ± 5 ⁺
11/07/76	335	$16 \pm 1^{+}$	335	< 5	$14 \pm 1^{+}$	335	15 ± 1 ⁺
11/13/76	240	19 ± 3 ⁺	240	~	20 ± 3	240	$18 \pm 3^{+}_{\perp}$
11/21/76	330	$14 \pm 2^{+}$	330	~	18 ± 3 ⁺	330	16 ± 3 [™]
11/27/76	245	14 ± 2+	230	-	$13 \pm 2^{+}$	240	15 ± 2 ⁺
12/04/76	285	$13 \pm 2 +$	285	< 5	13 ± 2 ⁺	285	11 ± 2 ⁺
12/11/76	285	14 ± 2+	280	~	16 ± 2 ⁺	280	17 ± 3 ±
12/18/76	285	11 ± 2+	285	~	11 ± 2 ⁺	285	14 ± 2^{T}
12/24/76	245	10 ± 2+	245	~-	9 ± 2	245	9 ± 2
12/31/76	290	14 ± 2+	290	-	$10 \pm 2+$	290	9 ± 2

^{*}Iodine-131 is sampled alternate weeks. Activity is <.03 pCi/m³ unless otherwise specified. Data reported as "<" are at the 99% confidence level. All other data are at the 95% confidence level, all based on counting errors. **Low sensitivity due to small sample size. +Unusual reading; refer to Section 5.0.

TA 5.2-5

AIRBORNE IODINE-131* AND GROSS ALPHA AND BETA IN AIR PARTICULATES Background Stations

		D-06	MORRIS	J16	D-07	LISBON J24	D-08	COAL CITY	
	Week	Volume	Gross α	Gross β	Volume	Gross β	Volume	Gross a	Gross β
	Ending	(m^3)	$(10^{-3} \text{ pCi/m}^3)$	$(10^{-2} \text{ pCi/m}^3)$	(m^3)	$(10^{-2} \text{ pCi/m}^3)$	(m^3)	$(10^{-3} \text{ pCi/m}^3)$	$(10^{-2} \text{ pCi/m}^3)$
	07/03/76	295	3 ± 1	3 ± 1	295	4 ± 1	295	2 ± 1	3 ± 1
	07/10/76	280	_	4 ± 1	280	4 ± 1	280	-	3 ± 1
	07/17/76	280	-	4 ± 1	285	3 ± 1	280	-	4 ± 1
	07/24/76	285	-	3 ± 1	285	4 ± 1	285	_	3 ± 1
	07/31/76	285	-	4 ± 1	280	4 ± 1	280	-	3 ± 1
	08/07/76	290	< 5	5 ± 1	290	4 ± 1	285	< 5	4 ± 1
	08/13/76	240	-	5 ± 1	240	4 ± 1	240	-	5 ± 1
	08/21/76	330	-	6 ± 1	330	5 ± 1	330	_	4 ± 1
	08/29/76	330	_	5 ± 1	330	5 ± 1	325	-	5 ± 1
	09/04/76	245	< 5	3 ± 1	245	3 ± 1	245	< 5	4 ± 1
	09/11/76	285	-	4 ± 1	285	4 ± 1	285	-	4 ± 1
	09/18/76	280	-	3 ± 1	280	4 ± 1	280	-	4 ± 1
	09/25/76	290	-	5 ± 1	290	4 ± 1	290	-	4 ± 1
л О	10/03/76	325	< 1	6 ± 1	325	6 ± 1	325	2 ± 1	5 ± 1
	10/09/76	245	-	3 ± 1	245	3 ± 1	245	-	3 ± 1
	10/16/76	285	-	19 ± 1 ⁺	285	$20 \pm 2^{+}$	285	-	$13 \pm 1^{+}$
	10/23/76	290	-	11 ± 2 ⁺	290	6 ± 1	290	-	8 ± 2
	10/30/76	285	-	26 ± 4 ⁺	285	40 ± 6 ⁺	285	-	$23 \pm 3^{+}$
	11/07/76	330	< 5	$12 \pm 1^{+}$	330	$13 \pm 1^{+}$	330	< 5	16 ± 1 ⁺
	11/13/76	235	-	15 ± 3 ⁺	235	$14 \pm 3^{+}$	235	-	$22 \pm 3^{+}$
	11/21/76	335	-	15 ± 2 ⁺	335	$11 \pm 2^{+}$	335	-	$14 \pm 2^{+}$
	11/27/76	240	-	$12 \pm 2^{+}$	240	12 ± 2 +	240	-	$12 \pm 2^{+}$
	12/04/76	285	< 5	12 ± 2+	285	9 ± 2	285	< 5	$12 \pm 2^{+}$
	12/11/76	280	-	15 ± 2 ⁺	250	$15 \pm 2 +$	285	-	$14 \pm 2^{+}$
	12/18/76	285	-	10 ± 2 ⁺	285	9 ± 2	285	-	11 ± 2 ⁺
	12/24/76	245	-	9 ± 2	245	$10 \pm 2 +$	245	-	$10 \pm 2^{+}$
	12/31/76	290	-	$10 \pm 2^{+}$	290	3 ± 1	290	-	7 ± 2

^{*}Iodine-131 is sampled alternate weeks. Activity is <.03 pCi/m³ unless otherwise specified. Data reported as "<" are at the 99% confidence level. All other data are at the 95% confidence level, all based on counting errors. +Unusual reading; refer to Section 5.0.

AIRBORNE IODINE-131* AND GROSS ALPHA AND BETA IN AIR PARTICULATES Background Stations

	D-11	CHANNAHON CH	D-14	MINOOKA	. J27	D-44	GOOSE LAKE	VILLAGE GLV
Week	Volume	Gross β	Volume	Gross a	Gross β	Volume	Gross α	Gross β
Ending	(m^3)	$(10^{-2} \text{ pCi/m}^3)$	(m^3)	$(10^{-3} \text{ pCi/m}^3)$	$(10^{-2} \text{ pCi/m}^3)$	(m ³)	(10^{-3} pCi/m)	$(10^{-2} \text{ pCi/m}^3)$
07/03/76	295	2 ± 1	260	2 ± 1	3 ± 1	260	< 1	3 ± 1
07/10/76	285	4 ± 1	280	-	5 ± 1	260	_	4 ± 1
07/17/76	285	4 ± 1	285	-	3 ± 1	245	_	4 ± 1
07/24/76	285	4 ± 1	285	-	4 ± 1	275	-	5 ± 1
07/31/76	280	3 ± 1	280	-	3 ± 1	265	-	3 ± 1
08/07/76	290	3 ± 1	290	< 5	4 ± 1	285	< 5	5 ± 1
08/13/76	245	4 ± 1	240	-	6 ± 1	235	_	4 ± 1
08/21/76	330	6 ± 1	330	-	5 ± 1	330	-	6 ± 1
08/29/76	330	7 ± 1	330	-	6 ± 1	325	-	8 ± 1
09/04/76	245	4 ± 1	245	< 5	3 ± 1	245	< 5	5 ± 1
09/11/76	285	5 ± 1	285	_	4 ± 1	285	-	5 ± 1
09/18/76	280	5 ± 1	280	-	5 ± 1	280	-	5 ± 1
09/25/76	30	6 ± 6	290	-	5 ± 1	290	-	2 ± 1
10/03/76	**		325	2 ± 1	6 ± 1	330	2 ± 1	6 ± 1
10/09/76	245	4 ± 1,	245	-	4 ± 1	245	-	3 ± 1
10/16/76	285	$24 \pm 3^{+}$	285	-	16 ± 2+	285	-	22 ± 2+
10/23/76	290	7 ± 1,	290	-	26 ± 5+	290	-	17 ± 3 ⁺
10/30/76	285	$20 \pm 3^{+}$	285	-	25 ± 4 ⁺	285	-	28 ± 4 ⁺
11/07/76	330	$13 \pm 1^{+}$	330	3 ± 2	$18 \pm 1^{+}$	330	< 5	16 ± 1 ⁺
11/13/76	235	$18 \pm 3^{+}$	235	-	$27 \pm 3^{+}$	235	-	27 ± 3 ⁺
11/21/76	330	$16 \pm 3^{+}$	335	-	$13 \pm 2^{+}$	335	-	13 ± 2 ⁺
11/27/76	240	$13 \pm 2^{+}$	240	_	12 ± 2 ⁺	240	_	$11 \pm 2^{+}$
12/04/76	285	$\frac{13 \pm 2^{+}}{1}$	285	< 5	10 ± 2 ⁺	285	< 5	12 ± 2 ⁺
12/11/76	285	16 ± 2 ⁺	285	_	19 ± 3+	280***		18 ± 3 ⁺
12/18/76	285	$13 \pm 2^{+}$	285	_	12 ± 2+	285	_	$10 \pm 2^{+}$
12/24/76	245	9 ± 2	245	-	10 ± 2+	245	-	8 ± 2
12/31/76	290	9 ± 2	290	-	9 ± 2	290	-	9 ± 2

6

^{*}Iodine-131 is sampled alternate weeks. Activity is <.03 pCi/m³ unless otherwise specified. Data reported as "<" are at the 99% confidence level. All other data are at the 95% confidence level, all based on counting errors.

Sample not collected due to faulty pump. *Estimated volume. **Unusual reading; refer to Section 5.0.

TABLE 5.2-7

GAMMA ISOTOPIC (GeLi) ANALYSIS OF MONTHLY COMPOSITE AIR PARTICULATE FILTERS

(Stations D-02 to D-18, D-44 to D-47)

		pCi/m ³
Month	Be-7	Other Gamma Emitters*
July	0.13 ± 0.01	< .01
August	0.15 ± 0.01	< .01
September	0.08 ± 0.01	< .01
October	0.06 ± 0.01	< .01**
November	0.04 ± 0.01	< .01
December	0.07 ± 0.01	< .01⁺

⁺Ru-103, Ru-106, Ce-141 detected at < 0.1 pCi/m³ but not further quantified.

^{**}Ce-141 detected but not quantified.

*The spectrum is computer scanned from ~20 to ~2000 KeV. Specifically included are Ce-144, Ba-La-140, Cs-134, Cs-137, Zr-Nb-95, Co-58, Co-60, Mn-54, Zn-65. Naturally occurring gamma emitters such as K-40 and Ra daughters are frequently detected but not listed here. Data listed as "<" are at the 3σ level, others are 2σ . Listed concentration is for Cs-137 and may be slightly more or less sensitive for other nuclides.

TABLE 5.2-8

COMPOSITE OF ALL DNPS AP FILTERS COLLECTED 10/16/76

- (1) Gamma Emitters* identified by computer pCi/m³: < 3 E-04
- (2) Gamma emitters identified visually and confirmed by the presence of two or more characteristic energies (fission and/or activation products only).

Ce-141	Cs-137 (662 KeV only)
Sb-125	Rh-102
Pm-151	Rh-102m
I-131	Ag-110m
Ba-140	Sb-124
La-140	Eu-154
Bi-207	Mn-54

(3) Gamma emitters identified visually with less confidence (i.e., no confirming energies or no reasonable explanation of presence).

Ir-192	I-134	I-133	Ir-192
Cs-134	I-135	Bi-207	Eu-152

COMPOSITE OF ALL DNPS AP FILTERS COLLECTED 10/03/76

- (1) Gamma emitters* identified by computer: Nuclide $\frac{\text{Nuclide}}{\text{Sb-125}}$ Not quantified(<1E-02) Others < 3.4 (E-04)
- (2) Gamma emitters identified visually and confirmed by the presence of two or more characteristic energies (fission and/or activation products only).

Ba-La-140, Sb-125, Eu-152(?), Co-60

(3) Gamma emitters identified visually with less confidence (i.e., no confirming energies or no reasonable explanation of presence).

None

*The spectrum is computer scanned from ~20 to ~2000 KeV. Specifically included are Ce-144, Ba-La-140, Cs-134, Cs-137, Zr-Nb-95, Co-58, Co-60, Mn-54, Zn-65. Naturally occurring gamma emitters such as K-40 and Ra daughters are frequently detected but not listed here. Data listed as "<" are at the 3σ level, others are 2σ . Listed concentration is for Cs-137 and may be slightly more or less sensitive for other nuclides.



GROSS ALPHA, GROSS BETA AND IODINE-131* IN SURFACE WATER SAMPLES

	Background		Indicator		Indicator		Indicator S	
		INLET		CHARGE ANAL 1D		SCHARGE CANAL 2/3D	D-21 EJ ai	VER AT
Collection	Gross α	CANAL 1D Gross β	$\frac{D-20-1}{Gross} \alpha$	Gross β	Gross a	Gross β	Gross a	Gross β
Date	(pCi/1)	(pC1/1)	(pCi/1)	(pCi/1)	(pCi/1)	(pCi/1)	(pCi/1)	(pCi/1)
07/03/76	$\frac{(pc1/1)}{1 \pm 1}$	$\frac{(\beta(1/1))}{9 \pm 2}$	<u>⟨pc1/1)</u> <1	$\frac{(601/1)}{6 \pm 2}$	$\frac{(pc1/1)}{1 \pm 1}$	$\frac{(\beta C1/1)}{6 \pm 2}$	$\frac{(pc1/1)}{2 \pm 1}$	$\frac{(pc1/1)}{10 \pm 3}$
07/10/76	<1	6 ± 3	<1 <1	6 ± 2	<1	4 ± 2	3 ± 2	24 ± 4
07/17/76	<0.5	0 ± 3 4 ± 3	<0.5	4 ± 2	<0.5	7 ± 3	<0.5	13 ± 3
07/24/76	<1 <1	4 ± 3 6 ± 3	<1 <1	4 ± 2	<0.5	5 ± 2	2 ± 1	10 ± 3
07/31/76	2 ± 1	13 ± 4	3 ± 2	8 ± 3	1 ± 1	12 ± 4	<1	10 ± 3
08/07/76	<1 ×1	16 ± 4	<1 ×1	16 ± 3	<1	14 ± 4	<1 <1	7 ± 4
08/13/76	1 ± 1	9 ± 3	1 ± 1	6 ± 2	<1	7 ± 3	3 ± 2	11 ± 3
08/21/76	<1	9 ± 4	<1	7 ± 4	<1 <1	9 ± 4	<1	7 ± 4
08/27/76	<1	6 ± 2	<1 <1	7 ± 4 5 ± 2	<1 <1	5 ± 2	<1**	4 ± 3
09/04/76	<1 <1	8 ± 2	\(\frac{1}{1}\)	8 ± 2	<1 <1	10 ± 3	<1 <1	9 ± 3
09/11/76	<1	14 ± 3	<1	7 ± 2	⟨0.5	7 ± 3	<0.5	6 ± 3
09/18/76	<1 <1	9 ± 3	<1 <1	8 ± 2	<0.5	18 ± 3	<0.5	8 ± 3
09/25/76	<1 <1	8 ± 3	<1	7 ± 2	<1 <1	8 ± 2	<1	10 ± 3
10/02/76	<1 <1	0 = 3 11 ± 4	<1 <1	7 ± 3	<1	5 ± 3	<1***	7 ± 2
10/02/76	<0.5	3 ± 2	0.6 ± 0.5	4 ± 2	<0.5	4 ± 2	<1	3 ± 2
10/16/76	<0.5	4 ± 2	<0.5	4 ± 2	<0.5	4 ± 2	<0.5	5 ± 3
10/23/76	<0.5	12 ± 2	<0.5	20 ± 4	<0.5	16 ± 3	1 ± 1	12 ± 4
10/30/76	<1	9 ± 3	<1	6 ± 2	<1 <1	9 ± 3	<1	7 ± 3
11/06/76	2 ± 1	10 ± 3	<1	10 ± 3	2 ± 1	8 ± 3	₹2	7 ± 4
11/13/76	3 ± 2	20 ± 4	<1	10 ± 3	<1	18 ± 4	< <u>1</u>	13 ± 3
11/20/76	<0.9	8 ± 2	2 ± 1	8 ± 2	4 ± 1	7 ± 2	6 ± 2	=
11/28/76	<1	4 ± 3+	<1	4 ± 3+	<1	6 ± 3	<1 Z	8 ± 2 5 ± 3
12/04/76	₹0.5	< 3	<0.5	4 ± 3	<0.5	< 5	<0.5	4 ± 3
12/11/76	<1	6 ± 3	<1	4 ± 2	2 ± 2	, 6 ± 2	3 ± 2	14 ± 4
12/18/76	<1	3 ± 2	\(\)1	3 ± 2	<1	5 ± 2	\(\frac{1}{1}\)	3 ± 2
12/23/76	<1	4 ± 2	< 1	6 ± 2	<1	5 ± 2	<0.5	10 ± 3
12/30/76	<1	3 ± 2	<1	4 ± 2	<1	6 ± 2	1 ± 1	4 ± 2

^{*}Iodine-131 sampled weekly. Activity is <4 pCi/1 unless otherwise specified. Data reported as "<" are at the 99% confidence level. All other data are at the 95% confidence level, all based on counting errors.

^{**}Collected 08/29/76. ***Collected 10/03/76. +Unusual finding, I-131 activity for D-19 = 5 ± 3; D-20-1 = 4 ± 3.

TABLE 5.3-2

GROSS BETA IN SURFACE WATER SAMPLES Indicator Stations

Collectic Date	on 1		ver at Mo ss β (pCi/	orris (D-22)+ (1)	Collection Date	Dresden Lake (Pond) (D-34) Gross β (pCi/1)
07/17/76			10 ± 2		07/03/76	4 ± 2
07/24/76			17 ± 3		07/10/76	6 ± 2
07/31/76			5 ± 3		07/17/76	11 ± 3
08/15/76			6 ± 3		07/24/76	10 ± 7
08/31/76			16 ± 3		07/31/76	3 ± 3
09/15/76			7 ± 3		08/07/76	5 ± 3
09/31/76			7 ± 2		08/13/76	4 ± 3
10/15/76			9 ± 3		08/21/76	4 ± 3
10/31/76			9 ± 2		08/29/76	5 ± 3
11/15/76			9 ± 2		09/04/76	6 ± 2
11/31/76			9 ± 2		09/11/76	6 ± 2
12/15/76			6 ± 2		09/18/76	5 ± 3
12/31/76			3 ± 2		09/25/76	5 ± 2
					10/03/76	32 ± 5**
					10/09/76	6 ± 2
					10/16/76	8 ± 3
					10/23/76	6 ± 3
					10/30/76	7 ± 3
					11/07/76	3 ± 2
					11/13/76	30 ±11**
	(D-23)	·		sden Lock and Dam	11/21/76	7 ± 2
Collection			pCi/1		11/27/76	11 ± 2
Date	Gross β	<u>Sr-89</u>	Sr-90	Gamma Emitters*	12/04/76	7 ± 2
					12/11/76	9 ± 3
08/07/76	6 ± 3	< 5	< 1	< 10	12/18/76	6 ± 2
11/07/76	6 ± 4	< 5	< 1	< 10	12/24/76	9 ± 2
					12/31/76	3 ± 2

+This station collected by the State of Illinois and is not always available on scheduled dates. **High solids content, and/or fresh fallout (See Section 5.0.

*The spectrum is computer scanned from ~20 to ~2000 KeV. Specifically included are Ce-144, Ba-La-140, Cs-134, Cs-137, Zr-Nb-95, Co-58, Co-60, Mn-54, Zn-65. Naturally occurring gamma emitters such as K-40 and Ra daughters are frequently detected but not listed here. Data listed as "<" are at the 3σ level, others are 2σ. Listed concentration is for Cs-137 and may be slightly more or less sensitive for other nuclides.



TRITIUM, Sr-89 and Sr-90 IN SURFACE WATER COMPOSITE SAMPLES

Collection Site	Tritiu July - Sept.	m pCi/1 Oct Dec.	Sr-89 July - Sept.	pCi/1 Oct Dec.	Sr-90 July - Sept.	pCi/1 Oct Dec.
Inlet Canal (D-19)	210 ± 100	360 ± 120	< 5	< 5	< 1	< 1
Unit 1 Discharge Canal (D-20-1)	360 ± 100	470 ± 130	< 5	< 5	< 1	< 2
Unit 2 Discharge Canal (D-20-2/3)	380 ± 100	590 ± 140	< 5	< 5	< 1	< 2
Illinois River at EJ&E RR Bridge (D-21)	440 ± 100	720 ± 140	< 5	< 5	< 1	< 2
Illinois River at Morris (D-22)	190 ± 100	370 ± 120	NR	NR	NR	NR
Dresden Lake (D-34)	280 ± 100	310 ± 120	NR	NR	NR	NR

ADDITIONAL ANALYSIS OF SURFACE WATER

Collection Site	Collection Date	Gamma Emitters* (pCi/1)
D-19 Inlet Canal	11/20/76	< 10
D-20-1 Unit 1 Discharge Canal	11/20/76	< 10

NR = Not required.

*The spectrum is computer scanned from ~20 to ~2000 KeV. Specifically included are Ce-144, Ba-La-140, Cs-134, Cs-137, Zr-Nb-95, Co-58, Co-60, Mn-54, Zn-65. Naturally occurring gamma emitters such as K-40 and Ra daughters are frequently detected but not listed here. Data listed as "<" are at the 3 σ level, others are 2 σ . Listed concentration is for Cs-137 and may be slightly more or less sensitive for other nuclides.

TABLE 5.3-4

GAMMA ISOTOPIC, GROSS BETA ANALYSES OF PERIPHYTON (SLIME) SAMPLES

		pCi/g (Dry)			
Collection Site	Collection Date	Gross Beta	Gamma Isotopic*		
Dresden Lock and Dam (D-23)	08/07/76	52 ± 3	< 1		
	11/13/76	6 ± 2	NR		
Kankakee River (D-36)	08/07/76	65 ± 4	< 1		
	11/13/76	15 ± 2	NR		
Des Plaines River (D-37)	08/07/76	42 ± 3	< 1		
	11/13/76	14 ± 2	NR		

RADIONUCLIDES IN AQUATIC PLANTS

Collection	Collection	Wt. Ratio			pC:	i/g (Wet))		
Site	<u>Date</u>	Wet - Dry	Gross β	Cs-134	Cs-137	Co-60	<u>I-131</u>	<u>Sr-89</u>	Sr-90
(D-19) Inlet Canal	08/08/76	8.22	< 1	< 1	< 1	< 1	< 1	< 2	< 1
(D-20-1) Disch. Canal	08/08/76	6.21	1 ± 1	< 1	< 1	< 1	< 1	< 2	< 1
(D-20-2/3) Disch. Canal	L 08/08/76	4.78	6 ± 1	< 1	< 1	< 1	< 1	< 2	< 1

GROSS BETA, Sr-89, Sr-90 AND GAMMA ISOTOPIC ANALYSES OF FISH SAMPLES

Collection	Collection	Sample	Radion	iclide Cond	centration	pCi/g (Wet)
Site	Date	Description	Gross β	Sr-89	Sr-90	Gamma Isotopic*
D-23 Dresden Lock and	08/08/76	Carp - Whole	6 ± 2	< 2	- 1	< 0.1
Dam	08/08/76	Carp - Edible	8 ± 2	< 2	< 1	< 0.1
	08/08/76	Bullhead-Whole	6 ± 2	< 2	< 1	< 0.1
	08/08/76	Bullhead-Edible	9 ± 2	< 2	< 1	< 0.1

GAMMA ISOTOPIC, GROSS BETA, Sr-89 and Sr-90 ANALYSES OF SEDIMENT SAMPLES

•			pC	:i/g (Dry)	
Collection Site	Collection Date	Gross Beta	Sr-89	Sr-90	Gamma Isotopic*
(D-23) Dresden Lock and Dam	08/07/76	3 ± 1	< 2	< 1	< 1
	11/13/76	6 ± 1	< 2	< 1	< 1
(D-36) Kankakee River	08/07/76	1 ± 1	< 2	< 1	< 1
	11/13/76	< 1	< 2	< 1	NR
(D-37) Des Plaines River	08/07/76	3 ± 1	< 2	< 1	< 1
	11/13/76	3 ± 1	< 2	< 1	NR

*The spectrum is computer scanned from ~20 to ~2000 KeV. Specifically included are Ce-144, Ba-La-140, Cs-134, Cs-137, Zr-Nb-95, Co-58, Co-60, Mm-54, Zn-65. Naturally occurring gamma emitters such as K-40 and Ra daughters are frequently detected but not listed here. Data reported as "<" at the 99% confidence level. All other data are the 95% compared level, all based on counting errors.

NR - Not required.

IODINE-131 IN MILK

pCi/l at time of collection Collection Davidson Farm Dorin Farm Mather Farm Date D - 30D - 59D-53DA DF < 0.5 < 0.5 07/03/76 ₹ 0.5 < 0.5 < 0.5 07/10/76 < 0.5 < 0.5 < 0.5 07/17/76 (a) (a) < 0.5 < 0.5 07/24/76 07/31/76 < 0.5 < 0.5 < 0.5 08/07/76 < 0.5 < 0.5 < 0.5 08/13/76 < 0.5 < 0.5 < 0.5 08/21/76 < 0.5 < 0.5 < 0.5 08/28/76 < 0.5 < 0.5 < 0.5 09/04/76 < 1.5* < 0.5 < 0.5 09/11/76 < 0.5 < 0.5 < 0.5 09/18/76 < 0.5 < 0.5 < 0.5 09/25/76 < 0.5 < 0.5 < 0.5 10/02/76 < 4.0 < 4.0 < 4.0 $0.90 \pm 0.09(b)$ 10/09/76 $0.74 \pm 0.15(b)$ $1.01 \pm 0.10(b)$ 10/16/76 (a) (a) (a) 12.2 ± 0.3 (b) $6.90 \pm 0.30(b)$ 7.0 ± 0.3 (b) 10/23/76 $6.58 \pm 0.36(b)$ $5.87 \pm 0.37(b)$ $0.52 \pm 0.20(b)$ 10/30/76 11/07/76 $5.32 \pm 0.37(b)$ $2.45 \pm 0.25(b)$ $2.47 \pm 0.30(b)$ 11/13/76 < 4.0 < 4.0 < 4.0 11/20/76 < 4.0 < 4.0 < 4.0 11/27/76 < 4.0 < 4.0 < 4.0 < 4.0 12/04/76 < 4.0 < 4.0 12/11/76 < 4.0 < 4.0 < 4.0 12/18/76 < 4.0 < 4.0 < 4.0 12/24/76 < 4.0 < 4.0 < 4.0

Data reported as "<" are at the 99% confidence level. All other data are at the 95% confidence level, all based on counting errors.

⁽a) Lost in processing. *Contamination on filter prevents more sensitive analysis.

⁽b) Unusual reading; refer to Sections 5.0 and 5.4.

TABLE 5.4-2

RADIONUCLIDES IN MILK

Monthly Composites

	D-30		DAVIDSON FA	ARM	
Month of	Sr-89	Sr-90	Cs-137	Calcium	HTO*
Collection	(pCi/1)	(pCi/1)	(pCi/1)	(g/1)	(pCi/1)
July	< 5	6 ± 2	< 5	1.63	
August	< 5	8 ± 3	< 5	0.89	
September	< 5	2 ± 1	< 5	1.61	240 ± 100
October	< 5	< 2	< 5	1.42	
November	< 5	2 ± 1	< 5	1.41	
December	< 5	2 ± 1	< 5	1.64	

	D-59		DORIN FARM		
Month of	Sr-89	Sr-90	Cs-137	Calcium	HTO*
Collection	(pCi/1)	(pCi/1)	(pCi/1)	(g/1)	(pCi/1)
July	< 5	4 ± 2	< 5	1.79	
August	< 5	8 ± 2	< 5	1.17	
September	< 5	3 ± 2	< 5	1.48	350 ± 120
October	< 5	6 ± 2	< 5	1.36	
November	< 5	5 ± 1	< 5	1.40	
December	< 5	6 ± 1	< 5	1.56	

D-53			MATHER FA	RM	
Month of	Sr-89	Sr-90	Cs-137	Calcium	HTO*
Collection	(pCi/1)	(pCi/1)	(pCi/1)	(g/1)	(pCi/1)
July August September October November December	< 5 < 5 < 5 < 5 < 5 < 5 < 5 < 5 < 5 < 5	4 ± 2 3 ± 2 6 ± 1 6 ± 2 4 ± 1 3 ± 1	<pre>< 5 < 5</pre>	1.89 0.89 1.69 1.37 2.00	200 ± 100

^{*}HTO required on September sample only. Data reported as "<" are at the 99% confidence level. All other data are at the 95% confidence level, all based on counting errors.

TABLE 5.4-3

GROSS BETA AND RADIOSTRONTIUM IN GRASS AND CATTLEFEED

Collection	Collection		pCi/g	g (Wet)	
Site	Date	Type Feed	Gross Beta	Sr-89	Sr-90
Davidson Farm	07/03/76	Grain	6 ± 1	< 2	< 1
(D-30) Ind.	07/03/76	Grass	16 ± 2	< 2	< 1
	07/07/76	Grain and Silage	1 ± 1	< 2	< 1
	(a)08/07/76	Grass	8 ± 1	< 2	< 1
	09/04/76	Grain and Silage	4 ± 1	< 2	< 1
	(a)09/11/76	Grass	10 ± 1	< 2	< 1
	(a)09/25/76	Grass	4 ± 1	< 2	< 1
	09/04/76	Grass	4 ± 1	< 2	< 1
	10/03/76	Silage	9 ± 1	< 2	< 1
	10/03/76	Grass	3 ± 1	< 2	< 1
	10/03/76	Hay	5 ± 2	< 2	< 1
	11/07/76	Grass	33 ± 3	< 2	< 1
	11/07/76	Grain	4 ± 2	< 2	< 1
	(a)12/24/76	Grass	8 ± 2	< 2	< 1
	12/04/76	Hay	13 ± 2	< 2	< 1
	12/04/76	Grain	4 ± 1	< 2	< 1
Mather Farm	07/03/76	Grain	4 ± 1	< 2	< 1
(D-53) Bkg	07/03/76	Grass	8 ± 1	< 2	< 1
	08/07/76	Grain	4 ± 1	< 2	< 1
	(a)08/07/76	Grass	8 ± 1	< 2	< 1
	09/04/76	Grain	3 ± 1	< 2	< 1
	09/04/76	Grass	4 ± 1	< 2	< 1
	(a)09/11/76	Grass	29 ± 4	< 2	< 1
	(a)09/25/76	Grass	2 ± 1	< 2	< 1
	10/03/76	Grain	4 ± 1	< 2	< 1
	10/03/76	Grass	2 ± 1	< 2	< 1
	10/03/76	Hay	11 ± 2	< 2	< 1
	11/07/76	Grass	13 ± 2	< 2	< 1
	11/07/76	Grain	1 ± 1	< 2	< 1
	12/04/76	Hay	17 ± 2	< 2	< 1
	12/04/76	Grain	3 ± 1	< 2	< 1
	(a)12/24/76	Grass	2 ± 1	< 2	< 1
Dorin Farm	07/03/76	Grain	4 ± 1	< 2	< 1
(D-59) Ind.	07/03/76	Grass	14 ± 1	< 2	< 1
\	08/07/76	Grain	7 ± 2	< 2	< 1
	(a)08/07/76	Grass	7 ± 1	< 2	< 1
	09/04/76	Grain	9 ± 1	< 2	< 1
	09/04/76	Grass	5 ± 1	< 2	< 1
	(a)09/11/76	Grass	11 ± 2	< 2	< 1
	(a)09/25/76	Grass	5 ± 1	< 2	< 1
	10/03/76	Grain	5 ± 1	< 2	< 1
	10/03/76	Grass	1 ± 1	< 2	< 1
	10/03/76	Hay	11 ± 2	< 2	< 1
	11/07/76	Grain	5 ± 2	< 2	< 1
	11/07/76	Grass	13 ± 2	< 2	< 1
					< 1
	12/04/76	Hav	Z1	\	\ 1
\	12/04/76 12/04/76	Hay Grain	21 ± 2 5 ± 1	< 2 < 2	< 1

TABLE 5.4-4

GAMMA ISOTOPIC ANALYSES OF GRASS AND CATTLE FEED

Collection	Collection	Туре	pCi/gm (Dry)			
Site	Date	Feed	Cs-137	<u>I-131</u>	Other Gamma	
Davidson Farm	07/03/76	Grass	< 1	< 1	< 1	
(D-30)	(a)08/07/76	11	< 1	< 0.5	< 1	
Indicator Station	09/04/76	11	< 1	< 1	< 1	
	(a)09/11/76	11	< 1	< 1	< 1	
	(a)09/25/76	11	< 1	< 1	< 1	
	10/03/76	11	< 1	< 1	< 1	
	11/07/76	n	< 1	< 1	< 1	
	(a)12/24/76	11	< 1	< 0.25	< 1	
	12/31/76	11	< 1	< 0.31	<. 1	
Dorin Farm	07/03/76	Grass	< 1	NR	< 1	
(D-59)	(a)08/07/76	**	< 1	NR	< 1	
Indicator Station	(a)09/11/76	11	< 1	NR	< 1	
	(a)09/25/76	**	< 1	NR	< 1	
	09/04/76	11	< 1	NR	< 1	
	10/03/76	**	< 1	NR	< 1	
	11/07/76	11	< 1	NR	< 1	
	(a)12/24/76	11	< 1	NR	< 1	
Mather Farm	07/03/76	Grass	< 1	NR	< 1	
(D-53)	(a)08/07/76	11	< 1	NR	< 1	
Background Station	09/04/76	71	< 1	NR	< 1	
	(a)09/11/76	11	< 1	NR	< 1	
	(a)09/25/76	11	< 1	NR	< 1	
	10/03/76	11	< 1	NR	< 1	
	11/07/76	11	< 1 < 1	NR	< 1	
	(a)12/24/76	**	< 1	NR	< 1	

NR = Not required.

^{*}The spectrum is computer scanned from ~20 to ~2000 KeV. Specifically included are Ce-144, Ba-La-140, Cs-134, Cs-137, Zr-Nb-95, Co-58, Co-60, Mn-54, Zn-65. Naturally occurring gamma emitters such as K-40 and Ra daughters are frequently detected but not listed here. Data listed as "<" are at the 3 σ level, others are 2 σ . Listed concentration is for Cs-137 and may be slightly more or less sensitive for other nuclides.

⁽a) Special collection.

TABLE 5.5-1

RADIONUCLIDE CONCENTRATIONS IN PRECIPITATION

July - December 1976

Collection Site	Collection Date	Gross Beta (pCi/1)	Gross Beta (pCi/m²)	H-3 as Water (pCi/1)
D-17 On-Site 2	July	18 ± 4	260 ± 60	250 ± 100
	Aug.	107 ± 21	424 ± 87	< 200
	Sept.	49 ± 3	800 ± 80	330 ± 130
	Oct.	749 ± 62	1142 ± 135(a)	< 800
	Nov.	85 ± 9	1100 ± 100(a)	160 ± 100
	Dec.	17 ± 9	180 ± 95	< 200
D-30 Davidson Farm	ı July	5 ± 3	280 ± 180	160 ± 100
	Aug.	68 ± 29	198 ± 84	< 200
	Sept.	15 ± 3	380 ± 40	290 ± 130
	Oct.	136 ± 12	435 ± 53	<1300
	Nov.	530 ± 50	12,000 ± 2000(a)	190 ± 100
	Dec.	26 ± 14	138 ± 74	< 300
D-32 Brandon Lock	July	9 ± 3	690 ± 270	210 ± 100
<u> </u>	Aug.	84 ± 20	270 ± 64	< 200
	Sept.	28 ± 4	700 ± 80	620 ± 150
	Oct.	101 ± 10	816 ± 74	<1300
	Nov.	72 ± 8	1100 ± 100(a)	190 ± 100
	Dec.	9 ± 4	143 ± 64	< 200
D-53 Mather Farm	July	4 ± 3	320 ± 250	270 ± 100
	Aug.	24 ± 4	336 ± 56	< 200
	Sept.	25 ± 4	550 ± 60	< 200
	Oct.	150 ± 10	742 ± 53	<1300
	Nov.	43 ± 5	830 ± 100	200 ± 100
	Dec.	9 ± 4	143 ± 64	< 200

ADDITIONAL ANALYSIS OF PRECIPITATION SAMPLES

		pC1/1			
Collection Site	Collection Date	Cs-137	Other Gamma*		
D-17 On-Site 2	12/04/76	< 10	< 10		
D-30 Davidson Farm	12/04/76	< 10	< 10		
D-32 Brandon Lock	12/04/76	< 10	< 10		
D-53 Mather Farm	12/04/76	< 10	< 10		

^{*}Traces of Zr-95, Nb-95, and Ce-141 detected but not quantified at concentrations

below sensitivity requirements.

Data reported as "<" are at the 99% confidence level. All other data are at the 95% confidence level, all based on counting errors. (a) Unusual readings; refer to Sections 5.0 and 5.5.

D-30			David	son Farm	D-59			Do	rin Farm
Collection		pCi/g	(Dry)		Collection		pCi/g (Dry)	
Date	Gross Beta	Sr-89	Sr-90	Gamma*	Date	Gross Beta	Sr-89	Sr-90	Gamma*
07/03/76	4 ± 1	< 2	< 1	< 1	07/03/76	4 ± 1	< 2	< 1	< 1
08/07/76(a)	3 ± 1	< 2	< 1	< 1	08/07/76(a)	6 ± 1	< 2	< 1	< 1
09/11/76(a)	5 ± 1	< 2	< 1	< 1	09/11/76(a)	4 ± 1	< 2	< 1	< 1
09/25/76(a)	4 ± 1	< 2	< 1	< 1	09/25/76(a)	3 ± 1	< 2	< 1	< 1
10/03/76	3 ± 1	< 2	< 1	< 1	10/03/76	3 ± 1	< 2	< 1	< 1
12/24/76(a)	9 ± 1	< 2	< 1	< 1	12/24/76(a)	5 ± 1	< 2	< 1	< 1

D-53	Mather Far				D-27		Thorsen Farm		
Collection		pCi/g (Dry)		Collection		pCi/g ((Dry)	
Date	Gross Beta	Sr-89	Sr-90	Gamma*	Date	Gross Beta	Sr-89	Sr-90	Gamma*
08/07/76(a)	3 ± 1	< 2	< 1	< 1	07/03/76	< 1	< 2	< 1	< 1
09/11/76(a)	5 ± 1	< 2	< 1	< 1	09/11/76(a)	8 ± 1	< 2	< 1	< 1
09/25/76(a)	4 ± 1	< 2	< 1	< 1	09/25/76(a)	10 ± 8	< 2	< 1	< 1
10/03/76	4 ± 1	< 2	< 1	< 1	10/03/76	3 ± 1	< 2	〈 1	< 1
12/24/76(a)	7 ± 1	< 2	< 1	< 1	12/24/76(a)	9 ± 1	< 2	< 1	< 1

*The spectrum is computer scanned from ~20 to ~2000 KeV. Specifically included are Ce-144, Ba-La-140, Cs-134, Cs-137, Zr-Nb-95, Co-58, Co-60, Mn-54, Zn-65. Naturally occurring gamma emitters such as K-40 and Ra daughters are frequently detected but not listed here. Data listed as "<" are at the 3σ level, others are 2σ. Listed concentration is for Cs-137 and may be slightly more or less sensitive for other nuclides. (a) Special Collection.

TABLE 5.6-1

RADIOACTIVITY IN VEGETABLES

		•					
Collection	Collection				pCi/g	(Wet)	
Site	Date	Sample Type	Gross β	Sr-89	Sr-90	Cs-137	Other Gamma*
(5.45)					_		
(D-49)	07/31/76	Turnips	< 1	< 2	< 1	< 1	< 1
Rousonellis Trk	07/31/76	Collords	< 1	< 2	< 1	< 1	< 1
Farm	07/31/76	Green Beans	< 1	< 2	< 1	< 1	< 1·
	08/13/76	Beets	8 ± 1	< 2	< 1	< 1	< 1
	08/13/76	Corn	4 ± 1	< 2	< 1	< 1	< 1
	08/13/76	Beans	2 ± 1	< 2	< 1	< 1	< 1
•	09/04/76	Beets	$3 \pm .1$	< 2	< 1	< 1	< 1
•	09/04/76	Collards	6 ± 1	< 2	< 1	< 1	< 1
-	09/04/76	Green Beans	1 ± 1	< 2	< 1	< 1	< 1
(D-50)	07/31/76	Cucumber	< 1	< 2	< 1	< 1	< 1
Glasscock Trk	07/31/76	Cabbage	< 1	< 2	< 1	< 1	< 1
Farm	07/31/76	Green Beans	< 1	< 2	< 1	< 1	< 1
·	08/13/76	Beets	< 1	< 2	< 1	< 1	< 1
12 mi NE of	08/13/76	Squash	5 ± 1	< 2	< 1	< 1	< 1
station	08/13/76	Cucumbers	1 ± 1	< 2	< 1	< 1	< 1
	09/04/76	Cucumbers	2 ± 1	< 2	< 1	< 1	< 1
	09/04/76	Beets	2 ± 1	< 2	< 1	< 1	< 1
	09/04/76	Cabbage	2 ± 1	< 2	< 1	< 1	< 1
(D51)	07/31/76	Cucumbers	< 1	< 2	< 1	< 1	< 1
Girot Truck	07/31/76	Corn	1 ± 1	< 2	< 1	< 1	< 1
Farm	08/13/76	Tomatoes	2 ± 1	< 2	< 1	< 1	< 1
	08/13/76	Squash	1 ± 1	< 2	< 1	< 1	< 1
10 mi NE of	08/13/76	Cucumbers	< 1	< 2	< 1	< 1	< 1
station	09/04/76	Cucumbers	2 ± 1	< 2	< 1	< 1	< 1
	09/04/76	Peppers	2 ± 1	< 2	< 1	< 1	< 1
	09/04/76	Tomatoes	2 ± 1	< 2	< 1	< 1	< 1
(D-43)	07/31/76	Cabbage	1 ± 1	< 2	< 1	< 1	< 1
Phillips Farm	07/31/76	Yellow Squash	< 1	< 2	< 1	< 1	< 1
-	07/31/76	Onions	1 ± 1	< 2	< 1	< 1	< 1
	08/13/76	Squash	6 ± 1	< 2	< 1	< 1	< 1
•	08/13/76	Onions	3 ± 1	< 2	< 1	< 1	< 1
	08/13/76	Cabbage	< 1	< 2	< <u>1</u>	< 1	< 1
	09/04/76	Cabbage	2 ± 1	< 2	< 1	< 1	< 1
	09/04/76	Squash	2 ± 1	< 2	< 1	< 1	< 1
	09/04/76	Tomatoes	2 ± 1	< 2	< 1	< 1	< 1

^{*}The spectrum is computer scanned from ~20 to ~2000 KeV. Specifically included are Ce-144, Ba-La-140, Cs-134, Cs-137, Zr-Nb-95, Co-58, Co-60, Mn-54, Zn-65. Naturally occurring gamma emitters such as K-40 and Ra daughters are frequently detected but not listed here. Data listed as "<" are at the 3σ level, others are 2σ. Listed concentration is for Cs-137 and may be slightly more or less sensitive for other nuclides.

TABLE 5.7-1

GROSS BETA AND TRITIUM IN WELL WATER SAMPLES

Collection Site	Collection Date	Gross Beta (pCi/1)	Tritium (pCi/1)
(D-24) Dresden Well 1	07/03/76	24 ± 4	< 100
Indicator Station	10/03/76	25 ± 5	200 ± 100
Indicator Station	10,03,,0		
(D-25) Dresden Well 2	08/07/76	22 ± 5	< 100
Indicator Station	11/07/76	38 ± 6	< 140
(D-27) Thorsen Farm	07/03/76	8 ± 2	< 100
Indicator Station	10/03/76	4 ± 3	360 ± 150
			_
(D-09) Bennitt Farm	07/03/76	15 ± 7	NR
Indicator Station	10/03/76	9 ± 8	NR
(5.10) ** 1	07/02/76	2/ + /	NR
(D-10) Hansel	07/03/76	24 ± 4	NR NR
Background Station	10/03/76	13 ± 5	INK
(D-12) Breen	08/07/76	35 ± 6	NR
Background Station	11/07/76	16 ± 5	NR
background Station	11/0///0	10 _ 3	****
(D-23) Dresden Lock and Dam	07/03/76	18 ± 3	NR
(2 23) 2200001 2001 0110 1111	08/07/76	17 ± 4	NR
	09/04/76	27 ± 3	NR
	10/03/76	25 ± 5	NR
	11/07/76	21 ± 5	NR
	12/04/76	20 ± 4	NR
(D-26) Drinking Fountain	08/07/76	18 ± 5	NR
Unit 1	11/07/76	27 ± 5	NR
(D-28) Anderson Farm	08/07/76	16 ± 5	NR
Indicator Station	11/07/76	23 ± 5	NR
(D. 20) 01 B	00/07/76	12 + 5	NTD
(D-29) Olson Farm	08/07/76	13 ± 5	NR NB
Background Station	11/07/76	20 ± 5	NR .

NR = not required.

Data reported as "<" are at the 99% confidence level. All other data are at the 95% confidence level, all based on counting errors.

SPECIAL COLLECTIONS

	Collection	Sample	pCi/g ($\pm 2\sigma$) as received				
Collection Site	Date	Туре	Gross β	Sr-89	Sr-90	Gamma Emitters*	
D-30 Davidson Farm	08/07/76	Soil	3.3 ± 0.7	< 2	< 1	< 1	
D-53 Mather Farm	08/07/76	Soil	3.2 ± 0.8	< 2	< 1	< 1	
D-59 Dorin Farm	08/07/76	Soil	5.7 ± 0.8	< 2	< 1	< 1	
D-30 Davidson Farm	08/07/76	Grass	47.7 ± 3.0	< 2	< 1	< 1	
D-53 Mather Farm	08/07/76	Grass	37.3 ± 2.6	< 2	< 1	< 1	
D-59 Dorin Farm	08/07/76	Grass	16.2 ± 1.8	< 2	< 1	< 1	
D-27 Thorsen Farm	09/11/76	Soil	7.5 ± 0.8	< 2	< 1	< 1	
D-30 Davidson Farm	09/11/76	Soil	5.2 ± 0.8	< 2	< 1	< 1	
D-53 Mather Farm	09/11/76	Soil	5.0 ± 0.7	< 2	< 1	< 1	
D-59 Dorin Farm	09/11/76	Soi1	3.6 ± 0.6	< 2	< 1	< 1	
D-27 Thorsen Farm	09/11/76	Grass	13.0 ± 3.0	< 2	< 1	< 1	
D-30 Davidson Farm	09/11/76	Grass	42.0 ± 5.0	< 2	< 1	< 1	
D-53 Mather Farm	09/11/76	Grass	33.0 ± 4.0	< 2	< 1	< 1	
D-59 Dorin Farm	09/11/76	Grass	24.0 ± 3.0	< 2	< 1	< 1	
D-27 Thorsen Farm	09/25/76	Soil	9.9 ± 8.1	< 2	< 1	< 1	
D-30 Davidson Farm	09/25/76	Soil	4.0 ± 1.0	< 2	< 1	< 1	
D-53 Mather Farm	09/25/76	Soil	4.4 ± 0.9	< 2	< 1	< 1	
D-59 Dorin Farm	09/25/76	Soil	2.7 ± 0.8	< 2	< 1	< 1	
D-27 Thorsen Farm	09/25/76	Grass	11.0 ± 2.0	< 2	< 1	< 1	
D-30 Davidson Farm	09/25/76	Grass	11.0 ± 2.0	< 2	< 1	< 1	
D-53 Mather Farm	09/25/76	Grass	13.0 ± 2.0	< 2	< 1	< 1	
D-59 Dorin Farm	09/25/76	Grass	9.0 ± 2.0	< 2	< 1	< 1	
D-27 Thorsen Farm	12/04/76	Snow	NR	< 5	< 2	<10	
D-30 Davidson Farm	12/04/76	Snow	NR	< 5	< 2	<10	
D-53 Mather Farm	12/04/76	Snow	NR	< 5	< 2	<10	
D-59 Dorin Farm	12/04/76	Snow	NR	< 5	< 1	<10	

NR = Not required.

*The spectrum is computer scanned from ~20 to ~2000 KeV. Specifically included are Ce-144, Ba-La-140, Cs-134, Cs-137, Zr-Nb-95, Co-58, Co-60, Mn-54, Zn-65. Naturally occurring gamma emitters such as K-40 and Ra daughters are frequently detected but not listed here. Data listed as "<" are at the 3σ level, others are 2σ . Listed concentration is for Cs-137 and may be slightly more or less sensitive for other nuclides.

TABLE 5.8-1 (Cont'd)

SPECIAL COLLECTION

	Collection	Sample	pCi/g (±2 σ) as received				
Collection Site	Date	Туре	Gross Beta	Sr-89	Sr-90	Cs-137	Other Gamma
D-27 Thorsen Farm	12/24/76	Grass	18 ± 2	< 2	< 1	< 1	< 1
D-30 Davidson Farm	12/24/76	Grass	9 ± 2	< 2	< 1	< 1	< 1
D-53 Mather Farm	12/24/76	Grass	7 ± 1	< 2	< 1	< 1	< 1
D-59 Dorin Farm	12/24/76	Grass	8 ± 1	< 2	< 1	< 1	< 1
D-27 Thorsen Farm	12/24/76	Soi1	9 ± 1	< 2	< 1	< 1	< 1
D-30 Davidson Farm	12/24/76	Soil	9 ± 1	< 2	< 1	< 1	< 1
D-53 Mather Farm	12/24/76	Soil	7 ± 1	< 2	< 1	< 1	< 1
D-59 Dorin Farm	12/24/76	Soil	5 ± 1	. < 2	< 1	< 1	< 1

*The spectrum is computer scanned from ~20 to ~2000 KeV. Specifically included are Ce-144, Ba-La-140, Cs-134, Cs-137, Zr-Nb-95, Co-58, Co-60, Mn-54, Zn-65. Naturally occurring gamma emitters such as K-40 and Ra daughters are frequently detected but not listed here. Data listed as "<" are at the 3 σ level, others are 2 σ . Listed concentration is for Cs-137 and may be slightly more or less sensitive for other nuclides.

76

TABLE 5.8-2

GAMMA ISOTOPIC* ANALYSIS OF WELL WATER D-1 RADWASTE AREA

Collection		Filterable S	Filterable Solids			
Date	mg/1	pCi/g solids	pCi/1	<u>pCi/1</u>		
08/13/76	24	< 170	< 10	< 10		
10/16/76	31	(1)	(2).	< 40		
11/27/76	190	< 50	< 10	< 10		

⁽¹⁾ $Co-60 = 620 \pm 300 \text{ pCi/g}$, others < 200 pCi/g. (2) Co-60 = 20 pCi/l, others < 10 pCi/l.

^{*}The spectrum is computer scanned from ~20 to ~2000 KeV. Specifically included are Ce-144, Ba-La-140, Cs-134, Cs-137, Zr-Nb-95, Co-58, Co-60, Mn-54, Zn-65. Naturally occurring gamma emitters such as K-40 and Ra daughters are frequently detected but not listed here. Data listed as "<" are at the 3σ level, others are 20. Listed concentration is for Cs-137 and may be slightly more or less sensitive for other nuclides.

Collection

Customer

pCi/g

⁺Collected in restricted area.

^{*}The spectrum is computer scanned from ~20 to ~2000 KeV. Specifically included are Ce-144, Ba-La-140, Cs-134, Cs-137, Zr-Nb-95, Co-58, Co-60, Mn-54, Zn-65. Naturally occurring gamma emitters such as K-40 and Ra daughters are frequently detected but not listed here. Data listed as "<" are at the 3σ level, others are 2σ. Listed concernation is for Cs-137 and may be slightly more less sensitive for other nuclides.



ADDITIONAL DATA FOR THE PERIOD JANUARY - JUNE 1976

	Collection	Sample V	Wt. Ratio	pCi/g (Dry)			
Collection Site	Date	Type	Wet - Dry	Gross Beta	Sr-89	Sr-90	Gamma Emitters*
(D-19) Inlet Canal	06/06/76	Aquatic Plants	s 8.22	15 ± 2	< 2	< 1	< 1
(D-20-1) Disch. Canal**		Aquatic Plants	s 6.21	27 ± 2	< 2	< 1	< 1
(D-20-2/3) Disch. Canal							

	Collection	Sample		ŗ	Ci/1	
Collection Site	Date	Туре	Gross Beta	Sr-89	<u>Sr-90</u>	Gamma Emitters*
(D-23) Dresden Lock	02/07/76	Surface Water	4 ± 4	< 1	2.7 ± 1.2	< 5
and Dam	05/08/76	Surface Water	10 ± 3	< 5	< 2	<10
Collection Site	Collection Date	Sample Type	Gross Beta (pCi/1)		oss Beta oCi/m²)	H-3 as Water (pCi/1)
D-17 On-Site 2	07/03/76	Precipitation	Insufficient	sample for	r analysis	
D-30 Davidson Farm	07/03/76	ii .	11	11 11	11	
D-32 Brandon Lock	07/03/76	11	11	11 11	11	
D-52 Mather Farm	07/03/76		tt .	11 11	11	

^{**}D-20-1 and D-20-2/3 were run as a composite due to a misunderstanding.

*The spectrum is computer scanned from ~20 to ~2000 KeV. Specifically included are Ce-144, Ba-La-140, Cs-134, Cs-137, Zr-Nb-95, Co-58, Co-60, Mn-54, Zn-65. Naturally occurring gamma emitters such as K-40 and Ra daughters are frequently detected but not listed here. Data listed as "<" are at the 3σ level, others are 2σ. Listed concentration is for Cs-137 and may be slightly more or less sensitive for other nuclides.

APPENDIX II

METEOROLOGICAL DATA

DRESDEN NUCLEAR POWER STATION PERIOD OF RECORD - JULY - SEPTEMBER 1976 STABILITY CLASS - EXTREMELY UNSTABLE (DELTA T 150-35 FT) WINDS MEASURED AT 35 FEET

WIND			WIND SPE				
DIRECTION	1-3	4- 7	8-12	13-18	19-24	GT 24	TOTAL
N	1	10	10	0	0	0	21
NNE	0	. 26	49	3	0	0	78
NE	0	15	16	3	0	Ů	34
ENE	2	9	1	0	0	0	12
Ε	0	8	4	0	0	0	12
ESE	1	7	0	0	0	0	8
SE	. 2	16	5	0	0	0	23
SSE	0	9	1	0	0	0	10
s	0	11		0	0	0	11
SSW	0	9	2	1	0	0	12
SW	0	4	13	18	2	0	37
WSW	0	12	28	6	0	0	46
W	0	11	8	0	0	0	19
MNM	0	4	0	1	0	0	5
NW	1	8	7	5	0	0 .	21
NNW	0	12	8	15	0	0	35
VARIABLE	2	0	0	0	0	0	2
TOTAL	9	171	152	52	2	0	386

HOURS OF CALM IN THIS STABILITY CLASS - 0
HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 0

DRESDEN NUCLEAR POWER STATION PERIOD OF RECORD - JULY - SEPTEMBER 1976 STABILITY CLASS - MODERATELY UNSTABLE (DELTA T 150+35 FT) WINDS MEASURED AT 35 FEET

WIND								
DIRECTION	1- 3	4- 7	8-12	13-18	19-24	GT 24	TOTAL	
4	0	1	4	0	0	0	5	
NE	0	1	3	0	0	0	4	
IE .	0	٥	2	3	0	0	5	
ENE	0	1	1	0	0	0	2	
<u> </u>	0	2	2	0	0	0	4	
ESE	0	1	1	0	O	O	2	
SE	0	2	2	0	0	. 0	4	
SSE	0	4	2	0	0	0	6	
5	0	5	0	0	0	0	5	
SSH	1	3	6	2	0	0	12	
SW	1	4	1	0	0	0	6	
ISM	2	3	3	1	0	0	9	
•	1	1	4	0	0	0	6	
4NH	0	2	1	0	. 0	0	3	
чи	0	2	4	0	0	O	6	
NNM	0	5	4	1	0	0	10	
/ARIABLE	0	0	0	0	0	0	0	
TOTAL	5	37	40	7	0	0	89	
	INE INE ENE ESE SSH SW INW INW INW INW IARIABLE	INE O	DIRECTION 1-3 4-7 NNE	DIRECTION 1-3 4-7 8-12 NINE	DIRECTION 1-3 4-7 8-12 13-18 NINE	DIRECTION 1-3 4-7 8-12 13-18 19-24 NNE	DIRECTION 1-3 4-7 8-12 13-18 19-24 GT 24 NINE	DIRECTION 1-3 4-7 8-12 13-18 19-24 GT 24 TOTAL A

HOURS OF CALM IN THIS STABILITY CLASS - 0
HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 0

DRESDEN NUCLEAR POWER STATION PERIOD OF RECORD - JULY - SEPTEMBER 1976 STABILITY CLASS - SLIGHTLY UNSTABLE (DEL WINDS MEASURED AT 35 FEET

(DELTA T 150-35 FT)

WIND DIRECTION	1- 3	4- 7	IND SPEE 8-12	ED (IN MI 13-18	PH) 19-24	GT 24	TOTAL
N	0	2	2	0	0	0	4
NNE	0	6	1	0	0	0	7
NE	1	2	8	1	0	0	12
ENE	0	4	0	0	0	0	4
E	0	5	0	0	0	0	. 5
ESE	0	2	1	0	0	0	3
SE	0	6	1	0	0	0	7
SSE	1	3	2	0	Đ	0	6
S	1.	3	0	0	0	0	4
SSW	0	4	3	3	0	0	10
SW	0	2	3	2	0	a	7
HSH	1	6	4	2	0	0	13
· W	1	3	2	0	0	0	6
HNH	1	2	1	1	0	0	5
NW	0	2	9	0	0	0	11
NNW	0	3	2	0	0	0	5
VARIABLE	1		0	0	0	0	1
TOTAL	7	55	39	9	0	0	110

HOURS OF CALM IN THIS STABILITY CLASS - 1
HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 0

DRESDEN NUCLEAR POWER STATION PERIOD OF RECORD - JULY - SEPTEMBER 1976 STABILITY CLASS - NEUTRAL (DEL WINDS MEASURED AT 35 FEET

1976 (DELTA T 150-35 FT)

WIND)	IND SPE	ED (IN MI	PH)			(
DIRECTION	1- 3	4- 7	8-12	13-18	19-24	GT 24	TOTAL	
N	4	10	3	0	0	0	17	
NNE	0	12	5	0	0	0	17	
NE	3	18	32	4	0	0	57	
ENE	0	32	14	0	0	0	46	
Ε	2	16	5	Q	a	Q	23	
ESE	2	10	1	0	0	0	13	
SE	4	12	0	0	0	0	16	
SSE	4	24	11	1	0	0	40	
s	4	29	20	12	8	0	65	
SSW	5	16	25	8	1	0	55	
SW	4	15	15	7	0	8	41	
MSM	1	9	12	3	0	0	25	(
W	4	10	8	5	0	0	27	
WNW	3	7	7	5	0	0	22	
ИМ	3	18	15	2	0	0	30	
NNW	1	11	7	1	Đ	0	20	
VARIABLE	8	0	0	0	0	0	8	
TOTAL	52	241	180	48	1	0	522	

HOURS OF CALM IN THIS STABILITY CLASS - 0
HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 0

DRESDEN NUCLEAR POWER STATION PERIOD OF RECORD - JULY - SEPTEMBER 1976 STABILITY CLASS - SLIGHTLY STABLE (DELTA T 150-35 FT WINDS MEASURED AT 35 FEET

WIND		WIND SPEED (IN MPH)								
DIRECTION	1- 3	4- 7	8-12	13-18	19-24	GT 24	TOTAL			
N	3	23	5	0	0	0	31			
NNE	1	22	0	1	Đ	0	24			
NE	1	19	10	1	0	0	31			
ENE	6	14	3	0	0	0	23			
Ε	5	23	10	0	0	0	38			
ESE	9	30	0	0	8	0	39			
SE	4	18	0	0	0	0	22			
SSE	6	35	17	0	0	0	58			
S	11	26	30	13	0	0	80			
SSW	7	33	20	9	0	0	69			
SW	3	24	11	3	1	0	42			
MSM	2	22	12	3	0	0	39			
W	1	19	6	6	0	0	32			
MNM	3	15	6	8	0	0	32			
NW	1	14	16	2	0	0	33			
NNW	3	24	4	0	0	0	31			
VARIABLE	28	0	0	0	0	0	28			
TOTAL	94	361	150	46	1	0	652			

HOURS OF CALM IN THIS STABILITY CLASS -HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES -

DRESDEN NUCLEAR POWER STATION PERIOD OF RECORD - JULY - SEPTEMBER 1976 STABILITY CLASS - MODERATELY STABLE (DELTA T 150-35 FT) WINDS MEASURED AT 35 FEET

WIND		١	WIND SPE	ED (IN MI	PH)		
DIRECTION	1- 3	4- 7	8-12	13-18	19-24	GT 24	TOTAL
N	3	4	0	0	0	0	7
NNE	2	10	1	0	0	0	13
NE	1	4	1	0	0	0	6
ENE	2	1	0	0	0	0	3
E	1	2	O	0	0	a	3
ESE	4	8	0	0	0	0	12
SE	2	8	2	0	0	0	12
SSE	4	4	6	0	0	0	14
S	3	19	19	0	0	0	41
SSW	7	18	3	a	0	0	28
SW	6	24	3	0	0	0	33
WSW	10	18	4	0	0	0	32
W	11	14	2	0	0	0	27
MNM	5	14	1	0	0	0	20
NW	7	12	0	0	0	0	19
NNW	6	12	1	0	0	0	19
VARIABLE	39	0	0	0	. 0	0	39
TOTAL	113	172	43	0	0	0	328

HOURS OF CALM IN THIS STABILITY CLASS -HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS -

HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES -

DRESDEN NUCLEAR POWER STATION PERIOD OF RECORD - JULY - SEPTEMBER 1976 STABILITY CLASS - EXTREMELY STABLE (DELTA T 150-35 FT WINDS NEASURED AT 35 FEET

WIND		₩.	IND SPEE	D (IN MP	H)		
DIRECTION	1- 3	4- 7	8-12	13-18	19-24	GT 24	TOTAL
******		*****					
N	2	0	0	0	0	0	2
NNE	0	1	0	0	O	0	1
NE	0	0	0	0	0	0	0
ENE	0	٥	0	0	0	0	0
Ε	0	0	0	0	0	0	0
ESE	0	3	0	0	0	G	3
SE	0	0	0	0	0	0	0
SSE	1	4	0	0	0	0	5
s	1	7	0	0	0	0	8
SSW	2	4	0	0	0	0	6
SH	3	14	2	0	0	0	19
HSW	1	8	0	0	0	0	9
H	2	2	0	0	0	0	4
HNH	7	3	0	0	0	0	10
NW	9	11	0	0	0	0	20
NNW	4	10	0	0	0	0	14
VARIABLE	13	0	0	O	0	0	13
					_	_	
TOTAL	45	67	2	0	0	0	114

HOURS OF CALM IN THIS STABILITY CLASS -HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES -

DRESDEN NUCLEAR POHER STATION PERIOD OF RECORD - OCTOBER - DECEMBER 1976 STABILITY CLASS - EXTREMELY UNSTABLE (DELTA T 150-35 FT) WINDS MEASURED AT 35 FEET

WIND		WIND SPEED (IN MPH)						
DIRECTION	1-3	4- 7	8-12	13-18	19-24	GT 24	TOTAL	
N	1	17	31	4	0	0	53	
NNE	1	10	7	2	0	0	20	
NE	2	2	1	2	0	0	7	
ENE	1	4	2	0	0	0	7	
E	1	10	5	0	0	0 .	16	
ESE	0	12	16	2	0	0	30	
SE	0	8	13	0	0	0	21	
SSE	9	2	6	1	0	0	9	
S	9	4	3	4	0	0	11	
SSW	1	7	14	8	5	0	35	
SW	2	5	6	15	2	0	30	
HSH	2	12	9	22	0	0	45	
W	2	17	36	9	2	0	66	
WNW	1	10	40	17	9	0	77	
NW	1	8	38	30	4	0	81	
КИИ	1	27	54	17	0	0	99	
VARIABLE	0	٥	0	0	0	0	0	
TOTAL	16	155	281	133	22	0	607	

HOURS OF CALM IN THIS STABILITY CLASS - 1
HOURS OF HISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 57

HOURS OF HISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES -

DRESDEN NUCLEAR POWER STATION PERIOD OF RECORD - OCTOBER - DECEMBER 1976 STABILITY CLASS - MODERATELY UNSTABLE (DELTA T 150-35 FT) WINDS MEASURED AT 35 FEET

WIND							
DIRECTION	1- 3	4- 7	8-12	13-18	19-24	GT 24	TOTAL
						40000	
N	1	5	12	0	0	0	18
NNE	0	0	1	0	0	0	1
NE	0	1	2	0	0	0	3
ENE	0	0	0	0	0	0	٥
E	0	O	0	0	0	0	0
ESE	0	1	0	0	0	0	1
SE	0	٥	1	٥	0	0	1
SSE	0	O	1	0	0	. 0	1
S	0	0	0	2	1	0	3
SSW	0	0	0	1	1	0	2
SW	0	0	1	1	0	0	2
HSH	0	1	1	Đ	0	0	2
W	0	0	1	0	0	0	1
MNM	0	1	3	4	0	0	8
NW	0	D	2	1	1	0	4
NNW	0	O	7	1	0	0	8
VARIABLE	1	0	0	0	0	0	1
TOTAL	2	9	32	10	3	0	56

HOURS OF CALM IN THIS STABILITY CLASS - 0
HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 7
HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 0

ORESDEN NUCLEAR POWER STATION PERIOD OF RECORD - OCTOBER - DECEMBER 1976 STABILITY CLASS - SLIGHTLY UNSTABLE (DELTA T 150-35 FT) WINDS MEASURED AT 35 FEET

WIND		,	NINO SPE	ED (IN MF	РН)			(
DIRECTION	1-3	4- 7	8-12	13-18	19-24	GT 24	TOTAL	
N	0	2	1	3	0	0	6	
NNE	0	2	3	O	0	0	5	
NE	0	0	2	0	0	0	2	
ENE	0	٥	0	0	0	0	0	
E	i	1	0	0	0	0	2	
ESE	1	1	1	0	0	0	3	
SE	0	1	2	0	0	0	3	
SSE	0	0	2	0	0	0	2	
S	٥	2	2	2	0	0	6	
SSW	0	2	2	0	0	0	4	
SW	0	. 0	0	3	0	O	3	
MSM	1	0	1	0	0	0	2	
W	0	0	4	0	0	0	4	
MNM	0	0	11	2	0	0	13	
NH	0	3	5	2	0	. 0	10	
NNW	0	O	10	3	0	0	13	
VARIABLE	0	0	0	0	0	0	0	
TOTAL	3	14	46	15	0	0	78	

HOURS OF CALM IN THIS STABILITY CLASS - 0
HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 14
HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 0

ORESOEN NUCLEAR POWER STATION PERIOD OF RECORD - OCTOBER - DECEMBER 1976 STABILITY CLASS - NEUTRAL (DELTA T 150-35 FT)

WINDS MEASURED AT 35 FEET

WIND DIRECTION	1- 3	4- 7	1NO SPEE 8-12	ED (IN M)	PH) 19-24	GT 24	TOTAL
N	1	8	12	7	0	0	28
NNE	1	5	4	3	0	0	13
NE	1	7	4	0	0	0	12
ENE	0	1	2	0	0	0	3
E	1	6	3	0	0	0	10
ESE	0	10	5	0	0	0	15
SE	0	7	4	0	0	0	11
SSE	1	8	10	3	Đ	0	22
S	2	10	6	12	2	0	32
SSW	1	7	17	8	5	0	38
SW	1	10	8	7	3	0	29
HSH	0	3	6	6	0	0	15
H	1	13	23	6	0	0	43
MNM	0	7	36	30	1	0	74
NW	0	14	33	16	0	0	63
NNW	0	11	40	8	1	0	60
VARIABLE	4	0	0	0	0	0	4
TOTAL	14	127	213	106	12	0	472

HOURS OF CALM IN THIS STABILITY CLASS - 0
HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 61

HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES -

DRESDEN NUCLEAR POWER STATION PERIOD OF RECORD - OCTOBER - DECEMBER 1976 STABILITY CLASS - SLIGHTLY STABLE (DELTA T 150-35 FT) WINDS MEASURED AT 35 FEET

WIND			WIND SPE	ED (IN N	1PH)			
DIRECTION	1- 3	4- 7	8-12	13-18	19-24	GT 24	TOTAL	`
N	1	5	2	0	0	0	8	
					_			
NNE	S	3	0	0	0	0	5	
NE	1	5	0	0	0	0	6	
ENE	0	1	1	0	0	0	2	
Ε	1	1	0	0	0	0	. 2	
ESE	1	4	1	0	0	0	6	
SE	0	5	1	0	0	0	6	
SSE	3	9	9	0	0	0	21	
S	ı	8	9	20	1	1.	40	
SSM	3	7	11	13	18	2	54	
SW	6	17	30	2	4	0	59	
WSW	1	10	12	5	0	0	28	
W	1	24	28	8	0	0	61	
WNW	3	23	51	13	0	0	90	
NW	0	23	21	20	5	0	69	
NNW	0	18	10	1	1	0	30	
VARIABLE	7	0	0	. 0	0	.0	. 7	
TOTAL	31	163	186	82	29	3	494	

HOURS OF CALM IN THIS STABILITY CLASS - 0
HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 38
HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 0

ORESOEN NUCLEAR POWER STATION PERIOD OF RECORD - OCTOBER - DECEMBER 1976 STABILITY CLASS - MODERATELY STABLE (DELTA T 150-35 FT) WINDS MEASURED AT 35 FEET

MIND		_		ED (IN)			
DIRECTION	1- 3	4- 7	8-12	13-18	19-24	GT 24	TOTAL
N	2	5	0	0	0	0	7
NNE	2	1	0	0	0	0	3
NE	3	3	0	0	0	. 0	6
ENE	i	3	0	0	0	0	4
Ε	0	0	0	0	0	0	O
ESE	1	10	3	0	0	0	14
SE	2	6	1	0	0	0	9
SSE	2	4	8	0	0	0	14
S	4	14	7	1	0	0	26
SSW	5	15	5	0	0	0	25
SW	6	22	3	0	0	0	31
MSM	2	12	5	• 1	0	0	20
W	4	19	3	0	0	0	26
WNW	2	10	8	0	0	0	20
NW	7	6	3	1	0	0	17
NNW	2	5	0	0	0	0	7
VARIABLE	13	0	0	0	0	0	13
TOTAL	58	135	46	3	0	0	242

HOURS OF CALM IN THIS STABILITY CLASS - 2
HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 6
HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 0

DRESDEN NUCLEAR PONER STATION PERIOD OF RECORD - OCTOBER - DECEMBER 1976 STABILITY CLASS - EXTREMELY STABLE (DELTA T 150-35 FT) WINDS MEASURED AT 35 FEET

WIND DIRECTION	1- 3	4- 7	8-12	ED (IN MF 13-18	19-24	GT 24	TOTAL	(
N	0	0	0	0	0	0	0	
NNE	0	٥	0	0	0	0	0	
NE	0	0	0	0	0	0	0	
ENE	0	0	0	0	0	0	0	
E	0	0	0	0	0	0	0	
ESE	0	10	0	0	0	0	10	
SE	0	5	0	0	0	0	5	
SSE	1	1	0	0	0	0	2	
S	5	2	2	0	0	0	9	
SSW	1	10	0	0 .	0	0	11	
SH	6	5	0	0	0	0	11	
MSM	1	4	0	0	0	0	5	
W	0	2	2	0	0	0	4	
мим	1	3	0	0	O O	0	4	
NW	3	1	0	0	0	0	4	
NNN	1	1	0	0	0	0	2	
VARIABLE	4	0	0	0	0	0	4	
TOTAL	23	44	4	o	0	O	71	

HOURS OF CALM IN THIS STABILITY CLASS - 1
HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 1
HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 0

APPE

Dresden Station

1976 Report of Occupational Personnel Radiation Doses

Commonwealth Edison Employees

Work Function

Reactor Operations Routine Maint. & Inservice Inspection Waste Processing Refueling Tob Function & Surveillance # of people/man-rem # of people/man-rem # of people/man-rem # of people/man-rem 147 / 318. 5. faintenance / 53. 39. 111 / 122. 33 / 90. perating 21 / 70. Health Physics 7 / 22. 86 52. 6. Supervisory 53 / 15. 46. ' 92 / 42. Ingineering Contract Workers 2162 / Maintenance 720.

54 /

9.* △

Special Maintenance

^{*}Company employees other than station employees Δ Work on firestops and cable runs.