

2.2.7 Extra Borating System

Design Description

1.0 System Description

The extra borating system (EBS) is a safety-related system. The EBS has two divisions. The EBS provides the following safety related functions:

- Core reactivity control.
- Reactor coolant pressure boundary integrity.

The EBS provides the following non-safety-related functions:

- Borated water to the RCS for beyond design basis events.

2.0 Arrangement

2.1 The functional arrangement of the EBS is as described in the Design Description of Section 2.2.7, Tables 2.2.7-1—EBS Equipment Mechanical Design and 2.2.7-2—EBS Equipment I&C and Electrical Design, and as shown on Figure 2.2.7-1—Extra Borating System Functional Arrangement.

2.2 Deleted.

2.3 Physical separation exists between divisions of the EBS, except for the suction piping interconnect, located in the Fuel Building as shown on Figures 2.1.1-38 and 2.1.1-39.

3.0 Mechanical Design Features

3.1 Pumps and valves listed in Table 2.2.7-1 will be functionally designed and qualified such that each pump and valve is capable of performing its intended function under the full range of fluid flow, differential pressure, electrical conditions, and temperature conditions up to and including design basis accident conditions.

3.2 Check valves listed in Table 2.2.7-1 will function to change position as listed in Table 2.2.7-1 under normal operating conditions.

3.3 Deleted.

3.4 Equipment identified as Seismic Category I in Table 2.2.7-1 can withstand seismic design basis loads without a loss of safety function(s).

3.5 Deleted.

3.6 Deleted.

3.7 Deleted.

3.8 Deleted.

- 3.9 Deleted.
- 3.10 Deleted.
- 3.11 Deleted.
- 3.12 Deleted.
- 3.13 Deleted.
- 3.14 Deleted.
- 3.15 ASME Code Class 1 and 2 piping systems are designed in accordance with ASME Code Section III requirements.
- 3.16 As-built ASME Code Class 1 and 2 components listed in Table 2.2.7-1 are reconciled with the design requirements.
- 3.17 Pressure-boundary welds in ASME Code Class 1 and 2 components listed in Table 2.2.7-1 meet ASME Code Section III non-destructive examination requirements.
- 3.18 ASME Code Class 1 and 2 components listed in Table 2.2.7-1 retain their pressure-boundary integrity at their design pressure.
- 3.19 ASME Code Class 1 and 2 components listed in Table 2.2.7-1 are fabricated, installed, and inspected in accordance with ASME Code Section III requirements.
- 4.0 I&C Design Features, Displays, and Controls**
- 4.1 Displays listed in Table 2.2.7-2 are indicated on the PICS operator workstations in the main control room (MCR) and the remote shutdown station (RSS).
- 4.2 Controls on the PICS operator workstations in the MCR and the RSS perform the function listed in Table 2.2.7-2.
- 4.3 Equipment listed as being controlled by a priority and actuator control system (PACS) module in Table 2.2.7-2 responds to the state requested and provides drive monitoring signals back to the PACS module. The PACS module will protect the equipment by terminating the output command upon the equipment reaching the requested state.
- 5.0 Electrical Power Design Features**
- 5.1 Equipment designated as Class 1E in Table 2.2.7-2 are powered from the Class 1E division as listed in Table 2.2.7-2 in a normal or alternate feed condition.
- 5.2 Deleted.
- 6.0 Environmental Qualifications**
- 6.1 Equipment designated as harsh environment in Table 2.2.7-2 can perform the function listed in Table 2.2.7-1 under normal environmental conditions, containment test

conditions, anticipated operational occurrences, and accident and post-accident environmental conditions.

7.0 Equipment and System Performance

7.1 The pumps listed in Table 2.2.7-1 have net positive suction head available (NPSHA) that is greater than net positive suction head required (NPSHR) at system run-out flow.

7.2 Class 1E valves listed in Table 2.2.7-2 will function to change position as listed in Table 2.2.7-1 under normal operating conditions.

7.3 The EBS has provisions to allow flow testing of each EBS pump during plant operation.

7.4 The EBS delivers water to RCS cold legs 1 and 2.

Inspections, Tests, Analyses, and Acceptance Criteria

Table 2.2.7-3 lists the EBS ITAAC.

Table 2.2.7-1—EBS Equipment Mechanical Design

Description	Tag Number⁽¹⁾	Location	ASME Code Section III	Function	Seismic Category
EBS Tank Division 1 (Division 4)	30JDH10BB001 (30JDH40BB001)	Fuel Building	Yes	Storage Volume	I
EBS Pump Division 1 (Division 4)	30JDH10AP001 (30JDH40AP001)	Fuel Building	Yes	Run	I
EBS Containment Isolation Valve Division 1 (Division 4)	30JDH10AA006 (30JDH40AA006)	Fuel Building	Yes	Open-Close	I
EBS Containment Isolation Check Valve Division 1 (Division 4)	30JDH10AA007 (30JDH40AA007)	Reactor Building	Yes	Open-Close	I
EBS RCPB Isolation Valve to RCS Cold Leg 1 Division 1	30JDH10AA015	Reactor Building	Yes	Open-Close	I
EBS RCPB Isolation Valve to RCS Cold Leg 2 Division 1	30JDH20AA015	Reactor Building	Yes	Open-Close	I
EBS RCPB Isolation Valve to RCS Cold Leg 3 Division 4	30JDH30AA015	Reactor Building	Yes	Open-Close	I
EBS RCPB Isolation Valve to RCS Cold Leg 4 Division 4	30JDH40AA015	Reactor Building	Yes	Open-Close	I
EBS Test Line Isolation Valve Division 1 (Division 4)	30JDH10AA008 (30JDH40AA008)	Fuel Building	Yes	Close	I

1. Equipment tag numbers are provided for information only and are not part of the certified design.

Table 2.2.7-2—EBS Equipment I&C and Electrical Design

Description	Tag Number ⁽¹⁾	Location	IEEE Class 1E ⁽²⁾	EQ – Harsh Env.	PACS	MCR/RSS Displays	MCR/RSS Controls
EBS Pump Division 1 (Division 4)	30JDH10AP001 (30JDH40AP001)	Fuel Building	1 ^N 2 ^A (4 ^N) (3 ^A)	Yes	Yes	On-Off / On-Off	Start-Stop / Start-Stop
EBS Containment Isolation Valve Division 1 (Division 4)	30JDH10AA006 (30JDH40AA006)	Fuel Building	1 ^N 2 ^A (4 ^N) (3 ^A)	Yes	Yes	Position / Position	Open-Close / Open-Close
EBS RCPB Isolation Valve to RCS Cold Leg 1 Division 1	30JDH10AA015	Reactor Building	1 ^N 2 ^A	Yes	Yes	Position / Position	Open-Close / Open-Close
EBS RCPB Isolation Valve to RCS Cold Leg 2 Division 1	30JDH20AA015	Reactor Building	2 ^N 1 ^A	Yes	Yes	Position / Position	Open-Close / Open-Close
EBS RCPB Isolation Valve to RCS Cold Leg 3 Division 4	30JDH30AA015	Reactor Building	3 ^N 4 ^A	Yes	Yes	Position / Position	Open-Close / Open-Close
EBS RCPB Isolation Valve to RCS Cold Leg 4 Division 4	30JDH40AA015	Reactor Building	4 ^N 3 ^A	Yes	Yes	Position / Position	Open-Close / Open-Close
EBS Test Line Isolation Valve Division 1 (Division 4)	30JDH10AA008 (30JDH40AA008)	Fuel Building	1 ^N 2 ^A (4 ^N) (3 ^A)	Yes	Yes	Position / Position	Open-Close / Open-Close

1. Equipment tag numbers are provided for information only and are not part of the certified design.

-
2. ^N denotes the division the equipment is normally powered from. ^A denotes the division the equipment is powered from when alternate feed is implemented.

**Table 2.2.7-3—Extra Borating System ITAAC
Sheet 1 of 7**

Commitment Wording		Inspections, Tests, Analyses	Acceptance Criteria
2.1	The functional arrangement of the EBS is as described in the Design Description of Section 2.2.7, Tables 2.2.7-1 and 2.2.7-2, and as shown on Figure 2.2.7-1.	An inspection of the as-built EBS functional arrangement will be performed.	The EBS conforms to the functional arrangement as described in the Design Description of Section 2.2.7, Tables 2.2.7-1 and 2.2.7-2, and as shown on Figure 2.2.7-1.
2.2	Deleted.	Deleted.	Deleted.
2.3	Physical separation exists between divisions of the EBS, except for the suction piping interconnect, located in the Fuel Building as shown on Figures 2.1.1-38 and 2.1.1-39.	An inspection will be performed to verify that the as-built divisions of the EBS, except for the suction piping interconnect, are physically separated in the Fuel Building.	The divisions of the EBS, except for the suction piping interconnect, are physically separated by a wall in the Fuel Building as shown on Figures 2.1.1-38 and 2.1.1-39.
3.1	Pumps and valves listed in Table 2.2.7-1 will be functionally designed and qualified such that each pump and valve is capable of performing its intended function under the full range of fluid flow, differential pressure, electrical conditions, and temperature conditions up to and including design basis accident conditions.	Tests or type tests of pumps and valves will be performed to demonstrate that the pumps and valves function under the full range of fluid flow, differential pressure, electrical conditions, and temperature conditions up to and including design basis accident conditions.	A report concludes that the pumps and valves listed in Table 2.2.7-1 are capable of performing their intended function under the full range of fluid flow, differential pressure, electrical conditions, and temperature conditions up to and including design basis accident conditions.
3.2	Check valves listed in Table 2.2.7-1 will function to change position as listed in Table 2.2.7-1 under normal operating conditions.	Tests will be performed to verify the ability of check valves to change position under normal operating conditions.	The check valves change position as listed in Table 2.2.7-1 under normal operating conditions.
3.3	Deleted.	Deleted.	Deleted.

**Table 2.2.7-3—Extra Borating System ITAAC
Sheet 2 of 7**

Commitment Wording		Inspections, Tests, Analyses	Acceptance Criteria
3.4	Equipment identified as Seismic Category I in Table 2.2.7-1 can withstand seismic design basis loads without a loss of safety function(s).	<ul style="list-style-type: none"> a. Type tests, analyses, or a combination of type tests and analyses will be performed on the equipment identified as Seismic Category I in Table 2.2.7-1 using analytical assumptions, or under conditions, which bound the Seismic Category I design requirements. b. An inspection will be performed of the as-built equipment identified as Seismic Category I in Table 2.2.7-1 to verify that the equipment, including anchorage, are installed in a condition bounded by the tested or analyzed condition. 	<ul style="list-style-type: none"> a. Test/analysis reports conclude that the equipment identified as Seismic Category I in Table 2.2.7-1 can withstand seismic design basis loads without a loss of safety function(s). b. Inspection reports conclude that the equipment identified as Seismic Category I in Table 2.2.7-1, including anchorage, are installed in a condition bounded by the tested or analyzed condition.
3.5	Deleted.	Deleted.	Deleted.
3.6	Deleted.	Deleted.	Deleted.
3.7	Deleted.	Deleted.	Deleted.
3.8	Deleted.	Deleted.	Deleted.
3.9	Deleted.	Deleted.	Deleted.
3.10	Deleted.	Deleted.	Deleted.
3.11	Deleted.	Deleted.	Deleted.
3.12	Deleted.	Deleted.	Deleted.
3.13	Deleted.	Deleted.	Deleted.
3.14	Deleted.	Deleted.	Deleted.

**Table 2.2.7-3—Extra Borating System ITAAC
Sheet 3 of 7**

Commitment Wording		Inspections, Tests, Analyses	Acceptance Criteria
3.15	ASME Code Class 1 and 2 piping systems are designed in accordance with ASME Code Section III requirements.	An inspection of piping design and analysis documentation required by ASME Code Section III will be performed. {{DAC}}	ASME Code Section III Design Report(s) exist that meet the requirements of NCA-3550 and conclude that the design of ASME Code Class 1 and 2 piping systems complies with the requirements of ASME Code Section III. {{DAC}}
3.16	As-built ASME Code Class 1 and 2 components listed in Table 2.2.7-1 are reconciled with the design requirements.	A reconciliation analysis of ASME Code Class 1 and 2 components will be performed.	ASME Code Design Report(s) exist that meet the requirements of NCA-3550, conclude that the design reconciliation has been completed for as-built ASME Code Class 1 and 2 components, listed in Table 2.2.7-1, and document that the results of the reconciliation analysis comply with the requirements of ASME Code Section III.
3.17	Pressure-boundary welds in ASME Code Class 1 and 2 components listed in Table 2.2.7-1 meet ASME Code Section III non-destructive examination requirements.	An inspection of the as-built pressure-boundary welds in ASME Code Class 1 and 2 components will be performed.	ASME Code reports(s) exist that conclude that ASME Code Section III requirements are met for non-destructive examination of pressure-boundary welds in ASME Code Class 1 and 2 components listed in Table 2.2.7-1.
3.18	ASME Code Class 1 and 2 components listed in Table 2.2.7-1 retain their pressure-boundary integrity at their design pressure.	A hydrostatic test will be conducted on ASME Code Class 1 and 2 components listed in Table 2.2.7-1 that are required to be hydrostatically tested by ASME Code Section III.	ASME Code Data Report(s) exist and conclude that the results of the hydrostatic test of ASME Code Class 1 and 2 components listed in Table 2.2.7-1 comply with the requirements of ASME Code Section III.

**Table 2.2.7-3—Extra Borating System ITAAC
Sheet 4 of 7**

Commitment Wording		Inspections, Tests, Analyses	Acceptance Criteria
3.19	ASME Code Class 1 and 2 components listed in Table 2.2.7-1 are fabricated, installed, and inspected in accordance with ASME Code Section III requirements.	An inspection of the as-built construction activities and documentation for ASME Code Class 1 and 2 components will be conducted.	ASME Code Data Report(s) exist that conclude that ASME Code Class 1 and 2 components listed in Table 2.2.7-1 are fabricated, installed, and inspected in accordance with ASME Code Section III requirements.
4.1	Displays listed in Table 2.2.7-2 are indicated on the PICS operator workstations in the MCR and the RSS.	<p>a. Tests will be performed to verify that the displays listed in Table 2.2.7-2 are indicated on the PICS operator workstations in the MCR.</p> <p>b. Tests will be performed to verify that the displays listed in Table 2.2.7-2 are indicated on the PICS operator workstations in the RSS.</p>	<p>a. Displays listed in Table 2.2.7-2 are indicated on the PICS operator workstations in the MCR.</p> <p>b. Displays listed in Table 2.2.7-2 are indicated on the PICS operator workstations in the RSS.</p>
4.2	Controls on the PICS operator workstations in the MCR and the RSS perform the function listed in Table 2.2.7-2.	<p>a. Tests will be performed using controls on the PICS operator workstations in the MCR.</p> <p>b. Tests will be performed using controls on the PICS operator workstations in the RSS.</p>	<p>a. Controls on the PICS operator workstations in the MCR perform the function listed in Table 2.2.7-2.</p> <p>b. Controls on the PICS operator workstations in the RSS perform the function listed in Table 2.2.7-2.</p>
4.3	Equipment listed as being controlled by a PACS module in Table 2.2.7-2 responds to the state requested and provides drive monitoring signals back to the PACS module. The PACS module will protect the equipment by terminating the output command upon the equipment reaching the requested state.	A test will be performed using test input signals to verify equipment controlled by a PACS module responds to the state requested and provides drive monitoring signals back to the PACS module.	Equipment listed as being controlled by a PACS module in Table 2.2.7-2 responds to the state requested and provides drive monitoring signals back to the PACS module. The PACS module will protect the equipment by terminating the output command upon the equipment reaching the requested state.

**Table 2.2.7-3—Extra Borating System ITAAC
Sheet 5 of 7**

Commitment Wording		Inspections, Tests, Analyses	Acceptance Criteria
5.1	Equipment designated as Class 1E in Table 2.2.7-2 are powered from the Class 1E division as listed in Table 2.2.7-2 in a normal or alternate feed condition.	<ul style="list-style-type: none"> a. Testing will be performed by providing a test input signal in each normally aligned division. b. Testing will be performed by providing a test input signal in each division with the alternate feed aligned to the divisional pair. 	<ul style="list-style-type: none"> a. The test input signal provided in the normally aligned division is present at the respective Class 1E equipment identified in Table 2.2.7-2. b. The test input signal provided in each division with the alternate feed aligned to the divisional pair is present at the respective Class 1E equipment identified in Table 2.2.7-2.
5.2	Deleted.	Deleted.	Deleted.

**Table 2.2.7-3—Extra Borating System ITAAC
Sheet 6 of 7**

Commitment Wording		Inspections, Tests, Analyses	Acceptance Criteria
6.1	Equipment designated as harsh environment in Table 2.2.7-2 can perform the function listed in Table 2.2.7-1 under normal environmental conditions, containment test conditions, anticipated operational occurrences, and accident and post-accident environmental conditions.	<p>a. Type tests or type tests and analysis will be performed to demonstrate the ability of the equipment designated as harsh environment in Table 2.2.7-2 to perform the function listed in Table 2.2.7-1 under normal environmental conditions, containment test conditions, anticipated operational occurrences, and accident and post-accident environmental conditions.</p> <p>b. An inspection will be performed of the as-built equipment designated as harsh environment in Table 2.2.7-2 to verify that the equipment, including the associated cables, wiring, and terminations located in a harsh environment, are bounded by the type test or combination of type tests and analyses.</p>	<p>a. EQDPs conclude that the equipment designated as harsh environment in Table 2.2.7-2 can perform the function listed in Table 2.2.7-1 under normal environmental conditions, containment test conditions, anticipated operational occurrences, and accident and post-accident environmental conditions, including the time required to perform the listed function.</p> <p>b. A report exists and concludes that the equipment designated as harsh environment in Table 2.2.7-2, including the associated cables, wiring, and terminations located in a harsh environment, are bounded by the type test or combination of type tests and analyses.</p>
7.1	The pumps listed in Table 2.2.7-1 have NPSHA that is greater than NPSHR at system run-out flow.	Tests and analyses will be performed to verify pump NPSHA is greater than NPSHR at system run-out flow.	The pumps listed in Table 2.2.7-1 have NPSHA that is greater than NPSHR at system run-out flow.
7.2	Class 1E valves listed in Table 2.2.7-2 will function to change position as listed in Table 2.2.7-1 under normal operating conditions.	Tests will be performed to verify the ability of Class 1E valves to change position under normal operating conditions.	Class 1E valves listed in Table 2.2.7-2 change position as listed in Table 2.2.7-1 under normal operating conditions.
7.3	The EBS has provisions to allow flow testing of each EBS pump during plant operation.	Tests will be performed to verify EBS has provisions to allow flow testing of each EBS pump during plant operation.	The EBS pump flow test line recirculates a minimum of 49 gpm back to the EBS tank.

Table 2.2.7-3—Extra Borating System ITAAC
Sheet 7 of 7

	Commitment Wording	Inspections, Tests, Analyses	Acceptance Criteria
7.4	The EBS delivers water to RCS cold legs 1 and 2.	Tests will be performed to verify the EBS delivers water to RCS cold legs 1 and 2.	Each EBS pump delivers a minimum flow of 52 gpm to RCS cold legs 1 and 2.