

### 10.4.3 Turbine Gland Sealing System

The turbine gland sealing system (TGSS) prevents the escape of steam from the turbine shaft and casing penetrations and the glands of main steam stop and control valves. This system also prevents air leakage into the low pressure turbine glands.

#### 10.4.3.1 Design Bases

The TGSS performs no safety-related function and therefore has no nuclear safety-related design basis.

The TGSS is designed to meet the following functional criteria:

- Prevent atmospheric air leakage into the turbine casings and minimize steam leakage from the casings of the high-pressure (HP) and low-pressure (LP) turbines.
- Collect leak-off steam from the glands of large turbine valves in the leak-off steam piping.
- Return condensed steam to the condenser and exhaust noncondensable gases to the vent system of the main condenser evacuation system.
- Provide flow to and from all HP and LP turbine glands, assuming 1.5 to 2 times the normal gland clearances and the maximum allowable steam seal supply pressure.

#### 10.4.3.2 System Description

Figure 10.4.3-1 shows a flow diagram of the TGSS.

##### 10.4.3.2.1 General Description

During normal turbine operation, steam passing through the HP turbine shaft seals is throttled until it is only slightly above atmospheric pressure. It is then discharged from the inner steam space into a sealing steam header, which is common to the shaft seals of the turbine. The LP turbine shaft seals, which are under vacuum, are supplied with sealing steam from this header to prevent ingress of air.

A second steam space for gland steam is located between the inner steam space of the HP and LP turbine shaft seals and the atmosphere, which prevents the escape of seal steam to the atmosphere. The gland steam and any air entering this steam space through the shaft seals are normally drawn off by one of two exhaust fans via the condensate-cooled gland steam condenser.

The gland steam condenser is part of the condensate system that passes condensate through the tubing. Condensate produced by the gland steam condenser is routed to the condenser through a steam trap.

The steam side of the condenser can be bypassed in the event of gland steam condenser failure. Any condensate produced is passed to the Turbine Building drains system via a loop line upstream of the gland steam condenser isolation valve. This line also drains condensate that accumulates in the event of a tube leak in the gland steam condenser.

#### **10.4.3.2.2 Component Description**

Table 3.2.2-1 provides the seismic design and other design classifications for components in the TGSS. Section 3.2 describes how the guidance of RG 1.26 is implemented for the U.S. EPR.

##### **Condenser**

The gland steam condenser receives steam and noncondensable gases from the TGSS and condenses the steam. The gland steam condenser is integrated into the condensate system with condensate passing through the tubing. The drains from the gland steam condenser discharge to the main condenser over a drip leg and through a steam trap.

##### **Exhausters**

The gland steam exhausters produce a slight vacuum in the gland steam condenser to remove air and noncondensable gases that carry over into the gland steam condenser with the leak-off steam from the shaft glands.

Steam and noncondensable gases from the gland steam exhausters are routed to the nuclear auxiliary building ventilation system.

##### **Piping**

The TGSS piping provides steam for sealing the shafts of the HP and LP turbines. The system piping supplies the sealing steam from the HP turbine to the shaft seals of the HP and LP turbines and onto the gland steam condenser.

#### **10.4.3.2.3 System Operation**

##### **Plant Startup and Shutdown**

During startup and shutdown, and in the low-load power range, steam from the auxiliary steam system is supplied to the TGSS through the seal steam supply valves as required to maintain the gland steam header pressure. The motor-operated isolation valve fails as is. The pneumatically actuated pressure control valve fails to the position designated by the turbine supplier.

##### **Normal Operation**

During normal operation, enough steam escapes through the HP turbine shaft seals that it can be used as a seal steam supply for the shaft seals of the LP turbines. The

excess steam escaping at higher loads is dumped to the main condenser through the seal steam leak-off valve. Leak-off steam from the seals of the main stop and control valves is also discharged into the TGSS header. The steam seal leak-off valve is a pneumatically actuated pressure control valve, which fails to the position designated by the turbine supplier.

#### **10.4.3.3 Safety Evaluation**

The TGSS performs no safety-related functions and is not required to operate during or after an accident. The design of the TGSS satisfies general design criteria GDC 60 and GDC 64, related to the TGSS design for control and monitoring of release of radioactive materials.

The air and noncondensable gases discharged from the gland steam exhausters are not normally radioactive during plant operation. However, in the event of significant primary-to-secondary system leakage due to a steam generator tube rupture, it is possible for the seal steam to become contaminated resulting in the potential to discharge a radioactively contaminated mixture.

The gland steam condenser receives steam and noncondensable gases from the TGSS and condenses the steam. Air and non-condensable gases are evacuated from the gland steam condenser and discharged into the air vent system by exhaust fans. The exhaust flow is monitored for radioactivity as described in Section 11.5.4 (refer to Table 11.5-1, Monitor R-3) and discharged to the Nuclear Auxiliary Building ventilation system.

#### **10.4.3.4 Inspection and Testing Requirements**

The TGSS components are inspected during construction and functionally tested during plant startup. Refer to Section 14.2 (test abstract #064) for initial plant startup test program. Components of the TGSS are designed to permit periodic inspection and testing during plant operation. Components of the system are monitored during operation to demonstrate satisfactory functioning of TGSS equipment.

#### **10.4.3.5 Instrumentation Requirements**

The following TGSS parameters are monitored during plant operation:

- Steam seal header temperature.
- Steam seal header pressure.
- Gland steam exhauster vacuum.
- Gland condenser outlet temperature.
- Gland condenser pressure.

[Next File](#)