



GPU Nuclear Corporation  
 Post Office Box 388  
 Route 9 South  
 Forked River, New Jersey 08731-0388  
 609 971-4000  
 Writer's Direct Dial Number:

C3212011

November 15, 1990

U.S. Nuclear Regulatory Commission  
 Attn: Document Control Desk  
 Washington, DC 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station  
 Docket No. 50-219  
 Correction to Semiannual Effluent Release Report

Attached is a revised page for the 1990-1 Semiannual Effluent Release Report which GPUN submitted on August 29, 1990 in accordance with 10 CFR 50.36a(a)(2). Corrections have been made to the exposure data reported in Figure 2 on page 11.

If you have any questions, please do not hesitate to contact Michael Heller, Oyster Creek Licensing Engineer at 609-971-4680.

Very truly yours,

E.S. Fitzpatrick  
 Vice President and Director  
 Oyster Creek

EEF/MH/jc  
 Attachment

cc: Chief  
 Bureau of Nuclear Engineering  
 NJ Department of Environmental Protection  
 CN 411  
 Trenton, New Jersey 08623

Mr. Thomas Martin, Administrator  
 Region 1  
 U.S. Nuclear Regulatory Commission  
 475 Allendale Road  
 King of Prussia, PA 19406

NRC Resident Inspector  
 Oyster Creek

9011290079 901115  
 PDR ADOCK 05000219  
 R PDC

Figure 1




Figure 2

Maximum Offsite Exposure Due to Radionuclides in Radioactive Effluents January to June, 1990							
Tech Spec Ref.	3.6.J.1	3.6.J.1	3.6.L.1	3.6.L.1	3.6.K.1	3.6.M.2	3.6.K.1
	Liquid Dose		Air Dose (Noble Gas)		Whole	(Thyroid)	Skin
	WB	Organ	Beta	Gamma	Body	Organ	
	mrem	mrem	mrad	mrad	mrem	mrem	mrem
Jan-June Total	2.13E-05	3.34E-05	1.27E-03	1.07E-02	4.93E-03	3.05E-02	5.93E-03
Tech Spec Limit	3.00E+00	1.00E+01	2.00E+01	1.00E+01	5.00E+02	1.50E+01	3.00E+03
Fraction of Annual Limit	7.10E-06	3.34E-06	6.35E-05	1.07E-03	9.86E-06	2.03E-03	1.98E-06