

SEISMIC MARGIN EVALUATION


FOR TYPICAL RCS COMPONENTS

8008130434 .


SCE - UNIT #2 AND #3 :-

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS :-

VERTICAL COLUMN CLEVIS :-




MATERIAL - SA401 GR $\left\{ \begin{array}{l} \text{CAGNM} \\ \text{CENPS.} \end{array} \right.$



∴ GEOMETRY OF CLEVIS :-

LOADS :- (REF: R.C.S.S. DESIGN LOADS - CE DWG: E-1310-320-04 REV3 SHEET 1)
THE DESIGN LOADS TABULATED BELOW ARE THE MAXIMUM AXIAL FORCES ON THE COLUMNS.

PUMP NO 1A



COLUMN	FORCES IN KIPS			
	*NORMAL & UPSET CONDITION		FAULTED CONDITION	
	TENSION	COMPRESSION	TENSION	COMPRESSION
R _i	356	412	1431	1363

*NORMAL OPERATING LOAD
= -146 KIPS.

SCE - UNIT #2 AND #3 :-

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS :-

VERTICAL COLUMN CLEVIS - DETAILED ANALYSIS :-

CLEVIS MATERIAL : SA 487 GR CENPS OR CAGNM

NORMAL OPERATING TEMPERATURE : 130°F

(REF: (R.C.P. SUPPORT COLS. SPEC. FOR SANONFORE UNIT #2 AND #3
SPEC. NO. 1270-PE-513 REV. 1)

MATERIAL PROPERTIES :-

(REF: ASME SECT. III, 1974 ED, INCLUDING WINTER 1974 ADDENDUM)

$$S_m = 36.7 \text{ KSI}$$

$$S_y = 80.0 \text{ KSI}$$

$$S_u = 110.0 \text{ KSI}$$

STRESS ALLOWABLES FOR FAULTED CONDITION :-

(REF: ASME SECT. III, SECT. F1323.1 OF SUBSECT. NA)
(1974ED)

$$\text{PRIMARY MEMBRANE STRESS INTENSITY} = 0.7 S_u = 77.0 \text{ KSI}$$

$$\text{PRIMARY MEMBRANE PLUS PRIMARY BENDING STRESS INTENSITY} = 1.5 (0.7 S_u) = 115.5 \text{ KSI}$$

$$\text{PURE SHEAR STRESS} = 0.6 (0.7 S_u) = 46.2 \text{ KSI}$$

SCE - UNIT #2 AND #3:

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS:

VERTICAL COLUMN CLEVIS - DETAILED ANALYSIS - CONT'D.:


$r = 2.125''$

$R = 6.5''$

THICKNESS = 3.625''

$L = 9.25''$

LOAD = 1431K (TENSION)
(REF: PG. 1)



TENSION - NET SECTION A-A

AVERAGE SHEAR-SECTION B-B.

$AREA = (6.5'' - 2.125'') (3.625'') = 15.86 IN^2$

LOAD (N.O.P + SSE + LOCA) = $\frac{1431}{2} K = 715.5 K / SIDE$

$\sigma_A = \frac{P}{A} = \frac{715.5}{2(15.86)} = 22.6 KSI < 77.0 KSI$
O.K.

LENGTH B-B = $x' - x$

$\cos 40^\circ = \frac{x}{r} = \frac{x}{2.125} ; x = 1.63''$

$\sin 40^\circ = \frac{y}{r} = \frac{y}{2.125} ; y = 1.37''$

$\sin \theta = \frac{1.37}{6.5} ; \theta = 12.17^\circ$

$\cos 12.17^\circ = \frac{x'}{R} = \frac{x'}{6.5} ; x' = 6.35''$

LENGTH B-B = $6.35'' - 1.63'' = 4.72''$

AREA = $4.72 (3.625) = 17.1 IN^2$

$\tau_B = \frac{P}{A} = \frac{715.5}{2(17.1)} = 20.9 KSI < 46 KSI$
O.K.

SCE - UNIT #2 AND #3 :-

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS :-

VERTICAL COLUMN CLEVIS - DETAILED ANALYSIS - CONT'D :-

σ_u = UNSYMMETRICAL STRESS @ SECT. A-A

$$AREA @ A-A = 3.625(13) = 47.125 IN^2$$


$$I_{A-A} = M.O.I @ A-A$$

$$= \frac{13(3.625)^2}{12} = 51.6 IN^4$$



$$\sigma_u = \frac{P}{A} + \frac{Pe_u t_2/2}{I_{AA}}$$

$$e_u = \frac{3.625}{2} - \frac{1.7}{2} = 0.9625''$$

$$\sigma_u = \frac{1431}{2(47.125)} + \frac{1431(3.625/2)(.963)}{2(51.6)} = 39.4 KSI$$



COLUMN MISALIGNMENT STRESS CALCULATION :-



SCE - UNIT # 2 AND # 3

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS

VERTICAL COLUMN CLEVIS - DETAILED ANALYSIS - CONT'D

$$P_x = \text{LOAD IN X-DIRECTION} = 1431 (\sin 3^\circ) = 75 \text{ KIPS.}$$

$$P_z = \text{LOAD IN Z-DIRECTION} = 1431 (\sin 6.5^\circ) = 162 \text{ KIPS.}$$

$$M_z = 162 (9.25) = 1498.5 \text{ K-IN.}$$

$$M_x = 75 (9.25) = 693.8 \text{ K-IN.}$$

$$I_x = 13 (3.625)^3 / 12 = 51.6 \text{ IN}^4.$$



$$I_z = 3.625 (13)^3 / 12 = 663.7 \text{ IN}^4.$$

σ_1 = BENDING STRESS DUE TO P_x @ A-A

σ_2 = BENDING STRESS DUE TO P_z @ A-A

$$\sigma_1 = \frac{M_x C}{I_x} = \frac{693.8 (1.81)}{51.6} = 24.4 \text{ KSI.}$$

$$\sigma_2 = \frac{M_z C}{I_z} = \frac{1498.5 (6.5)}{2 (663.7)} = 7.4 \text{ KSI}$$



COMBINING ALL THE STRESSES @ SECT-A-A

$$\sigma_U = 39.4 \text{ KSI} \begin{cases} 15.2 \text{ KSI AXIAL} \\ 24.2 \text{ KSI BENDING} \end{cases}$$

$$\sigma_{A-A} = 39.4 + 24.4 + 7.4$$


$$= 71.2 \text{ KSI} < 115.5 \text{ KSI} \text{ (OK)}$$

SCE - UNIT # 2 AND # 3 :-

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS :-

VERTICAL COLUMN CLEVIS - DETAILED ANALYSIS - CONT'D :-

PLATFORM ANALYSIS :-



ASSUME FIXED-FIXED ABOUT ϕ OF BOLTS.

THIS FIXED BOUNDARY CONDITION FOR A BEAM IS A CONSERVATIVE APPROACH BECAUSE IT DOES NOT CONSIDER THE STIFFNESS OF THE LUGS AND CLOSELY REPRESENTS THE ACTUAL RESTRAINED CONDITIONS.

$$I_{BB} = \frac{b h^3}{12} = \frac{[22 - 2(3.125)] 4^3}{12} = 84 \text{ IN}^4$$

$$M = PL/8 = \frac{1431(22)}{8} = 3935.3 \text{ K-IN.}$$

$$\sigma_{AA} < \sigma_{BB} \text{ SINCE } I_{AA} > I_{BB}$$

σ_{B-B} = BENDING STRESS AT FAULTED CONDITION

$$\sigma_{B-B} = \frac{3935.3(2)}{84} = 93.7 \text{ KSI} < 115.5 \text{ KSI}$$

SCE - UNIT #2 AND #3:

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS:

VERTICAL COLUMN CLEVIS - FAULTED LOAD CAPACITY EVALUATION:

FROM THE RESULTS OF VERTICAL COL. CLEVIS ANALYSIS IT IS SEEN THAT THE CLEVIS DESIGN IS CONTROLLED BY THE BENDING STRESS OF CLEVIS PLATFORM @ SECT. B-B DUE TO THE TENSILE LOAD P (1431K) (REF. PG. 6).

HENCE PLATFORM BENDING STRESS EQUATION IS USED TO FIND THE FAULTED CAPACITY OF VERTICAL COLUMN CLEVIS, AS FOLLOWS.

$$\text{FAULTED CAPACITY} = F_{CAP.} = \frac{115.5(8)(84)}{44}$$

$$F_{CAP.} = 1765 \text{ KIPS}$$

THE N.O.P. LOAD = 146 KIPS (REF. PG. 1)

$$\therefore \text{ALLOWABLE SSE LOAD} = F_{CAP} - \text{N.O.P}$$

$$= 1765 - 146$$


$$\text{ALLOWABLE SSE LOAD} = 1619 \text{ KIPS}$$

SCE - UNIT # 2 AND # 3:-

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS:-

VERTICAL COLUMN:-

(REF: CE DRAWING. D-1370-320-056 REV.5)



GEOMETRY OF VERTICAL COLUMN:-

LOADS:- (REF: PG. 1, VERTICAL COL. CLEVIS CAL)

COLUMN	FORCES IN KIPS			
	*NORMAL AND UPSET CONDITION		FAULTED CONDITION	
	TENSION	COMPRESSION	TENSION	COMPRESSION
R _i	356	412	1431	1363

* NORMAL OPERATING LOAD = -146 KIPS.

SCE - UNIT # 2 AND # 3 :-

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS :-

VERTICAL COLUMN - DETAILED ANALYSIS :-

COLUMN MATERIAL: SA 540 CL 4 GR B 23 OR B 24 -

NORMAL OPERATING TEMPERATURE: 130°F.

(REF: R.C.P. SUPPORT COLS FOR SAN ONFORE UNITS 2 AND 3
SPEC. NO. 1370-PE-513 REV. 01)
MATERIAL PROPERTIES :-

REF: ASME SECT. III, 1974 ED, INCLUDING WINTER 1974 ADDENDA

$$S_m = 39.0 \text{ KSI}$$

$$S_y = 120.0 \text{ KSI}$$

$$S_u = 135.0 \text{ KSI}$$

STRESS ALLOWABLES FOR FAULTED CONDITION :-

(REF: ASME SECT. III, 1974, SECT. F.1323.1 OF SUBSECT. NA)

$$\text{PRIMARY MEMBRANE STRESS INTENSITY} = 0.7 S_u = 94.5 \text{ KSI}$$


$$\text{PRIMARY MEMBRANE PLUS PRIMARY BENDING STRESS INTENSITY} = 1.5 (0.7 S_u) = 141.8 \text{ KSI}$$

$$\text{PURE SHEAR STRESS} = 0.6 (7 S_u) = 56.7 \text{ KSI}$$

SCE - UNIT # 2 AND # 3 :-

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS :-

VERTICAL COLUMN - DETAILED ANALYSIS :-



TENSILE STRESS @ SECT. A-A :-

$$\sigma_{A-A} = \frac{P}{A} = \frac{1431}{(13 - 6.622)3.25}$$

$$\sigma_{A-A} = 68.4 \text{ KSI} < 94.5 \text{ KSI}$$

∴ OK

SHEAR STRESS @ SECT. B-B :-

$$\cos 40^\circ = \frac{x}{r} = \frac{x}{3.311}; x = 2.537''$$

$$\sin 40^\circ = \frac{y}{r} = \frac{y}{3.311}; y = 2.13''$$

$$\sin \theta = \frac{2.13}{8.5} = 0.25; \theta = 14.5^\circ$$


$$\cos 14.5^\circ = \frac{x'}{R} = \frac{x'}{8.5}; x' = 8.23''$$

$$\text{LENGTH B-B} = x' - x = 8.23 - 2.13 = 6.1''$$

$$\tau_{B-B} = \frac{P}{A} = \frac{1431}{(6.1)(3.25)2 - 2(\frac{3}{4})}$$

$$\tau_{B-B} = 40.3 \text{ KSI} < 56.7 \text{ KSI}$$

∴ OK.



SCE - UNIT #2 AND #3:-

SEISMIC EVALUATION - PUMP SUPPORTS:-

VERTICAL COLUMN - DETAILED ANALYSIS - CONTD:-

BUCKLING ANALYSIS OF VERTICAL COLUMNS UNDER AXIAL LOAD: (REF: ASME SECT. III 1974 ED, APP. XVII)

AXIAL LOAD = 1363 KIPS.

$$\text{ALLOWABLE AXIAL STRESS: } F_a = \frac{\left[1 - \left(\frac{kl}{r}\right)^2 / 2c_c^2\right] S_y}{\frac{5}{3} + \frac{3}{8} \frac{kl}{r} - \frac{(kl/r)^3}{c_c^3}}$$

$$l = 69.75'; \quad I_{xx} = I_{zz} = \pi \frac{9^4}{64} = 322.06 \text{ IN}^4.$$

$$A = \pi \frac{9^2}{4} = 63.62 \text{ IN}^2, \quad r = 2.25'', \quad \frac{kl}{r} = \frac{69.75}{2.25} = 31.0$$

$$c_c = \sqrt{\frac{2\pi^2 E}{S_y}} = \sqrt{\frac{2\pi^2 \times 30 \times 10^3}{100}} = 76.95 < \frac{kl}{r}$$

FOR FAULTED LOAD CASE F_a SHALL BE EQUAL TO OR LESS THAN $\frac{2}{3}$ BUCKLING STRESS (REF: ASME SECT. III, APP. F)

$$\text{BUCKLING STRESS} = \left[1 - \left(\frac{kl}{r}\right)^2 / 2c_c^2\right] S_y$$

$$= \left[1 - \left(\frac{31}{76.95}\right)^2 / 2\right] 100 = 91.89 \text{ KSI}$$

$$\therefore F_a = \frac{2}{3} (91.89) = 61.56 \text{ KSI}$$

$$\text{AXIAL STRESS } f_a = \frac{1363}{63.62} = 21.42 \text{ KSI} < 61.56 \text{ KSI} \text{ (OK)}$$

SCE - UNIT # 2 AND # 3 :-

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS:-

VERTICAL COLUMN - FAULTED LOAD CAPACITY EVALUATION:-

FROM THE RESULTS OF VERTICAL COL. ANALYSIS IT IS SEEN THAT THE COLUMN DESIGN IS CONTROLLED BY THE TENSILE STRESS @ SECT: A-A AND SHEAR STRESS @ SECT. B-B DUE TO TENSILE LOAD P (1431K) (REF: PG. 10).

HENCE THE FAULTED LOAD CAPACITY OF VERTICAL COLUMN IS DETERMINED USING EITHER EQ. FOR TENSILE STRESS @ SECT. A-A OR SHEAR STRESS @ SECT. B-B, WHICHEVER GIVES THE LEAST FAULTED LOAD CAPACITY OF COLUMN.

FAULTED LOAD CAPACITY USING SHEAR STRESS EQUATION:-

$$\begin{aligned} \text{FAULTED CAPACITY} = F_{CAP.} &= 56.7 [(6.1)3.28(2) - 2(.75)(3)] \\ F_{CAP.} &= 2014. \text{ KIPS.} \end{aligned} \quad (\text{REF: PG. 10})$$

FAULTED LOAD CAPACITY USING TENSILE STRESS EQUATION:-

$$\begin{aligned} \text{FAULTED CAPACITY} = F_{CAP.} &= 94.5 [(13 - 6.622)3.28] \\ &= 1977. \text{ KIPS.} \end{aligned}$$

$$\boxed{\therefore \text{FAULTED LOAD CAPACITY} = 1977. \text{ KIPS}}$$

$$\begin{aligned} \text{ALLOWABLE SSE LOAD} \} &= F_{CAP.} - \text{N.O.P.} \\ &= 1977 - 146 = 1831 \text{K} \end{aligned}$$


$$\boxed{\text{ALLOWABLE SSE LOAD} = 1831. \text{ KIPS.}}$$

SCE - UNIT #2 AND #3:-

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS:-

VERTICAL COLUMN PIN:-

(REF: DWG: D-1310-320-053)



GEOMETRY OF PIN

LOADS:- (REF: PG.1)

COLUMN	FORCES IN KIPS			
	*NORMAL AND UPSET CONDITION		FAULTED CONDITION	
	TENSION	COMPRESSION	TENSION	COMPRESSION
R _i	356	412	1431	1363

* NORMAL OPERATING LOAD = -146 KIPS

SCE - UNIT # 2 AND # 3 :-

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS :-

VERTICAL COLUMN PIN - DETAILED ANALYSIS :-

PIN MATERIAL :- SA540 CL1.

NORMAL OPERATING TEMPERATURE : 130°F.

(REF: R.C.P. SUPPORT COLS IN ON FIRE UNITS 2 AND 3, SPEC. # 1570-PE-513
REV. 01)

MATERIAL PROPERTIES :-

(REF: ASME SECT. III 1974, EDITION INCLUDING WINTER 1974 ADDENDA)

$$S_m = 39.0 \text{ KSI}$$

$$S_y = 120.0 \text{ KSI}$$

$$S_u = 135.0 \text{ KSI}$$

STRESS ALLOWABLES FOR FAULTED CONDITION :-

(REF: ASME SECT III 1974, SECT. F.1323.1, OF SUBSECT. NA)

$$\text{PRIMARY MEMBRANE STRESS INTENSITY} = 0.7 S_u = 115.5 \text{ KSI.}$$

$$\text{PRIMARY MEMBRANE PLUS PRIMARY BENDING STRESS INTENSITY} = 1.5 (0.7 S_u) = 113.3 \text{ KSI.}$$

$$\text{PURE SHEAR STRESS} = (0.7 S_u) 0.6 = 0.42 S_u = 69.3 \text{ KSI}$$


SCE - UNIT # 2 AND # 3:-

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS:-

VERTICAL COLUMN PIN - DETAILED ANALYSIS - CONT'D:-

PIN STRESSES:-

THE PIN STRESSES ARE CALCULATED FROM PIN GEOMETRY AND LINE LOADING DISTRIBUTION SHOWN BELOW.




THIS BEARING STRESS DISTRIBUTION ON CLEVIS LUG/PIN CONTACT AREA IS BASED ON FINITE ELEMENT ANALYSIS PERFORMED ON CLEVIS LUG/PIN INTERFACE.

SCE - UNIT 2 AND 3:

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS:

VERTICAL COLUMN PIN - DETAILED ANALYSIS - CONT'D:



THE FOLLOWING ARE THE VALUES FOR VERTICAL COL. PIN.

$$T_1 = 1.1", T_2 = 3.716"$$

$$T_3 = 3.734", G = 12.270"$$

$$D = 4.246", A = \frac{\pi D^3}{4} = 14.111"$$

$$e = 4/9(1.1) = 0.756"$$

SECTION MODULUS
 $S = \frac{\pi D^3}{32} = 7.515 \text{ IN}^3$

MAX. FORCE ON PIN CONNECTION = 1431 KIPS

MAX. BENDING STRESS IN PIN IN INCH-KIPS:

$$= \left[\frac{1431}{2} \left[0.756 + \frac{3.734}{2} \right] - \left(\frac{1431}{3.716} \right) \frac{(3.716)^2}{8} \right] \div 7.515$$

$$= 161.18 \text{ KSI} < 173.3 \text{ KSI}$$

MAX. AVG. SHEAR STRESS IN KSI = $\frac{1431}{2(14.11)} = 50.5 \text{ KSI}$
 $< 69.3 \text{ KSI}$

MAX. MEMBRANE STRESS INTENSITY IN KSI = $2(50.5)$
 $= 101.0 \text{ KSI} < 115.5 \text{ KSI}$

SCE - UNIT #2 AND #3:-

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS:-

VERTICAL COLUMN PIN-FAULTED LOAD CAPACITY EVALUATION:-

FROM THE RESULTS OF VERTICAL COLUMN PIN ANALYSIS IT IS SEEN THAT THE COLUMN PIN DESIGN IS CONTROLLED BY THE BENDING STRESS IN PIN DUE TO TENSILE LOAD P(1431K) (REF: PG:16).

HENCE THE FAULTED LOAD CAPACITY OF VERTICAL COLUMN PIN IS DETERMINED BY USING MAXIMUM BENDING STRESS EQUATION TO EVALUATE THE FAULTED LOAD CAPACITY.

FAULTED LOAD CAPACITY:- (REF: PG. 16)
($F_{CAP.}$)

$$173.3 = \frac{F_{CAP.} \left[0.756 + \frac{3.734}{2} \right] - \frac{F_{CAP.}}{3.716} \left[\frac{(3.716)^2}{8} \right]}{7.515}$$

$$F_{CAP} [1.3115 - 0.4645] = 173.3 (7.515)$$

$$F_{CAP.} = \frac{173.3 (7.515)}{0.847} = 1537 \text{ KIPS}$$

$$\boxed{\text{FAULTED LOAD CAPACITY} = 1537 \text{ KIPS}}$$

$$\begin{aligned} \text{ALLOWABLE SSE LOAD} \} &= F_{CAP.} - N.O.P \\ &= 1537 - 146 = 1391 \text{ K} \end{aligned}$$


$$\boxed{\text{ALLOWABLE SSE LOAD} = 1391 \text{ KIPS}}$$

SCE - UNIT #2 AND #3 :-

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS :-

VERTICAL COLUMN BEARING :-

REF: 1) CE DRAWING
71278-229-001 REV.2



GEOMETRY - SPHERICAL BEARING

LOADS :- (REF: PG.1)

COLUMN	FORCES IN KIPS			
	*NORMAL AND UPSET CONDITION		FAULTED CONDITION	
	TENSION	COMPRESSION	TENSION	COMPRESSION
R _i	356	412	1431	1363

* NORMAL OPERATING LOAD = -146. KIPS.

SSE - UNIT # 2 AND # 3 :-

SEISMIC MARGIN EVALUATION - PUMP SUPPORTS :-

VERTICAL COLUMN BEARING - FAULTED LOAD CAPACITY EVALUATION :-

THE BEARING IS ASSUMED CONSERVATIVELY TO BE STRESSED TO THE MAXIMUM ALLOWABLE DUE TO TENSILE LOAD P (1431K).

HENCE THE FAULTED LOAD CAPACITY OF BEARING IS EQUAL TO LOAD P.

$$\therefore \text{FAULTED LOAD CAPACITY} = 1431 \text{ KIPS.} \\ (\text{F}_{\text{CAP.}})$$

$$\text{ALLOWABLE SSE LOAD } \left. \begin{array}{l} \\ \end{array} \right\} = \text{F}_{\text{CAP.}} - \text{N.O.P.} \\ = 1431 - 146 = 1285 \cdot \text{K}$$

$$\text{ALLOWABLE SSE CAPACITY} = 1285 \text{ KIPS.}$$

STEAM GENERATOR LEVER

ALLOWABLE STRESSES - ASME BOILER AND PRESSURE VESSEL CODE SECTION III 1977 ED.

SHEAR $F_v = 0.4F_y (1.5)$
 $= 33.54 \text{ KSI}$

TENSION $F_t = .6(F_y)(1.88) = 63 \text{ KSI}$

BENDING - STRONG $F_{bs} = .6(F_y)(1.88) = 63$

BENDING WEAK $F_{bw} = .75(F_y)(1.88) = 70.8$

NORMAL ALLOWABLE INCREASE FOR FAULTED CONDITIONS:

$$F_r = 1.2 \left(\frac{S_y}{F_t} \right) \leq .7 \left(\frac{S_u}{F_b} \right)$$

$$= 1.2 \left(\frac{55.9}{.6(55.9)} \right) \leq .7 \left(\frac{90}{(55.9)(.6)} \right)$$

$$= 2 \leq 1.88$$

LIMIT $F_r = 1.5$ FOR $F_y \leq .42 S_u$


DETAILED ANALYSIS BASED ON FAULTED LOADS

SHEAR AT SECTION A-A

$$L = 17 - 5 \left(\frac{1}{19} \right) = 15.16 \text{ IN}$$

$$A = 2 \left[15.16 - \frac{8.626}{2} \right] 6 = 130.2 \text{ IN}^2$$

$$f_v = \frac{1913}{130.2} = 14.7 \text{ KSI} \leq 33.54$$




SHEAR AT SECTION B-B

$$L = 43 - 17 - 15 = 11 \text{ IN}$$

$$A = 2 \left[11 - \frac{8.626}{2} \right] 6 = 80.24 \text{ IN}^2$$

$$f_v = \frac{2334}{80.24} = 29.1 \text{ KSI} \leq 33.54$$



STEAM GENERATOR LEVER

DETAIL ANALYSIS

SHEAR BETWEEN BEARING AND BUSHING HOLE

$$A = 15(6) = 90 \text{ IN}^2$$




$$f_v = \frac{1913}{90} = 21.3 \text{ KSI} \leq 33.54$$

BENDING OF LEVER

STRESS AT SECTION E-E

PROPERTIES:

SECTION	A	x A
1	27.69(6) = 166.1	166.1(3.8) = 2292
2	(6.69)(6) = 40.1	40.1(39.66) = 1590
Σ	206.2	3882



$$N.A. \bar{x} = 3882 / 206.2 = 18.83$$

$$I = \frac{1}{12}(6)(27.69)^3 + [166.1](4.99)^2 + \frac{1}{12}(6)(6.69)^3 + 40.1(20.8)^2 = 32,292 \text{ IN}^4$$

$$S_{MIN} = 32,292 / 24.17 = 1336 \text{ IN}^3$$

$$f_{b_{MAX}} = \frac{1754.2(12)}{1336} = 15.76 \text{ KSI} \leq 63$$

STRESS AT SECTION C-C

$$I = \frac{1}{12}(6)(14)^3 = 1372 \text{ IN}^4 ; S = 1372 / 7 = 196 \text{ IN}^3$$

$$f_b = \frac{368.4(12)}{196} = 22.6 \text{ KSI} \leq 63$$

STEAM GENERATOR LEVER

STRESS AT SECTION D-D

$$P = 421/2 = 210.5 \text{ K} \quad M = 3.625(210.5) = 763.1 \text{ IN-K}$$

$$A = 21(3\frac{1}{2}) = 73.5 \text{ IN}^2$$

$$I = \frac{1}{12}(21)(3\frac{1}{2})^3 = 75 \text{ IN}^4 \quad S = 75/1.75 = 42.9 \text{ IN}^3$$

$$f_v = \frac{210.5}{73.5} = 2.86 \text{ KSI} \leq 33.54$$

$$f_b = \frac{763.1}{42.9} = 17.8 \text{ KSI} \leq 78.8 \text{ KSI}$$

FAULTED CAPACITY


THE MOST CRITICAL SECTION IS SHEAR AT SECTION A-A

$$F_L = 2334 \left(\frac{33.54}{29.1} \right) = 2690 \text{ K FAULTED CAPACITY}$$

SEISMIC MARGIN

$$\frac{F_L - \text{N.O.P}}{\text{DBE}} = \frac{2690}{689} = 3.90$$


REACTOR VESSEL COLUMN



MATERIAL: SA533-GRB-CL1

	100°F	600°F
F _y , KSI	50	42
S _U , KSI	80	80
E, KSI	29800	27,400


COLUMN X-SECTION PROPERTIES



$A = 330 \text{ IN}^2$
 $I_a = 24750 \text{ IN}^4, S_A = 1650 \text{ IN}^3$
 $I_c = 3327.5 \text{ IN}^4, S_c = 605 \text{ IN}^3$
 $r_a = 8.660 \text{ IN}$
 $r_c = 3.175 \text{ IN}$
 $L = 236.875 \text{ IN}$
 $\left(\frac{L}{r}\right)_{\text{MAX}} = \frac{236.875}{3.175} = 74.6063$

$\left(\frac{L}{r}\right)_{\text{MIN}} = \frac{236.875}{8.66} = 27.4$

REACTOR VESSEL COLUMN



LOADS - R.V. ASS'Y SPECIFICATION
SPECIFICATION NO. 01370-PE-110

	LOCATION	F _a	F _b	F _c	M _a	M _c
NORMAL OPERATION	T	38	1068 [†]	2	22	394
	T'	38	1068	2	22	372
	B'	38	1068	2	22	377
	KEY			2		
DBE SEISMIC	B	38	1068	4	22	409
	T**	7	628	8	733	213
	T'*	7	628	8	738	217
	B'*	7	628	8	537	71
	KEY			401		
	B	7	628	409	363	65

LOADS ARE IN KIPS
MOMENTS IN FT-K

* LOADS AT THESE LOCATIONS
ARE CONSERVATIVELY OBTAINED
ASSUMING SINGLE CURVATURE

** SEISMIC LOADS AT TOP OF COLUMN
ARE OBTAINED BY TRANSPOSITION
OF LOADS AT THE BOTTOM OF THE
COLUMN, CONSIDERING WORST
CASE SIGNS NOTING THAT F_c AND
E_B ARE OF OPPOSITE SIGN.
† INCLUDES 22% CEDMI STREAM LOAD

ALLOWABLE STRESSES

- FROM AISC WITH 1 1/3 INCREASE
FOR FAULTED CONDITIONS

$F_{bc} = 0.75 F_y (1 1/3)$ - BENDING ABOUT C-AXIS

$F_{bc} = 0.75(42)(1 1/3) = 42 \text{ ksi}$

$F_{ba} = 0.6 F_y (1 1/3)$ - BENDING ABOUT A-AXIS

$F_{ba} = 0.6(42)(1 1/3) = 33.6 \text{ ksi}$

F_a = ALLOWABLE COMPRESSIVE STRESS

$F_a = \left[1 - \frac{(kL/r)^2}{2c_c^2} \right] F_y (1 1/3)$

$\frac{5/3 + \frac{3(kL/r)}{8c_c} - \frac{(kL/r)^3}{8c_c^3}}$

= 28 ksi.

k = 0.65 FOR RESTAINED COMP. MEMBERS
PER AISC

$(kL/r)_{max} = 0.65(74.6) = 48.5$

$c_c = \sqrt{\frac{2\pi^2 E}{F_y}} = 113.48$

EULER BUCKLING STRESS

$F_{ea} = \frac{12}{23} \frac{\pi^2 E}{(kL/r)^2} (1 1/3)$

= 595 ksi

$(kL/r_a) = 0.65(27.4) = 17.81$

E = 27,400 ksi

REACTOR VESSEL COLUMN

ALLOWABLE STRESSES

EULER BUCKLING STRESS

$$F_{e'c} = \frac{12}{23} \frac{\pi^2 E}{\left(\frac{kl}{r_c}\right)^2} \quad \left(\frac{kl}{r_c}\right) = \left(\frac{kl}{r}\right)_{\max} = 48.5$$

$$= 79.8 \text{ ksi}$$

COMPRESSION - BENDING INTERACTION

$$(1) \quad \frac{f_a}{F_a} + \frac{C_{ma} f_{ba}}{\left(1 - \frac{f_a}{F_{e'a}}\right) F_{ba}} + \frac{C_{mc} f_{bc}}{\left(1 - \frac{f_a}{F_{e'a}}\right) F_{bc}} \leq 1.0 \quad \text{AISC EQ. 16-1a}$$

- CONSERVATIVELY ASSUME $C_{ma} = C_{mc} = 1.0$ WHICH IS THE HIGHEST POSSIBLE VALUE CONSIDERING RESTRAINED, JOINT TRANSLATION PREVENTED, SINGLE CURVATURE BENDING. SINCE $C_{ma} = C_{mc} = 1.0$ EQ 16-1b IS SATISFIED BY INSPECTION.

FAULTED CAPACITY

THE FAULTED CAPACITY IS DESCRIBED BY EQ 1 AND HAS AN INFINITE NUMBER OF SOLUTIONS. THE FAULTED CAPACITY IS DEFINED AS NORMAL OPERATION PLUS A LINEAR MULTIPLE OF THE FSAR SEISMIC RESPONSE. (FAULTED CAPACITY = N. OP. + X (DBE)) THE MOST CRITICAL LOCATION IS THE BOTTOM OF THE TOP FLANGE (T') SINCE MAXIMUM NORMAL OPERATION PLUS DBE LOADS EXIST HERE.

BY TRIAL AND ERROR
ASSUME A DBE
MULTIPLICATION FACTOR
OF $X = 1.9$

$$F_b = 1068 + 1.9(628) = 2262^k$$

$$M_A = 22 + 1.9(738) = 1424^1-k$$

$$M_c = 372 + 1.9(217) = 784^1-k$$

REACTOR VESSEL COLUMN

FAULTED CAPACITY

CONSERVATIVELY, AN OFFSET MOMENT EQUAL TO 1/4 INCH (.021') TIMES THE AXIAL LOAD (F_b) IS ADDED TO M_A AND M_C WHEN CALCULATING BENDING STRESSES.

$$f_{ba} = \frac{M_a}{S_a} = \frac{[1424 + .021(2262)]12}{1650} = 10.7 \text{ ksi}$$

$$f_{bc} = \frac{M_c}{S_c} = \frac{[784 + .021(2262)]12}{605} = 16.49 \text{ ksi}$$

$$f_a = \frac{F_b}{A} = \frac{2262}{330} = 6.86 \text{ ksi}$$

SUBSTITUTING IN EQ. 1

$$\frac{6.86}{28} + \frac{(1)(10.7)}{(1 - \frac{6.86}{595})33.6} + \frac{(1)(16.49)}{(1 - \frac{6.86}{770})42} = 0.245 + 0.322 + 0.43 = 0.997 \leq 1.0$$

WHICH DEFINES THE FAULTED CAPACITY BY THE PREVIOUSLY DEVELOPED CRITERIA AS:
(AT LOCATION T')

$$F_b = 2262^k$$

$$M_a = 1424^{1-k}$$

$$M_c = 784^{1-k}$$

SEISMIC MARGIN


$$F_b = (2262 - 1068) / 628 = 1.9$$

$$M_a = (1424 - 22) / 738 = 1.9$$

$$M_c = (784 - 372) / 217 = 1.9$$

THE MARGIN IN THE TABLE IS REPRESENTATIVE OF THE SAFETY FACTOR AVAILABLE ABOVE THE EXISTING DESIGN BASIS EARTHQUAKE.

REACTOR VESSEL LOWER SUPPORT
HONEYCOMB ASSEMBLY



MATERIAL:

SA 240 TYPE 321
FOIL SIZE = .010"
CELL SIZE = 1/8"
1" THK PRECRUSHED TO 1/16

LOADS


NORMAL OPERATION ~ 0 F_c
DBE = 400K

LOAD DEFLECTION CHARACTERISTICS - DESIGN CURVE

- THE FOLLOWING PROPERTIES ARE FROM THE PROJECT SPECIFICATION FOR REACTOR VESSEL COLUMN EXPANSION PLATE ASSEMBLIES FOR SOUTHERN CALIFORNIA EDISON SAN ONOFRE 2 AND 3. SPECIFICATION NO. 1370-PE-514 R02

REACTOR VESSEL LOWER SUPPORT
HONEYCOMB ASSEMBLY

LOAD DEFLECTION CHARACTERISTICS - (CONT)



FAULTED CAPACITY - ASME SECTION III APPENDIX F 1370(a).

$$F_{MAX} = 0.8L = 0.8(500) = 400K$$

SEISMIC MARGIN

$$= 400/400 = 1.0$$

NO MARGIN EXISTS BASED ON CODE ANALYSIS. 25% MARGIN EXISTS BASED ON THE MATERIAL SPECIFICATION.


$$ELASTIC DESIGN LIMIT = 500K$$

$$SEISMIC MARGIN = \frac{500}{400} = 1.25$$

SCE Units #2 and #3:

Seismic Margin Evaluation - Reactor Vessel Bottom Head Support Lug:

A. Geometry:



Material: Lug and Bottom Head - SA-533 Gr. B class 1

$$\left. \begin{aligned} S_m &= 26.7 \text{ KSI} \\ S_y &= 41.4 \text{ KSI} \\ S_u &= 80 \text{ KSI} \end{aligned} \right\} @ 650^\circ\text{F design temperature}$$

S_m value for the faulted condition (see par. F-1323.1 (a) and (b) of Ref. 3):

$$\begin{aligned} F S_m &= 1.2 S_y = 49.68 \text{ KSI} \text{ — For the Lug} \\ &= 0.7 S_u = 56 \text{ KSI} \text{ — For the bottom Head} \end{aligned}$$

B. Stress calculation:

(1) Support Lug: From p. A-417 through A-422 of Ref. 1 and par. F-1323.1 (a) of Ref. 3

Average Shear Stress

$$\tau = \frac{F_c}{9 \times 24} = .00463 F_c \leq .6 (F_{Sm}) = .6 \times 49.68 = 29.8 \text{ KSI}$$

$$\text{or } F_c = \frac{29.8}{.00463} = 6436.2 \text{ K}$$

Bending Stress

$$\sigma_B = \frac{F_c \times 8.3082}{\frac{1}{2} \times 9 \times 25^3} \left(\frac{25}{2} \right) = .00886 F_c \leq 1.5 (F_{Sm}) = 74.5 \text{ KSI}$$

$$\text{or } F_c = \frac{74.5}{.00886} = 8408.5 \text{ K}$$

Max. stress intensity

$$S.I. = (\sigma_B^2 + 4\tau^2)^{1/2} \leq 1.5 (F_{Sm}) = 74.5 \text{ KSI}$$

$$\text{or } [(0.00886 F_c)^2 + 4(0.00463 F_c)^2]^{1/2} = 74.5$$

$$\text{or } F_c = 5813 \text{ K}$$

Bearing Stress

$$\sigma_{\text{Bearing}} = \frac{F_c}{9 \times 4.01425} = 0.0277 F_c \leq \left(\frac{S_y}{S_m} \right) S_y = \frac{41.4^2}{26.7} = 64.1 \text{ KSI}$$

$$\text{or } F_c = \frac{64.1}{.0277} = 2314 \text{ K}$$

(2) Reactor Vessel Bottom Head: From P.A-430 through A-432 of Ref.1, we have the local membrane stress due to F_c for the head

$$\begin{aligned}\sigma_{\theta} &= .0001892 M_c = .0001892 (8.9991 F_c) \\ &= .001703 F_c\end{aligned}$$

$$\sigma_x = .0001809 M_c = .00163 F_c$$

Shear stress

$$\tau = \frac{F_c}{9 \times 25} + .001688 M_T \quad \begin{matrix} 3.3563 F_c \\ \end{matrix} = .01011 F_c$$

The pressure stress

$$\sigma_p = \frac{PR}{2t} = \frac{\text{(operating press.) } 2.25 \times 88.3125}{2 \times 4.375} = 22.71 \text{ ksi}$$

Therefore the limiting stress is

$$\begin{aligned}S.I. &= [(\sigma_p + \sigma_{\theta})^2 + 4\tau^2]^{1/2} + p \\ &= [(22.71 + .001703 F_c)^2 + 4(.01011 F_c)^2]^{1/2} + 2.25 \\ &\leq 1.5 (F_y)_m = 1.5 \times 56 = 84 \text{ ksi}\end{aligned}$$

$$\text{or } F_c = 3750 \text{ K}$$

(3) SSE Capacity load: The SSE capacity load is the smallest F_c value calculated in section (1) and (2) above or

$$\text{SSE } F_c = 2314 \text{ K} \\ \text{cap.}$$

The bearing stress of the support lug governs.

The next lowest F_c is 3750^k governed by the bottom head.

(4) - SSE allowable load and seismic margin:
From Refs. 1 and 2, for the normal operation case

$$N.op.F_c = 2^k$$

$$\begin{aligned} \therefore \text{SSE } F_c \text{ Allow.} &= \text{SSE } F_c \text{ cap.} - N.op.F_c \\ &= 2314 - 2 = 2312^k \end{aligned}$$

From Ref. 4

$$DBE F_c = 400^k$$

$$\begin{aligned} \therefore \text{Seismic Margin } G &= \frac{\text{SSE } F_c \text{ All.} - DBE F_c}{\text{SSE } F_c \text{ All.}} 100\% \\ &= \frac{2312 - 400}{2312} 100\% \\ &= 82.6\% \end{aligned}$$

C. References:




1. Analytical Report For Southern California San Onofre Unit 3 Reactor Vessel, Report Number CENC-1292, August 1977
2. Project Specification For A Reactor Vessel Assembly For San Onofre Units No. 2 & No. 3, Specification No. 01370-PE-110 Revision 4
3. ASME Boiler and pressure Vessel Code Section III, 1974

4. FSAR Table 3.7-23

SCE Units #2 and #3:

Seismic Margin Evaluation - Steam Generator Snubber Lug:

A. Geometry:



$$\begin{aligned}
 l_x &= 6.5'' \\
 l_\phi &= 22.945'' \\
 \theta &= 16.5^\circ \\
 t &= 5.5625'' \\
 d &= 5.1236'' \\
 e &= d + \frac{1}{2}t \cos \theta = 7.79'' \\
 D &= 9.75'' \\
 V_c &= S \cos \theta = .9588 S \\
 P &= S \sin \theta = .284 S \\
 A_{A-A} &= l_x \times l_\phi = 149.14 \text{ in}^2 \\
 Z_{A-A} &= \frac{1}{6} l_x l_\phi^2 = 570.35 \text{ in}^3
 \end{aligned}$$

Material: Vessel shell - SA-533 A class 1 } $S_m = 26.7$ KSI, $S_y = 42.5$ KSI
 Lug - SA-533 B class 1 } $S_u = 80$ KSI, all @ 560°F design temperature
 Sleeve - SA-540 Gr. B-23 class 3 - $S_m = 36.58$ KSI
 $S_y = 109$ KSI @ 560°F

B. Stress calculation:

(1) Lug: By par. F-1323.1 (a) of Ref. 3 and P.A-659 of Ref. 1, stress limits used in the calculation are:

Primary membrane stress $\sigma_t \leq 1.2 S_y = 51 \text{ ksi}$

Average shear stress $\tau \leq 0.6(1.2 S_y) = 30.6 \text{ ksi}$

Bearing stress $\sigma_{\text{Bearing}} \leq \left(\frac{S_y}{S_m}\right) S_y = 67.6 \text{ ksi}$

Primary membrane plus primary bending stress

$(\sigma_t + \sigma_B) \leq 1.5(1.2 S_y) = 76.5 \text{ ksi}$

Max. stress intensity

S.I. = $[(\sigma_t + \sigma_B)^2 + 4\tau^2]^{1/2} \leq 1.5(1.2 S_y) = 76.5 \text{ ksi}$

Bearing stress for the sleeve

sleeve $\sigma_{\text{Bearing}} \leq S_y = 109 \text{ ksi}$

The three critical stress regions, sections A-A, B-B and C-C are analyzed.

a) Section A-A:

1. Primary membrane stress

$\sigma_t = \frac{P}{A_{A-A}} = \frac{2845}{149.14} = 0.0019 S \leq 51 \text{ ksi}$

or $S = \frac{51}{0.0019} = 26842 \text{ K}$

2. Primary membrane plus primary bending :

$$\sigma_B = \frac{Sd}{Z_{AA}} = \frac{5.12365}{570.35} = .008985$$

$$\therefore (\sigma_t + \sigma_B) = .00195 + .008985 \leq 76.5 \text{ ksi}$$

$$\text{or } S = \frac{76.5}{.01088} = 7031 \text{ K}$$

3. Average shear stress :

$$\tau = \frac{V_c}{A_{AA}} = \frac{.95885}{149.14} = .006435 \leq 30.6 \text{ ksi}$$

$$\text{or } S = \frac{30.6}{.00643} = 4758.9 \text{ K}$$

4. Max. stress intensity :

$$S.I. = [(\sigma_t + \sigma_B)^2 + 4\tau^2]^{1/2}$$

$$= [(.00195 + .008985)^2 + 4(.006435)^2]^{1/2}$$

$$= .016845 \leq 76.5 \text{ ksi}$$

$$\text{or } S = \frac{76.5}{.01684} = 4542.7 \text{ K}$$

b) Section B-B :

: Primary membrane stress

$$\sigma_t = \frac{S}{A_{B-B}} = \frac{S}{12 \times 6.25} = .013333 S \leq 51 \text{ ksi}$$

$$\text{or } S = 3825 \text{ K}$$

c) Section C-C :

1. Primary membrane stress :

$$\sigma_t = \frac{S}{A_{CC}} = \frac{S}{(23.9.75)6.25} = .01215 S \leq 51 \text{ KSI}$$

or $S = 4214.8 \text{ K}$

2. Tearout shear stress :

$$\tau = \frac{S}{A_{Tearout}} = \frac{S}{(11.5 - \frac{9.75}{2} \cos 45^\circ) 2 \times 6.25}$$

$$= .00993 S \leq 30.6 \text{ KSI}$$

or $S = 3081.5 \text{ K}$

3. Bearing stress :

$$\text{lug } \sigma_{\text{Bearing}} = \frac{S}{9.75 \times 6.25} = .01641 S \leq 67.6 \text{ KSI}$$

or $S = 4119.4 \text{ K}$

$$\text{sleeve } \sigma_{\text{Bearing}} = \frac{S}{8.625 \times 6.25} = .01855 S \leq 109 \text{ KSI}$$

or $S = 5876 \text{ K}$

From the above calculations, one can see that the tearout shear stress at section C-C governs. The max. allowable load for S is

$S = 3081.5 \text{ K}$

(2) Steam Generator Upper Shell: The allowable load S can be calculated from the stress intensity equation. From p. A-674 of Ref. 1, We have

$$\begin{aligned}
 S.I. &= [(\sigma_{\phi} + \sigma_{N\phi})^2 + 4(\tau_{x\phi})^2]^{\frac{1}{2}} + p \\
 &= [(20.5 + 0.00695P)^2 + 4\left(\frac{V_c}{255.05}\right)^2]^{\frac{1}{2}} + 0.9 \\
 &= [(20.5 + 0.001974S)^2 + 4(0.00376S)^2]^{\frac{1}{2}} + 0.9 \\
 &\leq 1.5(0.75u) = 84^{ksi}, \text{ See par. F-1323.1 (b) of Ref. 3}
 \end{aligned}$$

$$\therefore S = 9700 \text{ K}$$

(3) SSE capacity load: The SSE capacity load is the smallest S load calculated in Sections (1) and (2) above, or

$$S_{SSE \text{ cap.}} = 3081.5 \text{ K}$$

The tearout shear stress of the lug governs.

(4) SSE allowable load and seismic margin:

For the normal operation case, see Refs 1 and 2, $S_{N.op.} = 0$. Therefore

$$\begin{aligned}
 S_{SSE \text{ Allowable}} &= S_{SSE \text{ cap.}} - S_{N.op.} \\
 &= 3081.5 - 0 \\
 &= 3081.5 \text{ K}
 \end{aligned}$$

From Ref 4, DBE load

$$DBE S = \frac{DBE F_x}{2} = \frac{1378}{2} = 689 K$$

$$\therefore \text{Seismic Margin } G = \frac{\frac{SSE}{All.} S - DBE S}{\frac{SSE}{All.} S} = \frac{3081.5 - 689}{3081.5} = .776 = 77.6\%$$

C. References :

1. Analytical Report For Southern California Edison San Onofre Unit No. 2 Steam Generator, Report Number CENC-1272, September 1976
2. Project specification For Steam Generator Assemblies for San Onofre Unit No. 2, Specification No. 01370-PE-120 Revision 5
3. ASME Boiler and pressure Vessel Code Section III, 1974
4. FSAR Table 3.7-23

SCE Units # 2 and # 3:

Seismic Margin Evaluation - Primary piping Cold Leg Discharge Elbow:


A. Geometry:

$$R_o = 18.25''$$

$$R_i = 15.25''$$

$$t = 3'', t_{clad} = .25''$$

$$I = \frac{\pi}{4} (R_o^4 - R_i^4) = 44646.2 \text{ in}^4$$



Material: SA-516 Gr. 70

$S_m = 18.4 \text{ ksi}$ @ 650°F design temp.

B. Stress Calculation:

The primary stress of the elbow is analyzed by EQ. (9) of Ref. 3. From p. A-35 of Ref. 1, we have

$$S_{EQ.9} = B_1 \frac{PD_o}{2t} + B_2 \frac{D_o M_i}{2I} = (15.21 + 0.01168 M_i) \text{ ksi}$$

Where $B_1 = 1.0$

$$B_2 = 2.382$$

$$D_o = 36.5''$$

$$t = 3''$$

$$I = 44646.2 \text{ in}^4$$

$$P = 2.5 \text{ ksi, Design pressure}$$

(1) : SSE Capacity:

By Par. F-1360 (b) of Ref. 3 and the above equation $S_{EQ.9}$, the SSE capacity of the elbow can be calculated as follows:

$$S_{EQ.9} = 15.21 + 0.01168 M_i \leq 3 S_m = 55.2 \text{ ksi}$$

$$\therefore \underset{\text{Cap.}}{\text{SSE } M_i} = 3423.8 \text{ FT-K}$$

(2) SSE allowable load and Seismic margin:

From p. A-34 of Ref. 1 and Ref. 2

$$n.op. M_i = 1390.6 \text{ FT-K}$$

From Ref. 3

$$DBE M_i = 1607 \text{ in-K} = 134 \text{ FT-K}$$

$$\therefore \underset{\text{Allow.}}{\text{SSE } M_i} = \underset{\text{Cap.}}{\text{SSE } M_i} - \underset{n.op.}{M_i}$$

$$= 3423.8 - 1390.6 = 2033.2 \text{ FT-K}$$

and Seismic Margin

$$G = \frac{\underset{\text{All.}}{\text{SSE } M_i} - DBE M_i}{\underset{\text{All.}}{\text{SSE } M_i}} = \frac{2033.2 - 134}{2033.2} = .934 \text{ or } 93.4\%$$

The primary bending stress governs.


C. References:

1. Analytical Report for Southern California Edison San Onofre Unit No. 2 Piping, Report Number CENC-1365, March, 1979
2. Project Specification For Reactor Coolant Pip and Fittings For San Onofre Unit No. 2, Specification No. 01370-PE-140 Revision 6
3. ASME Boiler and Pressure Vessel Code Section III, 1974
4. FSAR Table 3.7-23

SCE Units # 2 and # 3:

Seismic Margin Evaluation - R.C. Pump Discharge Nozzle:

A. Geometry: pump 1B is used for this analysis



Material: SA-351 Gr. CF8M

$$S_m = 16.6 \text{ KSI}$$

$$S_Y = 18.5 \text{ KSI}$$

$$S_U = 67 \text{ KSI}$$

@ 650°F design temperature

A-A

By Par. F-1323.1 (b) of Ref. 3, the S_m value for the faulted condition is chosen as the smaller of $2.4 S_m$ or $0.7 S_u$

$$\therefore \text{Faulted } S_m = 2.4 S_m = 2.4 \times 16.6 = 39.84 \text{ KSI}$$

Conservatively the Max. stress region Section A-A is considered as a 29" I.D. x 37" O.D. ring, and

$$A_{AA} = \frac{\pi}{4} (d_o^2 - d_i^2) = \frac{\pi}{4} (37^2 - 29^2) = 414.7 \text{ in}^2$$

$$I_{A-A} = \frac{\pi}{64} (d_o^4 - d_i^4) = \frac{\pi}{64} (37^4 - 29^4) = 57279 \text{ in}^4$$

$$J_{A-A} = 2 I_{A-A} = 114558 \text{ in}^4$$

B. stress calculation:

(1) Stress Limits: From Par. F-1323.1 (b) of Ref. 3, the following stress limits are used in the analysis:

(a) For the max. primary membrane stress

$$S_{mT} = \frac{F_x}{A_{AA}} + \frac{Pr_i}{2t} \leq \text{Faulted } S_m$$

$$\text{or } S_{mT} = \frac{F_x}{414.7} + \frac{2.25 \times 14.5}{2 \times 4} = .002411 F_x + 4.08 \text{ KSI} \leq 39.84 \text{ KSI}$$

(b) For the Max. primary membrane plus primary bending stress:

$$S_t = \frac{F_x}{A_{AA}} + \frac{M_c}{I_{A-A}} + \frac{Pr_i}{2t} \leq 1.5 (\text{Faulted } S_m)$$

$$\text{or } S_t = \frac{F}{A_{AA}} + \frac{M \times 18.5}{57279} + \frac{2.25 \times 14.5}{2 \times 4} \\ = .002411 F_x + .000323 M + 4.08 \leq 59.76 \text{ KSI}$$

(c) For the Max. average shear stress:

$$S_s = \frac{F}{A_{AA}} + \frac{M_x c}{J_{A-A}} \leq .6 (\text{Faulted } S_m)$$

$$\text{or } S_s = .002411 F + .0001615 M_x \leq 23.9 \text{ KSI}$$

(d) For the Max. stress intensity:

$$S.I. = (S_t^2 + 4S_s^2)^{1/2} + p \leq 1.5 (\text{Faulted } S_m) = 59.76 \text{ KSI}$$

where $\bar{F} = (F_Y^2 + F_Z^2)^{1/2}$
 $\bar{M} = [(M_Y - 11F_Z)^2 + (M_Z + 11F_Y)^2]^{1/2}$
 $P = 2.25 \text{ KSI}$, system operating pressure
 $r_i = \frac{29}{2} = 14.5''$
 $c = \frac{37}{2} = 18.5''$
 $t = 4''$

(2) Load stresses for the normal operating condition:
 From Table 10 of Ref 2, we have

$$F_x = 106 \text{ K}$$

$$\bar{F} = (F_Y^2 + F_Z^2)^{1/2} = (119^2 + 16^2)^{1/2} = 120.1 \text{ K}$$

$$M_x = 41 \text{ FT-K} = 492 \text{ in-K}$$

$$\bar{M} = [(M_Y - 11F_Z)^2 + (M_Z + 11F_Y)^2]^{1/2}$$

$$= [(141 \times 12 + 11 \times 16)^2 + (1057 \times 12 + 11 \times 119)^2]^{1/2}$$

$$= 14117 \text{ in-K}$$

Substituting the forces and moments into the above Par. B. (1) equations, we have

$$s_{m\sigma t} = 1.002411 F_x = 1.002411 \times 106 = .26 \text{ KSI}$$

$$s_t = 1.000323 \bar{M} + s_{m\sigma t} = 1.000323 \times 14117 + .26 = 4.82 \text{ KSI}$$

$$s_s = 1.002411 \bar{F} + 1.0001615 M_x = 1.002411 \times 120.1 + 1.0001615 \times 492$$

$$= .37 \text{ KSI}$$

$$s.l. = [s_t^2 + 4s_s^2]^{1/2} = [4.82^2 + 4 \times .37^2]^{1/2} = 4.88 \text{ KSI}$$

(3) Load stresses for the DBE condition: From Table 3.7-23 of Ref. 4, the DBE load stresses of the nozzle can be calculated as follows:

(a) Combined North-South and Vertical DBE case:

$$F_x = F_a = 790 \text{ K}$$

$$\bar{F} = (F_b^2 + F_c^2)^{1/2} = (61^2 + 145^2)^{1/2} = 157.31 \text{ K}$$

$$M_x = M_a = 1119 \text{ in-k}$$

$$\bar{M} = [(M_b + 11F_c)^2 + (M_c + 11F_b)^2]^{1/2} \text{ in-k}$$

$$= [(11531 + 11 \times 145)^2 + (5499 + 11 \times 61)^2]^{1/2} = 14503.82 \text{ in-k}$$

$$\therefore \sigma_m = \sigma_t = 1002411 F_x = 1002411 \times 790 = 1.9 \text{ KSI}$$

$$\sigma_t = 1000323 \bar{M} + \sigma_m = 1000323 \times 14503.82 + 1.9$$

$$= 6.59 \text{ KSI}$$

$$\sigma_s = 1002411 \bar{F} + 10001615 M_x$$

$$= 1002411 \times 157.31 + 10001615 \times 1119 = .56 \text{ KSI}$$

$$\sigma_{1.1} = (\sigma_t^2 + 4\sigma_s^2)^{1/2}$$

$$= (6.59^2 + 4 \times .56^2)^{1/2} = 6.68 \text{ KSI}$$

(b) Combined East-West and Vertical DBE case:

$$F_x = F_a = 222 \text{ K}$$

$$\bar{F} = (F_b^2 + F_c^2)^{1/2} = (36^2 + 56^2)^{1/2} = 66.6 \text{ K}$$

$$M_x = M_a = 1181 \text{ in-k}$$

$$\bar{M} = [(M_b + 11F_c)^2 + (M_c + 11F_b)^2]^{1/2} \text{ in-k}$$

$$= [(2864 + 11 \times 56)^2 + (3793 + 11 \times 36)^2]^{1/2} = 5446 \text{ in-k}$$

To compare case (a) with case (b), one can see case (a) governs.

C. SSE Capacity Loads: The SSE capacity loads are conservatively calculated by ratioing up the DBE loads by a factor K, where

$$K = \frac{(\text{ASME Code Allowable Stress}) - (\text{pressure stress})}{(\text{DBE Load stress})}$$

Therefore from par. B. (1) and (3) above, we have:

(1) For the primary membrane stress:

$$K_m = \frac{39.84 - 4.08}{1.9} = 18.8$$

(2) For the primary membrane plus primary bending stress:

$$K_t = \frac{59.76 - 4.08}{6.59} = 8.4$$

(3) For the shear stress:

$$K_s = \frac{23.9 - 0}{.56} = 42.6$$

(4) For the Max. stress intensity:

$$K_{s.i.} = \frac{59.76 - 4.08}{6.68} = 8.3$$

Using the smallest value of the above K 's

$$\therefore K = K_{3.1.} = 8.3$$

and
$$SSE_{cap.}(Load) = K \times DBE(Load)$$

$$\therefore \left. \begin{array}{l} SSE_{cap.} F_a = 790 \\ SSE_{cap.} F_b = 61 \\ SSE_{cap.} F_c = 145 \\ SSE_{cap.} M_a = 1119 \\ SSE_{cap.} M_b = 11531 \\ SSE_{cap.} M_c = 5499 \end{array} \right\} \times 8.3 = \left\{ \begin{array}{l} 6557 \text{ K} \\ 506 \text{ K} \\ 1203 \text{ K} \\ 9287 \text{ in-K} \\ 95707 \text{ in-K} \\ 45641 \text{ in-K} \end{array} \right.$$

D. SSE allowable loads and seismic margin:

(1) SSE allowable loads: The following equation is used in the analysis

$$SSE_{Allowable}(Load) = SSE_{cap.}(Load) - N.op.(Load)$$

From Table 10 of Ref. 2 and Par. C. above, we have

$$SSE_{All.} F_a = 6557 - 106 = 6451 \text{ K}$$

$$SSE_{All.} F_b = 506 - 119 = 387 \text{ K}$$

$$SSE_{All.} F_c = 1203 - 16 = 1187 \text{ K}$$

$${}_{All.}^{SSE} M_a = 9287 - 41 \times 12 = 8795 \text{ in-K} = 733 \text{ FT-K}$$

$${}_{All.}^{SSE} M_b = 95707 - 141 \times 12 = 94015 \text{ in-K} = 7834.6 \text{ FT-K}$$

$${}_{All.}^{SSE} M_c = 45641 - 1057 \times 12 = 32957 \text{ in-K} = 2746.4 \text{ FT-K}$$

(2) Seismic Margin: the seismic margin is conservatively calculated by

$$\text{Seismic Margin } G = \frac{{}_{All.}^{SSE}(\text{Load}) - {}_{DBE}(\text{Load})}{{}_{All.}^{SSE}(\text{Load})}$$

From Table 3.7-23 of Ref. 4 and Pars. B. (3) & D above, we have

$$G_{Fa} = \frac{6451 - 790}{6451} = .877 \text{ or } 87.7\%$$

$$G_{Fb} = \frac{387 - 61}{387} = .842 \text{ or } 84.2\%$$

$$G_{Fc} = \frac{1187 - 145}{1187} = .877 \text{ or } 87.7\%$$

$$G_{Ma} = \frac{8795 - 1119}{8795} = .872 \text{ or } 87.2\%$$

$$G_{Mb} = \frac{94015 - 11531}{94015} = .877 \text{ or } 87.7\%$$

$$G_{Mc} = \frac{32957 - 5499}{32957} = .833 \text{ or } 83.3\%$$

The seismic margin is conservatively chosen the

Smallest value of the above G 's, or

$$G = G_{MC} = 83.3\%$$

E. References:

1. Pump Case Analysis For Southern California Edison San Onofre Station, Units 2 And 3, Byron Jackson Report TCF-1025-STR, Vol. 2.
2. Project Specification For Reactor Coolant Pumps For Southern California Edison San Onofre Station, Units 2 And 3, Specification No. 1370-PE-480 Revision 05
3. ASME Boiler AND pressure Vessel Code Section III, 1977 AND Addenda Through The Winter of 1978.
4. FSAR Table 3.7-23