NRC FORM 374 PAGE _____ OF ____ PAGES Amendment No. 5 U.S. NUCLEAR REGULATORY COMMISSION MATERIALS LICENSE Pursuant to the Atomic Energy Act of 1954, as amended, the Energy Reorganization Act of 1974 (Public Law 93-438), and Title 10, Code of Federal Regulations, Chapter I, Parts 30, 31, 32, 33, 34, 35, 36, 37, 39, 40, and 70, and in reliance on statements and representations heretofore made by the licensee, a license is hereby issued authorizing the licensee to receive, acquire, possess, and transfer byproduct, source, and special nuclear material designated below; to use such material for the purpose(s) and at the place(s) designated below; to deliver or transfer such material to persons authorized to receive it in accordance with the regulations of the applicable Part(s). This license shall be deemed to contain the conditions specified in Section 183 of the Atomic Energy Act of 1954, as amended, and is subject to all applicable rules, regulations, and orders of the Nuclear Regulatory Commission now or hereafter in effect and to any conditions specified below. Licensee In accordance with the letter dated April 3, 2014, 1. ESSROC Cement Corporation 3. License number 13-26609-01 is amended in its entirety to read as follows: 2. Highway 31 4. Expiration date January 31, 2015 Speed, IN 47172 5. Docket No. 030-33669 Reference No. 6. Byproduct, source, and/or special 7. Chemical and/or physical form 8. Maximum amount that licensee may nuclear material possess at any one time under this license Cesium-137 A. Sealed Source (Ohmart A. One source not to exceed 30 Α Corp. Model A-2102) millicuries B. Californium- 252 B. Sealed Source (Frontier B. Two sources not to exceed a Technology Corporation combined total of 42 Model 100 Series, QSA millicuries. Global, Inc. Model CVN.CYn Series, and **Eckert & Ziegler Isotope Products Laboratories.** Models 3004, 3014, and N-252 Series) 9. Authorized Use: A. To be used in an Ohmart Corporation Model SH-F1 source holder to measure level of process material. B. To be used in Thermo Electron Corporation (Thermo Gamma Metrics) Model CBX Cross-Belt Elemental Analyzer for analysis of bulk materials. CONDITIONS 10. Licensed material shall be used only at the licensee's facilities located at Highway 31, Speed, Indiana. A. The Radiation Safety Officer for this license is David Hitt. B. Before assuming the duties and responsibilities as RSO for this license, future RSOs shall have successfully completed one of the training courses described in Criteria in Section 8.7.1 of NUREG-1556, Volume 4, dated October 1998.

r									
NRC	CFOR	M 374A U.S. NUCLEAR REGULATORY COMMISSION	PAGE 2 of 4 PAGES						
			License Number 13-26609-01						
		MATERIALS LICENSE SUPPLEMENTARY SHEET	Docket or Reference Number 030-33669						
			Amendment No. 5						
12.	Lice	ensed material shall be used by, or under the supervisic	on of, David Hitt.						
13.	A.	Sealed sources shall be tested for leakage and/or contamination at intervals not to exceed the intervals specified in the certificate of registration issued by the U.S. Nuclear Regulatory Commission under 10 CFR 32.210 or by an Agreement State.							
	В.	In the absence of a certificate from a transferor indicating that a leak test has been made within the intervals specified in the certificate of registration issued by the U.S. Nuclear Regulatory Commission under 10 CFR 32.210 or by an Agreement State, prior to the transfer, a sealed source received from another person shall not be put into use until tested and the test results received.							
	C.	Sealed sources need not be tested if they are in storage and are not being used. However, when they are removed from storage for use or transferred to another person, and have not been tested within the required leak test interval, they shall be tested before use or transfer. No sealed source shall be stored for a period of more than 10 years without being tested for leakage and/or contamination.							
	D.	The leak test shall be capable of detecting the presence of 0.005 microcurie (185 becquerels) of radioactive material on the test sample. If the test reveals the presence of 0.005 microcurie (185 becquerels) or more of removable contamination, a report shall be filed with the U.S. Nuclear Regulatory Commission in accordance with 10 CFR 30.50(c)(2), and the source shall be removed immediately from service and decontaminated, repaired, or disposed of in accordance with Commission regulations.							
	E.	The licensee is authorized to collect leak test samples for analysis by Ohmart Corporation. Alternatively, tests for leakage and/or contamination may be performed by persons specifically licensed by the Commission or an Agreement State to perform such services.							
14.	Sealed sources containing licensed material shall not be opened or sources removed from source holders by the licensee.								
15.	The dev	The licensee shall conduct a physical inventory every 6 months to account for the sealed source and/or device authorized under this license.							
16.	А.	The gauge shall be tested for the proper operation of the any, at intervals not to exceed 6 months or at such long registration issued by the U.S. Nuclear Regulatory Correquivalent regulations of an Agreement State.	he on-off mechanism (shutter) and indicator, if ger intervals as specified in the certificate of mmission pursuant to 10 CFR 32.210 or the						
	В.	Notwithstanding the periodic on-off mechanism (shutte apply to gauges that are stored, not being used, and he position. The gauges exempted from this periodic test	er) and indicator test, the requirement does not ave the shutter lock mechanism in a locked t shall be tested before use.						

NRC FORM 374A	U.S. NUCLEAR REGULATORY COMMISSION		PAGE	3	of	4	PAGES
	MATERIALS LICENSE SUPPLEMENTARY SHEET	License Number 13-26609-01					
		Docket or Reference Number 030-33669					
		Amendment No. 5					
							<u> </u>

- 17. The following services shall not be performed by the licensee: installation, initial radiation surveys, relocation, removal from service, dismantling, alignment, replacement, disposal of the sealed source and non-routine maintenance or repair of components related to the radiological safety of the gauge (i.e., the sealed source, the source holder, source drive mechanism, on-off mechanism (shutter), shutter control, shielding). These services shall be performed only by persons specifically licensed by the U.S. Nuclear Regulatory Commission or an Agreement State to perform such services.
- 18. A. The licensee may maintain, repair, or replace device components that are not related to the radiological safety of the device containing byproduct material and that do not result in the potential for any portion of the body to come into contact with the primary beam or in increased radiation levels in accessible areas.
 - B. The licensee may not maintain, repair, or replace any of the following device components: the sealed source, the source holder, source drive mechanism, on-off mechanism (shutter), shutter control, or shielding, or any other component related to the radiological safety of the device, except as provided otherwise by specific condition of this license.
- 19. Prior to initial use and after installation, relocation, dismantling, alignment, or any other activity involving the source or removal of the shielding, the licensee shall assure that a radiological survey is performed to determine radiation levels in accessible areas around, above, and below the gauge with the shutter open. This survey shall be performed only by persons authorized to perform such services by the U.S. Regulatory Commission or an Agreement State.
- 20. The licensee shall operate each device containing licensed material within the manufacturer's specified temperature and environmental limits such that the shielding and shutter mechanism of the source holder are not compromised.
- 21. The licensee shall assure that the shutter mechanism of each device is locked in the closed position during periods when a portion of an individual's body may be subject to the direct radiation beam. The licensee shall review and modify, as appropriate, its "lock-out" procedures whenever a new device is obtained to incorporate the device manufacturer's recommendations.
- 22. Except for maintaining labeling as required by 10 CFR Part 20, or 71, the licensee shall obtain authorization from the U.S. Nuclear Regulatory Commission before making any changes in the sealed source, device or source-device combination that would alter the description or specifications as indicated in the respective certificate of registration issued either by the Commission pursuant to 10 CFR 32.210 or by an Agreement State.
- 23. The licensee is authorized to transport licensed material in accordance with the provisions of 10 CFR Part 71, "Packaging and Transportation of Radioactive Material."

NRC FORM 374A	U.S. NUCLEAR REGULATORY COMMISSION		PAGE	4	of	4	PAGES
		License Number 13-26609-01					
	MATERIALS LICENSE SUPPLEMENTARY SHEET	Docket or Reference Number 030-33669	r				
	Amendment No. 5						
24. Except as s	specifically provided otherwise in this license, th	l le licensee shall condu	ict its p	rogr	am i	'n	

- 24. Except as specifically provided otherwise in this license, the licensee shall conduct its program in accordance with the statements, representations, and procedures contained in the documents, including any enclosures, listed below. The U.S. Nuclear Regulatory Commission's regulations shall govern unless the statements, representations, and procedures in the licensee's application and correspondence are more restrictive than the regulations.
 - A. Application dated September 22, 2004; and
 - B. Letter dated March 14, 2007 (with attachments).

FOR THE U.S. NUCLEAR REGULATORY COMMISSION

Date APR 2 3 2014

Leichhold illiam t By

William P. Reichhold Materials Licensing Branch Region III