



Entergy Nuclear Northeast  
Entergy Nuclear Operations, Inc.

James A. FitzPatrick NPP  
P.O. Box 110  
Lycoming, NY 13093

**Lawrence M. Coyle**  
Site Vice President - JAF

JAFP-14-0051  
April 29, 2014

United States Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555-0001

SUBJECT: 2013 Annual Radioactive Effluent Release Report

James A. FitzPatrick Nuclear Power Plant  
Docket No. 50-333  
License No. DPR-59

Dear Sir or Madam:

This letter transmits the James A. FitzPatrick Nuclear Power Plant's (JAF) Annual Radioactive Effluent Release Report, for the period of January 1, 2013 through December 31, 2013. The enclosure is submitted in accordance with the Reporting Requirements of the Technical Specifications, Section 5.6.3 and Appendix H of the Technical Requirements Manual, "Offsite Dose Calculation Manual (ODCM)," Part 1 Section 6.2, Radioactive Effluent Release Report.

This report (Enclosure) includes, as an Addendum, an Assessment of the Radiation Doses to the Public due to the radioactive liquid and gaseous effluents released during the 2013 calendar year. The format used for the effluent data is outlined in Appendix B of Regulatory Guide 1.21, Revision 1. Distribution is in accordance with Regulatory Guide 10.1, Revision 4.

There are no commitments contained in this letter.

If you have any questions concerning the enclosed report, please contact Mr. Robert Heath, Chemistry Manager, at (315)349-6635.

Sincerely,

A handwritten signature in black ink that reads "Chris M. Adner".

Chris M. Adner  
Regulatory Assurance Manager - JAF

CMA/RH/ds

Enclosure: Annual Radioactive Effluent Release Report, January 1 – December 31, 2013

cc: next page

cc:

Regional Administrator, Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406-1415

Resident Inspector's Office  
U.S. Nuclear Regulatory Commission  
James A. FitzPatrick Nuclear Power Plant  
P.O. Box 136  
Lycoming, NY 13093

Mr. Douglas Pickett, Project Manager  
Plant Licensing Branch I-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Mail Stop O-8-C2A  
Washington, DC 20555-0001

R. Heath (CHEM/JAF)  
B. Landers (CHEM/JAF)  
K. Stoffle (NMP)

Document Contents:  
001 Transmittal Letter, JAFP-14-0051 with enclosure

**JAFP-14-0051**

**Enclosure**

**2013 Annual Radioactive Effluent Release Report**

**(43 Pages)**

**ENERGY NUCLEAR OPERATIONS, INC.**  
**JAMES A. FITZPATRICK NUCLEAR POWER PLANT**  
**ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT**

**JANUARY 1, 2013 - DECEMBER 31, 2013**

**DOCKET NO. 50-333**

**LICENSE NO. DPR-59**

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

**SUPPLEMENTAL INFORMATION**

**FACILITY: JAFNPP      LICENSEE: ENTERGY NUCLEAR OPERATIONS, INC.**

**1. Offsite Dose Calculation Manual Part 1 Radiological Controls**

a. Fission and Activation Gases:

- (1) The dose rate at or beyond the site boundary due to radioactive materials released from the plant in gaseous effluent shall be limited as follows:
  - (a) Less than or equal to 500 mrem/year to the whole body and less than or equal to 3000 mrem/year to the skin from noble gases.
- (2) The air dose to areas at or beyond the site boundary from noble gases released from the plant in gaseous effluent shall be limited:
  - (a) During any calendar quarter, to less than or equal to 5 mrad from gamma radiation, and less than or equal to 10 mrad from beta radiation; and,
  - (b) During any calendar year, to less than or equal to 10 mrad from gamma radiation and less than or equal to 20 mrad from beta radiation.

b. Tritium, Iodines and Particulates, Half Lives > 8 days:

- (1) The dose to a member of the public at or beyond the site boundary from Iodine-131, Iodine-133, Tritium, and radionuclides in particulate form with half-lives greater than 8 days released from the plant in gaseous effluent shall be limited:
  - (a) During any calendar quarter to less than or equal to 7.5 mrem to any organ; and,
  - (b) During any calendar year to less than or equal to 15 mrem to any organ.
  - (c) Less than 0.1% of the limits of Specification 3.4.1.c.1.a and 3.4.1.c.1.b as a result of burning contaminated oil.
- (2) The dose rate at or beyond the site boundary due to radioactive materials released from the plant in gaseous effluents shall be limited as follows:
  - (a) Less than or equal to 1500 mrem/year to any organ from Iodine-131, Iodine-133, Tritium and for radioactive materials in particulate form with half-lives greater than 8 days (inhalation pathway only).

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**SUPPLEMENTAL INFORMATION (continued)**

c. Liquid Effluents:

- (1) The concentration of radioactive materials released to the unrestricted areas shall not exceed ten times the values specified in 10 CFR 20.1001-20.2402, Appendix B, Table 2, column 2. For dissolved or entrained noble gases the concentration shall be limited to 2.00E-04  $\mu\text{Ci/ml}$ .
- (2) The dose to a member of the public from radioactive materials released from the plant in liquid effluents to unrestricted areas shall be limited as follows:
  - (a) During any calendar quarter, limited to less than or equal to 1.5 mrem to the whole body and to less than or equal to 5 mrem to any organ; and,
  - (b) During any calendar year, limited to less than or equal to 3 mrem to the whole body and to less than or equal to 10 mrem to any organ.

**2. 10X Effluent Concentrations**

a. Fission and activation gases:	(None specified)			
b. Iodines:	(None specified)			
c. Particulates, half-lives >8 days:	(None specified)			
d. Liquid effluents:	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
(1) Fission and activation products (mixture EC) ( $\mu\text{Ci/ml}$ )	None	None	None	None
(2) Tritium ( $\mu\text{Ci/ml}$ )	1.00E-02	1.00E-02	1.00E-02	1.00E-02
(3) Dissolved and entrained gases ( $\mu\text{Ci/ml}$ )	2.00E-04	2.00E-04	2.00E-04	2.00E-04

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

**SUPPLEMENTAL INFORMATION (continued)**

3. **Average Energy** (None specified)

4. **Measurements and Approximations of Total Radioactivity**

- a. Fission and Activation Gases: Continuous monitor on each release path calibrated to a marinelli grab sample analyzed by gamma spectroscopy; bubbler grab sample analyzed for Tritium.
- b. Iodines: Gamma spectral analysis of charcoal cartridge and particulate filter on each release path.
- c. Particulates: Gamma spectral analysis of each particulate filter and charcoal cartridge for each release path. A four week per quarter composite of particulate filters for each release path for Strontium-89 and Strontium-90. One week per month particulate filter for each release path for gross alpha.
- d. Liquid Effluents: Gamma spectral analysis of each batch discharged, except composite analysis for Strontium-89, Strontium-90, Iron-55, Tritium, and Alpha.
- e. Solid Waste: Gamma spectral analysis of a representative sample of each waste shipment. Scaling factors established from off-site composite sample analyses to estimate concentration of non-gamma emitters. Low activity trash shipments curie content is estimated by dose rate measurement and application of appropriate scaling factors.
- f. Error Estimation Method: Overall error for sampling and analysis estimated by combining individual errors using error propagation methods. This process is composed of determinate and undeterminate errors.

Determinate - Pump flowrates, volume measurements and analysis collection yields

Undeterminate - Random counting error estimated using accepted statistical calculations

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**SUPPLEMENTAL INFORMATION (continued)**

**5. Batch Releases**

a. <u>Liquid: Canal</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
(1) Number of batch releases:	3.00E+00	2.00E+00	3.00E+00	4.00E+00
(2) Total time period for batch release: (min)	1.84E+02	1.40E+02	1.66E+02	1.90E+02
(3) Maximum time period for batch release: (min)	7.00E+01	8.00E+01	7.40E+01	7.20E+01
(4) Average time period for batch release: (min)	6.13E+01	7.00E+01	5.53E+01	4.75E+01
(5) Minimum time period for batch release: (min)	5.00E+01	6.00E+01	3.00E+01	1.00E+00
(6) Total Activity Released (Ci)	5.02E-06	2.27E-06	1.72E-06	2.40E-06
(7) Total Volume Released (liters)	2.32E+03	1.44E+03	1.66E+03	2.93E+03
b. <u>Liquid: Non-Canal</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
(1) Number of batch releases:	8.00E+00	9.00E+00	1.10E+01	7.00E+00
(2) Total time period for batch release: (min)	1.26E+03	1.16E+03	5.92E+02	6.99E+03
(3) Maximum time period for batch release: (min)	4.87E+02	5.91E+02	2.80E+02	2.57E+03
(4) Average time period for batch release: (min)	1.58E+02	1.29E+02	5.38E+01	9.98E+02
(5) Minimum time period for batch release: (min)	1.00E+00	1.00E+00	7.00E+00	1.60E+01
(6) Total Activity Released (Ci)	9.02E-04	1.06E-03	5.46E-04	4.03E-03
(7) Total Volume Released (liters)	4.77E+05	4.38E+05	2.25E+05	2.65E+06

c. Gaseous

There were no gaseous batch releases for this report period.



ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**SUPPLEMENTAL INFORMATION (continued)**

**6. Continuous Releases**

a. <u>Liquid: Non-Canal</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
(1) Number of releases:	2.60E+01	2.50E+01	2.80E+01	2.40E+01
(2) Total Activity Released (Ci)	6.39E-02	1.39E-02	1.08E-02	1.15E-02
(3) Total Volume Released (liters)	1.57E+07	5.23E+06	4.92E+06	7.67E+05
b. <u>Liquid: Canal</u>	<u>Quarter 1</u>	<u>Quarter 2</u>	<u>Quarter 3</u>	<u>Quarter 4</u>
(1) Number of releases:	8.00E+00	3.00E+00	0	0
(2) Total Activity Released (Ci)	7.96E-04	1.61E-05	NA	NA

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**TABLE 1A**  
**GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES**

	<u>UNIT</u>	<u>QTR 1</u>	<u>QTR 2</u>	<u>QTR 3</u>	<u>QTR 4</u>	<u>EST TOTAL ERROR %</u>
<b>A. FISSION AND ACTIVATION GASES</b>						
1. Total Release	Ci	1.00E+01	1.45E+01	1.14E+01	2.52E+01	≤2.50E+01
2. Average release rate for period	μCi/sec	1.28E+00	1.84E+00	1.44E+00	3.17E+00	
3. Applicable ODCM Limit	%	*	*	*	*	
<b>B. IODINE-131</b>						
1. Total Iodine-131	Ci	3.37E-05	6.83E-05	9.62E-05	1.39E-04	≤2.50E+01
2. Average release rate for period	μCi/sec	4.28E-06	8.68E-06	1.21E-05	1.75E-05	
3. Applicable ODCM Limit	%	*	*	*	*	
<b>C. PARTICULATES</b>						
1. Particulates with half-lives >8 days	Ci	3.20E-05	1.22E-06	7.72E-07	4.65E-07	≤3.60E+01
2. Average release rate for period	μCi/sec	4.07E-06	1.56E-07	9.71E-08	5.85E-08	
3. Applicable ODCM Limit	%	*	*	*	*	
4. Gross alpha radioactivity	Ci	3.28E-07	1.67E-07	3.81E-07	2.29E-07	≤2.50E+01
<b>D. TRITIUM</b>						
1. Total Release	Ci	3.10E+00	4.76E+00	6.68E+00	7.54E+00	≤2.50E+01
2. Average release rate for period	μCi/sec	4.17E-08	2.13E-08	4.79E-08	2.88E-08	
3. Applicable ODCM Limit	%	*	*	*	*	
<b>E. CARBON-14 (See attachment 8)</b>						
<b>*F. PERCENT OF APPLICABLE ODCM LIMITS</b>						
<b>FISSION AND ACTIVATION GASES</b>	<b><u>UNIT</u></b>	<b><u>QTR 1</u></b>	<b><u>QTR 2</u></b>	<b><u>QTR 3</u></b>	<b><u>QTR 4</u></b>	
1. Quarterly gamma air dose limit	%	5.47E-03	7.48E-03	5.76E-03	1.32E-02	
2. Quarterly beta air dose limit	%	7.54E-04	1.14E-03	7.77E-04	2.09E-03	
3. Yearly gamma air dose limit	%	2.73E-03	3.74E-03	2.88E-03	6.58E-03	
4. Yearly beta air dose limit	%	1.88E-04	2.85E-04	1.94E-04	5.23E-04	
5. Whole body dose rate limit	%	4.09E-03	6.51E-03	9.48E-03	8.20E-03	
6. Skin dose rate limit	%	8.78E-04	1.41E-03	2.06E-03	1.78E-03	
<b>HALOGENS, TRITIUM AND PARTICULATES WITH HALF-LIVES &gt;8 DAYS</b>						
7. Quarterly dose limit (organ)	%	7.17E-03	1.43E-02	2.06E-02	2.84E-02	
8. Yearly dose limit (organ)	%	3.59E-03	7.13E-03	1.03E-02	1.42E-02	
9. Organ dose rate limit	%	1.42E-05	1.63E-05	2.55E-05	2.51E-05	

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**TABLE 1B**  
**GASEOUS EFFLUENTS - ELEVATED RELEASE**

CONTINUOUS MODE

NUCLIDES RELEASED

<u>1. Fission Gases</u>	<u>UNIT</u>	<u>QUARTER 1</u>	<u>QUARTER 2</u>	<u>QUARTER 3</u>	<u>QUARTER 4</u>
Argon-41	Ci	3.54E+00	2.81E+00	3.45E+00	2.76E+00
Krypton-85m	Ci	6.96E-01	6.87E-01	1.22E+00	8.64E-01
Krypton-87	Ci	9.58E-01	1.08E+00	4.98E-01	1.94E+00
Krypton-88	Ci	6.69E-01	6.32E-01	5.77E-01	8.81E-01
Xenon-133	Ci	1.18E-01	2.17E-01	8.63E-01	9.24E-02
Xenon-135	Ci	1.14E+00	1.48E+00	5.05E-01	2.00E+00
Xenon-135m	Ci	6.64E-01	1.72E+00	9.80E-01	3.72E+00
Xenon-137	Ci	ND	4.41E-01	2.65E-01	1.07E+00
Xenon-138	Ci	2.20E+00	5.36E+00	3.09E+00	1.18E+01
TOTAL	Ci	9.98E+00	1.44E+01	1.14E+01	2.52E+01
<u>2. Iodines</u>					
Iodine-131	Ci	8.07E-06	1.03E-05	7.55E-06	1.63E-05
Iodine-132	Ci	ND	ND	ND	ND
Iodine-133	Ci	1.79E-05	9.52E-06	5.73E-05	9.25E-04
Iodine-135	Ci	4.76E-05	ND	4.08E-05	ND
TOTAL	Ci	7.35E-05	1.98E-05	1.06E-04	1.09E-04
<u>3. Particulates</u>					
Cesium-137	Ci	ND	ND	ND	2.74E-07
Manganese-54	Ci	1.30E-07	ND	ND	ND
Strontium-89	Ci	7.93E-07	1.22E-06	7.72E-07	1.92E-07
TOTAL	Ci	9.23E-07	1.22E-06	7.72E-07	4.65E-07
<u>4. Tritium</u>					
Hydrogen-3	Ci	5.08E-01	4.39E-01	5.94E-01	9.69E-01

Note: There were no batch releases for this report period.

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**TABLE 1C**  
**GASEOUS EFFLUENTS - GROUND LEVEL RELEASES**

<u>NUCLIDES RELEASED</u>		<u>CONTINUOUS MODE</u>			
<b>1. <u>Fission Gases</u></b>	<u>UNIT</u>	<u>QUARTER 1</u>	<u>QUARTER 2</u>	<u>QUARTER 3</u>	<u>QUARTER 4</u>
TOTAL	Ci	ND	ND	ND	ND
<b>2. <u>Iodines</u></b>					
Iodine-131	Ci	2.56E-05	5.79E-05	8.86E-05	1.23E-04
Iodine-133	Ci	2.10E-04	4.75E-04	6.30E-04	9.04E-04
TOTAL	Ci	2.36E-04	5.33E-04	7.19E-04	1.03E-03
<b>3. <u>Particulates</u></b>					
Cobalt-58	Ci	6.10E-06	ND	ND	ND
Cobalt-60	Ci	2.57E-06	ND	ND	ND
Manganese-54	Ci	6.57E-06	ND	ND	ND
Selenium-75	Ci	1.86E-06	ND	ND	ND
Zinc-65	Ci	1.39E-05	ND	ND	ND
TOTAL	Ci	3.10E-05	ND	ND	ND
<b>4. <u>Tritium</u></b>					
Hydrogen-3	Ci	2.59E+00	4.32E+00	6.09E+00	6.57E+00

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**TABLE 1C**  
**GASEOUS EFFLUENTS - GROUND LEVEL RELEASES**

BATCH MODE

NUCLIDES RELEASED

<u>1. Fission Gases</u>	<u>UNIT</u>	<u>QUARTER 1</u>	<u>QUARTER 2</u>	<u>QUARTER 3</u>	<u>QUARTER 4</u>
Xenon-133	Ci	3.02E-02	1.22E-02	ND	ND
Xenon-135	Ci	2.07E-02	1.19E-02	ND	ND
Xenon-135M	Ci	6.29E-04	3.36E-03	ND	ND
TOTAL	Ci	5.16E-02	2.74E-02	ND	ND
<u>2. Iodines</u>					
TOTAL	Ci	ND	ND	ND	ND
<u>3. Particulates</u>					
TOTAL	Ci	ND	ND	ND	ND
<u>4. Tritium</u>					
Hydrogen-3	Ci	ND	ND	ND	ND

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**TABLE 2A**  
**LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES**

	<u>UNIT</u>	<u>QTR 1</u>	<u>QTR 2</u>	<u>QTR 3</u>	<u>QTR 4</u>	<u>EST TOTAL ERROR %</u>
<b>A. FISSION AND ACTIVATION PRODUCTS</b>						
1. Total Release (not including tritium, gases and alpha)	Ci	ND	ND		ND	ND
NA						
2. Average diluted concentration during period	μCi/ml	ND	ND	ND	ND	
3. Applicable ODCM Limit	%	NA	NA	NA	NA	
<b>B. TRITIUM</b>						
1. Total Release	Ci	6.56E-02	1.50E-02	1.14E-02	1.55E-02	≤2.50E+01
2. Average diluted concentration during period (Note 1)	μCi/ml	3.95E-06	2.72E-06	2.34E-05	1.52E-06	
3. Applicable ODCM Limit	%	*	*	*	*	
<b>C. DISSOLVED AND ENTRAINED GASES</b>						
1. Total Release	Ci	ND	ND	ND	ND	NA
2. Average diluted concentration during period	μCi/ml	ND	ND	ND	ND	
3. Applicable ODCM Limit	%		NA	NA	NA	NA
<b>D. GROSS ALPHA RADIOACTIVITY</b>						
1. Total Release	Ci	ND	ND	ND	ND	NA
<b>E. VOLUME OF WASTE RELEASED (PRIOR TO DILUTION)</b>						
	liters	1.64+07	5.50E+06	4.84E+06	1.02E+07	
<b>F. VOLUME OF DILUTION WATER USED DURING PERIOD</b>						
	liters	4.29E+10	1.02E+10	2.55E+08	2.76E+08	
<b>*G. PERCENT OF APPLICABLE ODCM LIMITS</b>						
1. Quarterly Whole Body Dose	%	4.69E-04	2.80E-04	2.73E-04	5.56E-05	
2. Quarterly Organ Dose	%	1.41E-04	8.39E-05	8.19E-05	1.69E-05	
3. Annual Whole Body Dose	%	2.35E-04	1.40E-04	1.37E-04	2.82E-05	
4. Annual Organ Dose	%	7.04E-05	4.20E-05	4.10E-05	8.47E-06	

Note 1: Concentration includes summation from diluted and undiluted values from Canal and Non-Canal releases (Table 2B).

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**TABLE 2B**  
**LIQUID EFFLUENTS CANAL**

BATCH MODE

<u>NUCLIDES RELEASED</u>	<u>UNIT</u>	<u>QUARTER 1</u>	<u>QUARTER 2</u>	<u>QUARTER 3</u>	<u>QUARTER 4</u>
<b>1. <u>Fission and Activation Products</u></b>					
ND	Ci	ND	ND	ND	ND
<b>2. <u>Tritium</u></b>					
Hydrogen-3	Ci	5.02E-06	2.27E-06	1.72E-06	2.40E-06
<b>3. <u>Dissolved and Entrained Gases</u></b>					
ND	Ci	ND	ND	ND	ND

**TABLE 2B**  
**LIQUID EFFLUENTS CANAL**

CONTINUOUS MODE

<u>NUCLIDES RELEASED</u>	<u>UNIT</u>	<u>QUARTER 1</u>	<u>QUARTER 2</u>	<u>QUARTER 3</u>	<u>QUARTER 4</u>
<b>1. <u>Fission and Activation Products</u></b>					
ND	Ci	ND	ND	ND	ND
<b>2. <u>Tritium</u></b>					
Hydrogen-3	Ci	7.96E-04	1.61E-05	ND	ND
<b>3. <u>Dissolved and Entrained Gases</u></b>					
ND	Ci	ND	ND	ND	ND

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**TABLE 2B (SUPPLEMENT)  
 LIQUID EFFLUENTS NON-CANAL**

<u>CONTINUOUS MODE</u>					
<u>NUCLIDES RELEASED</u>	<u>UNIT</u>	<u>QUARTER 1</u>	<u>QUARTER 2</u>	<u>QUARTER 3</u>	<u>QUARTER 4</u>
<b>1. <u>Fission and Activation Products</u></b>					
ND	Ci	ND	ND	ND	ND
<b>2. <u>Tritium</u></b>					
Hydrogen-3	Ci	6.39E-02	1.39E-02	1.08E-02	1.15E-02
<b>3. <u>Dissolved and Entrained Gases</u></b>					
ND	Ci	ND	ND	ND	ND



ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**TABLE 2B (SUPPLEMENT)  
 LIQUID EFFLUENTS NON-CANAL**

<u>NUCLIDES RELEASED</u>	<u>UNIT</u>	<u>BATCH MODE</u>			
		<u>QUARTER 1</u>	<u>QUARTER 2</u>	<u>QUARTER 3</u>	<u>QUARTER 4</u>
<b>1. <u>Fission and Activation Products</u></b>					
ND	Ci	ND	ND	ND	ND
<b>2. <u>Tritium</u></b>					
Hydrogen-3	Ci	9.02-04	1.06E-03	5.46E-04	4.03E-03
<b>3. <u>Dissolved and Entrained Gases</u></b>					
ND	Ci	ND	ND	ND	ND

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**TABLE 2B (CONTINUED)**  
**ABNORMAL RELEASE**  
**LIQUID EFFLUENTS CANAL**

<u>CONTINUOUS MODE</u>					
<u>NUCLIDES RELEASED</u>	<u>UNIT</u>	<u>QUARTER 1</u>	<u>QUARTER 2</u>	<u>QUARTER 3</u>	<u>QUARTER 4</u>
<b>1. <u>Fission and Activation Products</u></b>					
ND	Ci	ND	ND	ND	ND
<b>2. <u>Tritium</u></b>					
ND	Ci	ND	ND	ND	ND
<b>3. <u>Dissolved and Entrained Gases</u></b>					
ND	Ci	ND	ND	ND	ND

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**TABLE 3A  
 SOLID WASTE AND IRRADIATED FUEL SHIPMENTS**

**A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (NOT IRRADIATED FUEL)**

<b>1. <u>Type of Waste</u></b>	<b><u>UNIT</u></b>	<b><u>CLASS A</u></b>	<b><u>CLASS B</u></b>	<b><u>CLASS C</u></b>	<b><u>EST. TOTAL ERROR %</u></b>
a. Spent resins, filter sludges, evaporator bottoms, etc.	m <sup>3</sup>	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
b. Dry compressible waste, contaminated equipment, etc.	m <sup>3</sup>	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
c. Irradiated components, control rods, etc.	m <sup>3</sup>	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
d. Other: Dry compressible waste, contaminated equipment, spent resins for volume reduction.	m <sup>3</sup>	3.41E+02	1.13E+01	0.00E+00	2.50E+01
	Ci	2.37E+01	4.36E+02	0.00E+00	2.50E+01

**2. Estimate of Major Nuclide Composition (by type of waste)**

a. Spent resins, filter sludges, evaporator bottoms, etc.

None

b. Dry compressible waste, contaminated equipment, etc.

None

c. Irradiated components, control rods, etc.

None

d. Other: Dry compressible waste, contaminated equipment, spent resins contaminated oil, glycol and water for volume reduction.

<u>Isotope</u>	<u>Percent</u>	<u>Curies</u>	<u>Isotope</u>	<u>Percent</u>	<u>Curies</u>
H-3	5.20E-2	1.22E-01 E	C-14	5.33E-01	1.26E+00 E
Cr-51	1.40E-2	3.35E-02 E	Mn-54	5.33E+00	1.26E+01 E
Fe-55	5.06E+01	1.20E+02 E	Fe-59	3.40E-02	8.02E-02 E
Co-58	1.01E-01	2.38E-01 E	Co-60	1.93E+01	4.56E+01 E
Ni-63	2.49E+00	5.91E+00 E	Zn-65	1.86E+01	4.39E+01 E
Sr-89	1.80E-02	4.22E-02 E	Sr-90	8.90E-01	2.10E-01 E
Sb-124	7.00E-03	1.73E-02 E	Sb-125	1.00E-02	2.44E-02 E
Cs-134	1.77E-01	4.19E-01 E	Cs-137	2.75E+00	6.50E+00 E
Ce-144	1.00E-03	1.90E-03 E			

(E- Estimated M- Measured)

Percentage of nuclides and total activities are based on a combination of direct measurements and scaling for non-gamma emitting nuclides.

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**TABLE 3A (continued)**  
**SOLID WASTE AND IRRADIATED FUEL SHIPMENTS**

**3. Solid Waste Disposition**

<u>No. of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
26	Truck	*Energy Solutions Oak Ridge, TN
11	Truck	*Barnwell Processing Barnwell, SC
1	Truck	*Perma-Fix of Florida, INC Gainesville, FL
1	Truck	*TOXCO, Inc. Oak Ridge, TN

\* Volume Reduction Facility

**B. IRRADIATED FUEL SHIPMENTS (Disposition)**

<u>No. of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
None	-----	-----

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**TABLE 3B**  
**SOLID WASTE AND IRRADIATED FUEL SHIPMENTS**

**A. NRC CLASS A**

<u>SOURCE OF WASTE</u>	<u>PROCESSING EMPLOYED</u>	<u>CONTAINER VOLUME</u>	<u>TYPE OF CONTAINER</u>	<u>NUMBER OF CONTAINERS</u>
Dry compressible Waste (DAW), Contaminated Equipment, etc.	Non-compacted	1280 ft <sup>3</sup>	STC	7
Dry compressible Waste (DAW), Contaminated Equipment, etc.	Non-compacted	96 ft <sup>3</sup>	STC	11
Dry compressible Waste (DAW), Contaminated Equipment, etc.	Non-compacted	206.1 ft <sup>3</sup>	STC	1
Spent Resins, Filter Sludges, evaporator Bottoms, etc.	Air Drying Non-compacted	205.8 ft <sup>3</sup>	HIC	17
Spent Resins, Filter Sludges, evaporator Bottoms, etc.	Air Drying Non-compacted	120.3 ft <sup>3</sup>	HIC	12
Spent Resins, Filter Sludges, evaporator Bottoms, etc.	Air Drying Non-compacted	170.8 ft <sup>3</sup>	HIC	5
Dry compressible Waste (DAW), Contaminated Equipment, etc.	Non-compacted	17.9 ft <sup>3</sup>	STC	2
Dry compressible Waste (DAW), Contaminated Equipment, etc.	Non-compacted	7.5 ft <sup>3</sup>	STC	6
Dry compressible Waste (DAW), Contaminated Equipment, etc.	Non-compacted	4.1 ft <sup>3</sup>	STC	1

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**TABLE 3B**  
**SOLID WASTE AND IRRADIATED FUEL SHIPMENTS (Continued)**

**A. NRC CLASS A (Continued)**

<u>SOURCE OF WASTE</u>	<u>PROCESSING EMPLOYED</u>	<u>CONTAINER VOLUME</u>	<u>TYPE OF CONTAINER</u>	<u>NUMBER OF CONTAINERS</u>
Dry compressible Waste (DAW), Contaminated Equipment, etc.	Non-compacted	1.64 ft <sup>3</sup>	STC	1
Dry compressible Waste (DAW), Contaminated Equipment, etc.	Non-compacted	0.7 ft <sup>3</sup>	STC	3

**B. NRC CLASS B**

<u>SOURCE OF WASTE</u>	<u>PROCESSING EMPLOYED</u>	<u>CONTAINER VOLUME</u>	<u>TYPE OF CONTAINER</u>	<u>NUMBER OF CONTAINERS</u>
	None			

**C. NRC CLASS C**

<u>SOURCE OF WASTE</u>	<u>PROCESSING EMPLOYED</u>	<u>CONTAINER VOLUME</u>	<u>TYPE OF CONTAINER</u>	<u>NUMBER OF CONTAINERS</u>
	None			

HIC- High Integrity Container  
 STC- Strong Tight Container

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**ATTACHMENT NO. 1**

**CHANGES TO THE OFFSITE DOSE CALCULATION MANUAL (ODCM)**

In accordance with the James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Part 1 Radiological Controls (REC) Section 6.2.3, changes made to the Offsite Dose Calculation Manual (ODCM) during the reporting period shall be included in the Annual Radioactive Effluent Release Report.

<u>REV</u>	<u>CHANGE AND REASON FOR CHANGE</u>	
12	1.	Cover Sheet  Updated the use class from Informational Use to Reference Use in compliance with EN-AD-102 (which has been superseded by EN-HU-106). This change increases the accuracy of the ODCM.
	2.	Part 1 Page 2 Section 1.2  Updated the Revision History of the ODCM. This is an editorial change.
	3.	Part 1 Page 3 Definition E  Changed NMPNS to Nine Mile Point Nuclear Station (NMPNS). This clarifies the acronym and increases the accuracy of the ODCM.
	4.	Part 1 Page 3 Definition G  Changed (NMPC) Niagara Mohawk Power Corporation Site to Constellation Energy Nuclear Group Site. This updates the current owners of the Nine Mile Point Nuclear Site. This change increases the accuracy of the ODCM.
	5.	Part 1 Page 5 Definition N  Changed NMPC to Constellation Energy Nuclear Group. This updates the current owners of the Nine Mile Point Nuclear Site. This change increases the accuracy of the ODCM.
	6.	Part 2 Page 17 Section 3.4.2.b.2  Updated Section 3.4.2.b.2 under the Section, Limited Analysis Approach, added following three sentences to the first paragraph. "Liquid effluent for the years 2002 through 2009 were also reviewed. Liquid releases have decreased dramatically as compared to 1980-1987. H-3 liquid releases have decreased; however, not as dramatically as the other nuclides and is added to this list." Critical pathways and critical age groups remained the same. This change increases the accuracy of the ODCM.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

**ATTACHMENT NO. 1**

**CHANGES TO THE OFFSITE DOSE CALCULATION MANUAL (ODCM) (Continued)**

<u>REV</u>	<u>CHANGE AND REASON FOR CHANGE</u>
12	<p>7. Part 2 Page 17 Section 3.4.2.b.2</p> <p>Under the Section, Limited Analysis Approach last sentence in first paragraph, “these radionuclides” changed to “these six radionuclides”. This was a result of updating Section 3.4.2.b. The critical pathways and age groups remained the same. This change increases the accuracy of the ODCM.</p>
	<p>8. Part 2 Page 17 Section 3.4.2.b.2 2<sup>nd</sup> Paragraph 2<sup>nd</sup> Sentence</p> <p>Under the Section, Limited Analysis Approach, five was changed to six. Tritium was the additional radionuclide. This was a result of updating Section 3.4.2.b. The critical pathways and age groups remained the same. This change increases the accuracy of the ODCM.</p>
	<p>9. Part 2 Page 18 Section 3.4.2.c.6 2<sup>nd</sup> Sentence</p> <p>Under Calculating Method, H-3 was added to the nuclides. This was a result of updating Section 3.4.2.b. The critical pathways and age groups remained the same. This change increases the accuracy of the ODCM.</p>
	<p>10. Part 2 Page 19 Table 3.4.2</p> <p>H-3 was added to the nuclides in the table. This was a result of updating Section 3.4.2.b. The critical pathways and age groups remained the same. This change increases the accuracy of the ODCM.</p>
	<p>11. Part 2 Page 19 Table 3.4.2</p> <p>Typographical correction made to footnote. Changed “Eq. 3-6aIf” to “Eq. 3-6a If”. This change clarifies the ODCM.</p>



ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**ATTACHMENT NO. 1**

**CHANGES TO THE OFFSITE DOSE CALCULATION MANUAL (ODCM) (Continued)**

<u>REV</u>	<u>CHANGE AND REASON FOR CHANGE</u>	
12	12. Part 2 Page 80 References	Two Technical References (6.21 and 6.22) for Appendix B, Table B-7, Quantification and Reporting of C-14 in JAF Releases were added. This change increases the accuracy of the ODCM.
	13. Part 2 Appendix B Table of Contents Page B-2	Table B-7 added to Appendix B, Table of Contents. This change increases the accuracy of the ODCM.
	14. Part 2 Appendix B Page B-47 Through B-52	Table B-7, Quantification and Reporting of C-14 in JAF Releases, added to Appendix B. This change increases the accuracy of the ODCM.
	15. Part 2 Appendix D Table of Contents Page D-2	Added Table D-9, Calculation of Total Ci/yr Releases for Liquids (2002 through 2009), to Table of Contents. This change increases the accuracy of the ODCM.
	16. Part 2 Appendix D Page D-4	Added last paragraph which discusses liquid effluent releases for the years 2002 through 2009. This change increases the accuracy of the ODCM.
	17. Part 2 Appendix D Table D-9 Page D-14	Added Table D-9, which updated liquid effluent releases for the years 2002 through 2009. This change increases the accuracy of the ODCM.
	18. Part 2 Page 78 Section 5.4	In Section 5.4, Independent Spent Fuel Storage & Installation, changed "18" to "22" storage casks. And changed "9 X 2" array to a "11 X 2" array. And also changed "Rev. 1" to "Rev. 2" on JAF-CALC-SFS-04025. JAF Radiological calculations were revised to reflect a Phase I ISFSI consisting of 22 casks rather than 18.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

**ATTACHMENT NO. 2**

**SUMMARY OF CHANGES TO THE PROCESS CONTROL PROGRAM**

In accordance with the James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Part 1 Radiological Controls (REC) Section 6.2.3, changes made to the Process Control Program (PCP) during the reporting period shall be included in the Annual Radioactive Effluent Release Report.

There were no changes to the Process Control Program.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

**ATTACHMENT NO. 3**

**SUMMARY OF CHANGES TO THE ENVIRONMENTAL  
MONITORING AND DOSE CALCULATION LOCATIONS**

In accordance with the James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Part 1, Section 6.2.3 a listing of new locations for dose calculation and/or environmental monitoring identified by the land use census shall be included in the Annual Radioactive Effluent Release Report.

There were no new locations identified in the land use census.

During the reporting period, no changes in Dose Calculation Receptor Locations and/or the Environmental Monitoring were required based on the results of the land use census.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

**ATTACHMENT NO. 4**

**DEVIATIONS FROM THE REQUIRED  
ENVIRONMENTAL SAMPLING SCHEDULE**

In accordance with the James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Part 1, Section 6.2.7, the cause for the unavailability of any environmental samples required during the report period shall be included in the Annual Radioactive Effluent Release Report.

The following reports samples that were a deviation from the requirements of ODCM Part 1, Table 5.1-1. ODCM Part Section 5.1.1.c.1 allows for deviations from the program due to hazardous conditions, seasonal unavailability, theft, uncooperative residents, or to a malfunction of automatic sampling equipment.

**A. ODCM Program Deviations**

The following are deviations from the program specified by the ODCM:

1/14/13 Air Stations R1 and R2 lost power for 6.2 hours. Air Stations R3 and R4 lost power for 2.1 hours.

1/29/13 Sample Station R5 lost power for approximately 7.5 hours.

8/6/13 R-1 offsite environmental air sample station was found not running by the Constellation technician during the weekly sample change out. The vacuum pump was found to have failed and was replaced. The station was returned to service. From the flow rate data, the sample ran for about 2 minutes before failing.

**B. Air Sampling Station Operability Assessment**

The ODCM required air sampling program consists of 5 individual sampling locations. The collective operable time period for the air monitoring stations was 44,336 hours out of a possible 44,520 hours. The air sampling availability factor for the report period was 99.6%. Air sampling equipment found inoperable was returned to service. Identification of locations for obtaining replacement samples was not required.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

**ATTACHMENT NO. 5**

**ANNUAL SUMMARY OF HOURLY METEOROLOGICAL DATA**

The James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Part 1, Radiological Controls (REC) Section 6.2 and 6.2.2 states in part: The Annual Radioactive Effluent Release Report submitted prior to May 1 of each year may include an annual summary of meteorological data collected over the previous year. If the meteorological data is not included, the licensee shall retain it on file and provide it to the U.S. Nuclear Regulatory Commission upon request.

In accordance with the aforementioned ODCM requirement, meteorological data is not included in this report. It is retained on file and is available upon request.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

**ATTACHMENT NO. 6**

**MAJOR MODIFICATIONS TO RADIOACTIVE LIQUID,  
GASEOUS AND SOLID WASTE TREATMENT SYSTEMS**

In accordance with the James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Part 1 Radiological Controls (REC) Section 7.0, Major Modifications to Radioactive Waste Treatment Systems (liquid, gaseous and solid) shall be reported in the Annual Radioactive Effluent Release Report for the period in which the modification is completed and made operational.

There were no major modifications to any liquid, gaseous, or solid radioactive waste treatment systems.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

**ATTACHMENT NO. 7**

**ONSITE GROUNDWATER MONITORING**

In response to the Nuclear Energy Institute (NEI) Groundwater Protection Initiative, JAF instituted a groundwater monitoring program in 2007. Five monitoring wells were installed during the fourth quarter of 2007. The first samples were collected in November 2007. Starting in March 2010, 16 additional monitoring wells were drilled in the area of the Reactor Building and nearby SSCs. In August 2013, 3 additional wells and 2 piezometers were installed on site.

All samples collected were analyzed for tritium and gamma emitting radionuclides. The detection limits and results are reported in the following tables. Analysis results of tritium ranged from non-detectable, a minimum positive indication of 338 pCi/l, and a maximum concentration of 6,643 pCi/l for a MW CST-B sample from 1/9/2013. Such levels are below the Reporting Level of the James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Part 1, Table 5.1-2, for tritium. The Reporting Level for tritium is 30,000 pCi/l. Approximately 240 ml was obtained from MW CST-B for the 1/9/2013 sample. The normal sample volume is one liter. MW CST-B is a shallow horizontal well and during periods of low precipitation, it yields very small sample volumes and elevated tritium concentrations. No drinking water sources are affected by this tritium. All of the effected wells are onsite. As such, there is no potential to influence any off-site drinking well. No drinking water pathway exists at the James A. FitzPatrick site under normal operating conditions due to the direction and distance of the nearest water intake (Oswego, 8.5 miles west of the JAF discharge).

In conclusion, the only radionuclide detected in groundwater during the 2013 monitoring effort that is attributable to James A. FitzPatrick operations is tritium, and all concentrations were below any reporting criteria.

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**ATTACHMENT NO. 7 (continued)**

**ONSITE GROUNDWATER MONITORING**

A) Gamma Isotopic Monitoring

For 2013, the 24 monitoring wells were sampled quarterly, providing enough water was present, and analyzed below the required lower limits of detection in accordance with the Offsite Dose Calculation Manual (ODCM) Part 1, Table 5.1-3.

Radionuclide	LLD Value (pCi/l)
Manganese-54	15
Cobalt-58	15
Iron-59	30
Cobalt-60	15
Zinc-65	30

Radionuclide	LLD Value (pCi/l)
Zirconium/Niobium-95	15
Iodine-131	15
Cesium-134	15
Cesium-137	18
Barium/Lanthanum-140	15

There were no plant related nuclides detected in the samples. Gross Beta and Hard to Detect nuclide analysis not required.



ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**ATTACHMENT NO. 7 (continued)**

**ONSITE GROUNDWATER MONITORING**

B) Tritium Summary

Well Name	# Samples in 2013	# Positive Samples in 2013	Minimum Positive Concentration	Maximum Positive Concentration
MW-1A	9	3	416	497
MW-1B	9	0		
MW-2A	9	8	421	641
MW-2B	9	0		
MW-3A	8	6	440	720
MW-3B	8	7	338	521
MW-4A	8	3	372	455
MW-4B	8	0		
MW-5	9	6	342	570
MW-6	9	9	342	666
MW-7	9	0		
MW-8	9	3	374	385
MW-9	9	3	392	403
MW-10A	8	4	367	568
MW-10B	8	0		
MW-13	8	6	355	499
MW-14	8	2	355	363
MW-15	8	1	361	361
MW-16	8	7	378	583
MW-19	1	0		
MW-20	1	0		
MW-21	1	0		
MW-CSTA	6	5	423	553
MW-CSTB	8	8	1377	6643

Note 1: All results are in pCi/L.

Note 2: A total of 178 samples were analyzed for H-3 in 2013 with 81 positive results.

Note 3: Samples were analyzed to an LLD of 500 pCi/L.

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**ATTACHMENT NO. 8**

**GASEOUS EFFLUENTS – CARBON-14**

- a) **Date:** January 01, 2013 – December 31, 2013
- b) **Location:** Elevated Release – Main Stack
- c) **Duration:** 365 Days
- d) **Flow rate:** N/A
- e) **Volume Released:** N/A
- f) **Nuclides Released:** Carbon-14
- g) **Curies Released<sup>(1)</sup>:**

	<u>UNIT</u>	<u>QTR 1</u>	<u>QTR 2</u>	<u>QTR 3</u>	<u>QTR 4</u>
2.65E+00	Ci	2.40E+00	2.43E+00	2.55E+00	
	μCi/sec	3.09E-01	3.09E-01	3.21E-01	3.33E-01

- h) **Resultant Doses:** See Addendum 1—Assessment of Radiation Doses to the Public January-December 2013 Table 1E
- i) **Dose Calculations:** Doses were calculated in accordance with the Offsite Dose Calculation Manual (ODCM) Section 4.4.1

<sup>(1)</sup>Curies released calculated using the methodology in EPRI Technical Report 1021106

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

**“Estimation of Carbon-14 in Nuclear Power Plant Gaseous Effluents”.**

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

**ATTACHMENT NO. 9**

**EVENTS LEADING TO CONDITIONS WHICH RESULTED IN EXCEEDING  
RADIOACTIVITY LIMITS.**

In accordance with the James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Part 1 Radiological Controls (REC) Section 6.2.9, the report shall contain the events leading to the conditions which resulted in exceeding the radioactivity limits for the specified outdoor radioactive radwaste tanks specified in the Technical Requirements Manual, TRM 3.7.E

The radioactivity limits for the specified outdoor radioactive radwaste tanks were not exceeded.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

**ADDENDUM 1**

**ASSESSMENT OF RADIATION DOSES TO THE PUBLIC  
JANUARY - DECEMBER 2013**

**1. INTRODUCTION**

The James A. FitzPatrick Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Part 1 Radiological Controls, requires an assessment of the radiation doses to the likely most exposed member of the public due to radioactive liquid and gaseous effluents. This assessment of doses to the likely most exposed member of the public is based on accepted methodologies found in the Offsite Dose Calculation Manual (ODCM).

**2. DOSE LIMITS**

A. DOSE FROM LIQUID EFFLUENTS (ODCM, Part 1, REC 2.3)

Applicability

Applies to doses from radioactive material in liquid effluents.

Objective

To ensure that the dose limitations of 10 CFR 50, Appendix I, are met.

Specifications

The dose to a member of the public from radioactive materials released from the plant in liquid effluents to unrestricted areas shall be limited as follows:

1. During any calendar quarter, limited to less than or equal to 1.5 mrem to the whole body and to less than or equal to 5 mrem to any organ.
2. During any calendar year, limited to less than or equal to 3 mrem to the whole body and to less than or equal to 10 mrem to any organ.

B. GASEOUS DOSE RATES (ODCM, Part 1, REC 3.2)

Applicability

Applies to the radiation dose from radioactive material in gaseous effluents.

Objective

To ensure that the dose rates at or beyond the site boundary from gaseous effluents do not

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

exceed the annual dose limits of 10 CFR 20, for unrestricted areas.

**ADDENDUM 1 (continued)**

Specifications

The dose rate at or beyond the site boundary due to radioactive materials released from the plant in gaseous effluents shall be limited as follows:

1. Less than or equal to 500 mrem/year to the whole body and less than or equal to 3000 mrem/year to the skin from noble gases; and,
2. Less than or equal to 1500 mrem/year to any organ from Iodine-131, Iodine-133, Tritium and for radioactive materials in particulate form with half-lives greater than 8 days (inhalation pathway only).

C. AIR DOSE, NOBLE GASES (ODCM, Part 1, REC 3.3)

Applicability

Applies to the air dose due to noble gases in gaseous effluents.

Objective

To ensure that the noble gas dose limitations of 10 CFR 50, Appendix I, are met.

Specifications

The air dose to areas at or beyond the site boundary from noble gases released from the plant in gaseous effluents shall be limited:

1. During any calendar quarter, to less than or equal to 5 mrad from gamma radiation, and less than or equal to 10 mrad from beta radiation; and,
2. During any calendar year, to less than or equal to 10 mrad from gamma radiation and less than or equal to 20 mrad from beta radiation.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

**ADDENDUM 1 (continued)**

D. DOSE DUE TO IODINE-131, IODINE-133, TRITIUM AND RADIONUCLIDES IN PARTICULATE FORM (ODCM, Part 1, REC 3.4)

Applicability

Applies to the cumulative dose from Iodine-131, Iodine-133, Tritium, and radionuclides in particulate form with half-lives greater than 8 days in gaseous effluents.

Objective

To ensure that the dose limitations of 10 CFR 50, Appendix I, are met.

Specifications

The dose to a member of the public at or beyond the site boundary from Iodine-131, Iodine-133, Tritium, and radionuclides in particulate form with half-lives greater than 8 days released from the plant in gaseous effluents shall be limited:

1. During any calendar quarter to less than or equal to 7.5 mrem to any organ; and,
2. During any calendar year to less than or equal to 15 mrem to any organ.

E. TOTAL DOSE FROM URANIUM FUEL CYCLE (ODCM, Part 1, REC 4.0)

Applicability

Applies to radiation dose from releases of radioactivity and radiation from uranium fuel cycle sources.

Objective

To ensure that the requirements of 40 CFR 190 are met.

Specifications

The dose or dose commitment to any member of the public, due to releases of radioactivity and radiation, from uranium fuel cycle sources shall be limited as follows:

1. Less than or equal to 25 mrem/year to the whole body; and,
2. Less than or equal to 25 mrem/year to any organ except the thyroid which shall be limited to less than or equal to 75 mrem/year.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
JANUARY 2013 - DECEMBER 2013

**ADDENDUM 1 (continued)**

**3. DOSE ASSESSMENT**

**A. METHODOLOGY**

The assessment of radiation doses to the public due to radioactive liquid and gaseous effluents is performed in accordance with the ODCM. The ODCM is based on methodologies and models suggested by the "Guidance Manual For Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants" (NUREG-0133) and "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the purpose of Evaluating Compliance with 10CFR50, Appendix I" (Regulatory Guide 1.109).

**B. ASSUMPTIONS**

Dose calculations are performed using formulas and constants defined in the ODCM. Specific radioactive release activities used in the dose calculations are listed in the Annual Radioactive Effluent Release Report (1.21 Report) for the period of January 1, 2013 to December 31, 2013. Historical meteorological data was used to generate tables of average dispersion factors. Locations of interest were identified from the 2013 land use census. Dispersion factors and locations of interest used in performing the dose calculations are listed in Table 2.

**C. ASSESSMENT RESULTS SUMMARY**

The calculated doses to the public due to radioactive effluents are listed in Table 1. The calculated doses are small fractions of their respective dose limits.

**4. 40 CFR 190 DOSE ASSESSMENT**

**A. METHODOLOGY**

Evaluation to demonstrate compliance with the 40 CFR 190 dose limits must be performed when the doses calculated for 10 CFR 50 compliance exceed twice their respective limits. When additional dose assessment is required to demonstrate compliance with 40 CFR 190 it is performed in accordance with the ODCM.

**B. RESULTS SUMMARY**

The cumulative dose contribution from liquid and gaseous effluents for this report period were calculated and are listed in Table 1. The cumulative dose contribution from direct radiation from the reactor unit and from radwaste storage tanks is measured by environmental thermoluminescent dosimeters for the report period. This data is contained in the Annual Environmental Operating Report. The calculated doses from liquid and gaseous effluents are less than twice their respective 10 CFR 50 limits; therefore, additional calculations are not necessary to demonstrate compliance with 40 CFR 190 dose limits.

**ADDENDUM 1 (continued)**



ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**TABLE 1**  
**ANNUAL DOSE ASSESSMENT 2013**

**A. LIQUIDS**

---

<u>QUARTER</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>ANNUAL</u>
	(a)	(a)	(a)	(a)	(a)
Organ (mrem)	7.04E-06	4.20E-06	4.10E-06	8.47E-07	1.79E-05
% of Limit	1.41E-04	8.39E-05	8.19E-05	1.69E-05	1.79E-04
	(b)	(b)	(b)	(b)	(b)
Whole Body (mrem)	7.04E-06	4.20E-06	4.10E-06	8.47E-07	1.79E-05
% of Limit	4.69E-04	2.80E-04	2.73E-04	5.65E-05	5.97E-04

---

(a) Dose to the Child Liver primarily by the potable water pathway.

(b) Dose to the Child Whole Body primarily by the potable water pathway.

---

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**ADDENDUM 1 (continued)**

**TABLE 1 (cont)**  
**ANNUAL DOSE ASSESSMENT 2013**

**B. NOBLE GASES**

---

<u>QUARTER</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>ANNUAL</u>
Total Body (mrem/yr)	2.04E-02	3.26E-02	4.74E-02	4.10E-02	4.74E-02
% of Limit	4.09E-03	6.51E-03	9.48E-03	8.20E-03	9.48E-03
Skin (mrem/yr)	2.64E-02	4.24E-02	6.17E-02	5.34E-02	6.17E-02
% of Limit	8.78E-04	1.41E-03	2.06E-03	1.78E-03	2.06E-03
Gamma (mrad)	2.73E-04	3.74E-04	2.88E-04	6.58E-04	1.59E-03
% of Limit	5.47E-03	7.48E-03	5.76E-03	1.32E-02	1.59E-02
Beta (mrad)	3.77E-05	5.70E-05	3.88E-05	1.05E-04	2.38E-04
% of Limit	3.77E-04	5.70E-04	3.88E-04	1.05E-03	1.19E-03

---

**C. IODINES AND PARTICULATES**

<u>QUARTER</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>ANNUAL</u>
	(a)	(a)	(a)	(a)	(a)
Organ (mrem)	5.38E-04	1.07E-03	1.55E-03	2.13E-03	5.28E-03
% of Limit	7.17E-03	1.43E-02	2.06E-02	2.84E-02	3.52E-02
	(a)	(a)	(a)	(a)	(a)
Organ Dose Rate (mrem/yr)	2.13E-04	2.44E-04	3.83E-04	3.77E-04	3.83E-04
% of Limit	1.42E-05	1.63E-05	2.55E-05	2.51E-05	2.55E-05

---

(a) Dose to the Child Thyroid primarily by the vegetation pathway.

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**ADDENDUM 1 (continued)**

**TABLE 1 (cont)**  
**ANNUAL DOSE ASSESSMENT 2013**

---

**D. CARBON 14**

<u>QUARTER</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>ANNUAL</u>
	(a)	(a)	(a)	(a)	(a)
Organ (mrem)	7.64E-03	7.73E-03	8.15E-03	8.46E-03	3.20E-02
% of Limit	1.02E-01	1.03E-01	1.09E-01	1.13E-01	2.13E-01
					(a)
Organ Dose Rate (mrem/yr)	NA	NA	NA	NA	3.20E-02
% of Limit	NA	NA	NA	NA	2.13E-03

---

(a) Dose to the Child Bone primarily by the vegetation pathway.

---

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**ADDENDUM 1 (continued)**

**TABLE 2  
 METEOROLOGICAL DATA AND LOCATIONS OF INTEREST**

RECEPTOR	GEOGRAPHIC LOCATION	ATMOSPHERIC** DISPERSION FACTOR			
		RELEASE POINT	X/Q (sec/m <sup>3</sup> )	D/Q (1/m <sup>2</sup> )	
<b>A. IODINE &amp; PARTICULATES</b>	1. Garden	0.90 mi @ 83°E	ST	2.83E-08*	1.75E-09
	Grazing Season	0.90 mi @ 83°E	RX	2.02E-07*	5.01E-09
	Cary	0.90 mi @ 83°E	TB	1.83E-07*	4.80E-09
	Location No. 78	0.90 mi @ 83°E	RF	2.02E-07*	5.01E-09
		0.90 mi @ 83°E	RW	3.21E-07*	5.76E-09
2. Meat	Grazing Season	1.18 mi @ 127°SE	ST	1.72E-08*	6.80E-10
	Parkhurst	1.18 mi @ 127°SE	RX	5.36E-08*	1.30E-09
	Location No. 26	1.18 mi @ 127°SE	TB	5.14E-08*	1.27E-09
		1.18 mi @ 127°SE	RF	5.36E-08*	1.30E-09
		1.18 mi @ 127°SE	RW	9.12E-08*	1.46E-09
3. Cow	Grazing Season	2.50 mi @ 139°SE	ST	1.67E-08*	2.65E-10
	France	2.50 mi @ 139°SE	RX	2.76E-08*	4.14E-10
	Location No. 10	2.50 mi @ 139°SE	TB	2.71E-08*	4.07E-10
		2.50 mi @ 139°SE	RF	2.76E-08*	4.14E-10
		2.50 mi @ 139°SE	RW	4.15E-08*	4.36E-10
4. Goat (D/Q)	Grazing Season	3.62 mi @ 113°ESE	ST	NA	2.28E-10
	Showers	3.62 mi @ 113°ESE	RX	NA	3.40E-10
	Location No. 71	3.62 mi @ 113°ESE	TB	NA	3.33E-10
		3.62 mi @ 113°ESE	RF	NA	3.40E-10
		3.62 mi @ 113°ESE	RW	NA	3.49E-10
5. Goat (X/Q)	Grazing Season	2.64 mi @ 152°SSE	ST	1.94E-08*	NA
	Nickolas	2.64 mi @ 152°SSE	RX	2.58E-08*	NA
	Location No. 61	2.64 mi @ 152°SSE	TB	2.57E-08*	NA
		2.64 mi @ 152°SSE	RF	2.58E-08*	NA
		2.64 mi @ 152°SSE	RW	3.59E-08*	NA

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**ADDENDUM 1 (continued)**

**TABLE 2  
 METEOROLOGICAL DATA AND LOCATIONS OF INTEREST**

RECEPTOR	GEOGRAPHIC LOCATION	ATMOSPHERIC** DISPERSION FACTOR		
<b>A. IODINE &amp; PARTICULATES</b>	DISTANCE/ DIRECTION	RELEASE POINT	X/Q (sec/m3)	D/Q (l/m2)
<b>6. Resident Annual Average</b>				
a. Inhalation <sup>(2)</sup>	1.55 mi @ 90°E <sup>(1)</sup>	ST	2.99E-08	NA
Cary	0.90 mi @ 83°E	RX	2.07E-07	NA
Location No. 78	0.90 mi @ 83°E	TB	1.88E-07	NA
	0.90 mi @ 83°E	RF	2.07E-07	NA
	0.90 mi @ 83°E	RW	3.06E-07	NA
b. Deposition <sup>(3)</sup>	0.71 mi @ 118°ESE	ST	NA	1.60E-09
Whaley	0.71 mi @ 118°ESE	RX	NA	5.52E-09
Location No. 199	0.71 mi @ 118°ESE	TB	NA	5.30E-09
	0.71 mi @ 118°ESE	RF	NA	5.52E-09
	0.71 mi @ 118°ESE	RW	NA	6.28E-09
<b>B. NOBLE GASES</b>				
1. Air Dose	1.55 mi @ 90°E <sup>(1)</sup>	ST	2.99E-08	NA
Annual Average	0.60 mi @ 90°E	ST(fc)	1.16E-07	NA
Site Boundary	0.60 mi @ 90°E	RX	3.58E-07	NA
	0.60 mi @ 90°E	TB	3.19E-07	NA
	0.60 mi @ 90°E	RF	3.58E-07	NA
	0.60 mi @ 90°E	RW	5.39E-07	NA
2. Total Body	0.60 mi @ 90°E	ST(fc)	1.16E-07	NA
Annual Average	0.60 mi @ 90°E	RX	3.58E-07	NA
Site Boundary	0.60 mi @ 90°E	TB	3.19E-07	NA
	0.60 mi @ 90°E	RF	3.58E-07	NA
	0.60 mi @ 90°E	RW	5.39E-07	NA

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT  
 JANUARY 2013 - DECEMBER 2013

**ADDENDUM 1 (continued)**

**TABLE 2  
 METEOROLOGICAL DATA AND LOCATIONS OF INTEREST**

RECEPTOR	GEOGRAPHIC LOCATION	ATMOSPHERIC** DISPERSION FACTOR		
B. NOBLE GASES (continued)	DISTANCE/ DIRECTION	RELEASE POINT	X/Q (sec/m3)	D/Q (l/m2)
3. Skin	1.55 mi @ 90°E	ST	2.99E-08	NA
Annual Average	0.60 mi @ 90°E	ST(fc)	1.16E-07	NA
Site Boundary	0.60 mi @ 90°E	RX	3.58E-07	NA
	0.60 mi @ 90°E	TB	3.19E-07	NA
	0.60 mi @ 90°E	RF	3.58E-07	NA
	0.60 mi @ 90°E	RW	5.39E-07	NA

\* Tritium Dose Calculation

\*\* Based on ODCM X/Q, D/Q Values Rev. 11

- (1) Highest Sector Average X/Q in a populated area, not an identified residence.
- (2) Inhalation uses Annual Average X/Q values. All other receptors use grazing season meteorology.
- (3) Deposition uses Annual Average D/Q values. All other receptors use grazing season meteorology.

ST = Main Stack

RX = Reactor Building Vent

TB = Turbine Building Vent

RF = Refuel Floor Vent

RW = Radwaste Building Vent

fc = Finite Cloud