



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**

REGION IV  
1600 E LAMAR BLVD  
ARLINGTON, TX 76011-4511

May 6, 2014

Lou Cortopassi, Vice President  
and Chief Nuclear Officer  
Omaha Public Power District  
Fort Calhoun Station FC-2-4  
P.O. Box 550  
Fort Calhoun, NE 68023-0550

SUBJECT: FORT CALHOON STATION - NOTIFICATION OF NRC TRIENNIAL HEAT  
EXCHANGER INSPECTION (05000285/2014003)

Dear Mr. Cortopassi:

The purpose of this letter is to notify you that U.S. Nuclear Regulatory Commission Region IV staff will conduct a triennial heat sink performance inspection at the Fort Calhoun Station. The inspection will be comprised of one reactor inspector from the NRC Region IV office. The inspection will be conducted in accordance with Inspection Procedure 71111.07, "Heat Sink Performance."

The schedule for the inspection is as follows:

Onsite inspection – June 9-13, 2014

Experience has shown that this inspection is resource intensive both for the NRC inspectors and your staff. In order to minimize the impact to your onsite resources and to ensure a productive inspection, we have enclosed a request for documents needed for this inspection. Please note that the documents are requested to be provided by June 2, 2014. We request, that during the onsite inspection week, you ensure that copies of analyses, evaluations, or documentation regarding the implementation and maintenance of your heat exchanger program are available. Of specific interest are those documents that establish that your heat exchanger program satisfies NRC regulatory requirements and conforms to applicable NRC guidance. Also, appropriate personnel knowledgeable of safety-related heat exchangers should be available to support the inspector at the site during the inspection.

We have discussed the schedule for this inspection activity with your staff and understand that our regulatory contact for this inspection will be Eric Matzke of your licensing organization. If there are any questions about this inspection or the material requested, please contact the inspector, Robert Latta, at 817-200-1532 or by email, [Robert.Latta@nrc.gov](mailto:Robert.Latta@nrc.gov)

This letter does not contain new or amended information collection requirements subject to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 et seq.). Existing information collection requirements were approved by the Office of Management and Budget, control number 3150-0011. The NRC may not conduct or sponsor, and a person is not required to

L. Cortopassi

- 2 -

respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid Office of Management and Budget control number.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

**/RA/**

Thomas R. Farnholtz, Chief  
Engineering Branch 1  
Division of Reactor Safety

Docket: 50-285  
License: DPR-40

Enclosure:  
Heat Sink Performance Inspection Document Request

cc: Electronic Distribution Fort Calhoun Station

Electronic distribution by RIV:

Regional Administrator (Marc.Dapas@nrc.gov)  
 Deputy Regional Administrator (Steven.Reynolds@nrc.gov)  
 DRP Director (Kriss.Kennedy@nrc.gov)  
 Deputy Director (Troy.Pruett@nrc.gov)  
 Acting DRS Director (Jeff.Clark@nrc.gov)  
 Acting DRS Deputy Director (Geoffrey.Miller@nrc.gov)  
 Senior Resident Inspector (John.Kirkland@nrc.gov)  
 Resident Inspector (Jacob.Wingebach@nrc.gov)  
 Branch Chief, DRP/F (Michael.Hay@nrc.gov)  
 Project Engineer, DRP/F (Chris.Smith@nrc.gov)  
 FCS Administrative Assistant (Janise.Schwee@nrc.gov)  
 RIV Public Affairs Officer (Victor.Dricks@nrc.gov)  
 RIV Public Affairs Officer (Lara.Uselding@nrc.gov)  
 NRR Project Manager (Lynnea.Wilkins@nrc.gov)  
 NRR Project Manager (Joseph.Sebrosky@nrc.gov)  
 RIV Branch Chief, DRS/TSB (Ray.Kellar@nrc.gov)  
 RIV RITS Coordinator (Marisa.Herrera@nrc.gov)  
 RIV Regional Counsel (Karla.Fuller@nrc.gov)  
 Congressional Affairs Officer (Jenny.Weil@nrc.gov)  
 OEmail Resource  
 OEWEB Resource (Sue.Bogle@nrc.gov)  
 RIV/ETA: OEDO (Joseph.Nick@nrc.gov)  
 RIV RSLO (Bill.Maier@nrc.gov)  
 MC 0350 Panel Chairman (Anton.Vegel@nrc.gov)  
 MC 0350 Panel Vice Chairman (Louise.Lund@nrc.gov)  
 MC 0350 Panel Member (Michael.Balazik@nrc.gov)  
 MC 0350 Panel Member (Michael.Markley@nrc.gov)

SUNSI Review Completed: Y ADAMS:  Yes  No Initials: TRF  
 Publicly Available  Non-Publicly Available  Sensitive  Non-Sensitive

R:\ REACTORS\FCS2014003 RFI Heat Sink-rml.docx

ML14126A549

RI:EB1		C:DRPF		C:EB1
R. Latta		M. Hay		T. Farnholtz
/RA/		/RA/		/RA/
5/2/2014		5/6/2014		5/6/2014

OFFICIAL RECORD COPY T=Telephone E=E-mail F=Fax

## **Heat Sink Performance Inspection Document Request**

Inspection Dates: June 9-13, 2014

Inspection Procedures: IP 71111.07, Triennial "Heat Sink Performance"

Inspector: Robert Latta, Senior Reactor Inspector

### **Information Requested for the In-Office Preparation Week**

The following information should be sent to the Region IV office in hard copy or electronic format (ims.certrec.com database preferred), in care of Robert Latta, by June 2, 2014. The inspectors will select specific items from the information requested below and then request from your staff additional documents needed during the on-site inspection week. We also request that you categorize the documents in your response with the numbered list below. Please provide requested documentation electronically if possible. If requested documents are large and only hard copy formats are available, please inform the inspector, and provide subject documentation during the first day of the onsite inspection. If you have any questions regarding this information request, please call the lead inspector as soon as possible.

The following heat exchangers/heat sinks have been selected for inspection:

- Raw Water/Component Cooling Water Heat Exchanger AC-1B
- Shutdown Cooling Heat Exchanger AC-4A
- Spent Fuel Pool Heat Exchanger

### **For all Generic Letter 89-13 exchangers:**

1. List of corrective action program documents (with a short description) associated with Generic Letter 89-13 heat exchangers, heat sinks, silting, corrosion, fouling, heat exchanger cavitation, or heat exchanger testing, in the previous three years
2. System health report(s) and maintenance rule system notebooks for all the GL 89-13 heat exchangers
3. Copy of any self-assessments done on any GL 89-13 heat exchangers in the previous three years
4. Copies of procedures developed to implement the recommendations of Generic Letter 89-13 (e.g., the Generic Letter 89-13 Heat Exchanger Program description)

**For the specific heat exchangers selected:**

Testing Documents

5. Copies of the two most recently completed tests confirming thermal performance for those heat exchangers which are performance tested
6. Instrument uncertainties of the instruments used during testing
7. Copy of any operability determinations or other documentation of degradation associated with the heat exchangers or the systems that support the operation for the selected heat exchangers
8. Documents that show the as-found results are recorded, evaluated, and appropriately dispositioned, such that the as-left condition is acceptable

Cleaning Documents

9. The cleaning and inspection maintenance schedule for each heat exchanger for the next five years
10. Copy of the document describing the inspection results for the last two cleaning and inspection activities completed on each heat exchanger
11. Cleaning procedures with acceptance criteria for the selected heat exchangers
12. Copies of the documents that verify the structural integrity of the heat exchanger, (e.g., eddy current summary sheets, ultrasonic testing results, and visual inspection results)
13. Copies of those documents that describe the methods taken to control water chemistry in the heat exchangers

Design Documents

14. Copies of the design basis documents and updated final safety analysis report pages for the selected heat exchangers
15. Provide a list of calculations with a description which currently apply to each heat exchanger
16. Copies of vendor data sheets and design basis data for the selected heat exchangers
17. Copy of the calculation which establishes the limiting (maximum) design basis heat load which is required to be removed by each of these heat exchangers
18. Copy of the calculation which correlates surveillance testing results from these heat exchangers with design basis heat removal capability (e.g., basis for surveillance test acceptance criteria)

19. Copy of the calculations or documents which evaluate the potential for water hammer or excessive tube vibration in the heat exchanger or associated piping
20. Copy of the document which identifies the current number of tubes in service for each heat exchanger and the supporting calculation which establishes the maximum number of tubes that can be plugged in each heat exchanger
21. Copy of the document establishing the repair criteria (plugging limit) for degraded tubes which are identified in each heat exchanger

**For the ultimate heat sink or safety-related service water system:**

22. Copies of calculations and surveillances that determine the ultimate heat sink reservoir capacity and heat transfer capability (if applicable)
23. Copies of any design changes performed on the ultimate heat sink or safety-related service water system
24. Copies of procedures for a loss of ultimate heat sink or safety-related service water system
25. Copies of inspections and/or maintenance related to macrofouling (silt, mussel shells, debris, etc.) and aquatic life
26. Copies of inspections and/or maintenance related to preventing biotic fouling
27. Copies of procedures and/or test results to survey or monitor interface valves between the safety-related section of the service water system and the non-safety-related section
28. Copy of the most recent service water flow balance test results, both as-found and as-left
29. History of any thru-wall pipe leaks on the safety-related service water system

Inspector Contact Information:

Robert Latta  
Senior Reactor Inspector  
817-200-1532  
Robert.Latta.@nrc.gov

Mailing Address:  
US NRC Region IV  
Attn: Robert Latta  
1600 East Lamar Blvd.  
Arlington, TX 76011-4511