



- NOTES CONT'D:
- LAP SPICE WILL BE PROVIDED BETWEEN EXISTING SHOTCRETE AND NEW SHOTCRETE.
  - SHOTCRETE SHALL CONFORM TO ALL REQUIREMENTS OF SPECIFICATIONS FOR MATERIALS, PROPORTIONING, AND APPLICATION OF SHOTCRETE (A.C.I. 506-77) EXCEPT AS MODIFIED BY THE REQUIREMENTS OF THESE NOTES.
  - ALL REINFORCEMENT SHALL BE LAPPED 6" ALONG SIDES AND 9" AT ENDS.
  - ALL SHOTCRETE SHALL BE EITHER DAMP CURED FOR AT LEAST 7 DAYS OR COATED WITH HUNT'S PROCESS CLEAR #90 OR EQUAL.
  - ALL STEEL WIRE MESH REINFORCEMENT SHALL BE WELDED MESH FABRICATED FROM COLD-DRAWN STEEL WIRE CONFORMING WITH THE REQUIREMENTS OF A.S.T.M. DESIGNATION A-92 & A-185.
  - SHOTCRETE SHALL HAVE A MIN. STRENGTH OF 4300 P.S.I. @ 28 DAYS.
  - ELEVATIONS ARE BASED ON M.L.L.M. = 0.00

PRC APERTURE CARD

NON SAFETY RELATED



PLAN - NORTH DITCH MODIFICATION SCALE 1" = 20'

568867	MAJOR STORM DRAINS
515305	GENERAL PLAN
515305	GENERAL NOTES
515305	ENTRY ROAD PAVING LAYOUT
515305	ENTRANCE CATCH BASIN
515306	CHANNEL WALL
W-25534	AT-30460-DWG LIST

No.	Revisions	Date	Approved	O.K.	O.K.	CLV.	Made	J.O.No.	Scale	AS NOTED

2	INCORPORATED C.C.N. # 2	10-18-78								
1	INCORPORATED C.C.N. # 1	11-11-77								
0	ISSUED FOR CONSTRUCTION	8-27-77								
B	ISSUED FOR REVIEW & COMMENTS	7-18-77								
A	ISSUED FOR INFORMATION	6-13-77								

PROBABLE MAXIMUM FLOOD UNIT - I	5-23
Location SAN ONOFRE NUCLEAR GEN. STA	
NORTH DITCH MODIFICATION	
Southern California Edison Company	

5153121-2

26X

Docket # 50-206  
Control # 8209170106  
Date 09-12-82 of Document  
REGULATORY DOCKET FILE

8209170106

REGULATORY DOCKET FILE COPY