



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 16, 2014

Mr. Michael J. Pacilio
President and Chief Nuclear Officer
Exelon Nuclear
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: OYSTER CREEK NUCLEAR GENERATING STATION – CORRECTION TO
ISSUANCE OF AMENDMENT TO REVISE TECHNICAL SPECIFICATIONS TO
ADOPT TSTF-522, "REVISE VENTILATION SYSTEM SURVEILLANCE
REQUIREMENTS TO OPERATE FOR 10 HOURS PER MONTH," USING THE
CONSOLIDATED LINE ITEM IMPROVEMENT PROCESS (TAC NO. MF3242)

Dear Mr. Pacilio:

By letter dated May 27, 2014 (Agencywide Documents Access and Management System Accession No. ML14008A350), the U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 282 to Renewed Facility Operating License No. DPR-16 and the technical specification (TS) for Oyster Creek Nuclear Generating Station, in response to your application dated December 12, 2013. The amendment modified a TS requirement to operate a ventilation system with charcoal filters for 10 hours each month in accordance with TS Task Force (TSTF) Traveler TSTF-522, Revision 0, "Revise Ventilation System Surveillance Requirements to Operate for 10 hours per Month," using the Consolidated Line Item Improvement Process.

Subsequently, it was discovered that the NRC staff made an administrative error by inserting an obsolete facility operating license page 3 into the amendment package. Enclosed is the correct page 3. This error does not change the NRC staff's conclusion in the amendment package.

If you have any questions regarding this matter, please contact me at (301) 415-3100 or by e-mail at John.Lamb@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "John G. Lamb".

John G. Lamb, Senior Project Manager
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-219

Enclosure:
Corrected License Page 3

cc: Distribution via Listserv

- (3) Pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use at any time any byproduct, source, or special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
 - (4) Pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess and use in amounts as required any byproduct source, or special nuclear materials without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
 - (5) Pursuant to the Act and 10 CFR Parts 30, 40, and 70, to possess, but not separate such byproduct, source, or special nuclear materials as may be produced by the operation of the facility.
- C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect and is subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

Exelon Generation Company is authorized to operate the facility at steady-state power levels not in excess of 1930 megawatts (thermal) (100 percent rated power) in accordance with the conditions specified herein.

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 282, are hereby incorporated in the license. Exelon Generation Company shall operate the facility in accordance with the Technical Specifications.

(3) Fire Protection

Exelon Generation Company shall implement and maintain in effect all provisions of the approved fire protection program as described in the Updated Final Safety Analysis Report for the facility and as approved in the Safety Evaluation Report dated March 3, 1978, and supplements thereto, subject to the following provision:

The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

June 16, 2014

Mr. Michael J. Pacilio
President and Chief Nuclear Officer
Exelon Nuclear
4300 Winfield Road
Warrenville, IL 60555

**SUBJECT: OYSTER CREEK NUCLEAR GENERATING STATION – CORRECTION TO
ISSUANCE OF AMENDMENT TO REVISE TECHNICAL SPECIFICATIONS TO
ADOPT TSTF-522, “REVISE VENTILATION SYSTEM SURVEILLANCE
REQUIREMENTS TO OPERATE FOR 10 HOURS PER MONTH,” USING THE
CONSOLIDATED LINE ITEM IMPROVEMENT PROCESS (TAC NO. MF3242)**

Dear Mr. Pacilio:

By letter dated May 27, 2014 (Agencywide Documents Access and Management System Accession No. ML14008A350), the U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 282 to Renewed Facility Operating License No. DPR-16 and the technical specification (TS) for Oyster Creek Nuclear Generating Station, in response to your application dated December 12, 2013. The amendment modified a TS requirement to operate a ventilation system with charcoal filters for 10 hours each month in accordance with TS Task Force (TSTF) Traveler TSTF-522, Revision 0, “Revise Ventilation System Surveillance Requirements to Operate for 10 hours per Month,” using the Consolidated Line Item Improvement Process.

Subsequently, it was discovered that the NRC staff made an administrative error by inserting an obsolete facility operating license page 3 into the amendment package. Enclosed is the correct page 3. This error does not change the NRC staff’s conclusion in the amendment package.

If you have any questions regarding this matter, please contact me at (301) 415-3100 or by e-mail at John.Lamb@nrc.gov.

Sincerely,

/RA/

John G. Lamb, Senior Project Manager
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-219

Enclosure:
Corrected License Page 3

cc: Distribution via Listserv

DISTRIBUTION

PUBLIC	RidsNrrDorLp1-2	RidsNrrPMOysterCreek
RidsNrrLAABaxter	RidsRgn1MailCenter	RidsAcrcAcnw_MailCTR
GHill, NRR	LPL1-2 R/F	

ADAMS Accession No.: ML14154A076

OFFICE	LPL1-2/PM	LPL1-2/LA	LPL1-2/BC	LPL1-2/PM
NAME	JLamb	ABaxter	MKhanna	JLamb
DATE	06/07/14	06/11/14	6/16/14	6/16/14

OFFICIAL RECORD COPY