



CB&I
128 South Tryon Street
Charlotte, NC 28202
Tel: +1 704 343 7500
www.CBI.com

10 CFR 21.21

May 20, 2014

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

**SUBJECT: CLOSURE OF INTERIM 10 CFR PART 21 REPORT REGARDING SUBMODULE
CA20-14 NONCONFORMANCE FOR VOGTLE UNIT 3 AP1000 PROJECT**

By letter dated April 23, 2014, CB&I submitted an interim report in accordance with 10 CFR.21.21 pertaining to the identification of a deviation associated with sub-module CA20-14 supplied for AP1000 CA20 module assembly for the Vogtle Unit 3 project. The sub-module was being supplied as a basic component. The report stated that evaluation of reportability in accordance with 10 CFR Part 21 was not completed within the 60-day evaluation period due to incorrectly associating the condition in the nonconformance and disposition (N&D) report with a condition that had been previously identified as part of another evaluation and interim report. The report also stated that it was expected that the evaluation of the condition would be completed by May 20, 2014.

Evaluation of the condition identified in the April 23, 2014, interim report was completed on May 9, 2014. The condition was determined to be not reportable in accordance with 10 CFR Part 21.

If you have any questions pertaining to this information, please contact Curtis Castell, Licensing Manager, at 980-321-8314.

Sincerely,

Don DePierro
Senior Vice President, Nuclear

cc: Regional Administrator, USNRC, Region II

TE19
N190