

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

394A

ACCESSION NBR: 7910100399 DOC. DATE: 79/10/02 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power and Light 05000261
 AUTH. NAME AUTHOR AFFILIATION
 STARKEY, R.B. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Region 2, Atlanta, Office of the Director

SUBJECT: LER 79-031/03L-0: on 790903, steam generator C pressure transmitter failed to full output. Cause not determined. Instrument is being closely monitored & will be returned to manufacturer if cause not found.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+2
 TITLE: Incident Reports

NOTES: -----

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL		ID CODE/NAME	LTR
	05 BC <u>ORB #1</u>	4	4			
INTERNAL:	<u>01 REG FILE</u>	1	1	02 NRC PDR	1	1
	09 I&E	2	2	11 MPA	3	3
	14 TA/EDO	1	1	15 NOVAK/KNIEL	1	1
	16 EEB	1	1	17 AD FOR ENGR	1	1
	18 PLANT SYS BR	1	1	19 I&C SYS BR	1	1
	20 AD PLANT SYS	1	1	22 REAC SAFT BR	1	1
	23 ENGR BR	1	1	24 KREGER	1	1
	25 PWR SYS BR	1	1	26 AD/SITE ANAL	1	1
	27 OPERA LIC BR	1	1	28 ACIDENT ANALYS	1	1
	29 AUX SYS BR	1	1	E JORDAN/IE	1	1
	HANAUER, S.	1	1	STS GROUP LEADR	1	1
	TMI-H STREET	1	1			
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	29 ACRS	16	16			

OCT 12 1979

cf

TOTAL NUMBER OF COPIES REQUIRED: LTR 48 ENCL 48

104



Carolina Power & Light Company

October 2, 1979

FILE: NG-3516 (R)

SERIAL: GD-79-2452

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET 50-261
LICENSE NO. DPR-23
LICENSEE EVENT REPORT 79-31

Dear Mr. O'Reilly:

In accordance with Section 6.9.2.b.1 of the Technical Specifications for the H. B. Robinson Steam Electric Plant, Unit 2, the attached Licensee Event Report is submitted. This report fulfills the requirement for a written report within thirty (30) days of a reportable occurrence and is in accordance with the format set forth in NUREG-0161, July, 1977.

Yours very truly,

H. R. Banks
Manager
Nuclear Generation

SBT:jga*

Attachment

cc: Messrs. R. A. Hartfield
V. Stello

7910100 394

5

A002
5/11