

PRELIMINARY NOTIFICATION

8005120088

April 14, 1980

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-80-58

This preliminary notification constitutes EARLY notice of an event of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by IE staff as of this date

FACILITY: Carolina Power and Light Company
Robinson Unit 2
Docket No. 50-261
Hartsville, South Carolina

SUBJECT: UNSCHEDULED OUTAGE

On April 13 the reactor was shut down to replace the seal package on the "C" reactor coolant pump after the number 2 seal indicated failure. The outage is scheduled for approximately six days.

Media interest is not expected. Neither the licensee nor the NRC plans to issue a news release. The State of South Carolina has been informed.

Region II (Atlanta) received notification of this occurrence by telephone from the licensee at 11:15 p.m. on April 13. This information is current as of 8:00 a.m. on April 14.

Contact: R. C. Sauer, RII 242-5564; P. J. Kellogg, RII 242-5649

Distribution: Transmitted H. St.
Chairman Ahearne
Commissioner Bradford
Commissioner Gilinsky
Commissioner Hendrie
Commissioner Kennedy
ACRS

S. J. Chilk, SECY
C. C. Kammerer, CA
(For Distribution)

Transmitted: MNBB
W. J. Dircks, EDO
C. Michelson, AEOD
J. J. Fouchard, PA
N. M. Haller, MPA
R. G. Ryan, OSP
H. K. Shapar, ELD
Applicable Resident Site
Other Regional Offices

Phillips
H. R. Denton, NRR
D. R. Muller, NRR
R. J. Mattson, NRR
D. Vassallo, NRR
D. Eisenhut, NRR
Willste
J. G. Davis, NMSS
R. J. Budnitz, RES

XOOS / 0:02 IE:HQ Dist.)

Landow (6 min./page)
J. J. Cummings, OIA

MAIL
R. Minogue, SD
XOOS

(Time)

PRELIMINARY NOTIFICATION