

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactors Safeguards
 Power Uprate Subcommittee: Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, June 10, 2014

Work Order No.: NRC-849

Pages 1-194

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
+ + + + +
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
(ACRS)
+ + + + +
POWER UPRATE SUBCOMMITTEE
+ + + + +
PEACH BOTTOM ATOMIC POWER STATION, UNITS 2 AND 3
EXTENDED POWER UPRATE
+ + + + +
OPEN SESSION
+ + + + +
TUESDAY
JUNE 10, 2014
+ + + + +
ROCKVILLE, MARYLAND
+ + + + +

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 8:30 a.m., Joy Rempe,
Chair, presiding.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24

COMMITTEE MEMBERS:

JOY REMPE, Chair

SANJOY BANERJEE, Member

DENNIS C. BLEY, Member

MICHAEL L. CORRADINI, Member

DANA A. POWERS, Member

HAROLD B. RAY, Member

PETER RICCARDELLA, Member

MICHAEL T. RYAN, Member

STEPHEN P. SCHULTZ, Member

GORDON R. SKILLMAN, Member

ACRS CONSULTANT:

KORD SMITH

DESIGNATED FEDERAL OFFICIAL:

WEIDONG WANG

T-A-B-L-E O-F C-O-N-T-E-N-T-S

Page

ACRS Opening Remarks

by Joy Rempe.....4

Staff Opening Remarks

by Louise Lund.....6

Introduction

by Rick Ennis.....10

EPU Overview - Background, Parameter Changes Summary,

Modification Summary, Elimination of Containment

Accident Pressure Credit

by Exelon.....15

Transient and Accident Analyses Summary

by Exelon.....78

Flow-Induced Vibration & Structural Analyses

by Exelon.....81

Power Ascension

by Exelon.....88

Public Comments.....99

Committee Comments.....108

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

P R O C E E D I N G S

(8:30 a.m.)

CHAIR REMPE: This meeting will now come to order. This is a meeting of the Power Uprate Subcommittee, a standing subcommittee, the advisory committee on reactor safeguards. I'm Joy Rempe, Chair of the subcommittee. ACRS Members in attendance are Michael Corradini, Mike Ryan, Steven Schultz, Dick Skillman, Harold Ray, Sanjoy Banerjee, and Pete Riccardella.

We expect to see Dennis Bley here soon. In addition, we have our ACRS consultant, Kord Smith here. Weidong Wang of the ACRS staff is the designated federal official for this meeting. In this meeting, the subcommittee will review the Peach Bottom Atomic Power Station, Units 2 and 3, license amendment request for an extended power uprate.

We'll hear presentations from the NRC staff and representatives from the licensee, Exelon Generation Company. We've received written comments and a request for time to make an oral statement from a member of the public regarding today's meeting also.

For agenda items, on nuclear design and safety analysis, containment analysis, and steam dryer analyses, the presentations will be closed in order to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 discuss information that's proprietary to the licensee
2 and its contract as pursuant to 5 USC 552(b)(c)(4).

3 Attendance at portions of this meeting
4 that deal with such information will be limited to the
5 NRC staff and its consultants, Exelon Generation
6 Company, and those individuals and organizations who
7 have entered into appropriate confidentiality
8 agreements with them. Consequently, we need to
9 confirm that we have only eligible observers and
10 participants in the room for the close portions of the
11 meeting.

12 In addition, I need to ask the help of the
13 staff, as well as the licensee, if some of our questions
14 in the open part of the meeting require a proprietary
15 response so that we don't violate that issue. The
16 subcommittee will gather information today, analyze
17 relevant issues and facts, and formulate proposed
18 positions and actions as appropriate for deliberations
19 by the full committee.

20 The rules for participation in today's
21 meeting have been announced as part of the notice of
22 this meeting previously published in the federal
23 register. A transcript of the meeting is being kept
24 and will be made available as stated in the federal
25 register notice. Therefore, we request that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 participants in this meeting use the microphones
2 located throughout the meeting room when addressing the
3 subcommittee.

4 The participants should first identify
5 themselves and speak with sufficient clarity and volume
6 so that they may be readily heard. We'll now proceed
7 with the meeting and I'd like to start by calling upon
8 Ms. Louise Lund and Mr. Rick Ennis from the staff.

9 MS. LUND: Okay. Thank you and good
10 morning. My name is Louise Lund and I'm the Deputy
11 Division Director for the Division of Operator Reactor
12 Licensing in the Office of Nuclear Reactor Regulations,
13 and sitting right next to me is Rick Ennis, the project
14 manager for Peach Bottom. And the staff appreciates
15 the opportunity to brief the ACRS Power Uprate
16 Subcommittee this morning on the Peach Bottom review,
17 Units 2 and 3, Extended Power Uprate Application.

18 As you know Peach Bottom Units 2 and 3 are
19 boiling water reactors owned and operated by Exelon.
20 At this meeting, the NRC staff will present the results
21 of our safety and technical review of Exelon's
22 application. Next slide.

23 The NRC has previously approved 154 power
24 uprates. Of the 854 approved power uprates, 29 are
25 considered extended power uprates, requiring major

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 modifications to the plant to achieve the increased
2 power level. Of the 29 EPUs that the staff has
3 approved, 11 were for pressurized water reactors and
4 18 were for boiling water reactors.

5 The proposed EPU power level of 3951
6 megawatts thermal, represents an increase of
7 approximately 12.4 percent above that current licensed
8 thermal power level of 3514 megawatts thermal.

9 MEMBER CORRADINI: Was there a prior
10 uprate for Peach Bottom?

11 MS. LUND: Yes. In fact, there is. Yes.
12 We'll get to that. Thank you, though. Since Peach
13 Bottom had previously implemented a 5 percent stretch
14 power uprate in the mid-1990s, and a 1.62 percent
15 measurement uncertainty uprate in 2002, the proposed
16 EPU represents an increase of approximately 20 percent
17 above the original licensed thermal power level of 3293
18 megawatts thermal.

19 To put the 12.4 percent proposed EPU in
20 perspective, here's a bar chart showing the 18 BWR EPUs
21 that have previously been approved. As you can see,
22 15 of the 18 were for power levels greater than the 12.4
23 percent proposed for Peach Bottom. Our review of the
24 proposed EPU for Peach Bottom was completed using EPU
25 Review Standard RS-001.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This review standard has been used for the
2 17 EPU reviews approved since 2005. RS-001 contains
3 guidance for evaluating each area of the review in the
4 application, including the specific general design
5 criteria used as the NRC's acceptance criteria. The
6 guidance and the template safety evaluation contained
7 in RS-001 is based on the GDC in Appendix A to 10 CFR
8 Part 50.

9 Peach Bottom Units 2 and 3 were designed
10 and constructed based on an earlier version of the GDC
11 referred to in the staff safety evaluation as the draft
12 GDC. As such, during the acceptance review, the NRC
13 staff requested Exelon to submit a supplement to the
14 EPU application to address the Peach Bottom
15 plant-specific design and licensing basis.

16 Exelon supplement provided a revision to
17 the template, safety evaluation in RS-001. The staff
18 used this template in preparing the Peach Bottom for
19 EPU safety and evaluation.

20 CHAIR REMPE: Somebody, I believe it's
21 you, Rick, that's using the microphone. Yes. I'm
22 sorry, but it bothers the recorder desperately.

23 MEMBER SKILLMAN: Louise, on that slide,
24 is the review resource requirement of 9000 hours in the
25 ballpark of other reviews or is this review

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 significantly greater in resource use?

2 MS. LUND: We talk about -- we've looked
3 at the amount of hours that -- and I would say it does
4 tend to be in the ballpark. What tends to -- it's hard
5 to generalize what a certain review is going to take
6 because it's largely driven by special topics like
7 steam dryers, you know, basically, the containment
8 pressure, upper pressure, things that end up being very
9 specific topics for reviews, so that's why it's kind
10 of hard, but this, I think, in the ballpark, wouldn't
11 you say?

12 MR. ENNIS: This is Rick Ennis. I think
13 we've recently looked at some of the hours that have
14 been spent on EPU's, and I think the average is around
15 7500. There's been some that I think has been as high
16 as 13,000, and some that's been less. I think the BWOR
17 reviews tend to be a little bit high a lot because of
18 the steam dryer reviews, so it's in the ballpark.

19 MEMBER SKILLMAN: Thank you.

20 MS. LUND: The staff's review has been
21 very thorough and involved a significant amount of
22 effort, and of course, you'll hear about that this
23 afternoon. The review has involved over 25 staff
24 members in about 9000 hours of review time to date.
25 Consistent with other BWR EPU reviews, a lot of that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 effort focused on the area of steam dryer analysis, and
2 that's largely what has driven a lot of the hours.

3 Unless there are other questions, I'd like
4 to turn it over to Rick Ennis, who is the NRC project
5 manager for the Peach Bottom EPU review, and obviously
6 knows a whole lot more about this than I do.

7 MR. ENNIS: Thank you, Louise. As Louise
8 said, my name is Rick Ennis. I'm the NRC project
9 manager for Peach Bottom in the Office Nuclear Reactor
10 Regulation Division of Operating Reactor Licensing.
11 Today you're going to hear presentations from the NRC
12 staff and Exelon regarding the proposed EPU for Peach
13 Bottom Units 2 and 3.

14 I'll present some background information
15 regarding the NRC staff review and then I'll discuss
16 the agenda for today's meeting. Throughout this
17 meeting, you may hear people refer to the PUSAR. The
18 PUSAR is the Power Uprate Safety Analysis Report which
19 summarizes the results of the safety analyses performed
20 by General Electric for Exelon to justify the proposed
21 EPU.

22 A proprietary version of the PUSAR is
23 included as Attachment 6 to the application, dated
24 September 28, 2012, and a non-proprietary public
25 version is included as Attachment 4 to the application.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The numbering in Section 2 of the PUSAR closely follows
2 the section numbering in the NRC staff's draft safety
3 evaluation that was provided to the ACRS on May 9, 2014.

4 Now I'd like to briefly discuss the
5 timeline for the review of the Peach Bottom EPU. After
6 Exelon submitted the application in September 2012, as
7 with other license amendment requests, the NRC staff
8 performs an acceptance review. In accordance with NRR
9 procedure LIC 109, acceptance reviews are performed to
10 determine if there's sufficient technical information
11 in scope and depth to allow the staff to complete its
12 detailed technical review.

13 As documented in the NRC staff letter to
14 Exelon, dated December 18, 2012, the staff determined
15 that supplemental information needed to be submitted
16 in order for the staff to perform the detailed technical
17 review. Three issues were identified.

18 First acceptance review issue related to
19 the safety evaluation template. As Louise mentioned
20 in her opening remarks, since Peach Bottom is a pre-GDC
21 plant, Exelon was requested to provide a revised safety
22 evaluation template reflecting the plant-specific
23 design and licensing basis.

24 The second acceptance review issue related
25 to additional information needed to support the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 replacement steam dryer analysis. This information
2 pertained to, in part, the design differences between
3 the Westinghouse replacement steam dryers and the
4 original equipment General Electric dryers.

5 The third acceptance review issue related
6 to the emergency core cooling ECCS analyses,
7 specifically, the application provided a summary of the
8 ECCS performance at EPU conditions, however, the NRC
9 staff determined that the application did not have
10 sufficient detail regarding the ECCS analyses in order
11 to make an independent assessment.

12 The licensee provided the supplemental
13 information requested by the staff in Supplement 1 to
14 the application, dated February 15, 2013. After the
15 staff reviewed the supplemental information, staff
16 determined that the proposed EPU was acceptable for
17 detailed review, as documented in our letter dated
18 March 8, 2013.

19 The NRC's current timeliness goals for
20 extended power uprate reviews is 18 months after the
21 staff accepts the application for detailed review. As
22 such, based on the March 8, 2013 letter, the staff
23 established a forecasted review completion date of
24 September 8, 2014. Completion by that date would
25 support Exelon's implementation of the amendment in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 fall 2014 outage for Unit 2 and Unit 3 would be
2 implemented during the fall 2015 outage.

3 During the course of the review, the NRC
4 staff sent Exelon a little over 200 requests for
5 additional information, RAI questions. These RAI
6 questions resulted in about 20 supplements to the
7 application being submitted by Exelon. And to give you
8 some perspective on the RAI questions that we asked,
9 this graphic shows you that almost half of the questions
10 were in the mechanical and civil engineering area of
11 our review, and more than half of those questions
12 related specifically to the steam dryer review.

13 Besides the steam dryer RAIs, we also had
14 a significant number in the reactor systems and
15 containment review areas. The reactor systems RAIs
16 covered a number of areas, including fuel and core
17 design, thermal hydraulic analyses, thermal
18 conductivity degradation, anticipated transients
19 without scram, and accident and transient analyses.

20 With respect to the containment review,
21 the RAIs included questions in areas such as
22 containment pressure and temperature response,
23 containment heat removal analysis, containment
24 integrity, and net positive suction head analyses.
25 The NRC staff's presentations that we'll give this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 afternoon closely align with these focus areas that we
2 had during the RAI process.

3 With respect to the agenda, this morning,
4 Exelon will provide an overview of the extended power
5 uprate. This discussion will address the plant
6 modifications that will be made, including those that
7 will be made to eliminate credit for containment
8 accident pressure for the ECCS pump's net positive
9 suction head analyses.

10 Following a break, Exelon will continue
11 with a summary of the transient and accident analyses.
12 Exelon will then discuss their flow-induced vibration
13 and structural analyses for the EPU. The last
14 presentation this morning will be discussion by Exelon
15 on the power ascension test program that'll be used as
16 part of the power uprate implementation.

17 Following a break for lunch, the four
18 topics for this afternoon will be in closed session due
19 to the proprietary nature of the information that will
20 be discussed. The first presentation will be by the
21 NRC reactor system staff and one of our contractors
22 regarding the nuclear design and safety analyses.

23 Our second presentation will be by our
24 containment and ventilation staff regarding the
25 containment analyses. Exelon will then give an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 overview on the replacement steam dryers, and following
2 a break, the NRC staff and our contractors will give
3 their presentation on the review of the steam dryer
4 analyses.

5 After the steam dryer presentation, we'll
6 be back at open session for public and ACRS comments.
7 And unless there's any questions, I'd like to turn it
8 over to Exelon.

9 CHAIR REMPE: Okay. Thank you.

10 MS. LUND: Thank you.

11 CHAIR REMPE: I need to remind you to be
12 very careful with the microphones. They're very
13 tempting to hit.

14 MR. BORTON: Good morning. My name is
15 Kevin Borton. I'm the licensing manager for power
16 uprates from Exelon. We'll do a brief introduction and
17 then we'll provide an overview, as Rick indicated, on
18 the EPU change impacts modification, in particular, the
19 cap elimination. Later this morning, we'll provide
20 summaries of the accident flow-induced vibration
21 analysis. We'll also take a look at our power
22 ascension. And finally, during the closed portion,
23 we'll discuss our overview of the replacement steam
24 dryer assessment.

25 On Slide 2 here, just as a brief

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 introduction, excuse me, Slide 3, just want to
2 introduce the folks here at the table and off to the
3 side. Again, I'm Kevin Borton, the senior manager for
4 licensing. Craig Lambert, who's over here to our
5 right, he's the vice president of power uprate. Next
6 to me is Mike Massaro. He's the site V.P.

7 John Rommel couldn't make it today. There
8 was a death in his family, so we're going to be filling
9 in for John. Ken Ainger is also at the side. He's our
10 director for power uprates, EPU. Jim Armstrong, in the
11 back here, is our reg assurance manager at Peach Bottom.
12 Dave Henry, to my left, is the senior manager of design
13 engineering at Peach Bottom.

14 And Jim Kovalchick is our senior manager
15 of operations specifically assigned for EPU
16 integrations. And then finally, Tony Hightower is our
17 shift supervisor who's been working on the project for
18 some time.

19 A little bit more about our team. Exelon
20 embarked on the Peach Bottom project back in 2009 and
21 initially staffed the project internally with Exelon
22 individuals having previous EPU and large project
23 experience. It's also important to integrate station
24 expertise and knowledge, so earlier on, we dedicated
25 an SRO, which is Tony over here, to work full-time on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the project, along with station design engineers.

2 We also brought in GE and design engineers
3 with Troy, Sargent & Lundy, who both have extensive
4 knowledge in site and design history knowledge. And
5 finally, we sought out EPU project experienced
6 individuals and companies in order to caption for
7 recent industry design and installation experiences.

8 Slide 5 is just a brief overview of our
9 application. It was based on the approved GE topical
10 reports, and as such, previous industry application
11 experience and previous NRC staff's request for
12 additional information were incorporated into the
13 Peach Bottom submittal. And for ease of review, the
14 application was prepared using the RS-001 format.

15 Okay. I'll turn it over to Mike Massaro,
16 our site V.P.

17 MR. MASSARO: Good morning again. Mike
18 Massaro, site vice president at Peach Bottom. A brief
19 overview of Peach Bottom. Again, we're a General
20 Electric BWR pool with a Mark 1 containment. Our
21 operating license was issued in 1973 for Unit 2 and '74
22 for Unit 3. We began commercial operation in 1974, and
23 those licenses were renewed in 2003, so for Unit 2, that
24 license will expire in 2033, and Unit 3 will be 2034.

25 Our original thermal license power was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 3293 with a stepped stretch uprate in '94 and '95 for
2 Units 2 and 3 respectively, and we had MUR power uprates
3 in 2002 to 3514, which is our current licensed power
4 uprate. Our proposed EPU is 20 percent of OLTP,
5 original licensed power, and 12 percent of our current
6 licensed power uprate.

7 I'll go over some key parameter changes.
8 Again, core thermal power with this proposed change
9 would move from 3514 megawatts thermal to 3951.
10 Licensed full power core flow range would move from
11 84.87 to 112.75, and from there, to 101.48, 112.75.
12 Again, it is constant power pressure uprate, so no
13 change in reactor pressure.

14 Vessel steam flow and feedwater flow
15 increased proportionality with the power increase.
16 Final feedwater temperature, we do expect, nominally,
17 to remain 381.5. And CAP credit containment accident
18 pressure credit will be eliminated, and we'll have a
19 presentation that talks specifically to that.

20 MEMBER CORRADINI: When we visited you, I
21 know you said this, but I can't remember, so the 110
22 percent of full power flow range has always been there
23 or is that something you guys had done recently?

24 MR. MASSARO: No, that's always been
25 there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: All right. Thank you.

2 MEMBER BANERJEE: I mean, it can be
3 actually operated at 110.

4 MR. MASSARO: No, we have not been able to
5 achieve 110.

6 MEMBER CORRADINI: That's what I
7 remembered, you guys gave us a discussion, but I don't
8 remember, but it can be over 100. There's some limit
9 on the heat exchangers? Am I remembering correctly?
10 I'm sorry.

11 MR. MASSARO: The limit, I believe, is
12 recirc --

13 MR. HENRY: This is Dave Henry from
14 Exelon. The limitation that we run into is recirc pump
15 speed, 1660 rpm speed, and with the jet pump efficiency,
16 depending on where we're at in cycle, we can get close
17 to 110 percent, but not up to 110 percent.

18 MEMBER CORRADINI: Okay. All right.
19 But it doesn't make it, but you can go above 100, is
20 what I remember.

21 MR. HENRY: Absolutely. Yes.

22 MEMBER CORRADINI: Okay. Thank you.

23 CHAIR REMPE: Also, could you just
24 clarify, from what we've been reading, what fuel's in
25 the plants now and what fuel will be in the plant when

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you start the EPU?

2 MR. BORTON: Right now we have a mixture
3 of -- it's all GE fuel. It's a GE14 and a GNF2 fuel,
4 but for power uprates for both Unit 2, we'll have full
5 core GNF2 fuel.

6 CHAIR REMPE: Okay.

7 MEMBER BANERJEE: So for the EPU, do you
8 intend any operation about the 100 percent bar within
9 the 100 to 110 to do any flow control?

10 MR. BORTON: Prior to EPU?

11 MEMBER BANERJEE: No, no. After EPU.

12 MR. BORTON: Could you state the question
13 again?

14 MEMBER BANERJEE: Let's say, after you
15 have your EPU, would you be considering any operation
16 above 100 percent of core flow?

17 MR. BORTON: I believe the answer to that
18 is yes. I'll turn it over to Tony. Yes.

19 MR. HIGHTOWER: Yes. Tony Hightower,
20 Peach Bottom operations, and yes, we will continue to
21 use the flow region above 100 percent.

22 MEMBER BANERJEE: But that would be used,
23 essentially, to do some full control?

24 MR. HIGHTOWER: Use of the flow region
25 above 100 percent will allow us to maintain power

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 through our operating cycle using flow control. It'll
2 allow us that flexibility.

3 MR. MASSARO: Tony, I believe that we were
4 looking at a flow range from 99 to 103, correct?

5 MR. HIGHTOWER: That's correct, Mike.
6 The 103 is based on the capability of the recirc system.
7 We'll continue to be licensed to the 110 percent core
8 flow. The 99 percent is the limitation with the EPU
9 power to flow map.

10 MR. MASSARO: Right. Thanks, Tony.
11 Okay. With that, I'll move into major modification
12 summary. Again, these are major mods that improve
13 reliability and operating. There are a number of other
14 modifications, which I won't cover here, unless there
15 are questions about it. We are adding one main steam
16 relief valve. That'll be set at 1260 psig, that is of
17 the same manufacturing design as the existing two. We
18 currently have two per unit.

19 It'll be added to the Charlie main
20 steamline and replace by removing a blank flange and
21 placing a dresser SRV in that location. We'll be
22 replacing the steam dryer, and again, there will be a
23 separate presentation regarding the steam dryer.
24 That'll improve our moisture carryover significantly.
25 We have found that a lot of our BOP plant steam cytosis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are a result of cobalt carryover.

2 This modification will not only improve
3 stress ratios on the dryer, but it'll also improve
4 reliability and doses in the plant by reducing moisture
5 carryover.

6 MEMBER CORRADINI: I'm sorry, but again,
7 back to what you guys were telling us when we were there,
8 and I'm trying to remember, did you guys already do a
9 turbine blade expansion so that you got a bit more out
10 of electrical power? And that helps there too I
11 assume.

12 MR. MASSARO: We've already replaced all
13 the LP turbines on both units.

14 MEMBER CORRADINI: Okay.

15 MR. MASSARO: So three LPs on each unit
16 have been previously replaced.

17 MEMBER CORRADINI: This would extend the
18 life on that lowest stage, right? Am I remembering
19 correctly? In other words, you don't have the chance
20 of the last stage replacement is -- of not replacing
21 it is improved by, essentially, reducing moisture
22 carryover, if I remember it correctly?

23 MR. MASSARO: I'm not so sure that it has
24 that much to do with moisture -- the DLP last stage has
25 that much to do with moisture carryover.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Okay. All right.

2 Thank you.

3 MEMBER BANERJEE: Do you use zinc in this
4 plant?

5 MR. MASSARO: Yes, we do.

6 MEMBER SCHULTZ: Mike, you're going to go
7 through a number of modification descriptions here.
8 Exelon has got, in a sense, a unique -- is in a unique
9 position in that, it's a company that has many BWRs,
10 many have been through an uprate process, and I'm just
11 interested knowing, as you go through the
12 modifications, which would be considered new in terms
13 of application, that is, is Peach Bottom doing
14 modifications which are different from what has been
15 done before; unique for the plant; unique for the fleet?

16 MR. MASSARO: Okay. I will --

17 MEMBER SCHULTZ: And Dave might want to
18 pitch in on that too.

19 MR. MASSARO: That's fine. I'll touch on
20 those as we go through.

21 MEMBER SCHULTZ: I'd appreciate that.
22 Thank you.

23 MR. MASSARO: You know, I'd start out by
24 saying the containment accident pressure elimination
25 modifications, for the most part, are all unique. Next

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on here is high pressure turbine replacement. As I
2 mentioned, we've replaced all the LP turbines, three
3 per unit, previously, and with EPU, we'll replace the
4 high pressure turbine. That'll be an awesome designed
5 machine, it will not have shrunk on rotors, and it will
6 fit within the existing shell, so essentially, we're
7 replacing the rotating element, diaphragms, and the
8 like. The shell will remain the same.

9 Feed pump turbine upgrades, the reactor
10 feed pump turbine upgrades, we have three feed pump
11 turbines on each unit. What we're proposing to do here
12 is replace the turbines on each of those feed pumps,
13 including casing and all components within the casing.
14 We will not be replacing the feed pumps themselves, just
15 the turbines.

16 And that's a result of our analysis that
17 there would be increased stress on some of the blades
18 in the existing feed pump turbines. I would mention
19 that, unique to Exelon fleet, we have benchmark, and
20 we are looking at the experience that, I guess it's free
21 to say, Susquehanna's had, so they're one of the units
22 we're looking at that's done something similar in this
23 area.

24 Feedwater heaters. We've reviewed all
25 our feedwater heater current condition, material

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 condition, for uprate, and we are replacing one on
2 Unit2, and four on Unit 3. We've already replaced two
3 of the ones on two of the LP turbines, or second stage
4 -- I'm sorry, second stage feedwater heaters on Unit
5 3 in the last refueling outage.

6 This outage, we'll be doing one on Unit 2
7 and then in 2015, we'll be replacing the other two feed
8 heaters on Unit 3. And again, the other feed heaters
9 have been analyzed and verified to be acceptable for
10 EPU conditions. And that was mostly the result of some
11 internal degradation in the feedwater heaters and two
12 flooding conditions.

13 Reactor water cleanup modification, we
14 have done similar modifications to this in other parts
15 of the fleet, and some of our fleet is following us in
16 this. We are not increasing flow-through reactor
17 water cleanup system as part of this modification.
18 What we are doing is improving the efficiency of the
19 cleanup system through a number of modifications.

20 One is an integrated flow distributor to
21 get a more even resident distribution in the cleanup
22 system. We're also doing a vessel slow pressurization
23 mod, if you will, not to disturb pre-coat, and a metered
24 pre-coat as well as a modification to the backwash
25 system to get a better backwash on the reactor water

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cleanup filter deviance.

2 Condensate pump motor upgrades, would not
3 say that we've done something similar to this through
4 the rest of the fleet, but it is pretty straightforward
5 in terms of its design. We will be installing new pumps
6 in the existing wells. These will require new motors
7 as well as upgraded motors, so pump motors will go from
8 4500 horsepower, nominally, to 5000 horsepower,
9 nominally. And again, new pumps in the existing wells
10 with new motors.

11 Condensate filter demineralizer. We have
12 ten condensate filter demineralizers on each unit.
13 The modification here, which is, I would say, unique
14 to Exelon, is to add two filter demins. They would be
15 very much the same as the existing ten and it will
16 improve the capacity of the condensate demin system by
17 20 percent.

18 The controls will be modified for all ten,
19 but that's strictly for backwash and pre-coat control.
20 So pretty straightforward modification in terms of
21 complexity, the large piping job, and, you know, with
22 two additional vessels being added.

23 Main steam pipe piping. We did review our
24 main steam piping support design and found that for EPU
25 conditions, we needed to make some upgrades to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 piping supports, including snubbers and supports. We
2 implemented those changes on Unit 3 in the last
3 refueling outage last year. That would include the
4 analysis was performed all the way from the reactor,
5 essentially, to the turbine control valves, and those
6 modifications were performed both inside and outside
7 containment.

8 So modifications completed on Unit 3, we
9 have had good experience and no issues with that on Unit
10 3, in our experience, and expect to do the same thing
11 on Unit 2 this coming refueling outage.

12 MEMBER SKILLMAN: Mike, what are the
13 details on the inspections? With new supports and
14 snubbers, that's great you're holding down the higher
15 mass flow rate, and the velocity, that type of thing,
16 what kind of inspections preceded those mods to make
17 sure that the piping that remains is fit for duty?

18 MR. MASSARO: Well, you're asking about --

19 MEMBER SKILLMAN: Pipe.

20 MR. MASSARO: -- prior to design, the
21 walk-downs that --

22 MEMBER SKILLMAN: Well, no, you've been
23 operating for years, you're not changing piping, you're
24 strengthening the support and restraint system.

25 MR. MASSARO: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: And I'm asking about the
2 piping that is being supported in the restraining, but
3 what inspections were performed so that we know that
4 that piping is not vulnerable to steamline break?

5 MR. MASSARO: If we could, take that
6 question and relay that back and get you an answer
7 before the closed session today.

8 MEMBER SKILLMAN: Yes, thank you.

9 MR. MASSARO: I would say that there was
10 initial inspection on Unit 3 as we entered the refueling
11 outage to go in and verify the condition of piping
12 supports as part of the ECR, what we expected to find
13 there, not only in terms of configuration, but in terms
14 of condition. You're asking specifically about the
15 piping. We'll followup with that.

16 MEMBER SKILLMAN: Thank you, Mike.

17 MR. MASSARO: Main generator
18 modifications. We did purchase a new main generator
19 rotor for Unit 3 and installed that rotor in the last
20 refueling outage in 2013. The rotor from Unit 3 was
21 removed and has been sent off to be upgraded and will
22 be installed in Unit 2 this coming refueling outage.
23 As part of that as well, we -- and that'll give us the
24 necessary MVA margin that we need for EPU conditions.

25 As part of that as well, we replaced the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Alterex on Unit 3, which included the doghouse, if you
2 will, and that was all completed on Unit 3, as well as
3 the automatic voltage regulator. All those mods were
4 completed on Unit 3 in 2013; in the fall. We've had
5 good experience with those modifications to date. And
6 essentially, expect to perform the same thing on Unit
7 2 this coming refueling outage, with the difference of
8 the rotor will be a refurbished rotor as opposed to a
9 brand new one.

10 Isophase bus duct modifications, this mod
11 has been performed at other facilities in our fleet.
12 Essentially, we're replacing portions of the isophase
13 to support the additional power. We did perform this
14 modification on Unit 3 in the last refueling outage,
15 so it was completed, and have had good experience with
16 that as well, and we expect to do, essentially, the same
17 thing on Unit 2 in the upcoming refueling outage.

18 The duct work goes from, nominally,
19 30-inch sized duct to 40-inch sized duct. It's not
20 complete replacement, but the majority, I would say,
21 between the generator out to the area of the in-power
22 transformers has been replaced.

23 ATWS recirc pump trip, we found as a result
24 of our analysis that the ATWS recirc pump trip needed
25 to be moved from the dry motor breaker to the generator

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 output breaker, I hesitate to say EOC breaker, but to
2 the breaker that also performs the end-of-cycle RPT
3 trip. That modification will be performed and
4 established by installing an additional trip coil on
5 that EOC RPT breaker and moving, essentially, the logic
6 signal from the dry motor breaker to the EOC RPT
7 breaker.

8 That is not particularly complex in
9 nature. I'm not aware of any other plant in our fleet
10 that's done that, but I wouldn't expect to have any
11 issues. We do have other plants that have dual trip
12 coils, you know, experience.

13 Motor-operated valves, we found that from
14 our review there were a handful of motor-operated
15 valves that would either be below margin or low margin
16 as a result of EPU, and those valves will be modified
17 in the upcoming refueling outage to support it.

18 We have a low margin program where we
19 continuously review valves. There are eight valves,
20 essentially, that require modification. They're all
21 associated with ECCS suction at the suppression pool
22 in the torus, you know, at HPCI, RCIC, core spray arch.
23 And those valve modifications will typically include
24 gear train modifications, not valve replacement.

25 RHR, the modifications on this page are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 specifically associated with CAP credit elimination.
2 I would say that all these modifications are fairly
3 unique within our fleet, and there will be extensive
4 discussion on them. I'll just touch on them briefly,
5 but essentially, we've got other experts in the room
6 that are probably better versed on talking to them.

7 An RHR heat exchanger cross-tie mod. This
8 will install a 10-inch cross-tie within divisions on
9 each of the RHR systems. We did a portion of this in
10 the last refueling outage in unit 3. We did not
11 complete the cross-tie modification. This was to gain
12 some knowledge about the difficulty. Most of this is
13 piping work and so we started into this in the Unit 3
14 refueling outage. We expect to do both divisions in
15 the upcoming Unit 2 refueling outage.

16 Again, it's a 10-inch cross-tie
17 modification within divisions, which will include a
18 valve to be able to balance flows through the RHR heat
19 exchangers for CAP elimination. HPSW, high pressure
20 service water cross-tie goes along with the RHR
21 cross-tie. It's part of CAP elimination. This is the
22 pooling water system for the RHR heat exchangers, and
23 essentially, this'll provide us a mechanism to cross
24 within divisions, also, to be able to cool RHR in the
25 event of a loss of a diesel or a vital bus.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Mike, for those two
2 modifications, the cross-tie for the RHR heat
3 exchangers, and the high pressure service water
4 cross-tie, in creating those cross-ties, have you
5 violated any of your string independence or credited
6 redundancy from your license?

7 MR. MASSARO: No, we have not, and I think
8 we can explain more or get into further details as we
9 do that. Again, it's within divisions and that's been
10 all thoroughly reviewed as we've gone through the
11 process.

12 MR. HIGHTOWER: This is Tony Hightower
13 from Peach Bottom. To clarify, the HPSW cross-tie
14 itself was between divisions. RHR is within
15 divisions. The HPSW cross-tie is an existing
16 cross-tie that we have for operational flexibility.
17 It's used after we have a single failure so it allows
18 us to continue to meet our separation criteria, and
19 operating procedures will be tailored to ensure that
20 we only operate that cross-tie after that single
21 failure of safety-related component has occurred.

22 MR. MASSARO: Thank you, Tony.

23 MEMBER SKILLMAN: Thank you.

24 MEMBER SCHULTZ: Mike, you've got a couple
25 more on this slide?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MASSARO: One more. Well, actually,
2 two more, condensate storage tank modifications, which
3 include a standpipe to preserve volume within the CST,
4 again, this is for CAP elimination in the event of an
5 Appendix R fire. And that also -- what goes
6 hand-in-hand with this is raising the torus suction
7 swap-over to HPCI, again, to preserve inventory in the
8 CST.

9 And last is standby liquid control system.
10 This is a modification to support. Essentially, what
11 we're doing here is increasing atom weight of boron-10
12 in the SLC system. There is a marginal increase in
13 inventory level, but that's specifically the change in
14 boron concentration is to support ATWS. The change in
15 level is to more support the pH within the torus
16 post-accident.

17 MEMBER BANERJEE: Could I ask you a
18 question, which you don't have to answer, why did you
19 decide to do this?

20 MR. MASSARO: I can get a little bit more
21 into that --

22 MEMBER BANERJEE: Will you get into it?

23 MR. BORTON: Yes.

24 MEMBER BANERJEE: Because it's
25 interesting. As you know, of course, plans are going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 forward with CAP and this is a very nice way to do it,
2 I'm sure, but it involves a little additional costs,
3 so I'd be very interested to know the answer to that.

4 MR. BORTON: And to cut to the chase a
5 little bit too, we had the opportunity to do it here.
6 We have kind of a unique design, you know, where other
7 plants did not. So I'll get into that --

8 MEMBER BANERJEE: Okay. Great. But you
9 take some sort of a financial hit on this, right?

10 MR. BORTON: There is an expense to making
11 this modification, of course.

12 MEMBER SCHULTZ: My question on the
13 modifications goes to, you mentioned a number that have
14 already been implemented on Unit 3, but not all have
15 been implemented there, and you didn't mention Unit 2
16 associated with any previous work here, so how are the
17 modifications going to be implemented going forward on
18 Unit 2 and then on Unit 3? If you're going to discuss
19 the process later, I'll wait, but I'm interested in
20 knowing what the sequence of events is for each of the
21 units going forward.

22 MR. MASSARO: Well, we will install all
23 the modifications that I've covered here, and then
24 some, on Unit 2 in the upcoming refueling outage, which
25 starts in October. That'll put everything in place to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 support EPU. The remainder of the modifications on
2 Unit 3 will be installed in 2015 in that refueling
3 outage.

4 MEMBER SCHULTZ: And then Unit 3 will
5 proceed to the upgraded condition.

6 MR. MASSARO: Correct.

7 MEMBER SCHULTZ: Good. Thank you.

8 CHAIR REMPE: But Unit 2 goes through the
9 EPU first, right, from what I've read and the dryer,
10 it will be installed this fall?

11 MR. MASSARO: That's correct.

12 MEMBER BANERJEE: Does this have any
13 implications on GSI-191?

14 MR. MASSARO: GSI-191?

15 MEMBER CORRADINI: You got to help him.

16 MEMBER BANERJEE: Debris blockage,
17 because, you know, the flows are being reoriented and
18 I don't know what all the implications of this are.

19 MR. MASSARO: Torus suction. Debris
20 blockage within the torus, that was considered as part
21 of the modifications to the RHR system. Core spray
22 system is essentially remaining unchanged to RCIC, and
23 no significant modifications, clearly, that was a
24 design consideration.

25 MEMBER BANERJEE: But you took that into

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 account, was there increased flows or anything that
2 occurred?

3 MR. MASSARO: Actually, when they talk
4 about the modifications, we'll find that, for the RHR
5 systems, the flows were decreased.

6 MEMBER BANERJEE: Okay.

7 MEMBER SCHULTZ: Mike, as you went through
8 and talked about the modifications on Unit 3, a couple
9 of times you mentioned that there were no issues
10 associated with those modifications. Were there any
11 issues associated with modifications in terms of
12 lessons learned?

13 MR. MASSARO: There were, clearly,
14 lessons learned from the modifications. The RHR
15 cross-tie, we had lessons learned about some of the
16 difficulty in dealing with the contaminated piping
17 welding. That was a large learning. The main
18 generator rotor upgrade, we actually, by design,
19 employed too many additional brushes in that design and
20 had to go and reduce some of the brushes. We employed
21 more brushes to support EPU. It turned out that that
22 didn't provide the current density that we needed, and
23 we found that as we came out of the outage by an
24 accelerated degradation of the brushes. We've since
25 reduced that brush configuration to local support

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 current power level.

2 We have critiques from all of the mods. We
3 actually had also done a causal analysis, put them all
4 together and done a causal analysis, a root cause around
5 many of the modifications to make sure that we
6 understood all the things that we needed to improve and
7 improved going into the Unit 2 refueling outage.

8 The modifications associated with the EPU
9 on Unit 3, none of them were necessarily mandatory in
10 the Unit 3 outage. So, you know, that was a learning
11 outage for us with respect to how difficult it would
12 be to do the mods and we took that opportunity to do
13 that, so clearly, we step back and look at lessons
14 learned from those modifications.

15 MEMBER SCHULTZ: Good. Thank you.

16 MR. BORTON: Okay. I'd like to move on to
17 the next major modification that we did. Again, John
18 Rommel could not be here today with us. He had to be
19 with his family. So I'll present today using John's
20 notes and the support of the other members of the team
21 here who worked on the elimination of CAP credit. So
22 turning to Slide 15. This should be a familiar figure
23 here.

24 As part of our initial EPU strategy, we
25 included an investigation to the practicality of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 eliminating the need for containment action to pressure
2 credit at Peach Bottom. We considered it as an
3 opportunity to improve the NPSH margins and
4 effectively, remove any industry concerns that might
5 exist with CAP credit at Peach Bottom as well.

6 So referring to this simple diagram. The
7 term in question here is the head generated by the
8 atmosphere present, and that's in this section here of
9 course, that's present in containment. So our current
10 licensing basis allows for some of the pressure
11 generated during an accident or special event, to
12 increase the value of this term above that pre-accident
13 condition.

14 MEMBER BANERJEE: Can you remind us for
15 how long and -- you had 6.1, was that psi?

16 MR. BORTON: Right, psig.

17 MEMBER BANERJEE: Psig, and for how long
18 was that needed?

19 MR. BORTON: Tony, I think that was for the
20 shorter portion of the accident. How long CAP credit
21 is needed and --

22 MEMBER BANERJEE: Apparently needed.

23 MR. HIGHTOWER: Right. This is Tony
24 Hightower from Peach Bottom. I don't have the specific
25 answer to that question.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Could we get it?

2 MR. BORTON: Mike?

3 MR. MASSARO: We can get that answer.
4 This is Mike. We can get that answer.

5 MEMBER BANERJEE: Thanks.

6 MEMBER CORRADINI: If you're going to go
7 through all the effort to find the time, what was the
8 limiting accident that needed it? I can't remember
9 which one it was. Was it LOCA or is it plant-wide?

10 MR. BORTON: Yes, I'm going to get through
11 that, each one of them, so each one will be addressed
12 here.

13 MEMBER CORRADINI: Okay. Sorry.

14 MR. BORTON: Again, this is just really an
15 overview to look at that we did for the CAP credit
16 elimination. Of course, the equation here, you know,
17 the atmospheric that we're talking about here, the
18 static head, any losses due to the piping and valving
19 configuration, and then vapor pressure in the pump,
20 which is also a reduction.

21 So in order to address the opportunity, we
22 look at a number of option combinations and concluded
23 that a practical design was possible that would
24 eliminate the need for CAP credit at Peach Bottom.
25 Thus, as part of our EPU submittal, we provided a design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that eliminated the need for CAP credit. In the next
2 few slides, I'll go and describe the key elements and
3 the actions we took to make that happen.

4 MEMBER BANERJEE: Did this process start
5 when we were still fighting over CAP credit or was it
6 --

7 MR. BORTON: Our process was, you know, we
8 started in 2009, it was around 2010, we started looking
9 at CAP credit and the opportunity to remove that. So
10 it was two major reasons, one is, we looked at the
11 opportunity we had, perhaps, a means, so we started the
12 investigation into that, and as we got further into it,
13 we saw we can improve the margins, and of course, we
14 would avoid any unnecessary delays or anything else
15 with EPU.

16 Okay. Slide 17, I'm on right now, to
17 start, we had a little background, so we had CAP credit
18 for both accidents and special events. And while the
19 debris of credit varies from event to event, currently,
20 we take 6.1 psig that occurs in the long-term portion
21 of the local, so we'll find out a little bit more detail
22 and we'll get that back to you on that as well.

23 I'd like to move on to Slide 18. So this
24 is, essentially, how we looked at removing CAP credit,
25 and there is not really one-size-fits-all-type answer.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Some of the actions we took applied to accidents and
2 other were special events, and some impacted both. As
3 this slide describes, there's a high-level, four key
4 actions that were required to eliminate CAP credit and
5 I'll go through each one in more specific detail. I'll
6 follow-up on subsequent slides here.

7 But for now, the four key steps in the CAP
8 credit elimination were, the first one was, to increase
9 the RHR heat transfer capability and remove more heat
10 allows for the reduction of pool temperature. This
11 reduces the loss due to vapor pressure and it also
12 increases the heat removal capacity accomplished. We
13 did that in two major steps.

14 First, the RHR in the HPSW cross-tie
15 modifications were performed, and I'll walk through
16 them in greater detail in a couple of slides, and then
17 second, we reduced the amount of allowable fouling in
18 a generic letter 8913 test program for the RHR heat
19 exchangers. In this case, we looked at the past test
20 data and we saw that there was a margin between the
21 actual performance and what our design basis was, so
22 therefore, we took advantage of some of that high margin
23 and left ourself some margin as well.

24 MEMBER CORRADINI: So this is a chemistry
25 effect, the actual fouling that you're measuring is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 much less than the assumed fouling.

2 MR. BORTON: That's correct.

3 MEMBER CORRADINI: And do you know the
4 source of why it's better than what you assume or did
5 it just turn out, empirically, it's best?

6 MR. BORTON: We just looked back and
7 that's what we found.

8 MEMBER CORRADINI: But I mean, the root
9 cause is chemistry change? I'm just kind of curious
10 what it was.

11 MR. BORTON: It was more likely, and we'll
12 go back and take a look and see if we can find an exact
13 answer to that question, but it's basically, we had
14 over-designed. We had more margin in our design.

15 MEMBER CORRADINI: Okay.

16 MR. MASSARO: And I would also say that the
17 preventative maintenance program cleaning program on
18 the RHR heat exchanger is factored into that as well.

19 MEMBER CORRADINI: Thank you.

20 MEMBER BLEY: Does this imply a commitment
21 to ensure that you maintain that margin?

22 MR. BORTON: Yes, it does.

23 MEMBER BLEY: Thank you.

24 MR. BORTON: So there'll be a new
25 cleanliness criteria that we have for just the heat

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 exchangers. The second key action, we needed to reduce
2 the required RHR pump flow, which was a question that
3 was asked earlier. Lowering the RHR flow reduces the
4 MPSH required values without significantly impacting
5 a de-cladding temperature of results.

6 The third key was to use the condensate
7 storage tank as a water source during special events.
8 The extra water inventory helped reduce the pool
9 temperature, vapor loss, again, as well as it adds extra
10 height, increasing our static head, both which increase
11 the available MPSH.

12 And then I'll get into more modifications
13 and more details about the CST in a couple slides here,
14 but finally, we increased the standby liquid control
15 boron-10 enrichment to 92 percent. This results in a
16 more rapid power reduction in the ATWS event and then
17 less heat being added to the containment.

18 MEMBER BANERJEE: So I mean, one important
19 effect is that the water in that tank is colder, right?

20 MR. BORTON: Yes.

21 MEMBER BANERJEE: And how much colder is
22 it compared to the peak? Is it 10 degrees Celsius or
23 Fahrenheit colder?

24 MR. BORTON: For our suppression pool?

25 MEMBER BANERJEE: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BORTON: Yes, so for the accident
2 conditions, the cross-tie, we did it on that, our heat
3 removal capacity, and I'll go into that, went up about
4 65 percent.

5 MEMBER BANERJEE: Oh, that much.

6 MR. BORTON: Yes.

7 MEMBER BANERJEE: So it's quite a bit
8 colder.

9 MR. BORTON: Yes, 1.6 times greater than
10 it was prior to that.

11 MR. DICK: This is Michael Dick from
12 Exelon. Actually it is, for the design basis LOCA, at
13 current power level, the design analysis had a peak pool
14 temperature of 206 Fahrenheit, and at EPU condition,
15 with the use of a cross-tie, the peak temperature goes
16 to 187.6, I believe. So effectively, we've reduced
17 that temperature significantly, plus we've overcome,
18 essentially, what you would assume the normal increase
19 of about 10 degrees of the effective EPU.

20 So the net effect is about a 30 degree
21 increase in heat removal capability for the
22 containment.

23 MEMBER BANERJEE: Thank you.

24 MR. BORTON: In the suppression pool.

25 MR. DICK: Suppression pool.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BORTON: Yes, I'm sorry. I was
2 talking about the heat exchanger earlier. So this
3 slide shows how each of the different actions we took
4 impacted the various event analysis and integrated to
5 an overall strategy to eliminate the need for CAP
6 credit.

7 As you can see, the RHR and the HPSW here
8 really effect the accidents and the condensate storage
9 tank actions are specifically for special events.

10 MEMBER BANERJEE: So with the reduced
11 flow, you got some additional margin on MPSH, right?

12 MR. BORTON: That's correct.

13 MEMBER BANERJEE: Are you going to go
14 through us for that; how that changes --

15 MR. BORTON: Yes, we're going to go
16 through each one of those and tell you the differences
17 here. The K-factor for the heat exchanger, for
18 cleanliness, and the RHR pump changes impacted the
19 overall RHR system, so they pretty much address all the
20 events. And what I'd like to do is -- well, I guess,
21 to answer your question now, looking ahead, we're going
22 to go through how each one of those go through, and I
23 think I can --

24 MEMBER BANERJEE: That's fine. Just take
25 your time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Just remind me. I
2 think I understand why the X's aren't in ATWS and SBO
3 for the cross-tie. Why isn't it in the Appendix R? I
4 don't remember. Is there a failure there; an assumed
5 failure?

6 MR. DICK: This is Michael Dick from
7 Exelon. Essentially, it is that there are, I believe,
8 about 70 Appendix R scenarios. As you go through the
9 plant, you assume fires in each one of the different
10 rooms and area of the plant. Well, essentially, when
11 we were looking to see if we could use the cross-tie
12 for those events, we found that we could use it for the
13 majority of the room fires, but we couldn't use it for
14 all of them.

15 MEMBER CORRADINI: So you're limited by
16 the most --

17 MR. DICK: Yes, so we did not credit it for
18 any fire events.

19 MEMBER CORRADINI: All right. Thank you.

20 CHAIR REMPE: When I looked through the
21 material that was provided to us, there's design basis
22 analysis and conservative analyses, and I believe it
23 was in the design basis, well, in both cases, there were
24 different assumptions made for the current power level
25 versus the EPU, and sometimes the explanation was that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we did sensitivity studies and picked the worst value,
2 but I believe you did those sensitivity studies on a
3 parameter-by-parameter basis individually.

4 And it wasn't clear to me that you really
5 nailed the most limiting value sometimes, and I wasn't
6 sure how important those assumptions were made. I
7 didn't see anything in your slides about this. In the
8 staff's slides, they mentioned that they had some
9 questions about how these parameters were selected, but
10 they were resolved, but I would really like to hear your
11 explanation of how this analysis was done, if you could.
12 Maybe that needs to be in the closed session, but I --

13 MEMBER BANERJEE: This is not closed?

14 CHAIR REMPE: This is open right now. And
15 so I would appreciate having a little more detail so
16 that I felt a bit more comfortable about what I was
17 reading.

18 MR. BORTON: Okay. And I think you're
19 talking about a few items that go beyond the CAP as well.

20 CHAIR REMPE: I believe most of it was put
21 in the framework for CAP, and especially in the staff's
22 presentation, and where it was located in the
23 documentation, but it would just --

24 MR. BORTON: We'll go over those details
25 in that session later this afternoon.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: Okay. I'd appreciate that.

2 MEMBER BANERJEE: So you can refuse to
3 answer any questions.

4 MEMBER CORRADINI: So one other
5 clarification, the number 2 bullet and the number 3
6 bullet, increased and reduced, they're coupled, right?
7 They're really the same effect. You get better heat
8 exchanger performance so you don't need to run the pump
9 as fast, right?

10 MR. BORTON: Right.

11 MEMBER CORRADINI: Okay.

12 MR. BORTON: So there's really a
13 combination --

14 MEMBER CORRADINI: Okay. So it's a
15 coupled effect. That's why it's applicable across the
16 way. Let me ask you another question, at least since
17 it's applicable across the way, did you guys do an
18 analysis, because you're taking credit for reduced
19 fouling, does that remove you out of CAP credit or does
20 that take you a lot of the way there? If all the other
21 things were disappearing, would that take you all the
22 way there or where does that take you?

23 MR. BORTON: Each and every one of these
24 were required to reduce CAP credit.

25 MEMBER CORRADINI: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: I guess his question is
2 one that I also had. If you only took the increased
3 credit for fouling, how far would it take you? Like,
4 you got a 30-degree change in temperature there, or
5 something like that, would you be able to get 5 degrees
6 with that, or 10 degrees with that, just out of the
7 reduced fouling?

8 MR. BORTON: We can take that as a
9 follow-up until we know -- do you know that?

10 MR. DICK: This is Michael Dick. I can
11 answer --

12 MEMBER BANERJEE: Give a rough number.

13 MR. DICK: -- your question more in a
14 qualitative sense, in that, the two most important
15 items were the changes in the K-factor, increased heat
16 removal from the heat exchanger, but it was also
17 necessary to reduce the RHR flow rates.

18 MEMBER CORRADINI: All right. Thank you.
19 Because that was your limiting accident way back when.
20 Your highest required CAP was 6 psi, but because of
21 LOCA, if I remember correctly, right?

22 MR. DICK: That's a correct statement,
23 sir.

24 MEMBER CORRADINI: Thank you.

25 MR. BORTON: Okay. So getting a little

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 bit more into the details here. So this Slide 20 gives
2 a simple overview of the RHR and the high pressure
3 service water cross-tie modifications. And I'm going
4 to drive here and speak at the same time here, but I'd
5 also like to leave this slide up as I go through the
6 other segments so you can get an idea of what all the
7 modifications were.

8 Peach Bottom is different than the other
9 plants in that, the fact that there's four heat
10 exchangers per unit. A lot of the vintage plants and
11 this size plants only had two heat exchangers. The
12 original design analysis requires only crediting one
13 heat exchanger, so therefore, there's an extra heat
14 exchanger removal capacity here that, if we could tap
15 into it, you know, with process and cooling water, we
16 would gain extra cooling effect here for the heat
17 exchangers.

18 So to take advantage of that extra heat
19 exchanger, we added this cross-tie valves right here,
20 just downstream of the pumps with normally closed
21 valves in-between them. We also included new control
22 valves upstream. There was a control valve on one and
23 a flow restrictor in another one.

24 We put new elements, also, downstream of
25 the heat exchangers to measure our flows. This change

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 allowed us to change our flow process and add the extra
2 heat exchanger, so we would pump through one pump going
3 to two heat exchangers, and that's only half the
4 equation, because the other half of the equation is our
5 HPSW pumps on this side.

6 So we replaced the existing cross-tie that
7 was there for only outage purposes with a valve that
8 could be opened against full flow and pump
9 differential. This allowed any available HPSW pump to
10 supply the cooling water to the extra heat exchanger,
11 and the combined effect of the RHR cooling increases
12 the heat removal capacity by about 65 percent.

13 So with these modifications, along with
14 the reduction in the RHR pump flow, and the reduced
15 fouling, we successfully reduced the post-accident
16 pool temperature to a point where the MPSH available
17 is greater than the MPSH required, and thus,
18 effectively eliminate a need for CAP credit for
19 accidents. So this is really -- I just gave you the
20 accidents --

21 MEMBER BANERJEE: Don't go so fast.

22 MR. BORTON: So I'm going to stay here and
23 answer questions.

24 MEMBER BANERJEE: Yes, right.

25 MEMBER BLEY: While we're waiting for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 questions, I just wanted to mention that, while I share
2 Professor Banerjee's curiosity and interest in this,
3 two points, I think you mentioned, Sanjoy, this has some
4 cost associated with it, but should you ever need the
5 CAP credit and not actually have it, the cost associated
6 with that could be a hell of a lot more, so you have
7 to look at the likelihood of it being there, and we
8 haven't stopped arguing over this.

9 Several of our letters this year have dealt
10 with CAP in a couple of specific cases, so we're still
11 very interested.

12 MEMBER BANERJEE: Yes, I think, in a way,
13 what you're saying is prudent to it.

14 MEMBER CORRADINI: Can I ask the question
15 a little differently? So let's say you did all this,
16 there was a question earlier, and I don't remember how
17 you guys answered it, which is, so is there no downside
18 to this? There must be some sort of accident situation
19 that this causes you pain somewhere else where you get
20 the gain here? Has that analysis been done? I've been
21 waiting for Dennis to ask this question, but I don't
22 understand enough of the details of the plant system
23 that I can't guess what that would be.

24 MEMBER BLEY: There must be, and if their
25 valves are not in the position that they've assured

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 themselves they are, there could be a problem.

2 MEMBER CORRADINI: So that's kind of the
3 root of my question, have you guys done some sort of
4 analysis that says, okay, now we installed this and now
5 there's a misalignment, this takes me down a path I
6 wouldn't have expected later on in terms of an accident
7 sequence?

8 MR. DICK: This is Michael Dick with
9 Exelon. The downside of this modification, other than
10 the cost, okay, is the --

11 MEMBER CORRADINI: You guys got the money.

12 MR. DICK: Right. But as far as in a
13 safety analysis space is the reduction in RHR flow
14 during a LOCA. And now I'm talking about fuel LOCA,
15 okay, because both the runout flows we -- two things
16 we did with this mod is, as far as the long-term RHR
17 flow and also the short-term run-out RHR flow. So what
18 we see is, is a hit on the large break LOCA fuel results,
19 and I believe that is about a 30-degree hit on peak
20 cladding temperature, but that's for the large break
21 LOCA.

22 Peach Bottom is not a large break LOCA
23 limiting plant. It's a small break LOCA, and so this
24 modification actually has zero impact on the licensing
25 basis PCT.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: There's a fairly large
2 margin of error, correct?

3 MR. DICK: Yes.

4 MEMBER BANERJEE: Did you use a best test
5 simulator analysis or what did you do for the LOCA mark?
6 Well, you'll revisit LOCA sometime, so we'll leave it
7 for that.

8 MR. DICK: Michael Dick. It's ECC -- use
9 the GE/Hitachi or GNF SAFER/PRIME methodology. That's
10 the licensing basis methodology.

11 MEMBER BANERJEE: Okay. That's fine.

12 MR. BORTON: Any other questions on the
13 accident side before I move on to special events?

14 MEMBER BANERJEE: So going back to the
15 pumps, I didn't quite follow what you did to that red
16 valve on the right.

17 MR. BORTON: This right here?

18 MEMBER BANERJEE: No, no, no.

19 CHAIR REMPE: Over to the right more.

20 MR. MASSARO: Yes, that valve previously
21 existed. We upgraded the operator, essentially, to be
22 able to open against dead head.

23 MEMBER BLEY: They had a valve you
24 couldn't open before if the system's operating.

25 MR. MASSARO: Yes, we also added manual

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 maintenance valves on either side of the cross-tie to
2 be able to service that pump.

3 MEMBER BANERJEE: Okay.

4 MR. BORTON: Okay. Just moving on, since
5 we eliminated the CAP credit for the accidents, and --
6 I'm sorry. I'm on the wrong slide. So to take
7 advantage of the extra heat exchangers gave us action
8 to credit --

9 MEMBER BANERJEE: What sort of heat
10 exchangers are these RHR heat exchangers?

11 MR. BORTON: I'm sorry, what was the
12 question?

13 MEMBER BANERJEE: What type of heat
14 exchangers are they, the RHR heat exchangers? Are they
15 just standard shell and tube?

16 MR. BORTON: Standard shell and tube.

17 MEMBER BANERJEE: Okay. You don't have a
18 diagram of it around somewhere?

19 MR. BORTON: We could provide one.

20 MEMBER BANERJEE: What the internals are.
21 Just a line diagram of some sort; where the flow goes
22 in and out.

23 MR. BORTON: I'm on Slide 21 now. Once we
24 figured out how to eliminate CAP credit for the
25 accidents, we focused our attention on special events.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 In order to eliminate CAP credit for special events,
2 we needed to figure out how to effectively use the
3 condensate storage tank water as additional water
4 inventory source. This had two impacts on MPSH, which
5 I mentioned before.

6 First, it adds extra water heat capacity,
7 thus, reducing pool temperature, impacting the vapor
8 pressure term. And second, it adds to the height of
9 the pump suction, thus, increasing the suction pressure
10 of the static head turbine.

11 MEMBER CORRADINI: So again, let me just
12 make sure, so I like your checkbox way of thinking about
13 this, so if the checkboxes with the CST were not there,
14 would the limiting accident change over from the LOCA
15 to an ATWS or an SBO if that improvement wasn't there,
16 or is this just extra margin you're giving yourself?
17 You see my point?

18 MR. BORTON: With the CST mod?

19 MEMBER CORRADINI: Yes. If there were no
20 CST mod, would that change what the limiting accident
21 would be or is that just extra margin you guys are giving
22 yourselves?

23 MR. BORTON: No, this is necessary to
24 eliminate the CAP credit that we currently have.

25 MEMBER CORRADINI: In Appendix R.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: In the Appendix R.
2 Okay. Thank you. Appendix R becomes the dominant --

3 MEMBER CORRADINI: Well, that's what I
4 wanted to get. Yes. Thank you.

5 MR. BORTON: To accomplish this goal,
6 several modifications were required. First, we added
7 the standpipe with the CST to prevent draining to ensure
8 an adequate water level. Next, key lock switches were
9 installed in the control room to prevent inadvertent
10 valve movement that could result in swapping the
11 suction from the CST port. And third, we raised the
12 torus high-level set point where swapping the HPCI
13 suction from CST to the pool occurs.

14 And finally, we made a procedure changes
15 to allow makeup for to the CST from a refueling water
16 storage tank, so those are the modifications that were
17 required for the special events. All these changes,
18 along with the boron-10 enrichment, the standby liquid
19 control system, combined with the other RHR system-type
20 changes we previously discussed, resulted in the
21 available MPSH being above the MPSH required for all
22 special events.

23 MEMBER BANERJEE: So you know your picture
24 here is very useful in understanding what happened in
25 your previous slide. How does CST affect things? Do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you have something equivalent to this picture to sort
2 of guide us through that? I mean, I can see the words,
3 but it's very hard for me to get a feel for what exactly
4 is going on.

5 MR. BORTON: Yes, I don't believe we
6 created a diagram at all that shows the individual
7 pieces.

8 MEMBER BANERJEE: Okay. There is no
9 schematic that you have of that.

10 MR. DICK: This is Michael Dick with
11 Exelon. Kevin, could you go back to the MPSH equation
12 slide? I think maybe that would be --

13 MEMBER BANERJEE: Yes, if you can just
14 guide me through it, that would be very helpful.

15 MR. DICK: Okay. So really, what we're
16 looking at is, is this H static term increases due to
17 the CST modification because the RPV makeup source
18 during an accident or an event -- well, let me clarify
19 this, is that the CST is not credited for the design
20 basis LOCA or the small break LOCA, so really, we're
21 talking about the special events. Let me clarify that.

22 But what it does is, using the CST for the
23 RPV makeup term during the special events, Appendix R,
24 station blackout, ATWS, okay, will result in a larger
25 volume in the torus, or the suppression pool, okay, so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that increases the H static term. And then there's
2 actually, then, a small effect because of the CST water
3 being cooler, but the biggest impact, though, is that
4 your H static term increases with this CST
5 modification.

6 The side benefit, though, of the CST
7 modification is, is that, RCIC and HPCI suction now is
8 credited exclusively during these special events from
9 the CST, and so then since that water is cool, is that
10 there's no impact on MPSH for those makeup systems.

11 MEMBER CORRADINI: But I guess to ask
12 Sanjoy's question differently, I guess there is a
13 static, but in the prior, maybe I don't remember, or
14 you guys explained it, procedures you weren't planning
15 to use the CST as the makeup for the RCIC or now you're
16 just documenting what you always would have planned to
17 do procedurally? That's what I didn't understand.

18 MR. DICK: This is Michael Dick again. It
19 was not credited. It was always available in
20 procedurally, but in the accident or in the licensing
21 analysis, the safety analysis was not credited.

22 MEMBER CORRADINI: Where were you getting
23 the water from?

24 MR. DICK: From the suppression pool.

25 MEMBER CORRADINI: Ah, so you were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 basically in a recirc mode versus pulling it in from
2 the CST.

3 MR. DICK: Correct.

4 MEMBER CORRADINI: Okay. Thank you.

5 MEMBER SKILLMAN: On Slide 22, please.
6 Would you explain the standpipe to control the volume
7 of CST? I understand all of the other items on that
8 slide, but I don't understand that. How does a
9 standpipe control the volume of the condensate storage
10 tank?

11 MR. BORTON: So it's actually the volume
12 around the outside of the standpipe. So this standpipe
13 goes to the makeup for the hot well. So it actually
14 allows the CST to retain that volume, and that's about
15 the depth I have on that question.

16 MEMBER BANERJEE: The standpipe is not
17 within the CST? Yes, it is. So if you raised it,
18 right?

19 MR. KOVALCHICK: Jim Kovalchick with
20 Exelon. The standpipe is inside the CST at a level
21 which it would protect all the inventory around the
22 standpipe to a certain level, and that standpipe, then,
23 connects to a line that normally is our makeup and
24 reject from the hot well of our condenser. So if the
25 valves in that line were to be affected by a fire, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 then spuriously drained or opened uncontrollably, the
2 inventory and the CST would be protected in that event.

3 MEMBER BANERJEE: So you basically raised
4 that standpipe, is that what happened?

5 MR. BORTON: That's correct.

6 MR. MASSARO: And again, that is on the
7 condensate makeup reject line which postulated the
8 Appendix R in one of the scenarios to fail and drain
9 the CST. So the standpipe prevents that draining in
10 that scenario.

11 MEMBER CORRADINI: Thank you.

12 MR. BORTON: Okay. So when all these
13 changes are combined for both the accident and the
14 special events, as we discussed, the combined effect
15 was to have a positive MPSH margin for all accidents
16 and events, and thus, we eliminated the need for CAP
17 credit. Let me just move on to the next slide.

18 As part of the investigation of design,
19 then we also looked at the changes and how they would
20 affect our operations, and I'll turn this over to Jim
21 Kovalchick, who will go through those changes about how
22 this system will then be operated.

23 MR. KOVALCHICK: Thanks, Kevin. Jim
24 Kovalchick, Exelon Peach Bottom operations. And in
25 discussing changes that we would need to make for EPU

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and eliminating CAP credit, I can make a general
2 statement that EPU, including changes to eliminate CAP
3 credit, will not cause us to change the basic strategies
4 of our abnormal operating and emergency operating
5 procedures.

6 In the case of the DBA LOCA with the diesel
7 failure, there will be a new time critical action to
8 use the RHR cross-tie and HPSW cross-tie to align an
9 RHR pump through two heat exchangers with two
10 high-pressure service water pumps in service. These
11 steps will be accomplished through system lineup
12 procedures as specified by our EOPs that are already
13 specifying maximizing containment cooling.

14 The one-hour time requirement to complete
15 the cross-tie lineup steps will not be a significant
16 operator challenge because the original assumption
17 that no actions are required during the first ten
18 minutes has not changed, and all the actions are from
19 the main control room at a level of complexity
20 consistent with the existing steps in the EOPs.

21 MEMBER BANERJEE: So as long as they're
22 done within an hour, it's fine.

23 MR. KOVALCHICK: That's correct.

24 MEMBER BANERJEE: You could take a full
25 hour.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KOVALCHICK: That's correct. For the
2 specific events of ATWS and Appendix R fires use of HPCI
3 and RCIC was suctioned from the CST is already specified
4 as the preferred source in our procedures. And
5 procedure steps to makeup to the CST during transient
6 response already exist. For EPU, these existing
7 actions just become acquired from an analysis
8 standpoint.

9 MEMBER SKILLMAN: In three of the four
10 sub-bullets under the first bullet are start, that's
11 a command, open, that's a command, open, that's a
12 command, the next one is balance, that means adjust.
13 Speak to us about what the operators must do to achieve
14 intended balance.

15 MR. KOVALCHICK: Yes, we've added, or will
16 be adding, and if you look, Kevin, if you could point
17 to them, you see the new motor-operated valves prior
18 to upstream of the heat exchangers, those are drag
19 valves that can be used, and that's specifically part
20 of their design, to throttle the flow. We're also
21 making sure that we have the proper instrumentation of
22 flow for the operator available to do that.

23 MEMBER SKILLMAN: And those are the FEs
24 that we see on the right?

25 MR. KOVALCHICK: That's correct. And all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 again, those actions are from the control room.

2 MEMBER BANERJEE: Does that mean you,
3 roughly, keep the same flow going through the -- looking
4 at those FEs? Is that what you mean by balance?

5 MR. KOVALCHICK: Yes.

6 MEMBER SKILLMAN: Cavitation downstream
7 of your valves; your drag valves? What consideration
8 has been given to that, please?

9 MR. KOVALCHICK: We only have a drag valve
10 in the system. We're restricting the orifice with a
11 drag valve on one of the loops, but we already actually
12 have drag valves there, and that's where, between that
13 and the heat exchanger, most of the head loss for the
14 RHR systems are. So this doesn't really represent a
15 new, you know, vulnerability to cavitation.

16 MEMBER SKILLMAN: What consideration has
17 been given to cavitation caused by the drag valve to
18 the tube bundles?

19 MR. KOVALCHICK: I would have to refer
20 back to the original design. As I said, there was
21 already a drag valve there and there is no cavitation
22 vulnerability. Tony, go ahead.

23 MR. HIGHTOWER: So this is Tony Hightower
24 from Peach Bottom. Just, in addition, engineering,
25 through the course of developing this modification, did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 do a hydraulic analysis for the entire flow path, that
2 included the heat exchangers. The drag valves, based
3 on their nature, do offer an advantage with their
4 distributed pressure drop over the length of their disc
5 to lessen the impact of cavitation, but they did do a
6 hydraulic model that looked at potential cavitation
7 effects throughout that heat exchanger suction and
8 discharge line, all the way up to the vessel, and
9 determined that it was satisfactory as far as the
10 modification process.

11 MR. KOVALCHICK: Thanks, Tony. Does that
12 answer your question, sir?

13 MEMBER SKILLMAN: I'd ask you one more
14 question. After the modification is completed, and
15 you actually test it, do the heat exchangers sing?
16 Those of you who have worked in plants as I have know
17 exactly what I'm talking about. If you adjust the drag
18 valve, and the throttle, and all of a sudden your heat
19 exchangers are buzzing because the tube's excited.

20 MR. KOVALCHICK: We have operational
21 history of throttling the drag valves. We use the drag
22 valves, for example, to limit flow during refueling
23 operations, and we'll bring those down all the way to,
24 I think the low limit, Tony, is, it's 4000 --

25 MR. HIGHTOWER: 4000 gallons per minute.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KOVALCHICK: -- gallons per minute,
2 which is significantly lower than the high end. And
3 during that range, we have not had issues with flow
4 stability or --

5 MEMBER SKILLMAN: That's where you're
6 taking your peak delta-P across the throttles, and
7 therefore, the cavitation would be greatest at the tail
8 end?

9 MR. KOVALCHICK: Yes. That's correct.

10 MEMBER SKILLMAN: Okay. Thank you.

11 MR. KOVALCHICK: You're welcome. Okay,
12 Kevin. Okay. So really, this is our conclusion slide
13 for the CAP credit.

14 MEMBER BLEY: I wanted to follow-up on
15 what Mike Corradini was asking before. What he was
16 really getting at was, although we've been very
17 interested in CAP all along, the scenarios in which
18 you'd need CAP and it wouldn't be there are pretty darn
19 unlikely scenarios. Did you rerun your probabilistic
20 risk assessment, I notice that we didn't see Greg Kruger
21 here today, but he went out with us when we were up at
22 the plant, did you run that under this modification to
23 see if there are any other scenarios that might be more
24 likely for which these changes wouldn't be a benefit
25 that could cause a problem, and none come to mind for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 me, but did you actually do that?

2 MR. BORTON: Yes, this was part of the
3 analysis that was done for PRA, and the analysis showed
4 that the CAP credit did not impact, you know,
5 significantly, any of the --

6 MEMBER BLEY: Formerly successful
7 scenarios.

8 MR. BORTON: The additional redundancy
9 and the availability, actually, was a positive thing
10 also in the PRA.

11 MEMBER BLEY: Okay. That's what I would
12 expect. Most studies we've done, this is what I was
13 mentioning -- it's nice to have them separated in case
14 you have some insul, but if you need to be able to cross
15 connect things that, usually, is a net benefit.

16 MEMBER CORRADINI: I guess I was just
17 curious about system interactions, so if everything's
18 better, that's good, and then I'm curious about, but
19 you guys have already considered that, what things rise
20 and fall in terms of what's important when you go beyond
21 the design basis.

22 MR. BORTON: It was a balancing act. I
23 mean, the whole approach to elimination of CAP with the
24 modifications that were put in, with the operator
25 actions, you know, so we did go back and forth with a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 number of different types of options as well that we
2 eliminated because they were not as viable in the
3 situations.

4 MEMBER CORRADINI: So I'm not an operator,
5 so are the operator actions more complex now or are they
6 simplified because of all this? I mean, that's the
7 other thing that would, at least I'd ask, which is,
8 given that you've done all this, is the operator more
9 challenged to do the right thing in the right timing,
10 or are things simplified?

11 MR. BORTON: I'll ask the operator.

12 MR. KOVALCHICK: No, I would consider them
13 neutral change with respect to complexity. You know,
14 they're actions that will need to be taken, but where
15 they're taking the actions, the level of complexity of
16 those actions, it isn't really going to be something
17 that's now like a diagnosis burden. You know, there's
18 not a lot of, like, hey, go do this now, kind of thing,
19 and rush and race, you know, so I consider them a
20 neutral.

21 And the impact on the overall strategy, we
22 didn't change the EPG implementation nor ELPs.

23 MEMBER CORRADINI: The only other thing
24 that, again, it's kind of in the conclusion part is,
25 we're not there yet, but in the implementation of a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 potential rule relative to venting, I assume that's
2 simplified substantially now that you don't need CAP
3 credit. That was my impression.

4 MR. KOVALCHICK: That's right. It would,
5 overall, expand the flexibility to do it at certain
6 times.

7 MEMBER CORRADINI: Okay.

8 MEMBER BANERJEE: So the operators have to
9 open some valves and things like the MOVs.

10 MR. KOVALCHICK: That's correct.

11 MEMBER BANERJEE: And the most complex act
12 there is the balancing? So if they're not able to
13 balance the flow to something, is there any --

14 MR. KOVALCHICK: I don't anticipate an
15 issue.

16 MEMBER BANERJEE: Is there problem that it
17 poses on balance so you can't get them balanced?

18 MR. HENRY: I mean, there was a
19 sensitivity study done that showed that, you know,
20 nominally, 4300 gpm per heat exchanger is what we're
21 aiming for, but we could have a mismatch up to 600
22 gallons and not have an issue.

23 MR. HIGHTOWER: So this is Tony Hightower
24 from Peach Bottom operations, we're currently
25 developing the procedures for balancing flow. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analysis assumes that we have a minimum of 4300 gallons
2 per minute through each RHR heat exchanger, and that
3 that minimum flow value, it assumes that flow is
4 balanced. If we have flow in excess of 4300 gallons
5 per minute, there's no minimum delta between the RHR
6 heat exchangers and the two trains that we're using.

7 So in the vast majority of cases, there
8 will be no limitations as far as balancing flow.
9 Operators will be able to maintain flow, approximately
10 equal, in the two heat exchanger trains without an undue
11 burden to balance heat exchangers. So our RHR flow
12 rates will primarily be driven by the net positive
13 suction head that is available at the time. Does that
14 answer your question?

15 MEMBER BANERJEE: Time to digest that.
16 Okay. Let me reflect. I'll talk to you offline.

17 MEMBER RICCARDELLA: You stated earlier
18 that there was some unique features at Peach Bottom that
19 made this modification possible, or at least
20 facilitated it, could you expand upon that?

21 MR. BORTON: It was really the number of
22 heat exchangers. We have four heat exchangers per
23 units. A lot of BWRs only have two heat exchangers for
24 flow pumps. So we have that availability within those
25 loops to have additional heat capacity leak across

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 using one pump per heat exchangers.

2 MEMBER RICCARDELLA: Thank you.

3 CHAIR REMPE: Well, we're scheduled for a
4 break at 10:30, and we're ahead of schedule, so if it's
5 -- because we might get behind later today, if it's okay
6 with you, just keep going, if that sounds good to
7 everybody else?

8 MR. MASSARO: Sounds good. Before Dave
9 starts, I would like to clarify a response that I made
10 earlier in response to a question about our experience
11 with installation of the mods. I mentioned that none
12 of them needed to be installed in the last refueling
13 outage. In the result of our analysis we did find that
14 the supports for the main steamlines were not evaluated
15 for turbine control valve fast closure, and so we were
16 compelled to go put that modification in on Unit 3 in
17 the last outage and it has been completed. I just
18 wanted to make sure I was clear on that.

19 MR. AINGER: I had some follow-up. This
20 is Ken Ainger with Exelon. I just wanted to answer some
21 follow-up questions. Mr. Corradini, you were asking
22 about how we're able to change the K-factor for the RHR
23 heat exchanger, the answer is that it's based on actual
24 performance testing of the RHR heat exchanger, we were
25 able to utilize some of the available margin with no

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 impact to design or operating requirements.

2 MEMBER CORRADINI: And I guess my second
3 of the question is, empirically now, you guys have shown
4 it, by, you know, some historical performance, do you
5 have any idea -- and I think you mentioned it was,
6 essentially, just conservatism in the original heat
7 exchanger design, is that it, versus, maybe, you guys
8 have improved, somehow, chemistry and fouling just as
9 an integral effect is produced? That was the second
10 part, I think, of --

11 MR. HENRY: I'd actually say it was two
12 parts. One was the plugging one that we had for the
13 heat exchangers themselves, and what was assumed
14 fouling factors, so based on the historical good
15 performance of our heat exchangers, minimal plugging
16 of any of the heat exchangers, and the historical good
17 performance from the tubes themselves, in addition to
18 the cleaning that we do periodically on the heat
19 exchangers, we've always been above that level and feel
20 that it was margins to be had for this modification.

21 MEMBER CORRADINI: Thank you.

22 MR. AINGER: Mr. Banerjee, another
23 follow-up question you had about how long do we take
24 credit for the containment accident pressure, the
25 answer is greater than 14 hours in our analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Currently. And that's
2 the large break flow curve.

3 MR. AINGER: Yes.

4 MR. HENRY: We did talk about the heat
5 exchanger. I don't know -- let me just give you a
6 verbal description of the heat exchanger, so it's a
7 high-pressure service water entering the top of the
8 heat exchanger, there's a baffle plate that directs all
9 the flow down half of the heat exchanger into a floating
10 head area, which returns it back up to the other side
11 of the heat exchanger, and then on the other side of
12 the tubes themselves is the RHR system flow.

13 MEMBER BANERJEE: So water goes that way.

14 MR. HENRY: The high-pressure service
15 water will come in and around --

16 MEMBER BANERJEE: There's a baffle in the
17 middle.

18 MR. HENRY: A baffle in the middle to
19 redirect it.

20 MEMBER BANERJEE: And there's sort of
21 U-tubes --

22 MR. HENRY: It's actually open on the
23 bottom of the heat exchanger. We have what's called
24 a floating head that turns the water and brings it back
25 up. And then on the RHR side, it's just simply on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 tube side of the heat exchanger itself.

2 MEMBER BANERJEE: And the tube side is a
3 U or what?

4 MR. HENRY: There's straight tubes. Just
5 on the bottom of it, we put a, it's called a floating
6 head, because it floats within the medium --

7 MEMBER BANERJEE: Oh, I see. I got it.

8 MR. HENRY: -- so the water will come down
9 into that open head, but it's redirected by pressure
10 up the other side of the heat exchanger. Does that
11 help?

12 MEMBER BANERJEE: Yes, it helps. And the
13 pressure differential isn't large across the two sides.

14 MR. HENRY: We have a high-pressure
15 service water system that maintains the service water
16 side higher than the RHR side, and there's an alarm
17 indication for the control room to allow them --

18 MEMBER BANERJEE: So your shell side is
19 higher pressure than your tube side.

20 MR. HENRY: Tube side.

21 MEMBER BANERJEE: It is. How much higher
22 is it?

23 MR. HENRY: I can't remember the --

24 MEMBER BANERJEE: Are these heat
25 exchangers vented in the sense that if there's a leak

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 or something, is it needed to vent it?

2 MR. KOVALCHICK: Normally, it's all
3 closed.

4 MEMBER BANERJEE: It's all closed.

5 MR. KOVALCHICK: That's correct.

6 MEMBER BANERJEE: Imagine the tubes
7 develop leaks if there's a -- what is the pressure
8 differential?

9 MR. HENRY: If we actually had a tube leak
10 on the heat exchanger during an accident condition, the
11 high-pressure service water system would leak into the
12 RHR side of the system, so the clean water would leak
13 into the potentially contaminated. Clean, in terms of
14 ultimate heat sink water. Raw water.

15 MEMBER BANERJEE: Well, what is the
16 pressure differential?

17 MR. KOVALCHICK: Tony, can we get that
18 looked up in an hour? Thank you. We'll get that for
19 you.

20 MEMBER BANERJEE: The reason I'm asking
21 is, there's been a lot of petroleum industry issues
22 which have arisen with pressure differences between the
23 shell side and the tube side recently, many with
24 off-shore operations, so I'm sort of interested in
25 knowing what that amount is.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HENRY: It's not a significant DP.

2 MEMBER BANERJEE: Yes, if it's not a
3 significant DP, it doesn't matter.

4 MR. HENRY: We'll get the average and they
5 do have an alarm that tells them that they need to make
6 adjustments to flow to maintain that positive DP.

7 MR. KOVALCHICK: And, for example, LPIC
8 mode, we wouldn't even have HPSW on, so the shell side
9 would be higher than the tube side in that case.

10 MEMBER BANERJEE: Okay. Well, just give
11 me that number.

12 MR. KOVALCHICK: We will.

13 MEMBER BANERJEE: Thanks.

14 MR. AINGER: Kevin, I got one more, this
15 is Ken Ainger from Exelon. Mr. Skillman, earlier, you
16 were asking about the condition of our main steam piping
17 that Mike had referred to in connection with the
18 modifications, and the answer to your question is that,
19 our main steam piping is included in our ASME Section
20 11 in-service inspection program, and inspections are
21 performed on selected piping supports refueling
22 outage. No deficiencies in this piping have been
23 identified in the last two refueling outages.

24 MEMBER SKILLMAN: Thank you.

25 MEMBER RICCARDELLA: I would assume

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they're also part of your FAC program.

2 MR. HENRY: They are included in our FAC
3 program.

4 MEMBER RICCARDELLA: Which is separate
5 from the --

6 MR. HENRY: Which is separate from -- I
7 mean, we're talking supports, which is part of the
8 technical specifications for snubbers, and supports,
9 and hangers, and then on the flipside, for the piping
10 side, they are in our FAC program based on its
11 susceptibility to FAC. Ken, anything else? Any other
12 follow-up?

13 MR. AINGER: That's it.

14 MR. HENRY: Thanks. Again, I'm David
15 Henry from Exelon. I'll direct you to Slide 26. I'm
16 here to talk about the effects of the extended power
17 uprate on transient and accident analysis, and I'll
18 include the containment response. From a transient
19 perspective, it's important to point out that the
20 limiting transients are evaluated in a cycle-to-cycle
21 basis, allowing for changes to be made in core design
22 or operating patterns to maintain or improve thermal
23 limit margin.

24 From a sensitivity perspective, the
25 increased power level was shown to have minimal effect

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on either the limiting pressurization event, which, for
2 Peach Bottom, is the load reject with no bypass or the
3 limiting non-pressurization event at the rod
4 withdrawal error. At EPU conditions, both events
5 produced a delta CPR of 0.27, which is the current delta
6 CPR for Unit 2 and in line with our normal historical
7 performance.

8 Additionally, for the rod withdrawal
9 error, the delta CPR is dependent on the rod block
10 monitor set point, which can be adjusted if margin to
11 the non-pressurization events is required. Also, for
12 the transient and accident analysis on a cycle-to-cycle
13 basis, the MSIV closure with APR and flux scram was
14 analyzed to verify peak pressure of 1325 and the steam
15 done is not exceeded. This was run at EPU conditions
16 and verified to be within limits.

17 From an accident response at EPU
18 conditions, as we mentioned earlier, the most limiting
19 event for peak clad temperature is the small break LOCA.
20 Utilizing a safer gesture prime, the peak cladding
21 temperature remained below the 10 CFR 5046 acceptance
22 criteria of 2200 degrees.

23 For non-LOCA conditions, the control rod
24 drop accident will remain bounded at EPU conditions.
25 Peach Bottom control rod patterns conform to the bank

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 position withdrawal sequence requirements, which
2 limits the control rod worth of any control rod.
3 Results show that the peak fuel enthalpy was 162
4 calories per gram versus the acceptance criteria of 280
5 calories per gram.

6 One item to note, in order to accommodate
7 the increased power level and the associated increase
8 in LOCA source terms, all the leakage in the assumed
9 failed main steamline was decreased by a factor of 1.2,
10 and that is reflected in our technical specifications.

11 From a containment response, due to the
12 benefits that Kevin mentioned earlier, the peak
13 suppression pool temperature is reduced for all design
14 basis events. Only in the special event of SBO did the
15 temperature increase slightly, but remain below our
16 established limits. Additionally, while both the
17 suppression pool and drywell shelf pressures and
18 temperatures increased slightly, all established
19 limits are met at EPU conditions. Any questions on
20 that slide?

21 I'll move you on to the flow-induced
22 vibration and structural analysis section. The first
23 slide is on Page 28. This portion of the presentation
24 will discuss the impact of the increased flow rates and
25 what they'll have on the plant system and components.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 As shown on this slide, multiple systems are affected
2 by the power increase, either directly proportional,
3 as is in the case for main steam and feedwater, or
4 multiple, as the case is for extraction, steam, and
5 heater drain.

6 To evaluate this change, the various
7 piping systems were reviewed through multiple means.
8 First were the components that protrude into the flow
9 system, such as thermal wells or sample probes, failure
10 from high-cycle fatigue through flow-induced
11 vibrations or vortex shedding frequencies were
12 evaluated.

13 Both qualitative and quantitative
14 analysis were performed to identify susceptible
15 components that required remediation. This review did
16 identify thermal wells that will require upgrading
17 prior to EPU conditions. These were done on Unit 3
18 during the last outage and will be done on Unit 2 in
19 the upcoming outage.

20 Similarly, for small bore cantilevered
21 branch connections, analysis indicated a potentially
22 low natural frequencies, and some of the main steam and
23 feedwater piping warranted modifications to prevent
24 line fatigue failures. These modifications include
25 tying back the branch line to the actual pipe to couple

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it with the pipe itself, replacing the valves on the
2 branch line with lighter valves to change the vibration
3 spectrum, or on Unit 2, we had two test taps that were
4 installed since the plant was operational for testing
5 that'll be cut and capped because they are no longer
6 required.

7 Finally, the main steamlines inside both
8 inside and outside containment, including the HPIC
9 steam supply line, the SRV/RV piping to the SRV and RV
10 outlet, and the new spring safety valve, that Mike
11 talked about earlier, were evaluated at EPU conditions
12 for multiple loading events, including the main stop
13 valve closure.

14 The new piping stresses were combined in
15 accordance with ANSI B31.1 and identified specific
16 upgrades required to maintain our requirements. All
17 these plant modifications that I mentioned either have
18 been completed or will be completed prior to exceeding
19 our current license power level.

20 I'll move you on to Slide 29. This is our
21 flow-induced vibration monitoring program. In
22 addition to the modeling that was performed and the
23 modifications that were made to the plant, we are
24 looking for confirmation of our expected results and
25 verification of the margin during our startup testing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 From the detailed analysis that were performed,
2 specific monitoring locations and criteria were
3 established for the vulnerable components, including
4 piping inside the drywell.

5 Allowable displacements and acceleration
6 limits were calculated based on the ASMI endurance
7 stress limits for steady-state vibration per ON-3.
8 Actual EPU vibration levels will be projected prior to
9 exceeding our current licensing thermal power to ensure
10 our proper response as we're coming up in power level.
11 Questions on the flow-induced vibration?

12 I'm going to move you on to Slide 30. This
13 is RPV and internals. Analysis were performed to
14 evaluate the effects of the increased power level.
15 Since the maximum core flow is not changing for EPU
16 conditions, components that only see core flow were
17 unaffected by the change. For components affected by
18 EPU, test data was extrapolated to 102 percent of EPU
19 conditions.

20 Vibration amplitudes were also adjusted by
21 the square of the increased flow velocity rates at each
22 of the extrapolated points. These expected vibration
23 levels were compared with the established vibration
24 level acceptance limits which limit the flow-induced
25 vibration alternating stress intensity for austenitic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 stainless steels and was found to be acceptable.

2 From a structural side, the EPU conditions
3 bounded by the current design requirements. For the
4 steam dryer, we have performed site-specific analysis
5 and have a detailed measurement and inspection program
6 to verify the structural integrity. Ken will discuss
7 this in detail this afternoon. The fatigue usage
8 factors meet the ASMI code requirements for a 60-year
9 license requirements at EPU conditions.

10 Our RPV components having a cumulative
11 usage factor of greater than 0.33 that experienced
12 increase flow, temperature, reactor internal pressure
13 differences, or other mechanical load, were evaluated
14 for fatigue and found acceptable. All evaluations
15 confirm that the RPV pressure retaining and internal
16 components remain structurally qualified at EPU
17 conditions.

18 MEMBER SKILLMAN: How great was the
19 population of those components that had a CUF greater
20 than 0.33? Is that a large population or a small
21 population?

22 MR. HENRY: It was a small population.
23 There's the feedwater nozzles and safe ends, the
24 reactor recirc inlet nozzle, and Unit 3 only, the outlet
25 nozzle.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: So less than half a
2 dozen.

3 MR. HENRY: Correct.

4 MEMBER SKILLMAN: Thank you.

5 MR. HENRY: Moving on to Slide 31.
6 Compliance with Appendix G is met and the current
7 inspection strategy for the reactor coolant pressure
8 boundary was found to be acceptable. The current PT
9 curves, bounding EPU conditions are actually bound to
10 EPU conditions due to the higher fluence values
11 utilized. Fluence values for EPU are actually less
12 than our current licensing thermal power limits due to
13 change from the dosimetry-based calculation to the
14 implementation of the NRC-approved theoretical fluence
15 calculation methods.

16 We will continue to perform inspections
17 based on the requirement of the BWRVIP program, which
18 ensure our compliance with the requirements.

19 CHAIR REMPE: So basically, that you have
20 data now, and that's why at EPU, you're going to have
21 an estimate to a fluence that's lower? Is that what
22 I'm hearing, is that, you have data versus a theoretical
23 method in the old method you were using?

24 MR. HENRY: We were actually utilizing the
25 new approved methodology, which allows us to have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 lower fluence level projected.

2 CHAIR REMPE: And the reason that there's
3 a lower fluence level is because there's more data?

4 MR. DICK: Michael Dick, Exelon. The
5 answer is yes.

6 CHAIR REMPE: Okay.

7 MEMBER RICCARDELLA: You're part of the
8 integrated surveillance program. Is that what you
9 mean by the BWRVIP program?

10 MR. HENRY: BWRVIP program, we are.
11 That's correct.

12 MEMBER SCHULTZ: With regard to the
13 flow-induced vibration effects on the main steam and
14 feedwater piping, for example, you've got a percent
15 increase there, but in terms of actual magnitude, the
16 experience that you anticipate, how does that compare
17 with industry experience to date?

18 MR. HENRY: I know we anticipated,
19 roughly, a 30 percent increase in vibrations on the main
20 steam and feedwater, for comparison to the industries,
21 I don't have a good value.

22 MR. BORTON: For EPUs, there's been
23 increases up to about 50 percent, so I checked earlier,
24 but we'll go back and look at the last couple of BWRs,
25 but I'm pretty certain it falls right into the middle

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there.

2 MR. HENRY: Do you have that, Ken? Do you
3 understand what the question is?

4 MR. BORTON: Yes.

5 MEMBER SCHULTZ: Thank you.

6 MR. HENRY: All right. I'll turn it over
7 to Jim.

8 CHAIR REMPE: Let's go ahead and we'll
9 have a closed session after break, if everyone's
10 willing to do it that way. It's more efficient.

11 MR. KOVALCHICK: Okay. Very good.
12 Again, I'm Jim Kovalchick. I'm an operations manager
13 with Exelon at Peach Bottom assigned to EPU
14 integration, and one of my responsibilities is working
15 with the team on preparing our power ascension plan,
16 so I'll make this presentation and we'll include
17 discussion of our preparations, major testing, and
18 acceptance criteria, except for the reactor steam
19 dryer, which will be discussed in that proprietary
20 presentation.

21 So moving on to Slide 33, our power
22 ascension test plan was developed using Section 14.2.1
23 of the standard review plan contained in NUREG 0800.
24 The plan will be implemented using a single procedure
25 that consolidates verification of individual

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 modification acceptance testing as well as integrated
2 plant operation validation.

3 Many of the modification tests for
4 specific equipment will be performed before plant
5 startup and the power ascension testing plan will
6 ensure those pre-startup tests are completed
7 satisfactorily. Modification equipment testing that
8 requires power operation, such as the new automatic
9 voltage regulator, will also be coordinated through the
10 master procedure.

11 We're preparing the integrated plant
12 testing using a method recommended in the standard
13 review plan, specifically, we evaluated the
14 applicability of testing done for the original plant
15 startup as well as uprates, and also, any new testing
16 appropriate for changes made since then. As a result,
17 we will test 16 areas from the original startup testing
18 scope, along with wide-range neutron monitoring
19 testing, which didn't exist in 1974, as well as
20 monitoring of the reactor steam dryer, which will be
21 discussed with specifics later.

22 And I'll pause here for a moment. The
23 wide-range neutron monitoring, given that it's unique
24 to Peach Bottom, I'll explain that that was a
25 modification that we made that is, in a nutshell, a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 combined source range, intermediate range monitoring
2 of neutrons.

3 We will implement the power ascension
4 testing using a special organization that includes
5 personnel with station-specific experience in
6 operations, chemistry, radiation protection,
7 predictive maintenance and instrument maintenance, and
8 the organization will include procedure and
9 engineering support.

10 CHAIR REMPE: In the documentation that we
11 reviewed, you refer to a plant operations review
12 committee that looks at the results at each hold point
13 during the ascension testing occurrence, and who is on
14 the PORC?

15 MR. HENRY: It's our PORC, or plant
16 overview review committee, that's chaired by the plant
17 manager, and has the directors from all the departments
18 on the actual -- so the operations, maintenance,
19 engineering, work management director, our normal
20 quorums, and then it's the expertise based on --

21 CHAIR REMPE: Is it, like, 10 people, 15
22 people?

23 MR. BORTON: Typically, the quorum is
24 five. Am I correct, Jim?

25 MR. ARMSTRONG: Hi. I'm Jim Armstrong,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the reg assurance manager, I'm also responsible for the
2 PORC function. Okay. So just a clarification, the
3 PORC is chaired by the operations director, the
4 alternate is the engineering director or myself.
5 Minimum quorum requirements are five people, okay? It
6 is required by tech specs that all plants have a similar
7 function.

8 CHAIR REMPE: Okay.

9 MR. BORTON: And as I understand it, the
10 plant manager approves the plans.

11 MR. ARMSTRONG: Yes. We make
12 recommendations to the plant manager and he approves
13 it or not.

14 CHAIR REMPE: Thanks.

15 MR. KOVALCHICK: Okay. Moving on, the
16 next two slides, 34 and 35, show when, within the
17 integrated plant testing, we'll do the specific areas
18 of that testing. Power ascension will be incremental
19 so margins of safety and expected performance can be
20 validated before we move on. I didn't expect to speak
21 to each of the individual areas here, except where the
22 Subcommittee had questions, but a few things that I'll
23 note, control rod drive testing will consist of normal
24 surveillances, including coupling checks for full out
25 rods and single-notch exercise testing through the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 power ascension.

2 Testing of turbine stop control and bypass
3 valves as well as MSIV testing will be performed for
4 at least one valve at power level steps to determine
5 the power level for future testing for acceptable plant
6 impact, and also, the MSIV testing, it was a partial
7 closure, not a full closure. And finally, for
8 clarification, portions of tests of the pressure
9 regulator and the feedwater control will not be done
10 where they would tend to raise power above new EPU 100
11 percent.

12 MEMBER CORRADINI: So just a logic
13 question, I think I get it, at least generally, but the
14 only thing that you don't test at low power, and then
15 again at high power, is the bypass MSIV and turbine
16 valve testing. Is there a reason why you don't need
17 to do it at 108 or EPU, because I was looking at the
18 other things, and either you're doing at the beginning,
19 at the end, or you're doing it just formally all the
20 way through.

21 That's the only one I didn't see some sort
22 of consistency.

23 MR. KOVALCHICK: Yes, I'll explain it
24 again. What I was trying to say there was, for those
25 valve tests, we will perform those until we get to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 place in power where we've decided that, okay, that's
2 the highest power that that's appropriate to test. I
3 don't expect that will be 100 percent EPU, for example,
4 and we don't perform those tests at 100 percent current
5 rated power.

6 So we expect to perform those tests, trend
7 the results, and then determine, okay, this will be what
8 we go ahead and move forward with where we perform
9 normal surveillances.

10 MEMBER CORRADINI: And again, since I'm
11 not in operations, you use the word appropriate, tell
12 me what the term is appropriate, I forget.

13 MR. KOVALCHICK: Appropriate will mean
14 that the -- for example, like, the EHC control of the
15 turbine is stable or that level changes are within our
16 normal acceptance that we consider reasonable. And
17 those criteria will be built into the procedure.

18 MEMBER RICCARDELLA: Regarding the
19 vibration monitoring, I know you have plans for
20 extensive monitoring of the steam dryers on Unit 2, are
21 there other vibration monitors going to be in place
22 during these power ascensions, like, on the piping and
23 other pump monitoring?

24 MR. HENRY: Absolutely. For both inside
25 and outside containment monitoring the steam lines,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 feedwater lines, condensate flows, extraction steam
2 probes, the whole section of data that we've been
3 getting that has established links.

4 MEMBER RICCARDELLA: And the small-bore
5 piping?

6 MR. HENRY: Small-bore piping also.

7 MR. MASSARO: To be clear about the
8 vibration equipment that's on the main steamlines,
9 there is vibration equipment there as well, not
10 installed as part of the test startup, you know, similar
11 to the dryer where it's installed and then we'll be
12 taking readings off that. The other areas that Dave's
13 talking about, we will be monitoring for vibration but
14 we don't have fixed vibration sensors in each location.

15 MEMBER SKILLMAN: Let me build on Dr.
16 Corradini's question about the bypass valves, the
17 MSIVs, and turbine valve testing. It would seem to me
18 that it would be logical to have an MSIV test at a higher
19 power level rather than, approximately, 90. It would
20 seem as you push this plant further, you would want to
21 have assurance that your MSIVs are going to close
22 tightly and stay closed tightly when you command them,
23 for whatever reason that might be.

24 Why aren't you pushing them at 108, or 105,
25 or something like that? Just giving yourself the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assurance that the capability of those valves will do
2 what you want those valves to do?

3 MR. KOVALCHICK: We're not changing the
4 design of the MSIVs. We know what their capabilities
5 are with respect to flow and pressure now. And also,
6 the design of those valves, steam flow closes them, so
7 there really isn't anything that we would gain from
8 trying to check that at 108 percent of current.

9 MEMBER SKILLMAN: Well, you would gain the
10 confidence that it will do what you intend it to do,
11 you would also probably have a transient that you might
12 not want to have.

13 MR. KOVALCHICK: And that's part of it
14 too, you know, that was part of the criteria, was, to
15 go through and what will we gain from it? What would
16 be the impact, for example? And that transient is not
17 one -- and it's been evaluated by PRA. It's not one
18 that we want to take that would potentially have impact
19 on our ability to provide continued generation to --
20 you know, if there was a transient that would cause the
21 plant to trip.

22 MEMBER SKILLMAN: So that's really the
23 answer to the question that Dr. Corradini asked, define
24 appropriate. Appropriate is that combination of plant
25 effect and equipment effect where you determine testing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on some of these just ceases to be what you want at the
2 higher power level.

3 MR. KOVALCHICK: Yes, other than we are
4 going to set what we consider appropriate,
5 conservative, well before there would be that effect,
6 but yes, I tend to agree with your premise.

7 MR. BORTON: And to answer also was,
8 operating experience, we looked at other plants EPU
9 conditions that had an expected occurrences, so that
10 also factors in generically when you're looking at, you
11 know, globally, our ascension plan as well. So we did
12 take a look at experiences at other plants.

13 MEMBER SKILLMAN: Okay. Thank you.

14 CHAIR REMPE: So as you go through this
15 decision process, do you have to get any additional
16 concurrence from the regulator or did they approve it
17 initially at this time and that's it?

18 MR. BORTON: When we submitted our power
19 ascension plan, we'll also provide procedures prior to
20 exceeding current power levels as well as part of our
21 license condition that's being built in.

22 CHAIR REMPE: But you don't have to ask
23 them about when you can stop the main steam isolation
24 valve testing, for example.

25 MR. BORTON: That's correct. I mean, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plan was put in with the constraints that are put into
2 the plant already, so they've evaluated the constraints
3 that we're proposing, and then based on that, we'll get
4 this approved.

5 CHAIR REMPE: Okay. Thanks.

6 MR. KOVALCHICK: And I would add too that,
7 one of the other potential benefits when you decide on
8 whether or not you are going to do a test like an MSIV
9 closure, would be whether or not the operators
10 understood how to respond. And in our review, we
11 determined that the simulator modeling and the training
12 that the operators had is sufficient for that as well.
13 So it's not just about the mechanics. We also consider
14 the operational aspects of that as well.

15 MEMBER SKILLMAN: Thank you.

16 MR. KOVALCHICK: You're welcome. Okay.
17 Any other questions on Slides 34 and 35? Okay. I'd
18 like now to talk about the acceptance criteria. There
19 are two types of acceptance criteria in the plan. The
20 first is designated as level 1 and it involves design
21 limits. If a level 1 test criterion is not met, the
22 plant will be placed in a hold condition, judged to be
23 satisfactory and safe based on prior testing. And I'll
24 pause here to say that more than likely this would
25 result in a reduction of power to a previous spot in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 our power ascension.

2 Resolution will be pursued by equipment
3 adjustments or engineering evaluation. The plant
4 operations review committee, or PORC, must approve
5 corrective actions and applicable test portions must
6 be repeated and results presented to PORC prior to
7 raising reactor power.

8 Moving on to the next slide. The next
9 acceptance criterion designation is level 2, which is
10 performance expectations. If a level 2 test criterion
11 is not met, an evaluation will be initiated to identify
12 cause and corrective actions, PORC must approve
13 corrective actions, if physical adjustments are
14 required, the test portions will be repeated to verify
15 level 2 requirements are satisfied prior to increasing
16 power.

17 MEMBER SCHULTZ: Now, in this context,
18 when you say, if there's a problem, then you said, also,
19 that you might then, or likely would be, decreasing
20 power, going to a lower power level to hold while the
21 review would be completed and corrective actions would
22 be taken. Now, when you talk about prior to increasing
23 power, is that above the power where you now sit or is
24 that increasing power above where you were when you ran
25 into the issue?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KOVALCHICK: Above where we now sit.

2 MEMBER SCHULTZ: Thank you.

3 MR. KOVALCHICK: If there's no other
4 questions for power ascension, that ends that portion
5 of the presentation.

6 CHAIR REMPE: Thank you. So at this
7 point, we're going to have our 15-minute break and come
8 back at 10:45, but when we come back, we're going to
9 be in closed session, so this will end the open session.
10 It's my understanding that the staff members that were
11 going to talk at 12:45 will be able to support this a
12 bit early and probably will just go through this first
13 discussion item of the closed session when we come back
14 before lunch. Does that sound good to everybody?
15 Okay. Thank you.

16 (Whereupon, the foregoing matter went
17 off the record at 10:26 a.m. and went back on the
18 record at 4:19 p.m.)

19 CHAIR REMPE: This is the public portion,
20 kind of, closeout of the meeting. Is there someone out
21 there in the public who could just say, I'm there, so
22 we could verify the lines are open? Okay. So I guess
23 we're going to assume that there are no members of the
24 public on the phone line, but we do have a member of
25 the public, I believe his name is Mr. Eric Epstein, here

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 today who would like to make comments, and because of
2 time, you do need to limit your comments to ten minutes
3 or less, okay?

4 MR. EPSTEIN: Sure. Where do you want me?

5 CHAIR REMPE: Go up to the mic.

6 MR. EPSTEIN: Good afternoon. I'm Eric
7 Epstein. I'm the chairman of Three-Mile Island Alert.
8 We're a safe energy organization founded in '77. We
9 monitor three nuclear power plants on the Susquehanna
10 River; Susquehanna 1 and 2, TMI 1 and 2, and Peach Bottom
11 1, 2, and 3. The focus of my comments, and let me be
12 blunt, have to do with omissions rather than
13 commission. I've tracked the process from the
14 beginning and I've participated in a number of the
15 teleconferences.

16 We're not theologically opposed to the
17 uprate, but we are theologically opposed to
18 uncoordinated regulation, and I think there are a lot
19 of holes in this process, which were similar to the
20 holes we witnessed in the re-licensing of PPL, which
21 resulted in a memorandum of understanding between the
22 NRC and the Susquehanna River Basin Commission.

23 Our testimony is 29 pages long and I've
24 learned as a professor and a teacher at the end of the
25 day, nobody really cares what you have to say, so I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 not interested in reading the 29 pages. Furthermore,
2 I learned as a teacher and a professor that I just made
3 the cardinal error by handing you a document that you
4 will read and not listen to me.

5 That being said, I'm just going to point
6 out a couple of the trends that we've noticed, and
7 essentially, what we did is, we outlined the licensing
8 of Peach Bottom, which has been quite an odyssey, and
9 many of you have probably been done there in Southern
10 York County, but I'd just like to remind you, we're
11 talking about a plant that really got off to its start
12 in July 1960.

13 Obviously, Peach Bottom 1 is done and one
14 of the concerns we have, if you track the trajectory
15 of the construction of the plant, and if you look at
16 the three uprates, because we're at our third uprate
17 right now, the characteristics of the plant have
18 changed dramatically since 1960, which, you know, was
19 a time when Kennedy was President, and I think your
20 predecessor agency actually was the one that reviewed
21 the original licensing requirements, some of which have
22 not been modified, and that causes me concern.

23 I'm not a real big fan of saying, get back
24 to me later with regulatory mandates. I'm one of those
25 old-school Harry Truman guys that, when you say to me,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ten minutes, it means ten minutes. No more, no less.
2 You know, you're looking at a plant that was built with
3 a combined capacity of 2194 megawatts. License for 40
4 years. It's now re-licensed to operate for 60 years.
5 The mega-wattage is almost 4000. It's a dramatic
6 increase.

7 This has been a forward process. I've
8 reviewed all the RAIs. I think the last one was January
9 of this year. In fact, the heat sink operability
10 requirements just landed on my desk Saturday.
11 Saturday. They were sent out Friday. So, you know,
12 it's difficult for an organization like ours to, you
13 know, monitor all these trends, but that's kind of late
14 in the game.

15 And that's not a hit on folks, because I
16 know it's a difficult process. I guess the concern I
17 have is also the fact that Peach Bottom is a closed
18 cooling system and most of my comments deal with
19 environmental impact. And again, if you look at the
20 discussion we have on Pages 6 through 10, thoroughly
21 researched impacts on the Susquehanna River.

22 And, you know, the river itself is an
23 extraordinary watershed which empties into the
24 Chesapeake Bay, and the last time I checked, that was
25 the most productive estuary in North America. Had a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 lot of problems since this plant was built with extreme
2 weather events, with flooding, with fish kill, and
3 again, that's enumerated, documented, and cited
4 throughout the document, which concerns me because
5 there was no site-specific evaluation of any of those
6 impacts, either by the SRBC or the DEP.

7 Which is interesting because, when this
8 plant was built, it wasn't what it looks like now. In
9 other words, right now, you have Muddy Run, you have
10 Holtwood, you have Conectiv, it's an energy park. It's
11 not what it was in 1960. Nothing is. The world
12 changes.

13 Special attention. I just want to read
14 you a couple things about the Conowingo Pond, because
15 last week, ironically, Holtwood was just re-licensed,
16 800 megawatts, and FERC had a much more rigorous and
17 aggressive review protocol. In fact, the only that
18 they got a WQ from DEP was based on a settlement, which
19 I'd encourage you to look at. There's no such
20 agreement between NRC and Exelon, SRBC and Exelon, DEP
21 and Exelon, and that's an 800 megawatt plant, about 1/4
22 the size, owned and operated by the same company.

23 But I'd like you, when you have a chance,
24 on Page 9, the Conowingo Pond is really the lynchpin
25 to what's occurring here. The other reality is this,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and let's be frank, Marcellus Shale is now a player.
2 And when you go to Susquehanna River Basin commissions,
3 almost all the applicants are Marcellus Shale. I don't
4 look for that to end.

5 So there's a limit to the water. It's also
6 ironic, Peach Bottom is only 36 miles north of
7 Baltimore, and we're talking about a water source that
8 also -- it goes as far east as Chester, the City of
9 Chester, so this is a dynamic, important asset. On
10 Page 11, and I'm sure with this many people here, by
11 the way, everybody seems to have gone to the same
12 tailor, so I think I added a little continuity to the
13 dress attire today.

14 I would point out the legal arguments that
15 we make, 11, 12, 13, 14, and 15, which were similar to
16 arguments that we've made in the past about illegal
17 fragmentation. Also, the SRBC's rules and regulations
18 have changed. Apparently, that has not been
19 incorporated into the NRC's oversight, which I find
20 deeply disturbing. There's now an Act 220. In fact,
21 if you look at the number of regulations that have been
22 promulgated, passed, adopted, and are now statute in
23 Pennsylvania, 1990, 2000, 2014, it's a whole new
24 aggressive, rigorous protocol.

25 So one of the things that really completely

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 dismays me is that we're grandfathering in the MPDES
2 and conditioning it based on requirements to occur down
3 the road. I just don't think that's any way to run a
4 business. DEP exempted Peach Bottom from an
5 environmental impact statement. And again, you know,
6 based on our research, the EIS that was concluded was
7 1973. I think Nixon was still President.

8 And if you look at the statutes that have
9 come along since re-licensing in Pennsylvania,
10 Radiation Act, Chesapeake Bay Commission Agreement
11 Act, Hazardous Site Cleanup Act, Pennsylvania
12 Environmental Stewardship and Watershed Act, Act 29,
13 Act 220, these things just can't be taken out of the
14 mix because it's inconvenient, arduous, or takes a lot
15 of time.

16 Also, I don't see any clear-cut continuity
17 between 316(b) and the implementation of the EPU.
18 That's 12.4 percent. It's a lot. With the other
19 increases, this is a new plant with new
20 characteristics. I ignored 316(a), although I still
21 think 316(a) has a part to play here. Also, the PUC
22 was not consulted regarding Title 66, and that has to
23 do with the cost of water.

24 And that argument is outlined again on Page
25 14. So everything, you know, I'm hoping, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that I'm articulating today in a really short and brief
2 format has been documented, and I'll hope you'll give
3 it some time to look at it. I think the major concern
4 we have and the takeaway we'd like you to come away with,
5 there's a lot of open issues, there's a lot of
6 generalizations, there's a lot of vagaries.

7 I'm a former professor of history and I
8 really am a stickler for facts, so some of the language,
9 maybe that's your nomenclature, gives me pause for
10 concern. I didn't really see any empirical data to
11 support environmental impact conclusions that were
12 also absent an environmental impact statement. And,
13 you know, I'm a little troubled that you would ignore
14 the aggregate impact of the EPU's.

15 I especially focused on the aquatic
16 resource impact and I just want to read you something,
17 and a lot of that is based on ongoing studies or studies
18 to be completed after you approve the EPU, which, I
19 don't get that regulatory protocol. This is from the
20 Conowingo Pond. "The conclusion was made assuming at
21 station conditions under the MPDES. After the study
22 is completed and based on the study results, Exelon will
23 submit to the PDP, an application to modify the MPDES.
24 For any future modifications, the GDAP" -- I guess
25 that's where it kind of sticks in my craw is, how do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you approve an EPU? How do you approve a license
2 amendment request on a condition that has yet to be met,
3 on a promise that may or may not be kept?

4 Again, looking at what we did, and I don't
5 want to get into it, a lot of aquatic challenges, not
6 just with algae blooms, not with invasive species, I
7 mean, there's tons. The river has changed. And if you
8 know the river, and you start at Susquehanna, you go
9 down to TMI, you go down to Peach, you can't have it
10 both ways. Exelon can't come in here and say, we're
11 going to delay our flooding compliance for a year to
12 2015 because we now want to coordinate with TMI, and
13 then ignore regional coordination.

14 The zebra mussels, the Asiatic clams, all
15 that, you know, they're a reality, whether or not
16 they'll impact Peach Bottom, I don't know. Asiatic
17 clams certainly have at TMI. I direct your attention,
18 actually, to about Page 22. These are miscellaneous.
19 I don't know, if you read this document, it's as if the
20 States of Maryland and Delaware don't exist.

21 I mean, we're less than two miles from the
22 Maryland border. I find that interesting. The census
23 data is four and a half years old. I understand.
24 Also, it looks like you completely bypassed the York
25 County Planning Commission, which is dedicated to doing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what you were supposed to do, and that's a
2 socio-economic impact statement.

3 I don't think the U.S. Fish and Wildlife
4 Service was consulted. I may be wrong. I didn't see
5 anything from the U.S. Army Corps of Engineers. I
6 didn't see anything acknowledging that Peach now
7 accepts radioactive waste from Limerick. So the
8 characteristics of the plant, much, much different.
9 It's a fluid situation.

10 And I would just conclude by saying in my
11 summary, our summary's in the back, that I just don't
12 think it's good regulation to leave open-ended
13 commitments to a time to be determined. I actually,
14 frankly, think that's awful. And I think one of the
15 problems, and I don't think this was intentional, is
16 there needs to be better coordination with the SRBC,
17 the Pennsylvania Fish and Boat Commission, the PHMC,
18 I mean, just a whole slot of agencies.

19 The fact that DEP gave them a free pass,
20 I don't think is an answer unto itself. So I think I'm
21 in under ten?

22 CHAIR REMPE: You made it. Thank you very
23 much for your comments. Is there anyone else in the
24 room who wanted to make a comment? Okay. So this is
25 a Subcommittee meeting, and at the end of Subcommittee

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 meetings we usually go around the table and ask for
2 final comments from the Member, and because of a plane
3 commitment, I'm going to let Kord Smith go first.

4 DR. SMITH: I'm afraid that most of
5 today's discussion was a little bit outside of my area.
6 I'm hoping we hear back on MELLA Plus, it'll weigh-in
7 a little more heavily in my area. I saw nothing that
8 caused me a safety concern today.

9 CHAIR REMPE: Okay. Thanks. Mike, did
10 you have any comment?

11 MEMBER CORRADINI: I don't have any
12 further comments. I've commented throughout the day.
13 I think from the standpoint of our discussion, both in
14 open session, closed session, and really closed
15 session, I do think the generic issue of consistent
16 steam dryer analysis that we understand and can feel
17 good about is probably the only thing that I'd repeat.

18 CHAIR REMPE: Okay. So, Dana, you've
19 been here a short period of time, but do you have any
20 comments?

21 MEMBER POWERS: Well, I did have a chance
22 to look through some of the view graphs. I've seen we
23 addressed CAP.

24 CHAIR REMPE: Yes.

25 MEMBER POWERS: I congratulate you. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 think that is a real major step.

2 CHAIR REMPE: Okay. So, Steve?

3 MEMBER SCHULTZ: The general comments I
4 have is that, with regard to, I'll, echo what Mike said,
5 and also what Dana said with regard to CAP, but I would
6 also further comment that there's a substantial number
7 of plant modifications that go, in fact, beyond what's
8 required for the EPU, and I think incorporating them
9 into this work is a very important initiative, and I'm
10 glad to see it.

11 Appreciate the presentations today,
12 especially, and with regard to the technical reviews
13 that we heard about from the staff, their technical
14 reviews of the application with regard to their
15 evaluations that we heard about today were very
16 thorough and well presented. I thank the staff and the
17 applicant for the presentations that we've heard.

18 MEMBER BLEY: The only thing I would add,
19 and it isn't directly relevant to the decisions we have
20 to make later, is the discussion about CAP, the interest
21 in side effect, which doesn't surprise me that the
22 features they've added to ensure CAP is not a problem
23 are doing them good in other areas where it's probably
24 much more likely to be helpful in terms of the
25 flexibility they're getting to respond to other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 situations, so I found that interesting.

2 CHAIR REMPE: Dick?

3 MEMBER SKILLMAN: I thank the staff and
4 the Exelon team for a thorough presentation. The
5 treatment of the dryer analysis and practical issues
6 to me was thorough and convincing. The fact that they
7 were codes that take into consideration thermal
8 conductivity, degradation for accidents and AOOs gives
9 me comfort. I had a number of issues that I was
10 concerned about relative to the plant modifications and
11 through the course of the morning, and through the
12 afternoon as well, those concerns were address, so
13 thank you.

14 CHAIR REMPE: Okay. Sanjoy.

15 MEMBER BANERJEE: First, I'd like to thank
16 the staff and the applicant. I think they all made
17 really good presentations. Of particular note is, of
18 course, how innovative they were in dealing with CAP,
19 which I really appreciated, and I think the whole
20 Committee did. It shows us that even though it's
21 somewhat plant-specific, that if somebody really wants
22 to do it, they can often do it.

23 And this was a point that Dave Bassette,
24 many years ago, who was one of our staff members,
25 pointed out to me, actually, and to several of us that,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 one of the ways to deal with CAP was to actually improve
2 the amount of heat removal so you could cool down the
3 fluid in the torus, and he showed something fairly
4 similar to this, so I'm glad that somebody is actually
5 doing this now. So that's really a big step forward.

6 And with regard to the other major issue,
7 which is steam dryer, I think with regard to the dryer,
8 there's enough empirical evidence, based on the
9 performance of the Nordic plants and other plants that
10 this dryer seems to be robust and should work. There
11 are issues that we still need to resolve, and whether
12 this be done on a generic basis and what impact it can
13 have here, I don't know, but it's something that we,
14 as a Committee, will need to consider in the future.

15 So with that, I don't know how it will
16 affect the letter, whether it should simply be noted
17 there or some other point should be made, so otherwise,
18 it's fine.

19 CHAIR REMPE: Okay. Pete.

20 MEMBER RICCARDELLA: Yes, you know, my
21 area of expertise is structural analysis, and so I had
22 particular interest in their replacement steam dryer
23 work. I think that there's been a significant amount
24 -- you presented a significant amount of analysis and
25 testing, and I think you have a power ascension plan

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that is well thought out and that, plus the associated
2 license conditions on the power ascension plan, I agree
3 with the staff conclusions that there's reasonable
4 assurance that the steam dryers will operate within
5 structural limits.

6 CHAIR REMPE: Okay. Yes, Dick.

7 MEMBER SKILLMAN: I have one more. I want
8 to thank Eric for making the trip from Harrisburg and
9 for his courage to speak. Thank you.

10 CHAIR REMPE: I didn't share the
11 appreciation that you have worked hard to eliminate
12 CAP. I went to look in a little bit more about some
13 of the assumptions that differed in the analysis to
14 justify that, and again, I'll do a bit more homework,
15 but it's still not entirely clear in my mind, but I think
16 it's something that I just need to make sure I
17 understand a bit more.

18 With respect to the full Committee
19 meeting, there will be, probably, at most, two hours
20 for the discussion, and so clearly, focus your
21 presentation, I think, on the most important issues,
22 the CAP elimination, and the steam dryer, and some
23 notice of the upgrades that are occurring. Are there
24 any other things that individuals on the Subcommittee
25 would suggest should be presented to our colleagues on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the full Committee?

2 And with that, is there anything the staff
3 wanted to say as a follow-up? Then I think we can close
4 the meeting. Thank you again.

5 (Whereupon, the meeting in the
6 above-entitled matter was concluded at 4:38 p.m.)

7

8



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

ACRS Subcommittee on Power Upgrades

NRC Staff Review of Extended Power Upgrade for Peach Bottom Atomic Power Station Units 2 and 3

June 10, 2014

Opening Remarks

Louise Lund

Deputy Director


**Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation**

Background

- **154 power uprates approved:**
 - **29 are extended power uprates (EPUs)**
 - **18 of 29 are for boiling-water reactors (BWRs)**
- **Peach Bottom Proposed EPU:**
 - **3514 to 3951 Megawatts Thermal (MWt)**
 - **12.4% increase**

Comparison to other BWR EPU's

**Number of Approved BWR EPU's
Versus Power Level Increases**



Peach Bottom EPU Review

- **EPU Review done with Review Standard RS-001:**
 - **RS-001 safety evaluation template modified to reflect Peach Bottom design and licensing basis**
 - **RS-001 used for 17 EPU's since 2005**
- **Review has involved:**
 - **Over 25 reviewers**
 - **9000 hours**

Introduction


Rick Ennis

**Senior Project Manager
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation**

Review Timeline

- **September 28, 2012 – Application submitted to NRC.**
- **December 18, 2012 – NRC informs Exelon of need for supplemental information.**
- **February 15, 2013 – Exelon submits supplemental information.**
- **March 8, 2013 – Application accepted by NRC for review.**
- **September 8, 2014 – NRC forecast for review completion based on 18 months from date of acceptance.**

Requests for Additional Information (RAIs)



Topics for Morning

- **EPU Overview**
- **Transient and Accident Analyses Summary**
- **Flow-Induced Vibration & Structural Analyses**
- **Power Ascension**

Topics for Afternoon

- **Nuclear Design & Safety Analyses**
- **Containment Analyses**
- **Replacement Steam Dryer Overview**
- **Steam Dryer Analyses**

Peach Bottom Atomic Power Station Extended Power Uprate

**Advisory Committee on Reactor Safeguards
Meeting of the Subcommittee on Power Uprates
June 10, 2014**



Exelon Generation®

Introductions

Peach Bottom Atomic Power Station (PBAPS) Extended Power Uprate

Agenda

- **Introductions**
- **EPU Project Overview**
 - Background
 - Parameter Changes Summary
 - Modification Summary
 - Elimination of Containment Accident Pressure (CAP) Credit
- **Transient and Accident Analyses Summary**
- **Flow Induced Vibration and Structural Analyses**
- **Power Ascension**
- **Replacement Steam Dryer Overview**
(afternoon closed session)

Key Team Members Present

- Kevin Borton - Power Uprate Licensing Sr Manager
- Craig Lambert - Power Uprate Vice President
- Mike Massaro - PBAPS Site Vice President
- John Rommel - Power Uprate Engineering Director
- Ken Ainger - EPU Project Management Director
- Jim Armstrong - PBAPS Regulatory Assurance Manager
- Dave Henry - PBAPS Sr Manager Design Engineering
- Jim Kovalchick - PBAPS Sr Manager Operations, EPU Integration
- Tony Hightower - PBAPS Operations Shift Supervisor

The EPU Project Team is staffed with personnel having extensive BWR plant and EPU experience:

- **Exelon**
 - Combination of Dedicated Project and Station Resources
- **GE-Hitachi (NSSS)**
- **Sargent & Lundy (BOP)**
- **Industry EPU experienced specialty contractors**

Standard Application

EPU License Application

- Based on GEH Topical Reports
 - NEDC-32424 (ELTR-1)
 - NEDC-32523 (ELTR-2)
 - NEDC-33004 (CLTR)
 - NEDC-33173 (IMLTR)
- NRC RS-001 Format “Review Standard for Extended Power Upgrades”

EPU Project Overview

Background

Parameter Changes Summary

Modification Summary

Elimination of Containment Accident Pressure (CAP) Credit

Peach Bottom Atomic Power Station Overview


- GE BWR 4 Mark I Containment
- Operating License issued 1973 (U2) and 1974 (U3)
- Commercial Operation commenced 1974
- Renewed License issued in 2003 (U2 and U3)
- Licensed Thermal Power History
 - Original Licensed Thermal Power (OLTP) 3293 MWt
 - Stretch Uprate in 1994 and 1995 3458 MWt
 - MUR power uprate in 2002 to CLTP 3514 MWt
 - Proposed EPU (20% OLTP, 12.4% CLTP) 3951 MWt

Parameter Changes Summary

<u>Parameter</u>	<u>CLTP</u>	<u>EPU</u>
Core Thermal Power (MWT)	3514	3951
Licensed Full Power Core Flow Range (Mlbm/hr)	84.87 to 112.75	101.48 to 112.75
Licensed Full Power Core Flow Range (% Rated)	82.8 to 110.0	99.0 to 110.0
Steam Dome Pressure (psia)	1050	1050
Vessel Steam Flow (Mlbm/hr)	14.387	16.171
Feedwater Flow Rate (Mlbm/hr)	14.355	16.139
Final Feedwater Temperature (°F)	381.5	381.5
CAP Credit Required (psig) (DBLOCA)	6.1	CAP not credited

Reactor Building

Overview of Plant Modifications



Major Modification Summary

Modifications to Improve Reliability and Operating Margins

Additional Main Steam Spring Safety Valve (SSV)

One additional SSV on each unit

Increases margin for ATWS analysis at EPU

Replacement Steam Dryer

Replacing steam dryers to improve structural margin

Improves Moisture Carryover (MCO) performance lowering in-plant radiation doses

High Pressure Turbine Replacement

Accommodates increase in steam flow at EPU

Improves operating margin for Main Turbine Control system

Reactor Feed Pump Turbine Upgrades

Accommodates higher blade stresses at EPU

Improves reliability

Major Modification Summary

Modifications to Improve Reliability and Operating Margins (continued)

Feedwater Heaters

Five replaced (1 on U2 and 4 on U3) to restore margin at EPU conditions
Other FW heaters analyzed and verified to be acceptable for EPU

Reactor Water Cleanup

Flow diffusers to be installed on all four RWCU demineralizers
Improves efficiency to maintain chemistry limits at EPU conditions

Condensate Pump/Motor Upgrades

Impellers to be replaced and larger motors installed
Improves margin at EPU conditions

Condensate Filter/Demineralizer

Two additional demineralizers to be installed on each unit
Maintains chemistry limits and operational flexibility at increased FW flowrate at EPU

Main Steam Piping

New supports and support modifications
Assures margin to Code requirements at EPU conditions

Major Modification Summary

Modifications to Improve Reliability and Operating Margins (continued)

Main Generator Modifications

U3 rotor replaced in 2013, U2 rotor to be modified for new rating
Restores generator margin at higher MVA at EPU

Isophase Bus Duct

Several portions of existing IPBD will be replaced
Restores IPBD margin at higher MVA at EPU

ATWS-Recirculation Pump Trip

The ATWS-RPT relocated from MG sets to Recirculation Pump motor breaker
Provides faster coastdown time for Recirculation Pumps to support ATWS analysis

Motor Operated Valves

MOVs affected by changes in EPU response were evaluated
Improves margin at EPU conditions

Major Modification Summary

Modifications Associated with CAP Credit Elimination

RHR Heat Exchanger Cross-Tie

Includes new cross-tie valve allowing two HXs to be supplied from one RHR pump
Increases RHR heat removal capability

HPSW Cross-Tie

Replaces existing cross-tie with valve able to open against full flow differential pressure
Increases RHR heat removal capability

Condensate Storage Tank

Provides protected CST volume and safeguards against fire-induced swapover to torus
Allows crediting of CST as suction source

Standby Liquid Control System


Boron-10 enrichment increased to 92 atom percent in SLC Storage Tank solution
Lowers Suppression Pool temperature during ATWS

Elimination of Containment Accident Pressure Credit

John Rommel
Power Uprate Engineering Director

Elimination of CAP Credit

$$\text{Available NPSH} = h_{\text{atm}} + h_{\text{static}} - h_{\text{loss}} - h_{\text{vp}}$$



Elimination of CAP Credit

- Opportunity to improve margins and remove concerns associated with Containment Accident Pressure (CAP) Credit
- Became key project goal
- Credible options existed to eliminate CAP Credit at PB

Elimination of CAP Credit

Current Licensing Basis

- **CAP Credit taken for following events**
 - LOCA (both long and short term)
 - SSLB
 - Appendix R
 - ATWS
 - SBO
- **Maximum CAP Credit Required: 6.1 psig
LOCA (Long Term)**

Elimination of CAP Credit

Actions to Eliminate CAP Credit

- **Increase Residual Heat Removal (RHR) system heat removal capability**
 - RHR and High Pressure Service Water (HPSW) cross-tie modifications
 - Increase RHR Heat Exchanger (HX) K-Value
- **Reduce RHR pump flow**
- **Credit Condensate Storage Tank (CST) as suction source for special events**
- **Increase Standby Liquid Control (SLC) system Boron-10 enrichment**


Elimination of CAP Credit

Methodology

<u>Modification or Analytical Change</u>	DBA-LOCA	SSLB	App R	ATWS	SBO
RHR HX Cross-tie and HPSW Cross-tie mods	X	X			
Increased single RHR HX K-Value from 270 to 305	X	X	X	X	X
Reduced RHR flow rate from 10000 gpm to 8600 gpm	X	X	X	X	X
Credit CST as HPCI and/or RCIC suction source			X	X	X
Increase SLC Boron Enrichment				X	

Elimination of CAP Credit

U2-DIV I RHR and HPSW Cross-Tie



Elimination of CAP Credit

RHR/HPSW Cross-tie Modifications

- **Modifications will:**
 - Allow two RHR HXs to be supplied from one RHR pump
 - Improve rate of Suppression Pool cooling
 - Lower peak Suppression Pool temperature, increasing NPSHA
 - Lower required RHR flow, decreasing $NPSHR_{eff}$
- **Modifications consist of:**
 - New cross-tie line with a normally closed cross-tie isolation on discharge of RHR pumps
 - New flow control valves upstream of each heat exchanger to balance flow
 - Replacement of existing HPSW cross-tie valve with one that can be repositioned against the full flow and differential pressure of a single HPSW pump

Elimination of CAP Credit

CST Modifications

- **Modifications will:**
 - Ensure adequate inventory in CST
 - Ensure that HPCI /RCIC pump suctions remain aligned to the CST
 - Produce additional heat capacity in Suppression Pool
 - Lower peak Suppression Pool temperature, increasing NPSHA
 - Provide additional volume (height) in torus, increasing pump NPSHA
- **Modifications consist of:**
 - A standpipe to control the volume of CST
 - Installation of key lock switches in the Control Room to prevent inadvertent suction source swap
 - Raising torus high level setpoint to prevent premature automatic switch of HPCI suction to Suppression Pool
 - Revised procedural guidance to ensure adequate CST inventory makeup from RWST

Elimination of CAP Credit

Operator Actions

- Limiting LOCA and SSLB (w/EDG failure to start)
Within 1 hour:
 - Start 1 additional HPSW pump
 - Open MOV to establish HPSW flow through 2nd HX
 - Open new RHR cross-tie MOV
 - Balance RHR flow through 2 HXs
- ATWS /App R
 - Open RWST to CST transfer valves

Elimination of CAP Credit

Conclusions

-For all events

- $NPSHA > NSPHR_{eff}$

-No CAP Credit is required

Nuclear Design and Safety Analyses

Transient and Accident Analyses
Limiting Events

Dave Henry
Sr Manager Design Engineering

Transient and Accident Analyses at EPU

Transient Response

- Limiting events are re-evaluated on a cycle to cycle basis
- Evaluation demonstrated minor changes in Critical Power Ratio (CPR) from CLTP to EPU conditions

Accident Response

- Peak clad temperature during limiting SBLOCA increased 47degrees to 1912°F, below 2200°F limit (DBLOCA peaks at 1728°F)
- Control Rod Drop Accident (CRDA) unaffected by EPU conditions

Containment Response

- Suppression pool temperature is reduced in all design bases events due to the modifications. SBO temperature increases from CLTP but remains below limit
- Suppression Pool and drywell pressure increase slightly, below limit
- Drywell air and shell temperature meets limit

Flow Induced Vibration and Structural Analyses

EPU Flow-Induced Vibration Reactor Vessel Structural Topics

Dave Henry
Sr Manager Design Engineering

EPU FIV Effects and Modifications

Effect on the power plant

- Main Steam (MS) Line and Feedwater (FW) flow increase ~12.4%
- Vibration levels in MS and FW are expected to increase 30 to 35%
- Extraction Steam (ES) Flow increases up to 33% in some lines
- Heater Drain (HD) flow from the 5th stage to the 4th stage heater increases ~35%
- Maximum Core flow and reactor pressure remain unchanged

Evaluation and Screening Process Performed

Results

- Upgraded thermowells
- Small bore piping modifications
- New and modified Main Steam Line supports
- All Code and regulatory requirements met

FIV Monitoring Program

Piping vibration startup test program will be performed during EPU power ascension

- Detailed analyses performed to establish monitoring locations and acceptance criteria
- Multiple components will be monitored inside and outside of the drywell
- Power increases made in predetermined increments so that EPU vibration levels can be projected before CLTP RTP is exceeded

EPU – RPV and Internals

Flow Induced Vibration Effects

- Analyses performed to evaluate FIV effects on reactor internals
- Maximum core flow is not increased by EPU therefore core flow dependent RPV internals not affected by EPU
- Analysis extrapolated to 102% of EPU power level
- Vibration levels were below acceptance criterion for austenitic stainless steel
- Structural Integrity of Reactor Internal components confirmed

Structural Effects

- Design conditions not changed by EPU
- Site specific analyses, measurement and inspection programs verify the structural integrity of the Replacement Steam Dryer
- All stresses and Cumulative Usage Factors (CUFs) within design basis Code allowables
- RPV pressure retaining and internal components maintain structural integrity at EPU conditions

EPU – RPV and Internals – Continued

Fracture Toughness and Materials

- RPV meets 10 CFR 50 Appendix G requirements
- Fluence values calculated for EPU using NRC-approved GEH neutron fluence methodology
- Inspection requirements based on BWRVIP program
- Current inspection strategy for RCPB is acceptable

Power Ascension Plan

Power Ascension Test Preparation

Major Testing

PAT Non-Dryer Acceptance Criteria

Jim Kovalchick

PBAPS Sr Manager Operations, EPU Integration

Power Ascension Test Preparation

- EPU test plan developed using guidance of SRP 14.2.1 (Generic Guidelines for EPU Testing Programs)
- Equipment modification acceptance testing will be verified satisfactory prior to start up
- Performance testing for modifications will be integrated into a single controlling Power Ascension Test Procedure to verify aggregate effect of EPU and modifications does not impact safety
- Test plan consists of 18 individual tests
 - 16 tests from original startup testing scope
 - Wide Range Neutron Monitor (WRNM)Calibration
 - Steam dryer power ascension test plan
- Tests developed and will be performed by personnel experienced in PBAPS testing

Power Ascension Major Testing

Test Description	Test Condition (%CLTP)					
	≤90	95	100	104.2	108.3	EPU
Chemical/ Radiochemical		X	X	X	X	X
Radiation Measurement		X	X	X	X	X
Control Rod Drives			X	X	X	X
Steam Dryer	X	X	X	X	X	X
WRNM	X					
APRM/PRNM Calibration	X	X	X	X	X	X
RCIC	X					X
HPCI	X					X

Power Ascension Major Testing (CONT'D)

Test Description	Test Condition (%CLTP)					
	≤90	95	100	104.2	108.3	EPU
Core Power Distribution	x					x
Core Performance	x	x	x	x	x	x
Pressure Regulator	x	x	x	x	x	x
Feedwater System	x	x	x	x	x	x
Bypass Valves	x					
MSIVs	x					
Turbine Valve testing	x					
Reactor Recirculation System	x	x	x	x	x	x
Vibration	x	x	x	x	x	x
Plant Monitoring	x	x	x	x	x	x

PAT Non-Dryer Acceptance Criteria

- **Level 1 Acceptance Criteria – Associated with design performance**
- **If a Level 1 Test Criterion is not met:**
 - The plant will be placed in a hold condition judged to be satisfactory and safe based on prior testing
 - Resolution will be pursued by equipment adjustments or engineering evaluation
 - Plant Operations Review Committee (PORC) must approve corrective actions
 - Applicable test portion must be repeated and results presented to PORC prior to increasing reactor power

PAT Non-Dryer Acceptance Criteria

- **Level 2 Acceptance Criteria – Associated with performance expectations**
- **If a Level 2 Test Criterion is not met:**
 - An evaluation will be initiated to identify cause and corrective actions
 - PORC must approve corrective actions
 - If physical adjustments are required, test portion will be repeated to verify Level 2 requirement is satisfied prior to increasing power

CLOSED SESSION

Replacement Steam Dryer - Exelon

Acronym List

- AOV – Air Operated Valve
- APRM – Average Power Range Monitor
- ASME – American Society of Mechanical Engineers
- ATWS – Anticipated Transient Without Scram
- BOP – Balance of Plant
- BWR – Boiling Water Reactor
- BWRVIP – Boiling Water Reactor Vessel Internals Program
- CAP – Containment Accident Pressure
- CD – Condensate System
- CLTP – Current Licensed Thermal Power
- CLTR – Constant Pressure Power Uprate
- CPR – Critical Power Ratio
- CRDA – Control Rod Drop Accident
- CST – Condensate Storage Tank
- CUF – Cumulative Usage Factor
- DBLOCA – Design Basis Loss of Cooling Accident
- EDG – Emergency Diesel Generator
- ELTR – Extended Power Uprate Licensing Topical Report
- EPU – Extended Power Uprate
- ES – Extraction Steam
- FFWTR – Final Feedwater Temperature Reduction
- FIV – Flow Induced Vibration
- FW – Feedwater
- GEH – GE-Hitachi
- HD – Heater Drain
- HP – High Pressure
- HPCI – High Pressure Coolant Injection
- HPSW – High Pressure Service Water
- HX – Heat Exchanger
- IASCC – Irradiation Assisted Stress Corrosion Cracking
- IGSCC – Intergranular Stress Corrosion Cracking
- IMLTR – Interim Methods Licensing Topical Report
- MASR – Minimum Alternating Stress Ratio
- Mlbm – Million pound mass
- MNGP – Monticello Nuclear Generating Plant
- MOV – Motor Operated Valve
- MPS – Minimum Recirculation Pump Speed
- MS – Main Steam
- MSIV – Main Steam Isolation Valve
- MSL – Main Steam Line
- MWT – Megawatt Thermal
- NPSH – Net Positive Suction Head
- NPSHA – Net Positive Suction Head Available
- NPSHR – Net Positive Suction Head Required
- $NPSHR_{eff}$ – Effective Net Positive Suction Head Required
- NSSS – Nuclear Steam Supply System
- OLTP – Original Licensed Thermal Power
- PBAPS – Peach Bottom Atomic Power Station
- PORC – Plant Operations Review Committee
- PRFO – Pressure Regulator Failure Open

Acronym List (CONT'D)

- PRNM – Power Range Neutron Monitor
- psia – pounds per square inch absolute
- psig – pounds per square inch gauge
- QC – Quality Control
- RCIC – Reactor Core Isolation Cooling
- RCPB – Reactor Coolant Pressure Boundary
- RHR – Residual Heat Removal
- RIPD – Reactor Internal Pressure Difference
- RPV – Reactor Pressure Vessel
- RSD – Replacement Steam Dryer
- RTP – Rated Temperature and Pressure
- RWST – Refueling Water Storage Tank
- SBO – Station Blackout
- SRV – Safety Relief Valve
- SLC – Standby Liquid Control
- SSLB – Small Steam Line Break
- TS – Technical Specification
- VPF – Vane Passing Frequency
- WRNM – Wide Range Neutron Monitor

June 10, 2014

Before the Advisory Committee on Reactor Safeguards
Re: Nuclear Regulatory Commission's Draft Safety
Evaluation in Support of the Proposed Extended Power
Uprate License Amendment for the Peach Bottom Atomic
Power Station Units 2 & 3

Testimony of Eric Epstein, Chairman of Three Mile
Island Alert , Inc. to Postpone Approval of the Proposed
Extended Power Uprate License Amendment for the
Peach Bottom Atomic Power Station Units 2 & 3
Until Open and Unresolved
Environmental, Health & Safety Issues Are Addressed

I. Introduction.

The Peach Bottom Atomic Power Station (“Peach Bottom”) located in southern York County, Pennsylvania is co-owned by (“Exelon”) based in Illinois and Public Service and Gas (“PS&G”) of New Jersey.

Philadelphia Electric's (“PECO”) applied for a license to operate the Peach Bottom Atomic Power Station in July, 1960. The application was approved by the Atomic Energy Commission (“AEC”).

Peach Bottom-1 was a 40 megawatt (“MWt”), High Temperature Graphite Moderated reactor that operated from 1966-1974.

Peach Bottom 2 & 3 are Boiling Water Reactor designed by General Electric and engineered by Bechtel. Both plants use a Mark 1 containment system. Peach Bottom 2's initial capacity was 1,159 MWt. Peach Bottom 2's capacity was initially set at 1,035 Net MWt for a total capacity of 2,194 MWt.

The construction permit for PBAPS, Units 2 and 3, was issued by the AEC on January 31, 1968. Both units were evaluated against the then-current AEC draft of the 27 General Design Criteria (“GDC”) issued in November 1965.

On July 11, 1967, the AEC published for public comment, in the *Federal Register* (32 FR 10213), a revised and expanded set of 70 draft GDC. The licensee concluded that PBAPS, Units 2 and 3, conforms to the intent of the draft GDC.”

On February 20, 1971, the AEC published in the *Federal Register* a final rule that added Appendix A to Title 10 of the *Code of Federal Regulations* (10 CFR) Part 50, "General Design Criteria for Nuclear Power Plants".

The NRC decided not to apply the final GDC to plants with construction permits issued prior to May 21, 1971.

Unit 2 and Unit 3 began operation in July, 1974, but had their licenses extended by the Nuclear Regulatory Commission ("NRC") and are expected to operate through 2034.

On March 31, 1987, PECO was ordered by the Nuclear Regulatory Commission to shutdown Peach Bottom 2 and 3 on due to operator misconduct, corporate malfeasance and blatant disregard for the health and safety of area.

On February 3, 1988, John H. Austin resigned as president of PECO after a unusually critical report by the Institute of Nuclear Power Operations (INPO) was published. The report asserted that Peach Bottom "was an embarrassment to the industry and to the nation." Zack T. Pate, president of INPO, added, "The grossly unprofessional behavior by a wide range of shift personnel ... reflects a major breakdown in the management of a nuclear facility."

On February 1, 1989, the NRC staff recommended that nuclear power plants that utilize the Mark 1 containment shell, modify the structure to reduce the risk of failure during a serious accident. PECO said it would make the \$2 to \$5 million changes only if the NRC.

Commission makes the modifications a requirement. This was the second time in two years that the NRC staff has advised the Commission to make changes to the Mark 1 containment structure.

The NRC released a report on June 21, 1989 relating to Mark 1 containment buildings entitled "Severe Accident Risks: An Assessment for Five U.S. Nuclear Plants." The NRC's six-member panel were evenly divided as to whether the Mark 1 containment would be breached during a serious accident. "The NRC decided not to order immediate changes in the Mark 1 containment." Yet half of the panel stated "with near certainty" the Peach Bottom's containment structure would fail during a core melt accident.

On April 21, 2000, the NRC approved the transfer of the Peach Bottom licenses from Delmarva Power and Light Company and Atlantic City Electric Company to PECO and PSEG Nuclear LLC.

By 2002, the NRC had approved Measurement Uncertainty Recapture Upgrades and Stretch Upgrades for Peach Bottom 2 & 3. The proposed amendments would authorize an increase in the maximum reactor power level from 3,514 megawatts thermal (MWt) to 3,951 MWt.

On August 2, 2005 Exelon Generation Company, LLC, on behalf of itself and PSEG Nuclear LLC, filed to acquire 100% of the facility following approval of the proposed license transfers.

In December, 2006 Exelon was fined \$640,000 by the Susquehanna River Basin Commission (“SRBC”) for water violations at Peach Bottom related to water use and power uprates. (SRBC, Docket #: 20061209). Exelon failed to seek the Commission's approval for any change in their processes that required them to increase water usage by 100,000 gallons a day.

Peach Bottom nuclear units were licensed to operate for 40 years and designed to produce 2,194 net MWt. Forty years later, the plants’ operational lives have been extended by an additional twenty years and their combined capacity will increase to 3,951 MWt.

II. History of Power Uprates at Peach Bottom Atomic Power Station Units 2 & 3

Peach Bottom 2 received approval for a 5% stretch uprate or 165 MWt increase on October 18, 1994. Peach Bottom 3 received approval for a 5% stretch uprate or 165 MWt increase on July 18, 1995.

Peach Bottom 2 & 3 received approval for a 1.62% Measurement Uncertainty Recapture (“MUR”) uprate or 56 MWt increase on November 22, 2002.

Peach Bottom 2 received approval for a 5% stretch uprate or 165 MWt increase in October 18, 2004.

In December, 2006 Exelon was fined \$640,000 by the Susquehanna River Basin Commission (“SRBC”) for water violations at Peach Bottom related to water use and power uprates.

On September 28, 2012, Exelon Generation Company, LLC (“Exelon” or “the licensee”) submitted a license amendment request for Peach Bottom Atomic Power Station, Units 2 and 3.

Peach Bottom announced an Extended Power Uprate (EPU) to 3,951 MWt core power for both units, which is 120% of Original Licensed (core) Thermal Power. The project was authorized for full implementation by co-owners Exelon and PSEG in July 2012. Implementation of modifications required for the EPU are planned over three refueling outages and during “online periods.”

On April 5, 2002, Exelon outlined the projected timeline for approval of License Amendment Request and anticipated approval in May 2014.

In summary, the Extended Power Uprate process has been fluid with many open ended issues only recently closed out or left to future commitments as posted in the Federal Register.

III: Peach Bottom's Environmental Impacts on the Susquehanna River Basin

Peach Bottom does not use a closed-cooling system. The Peach Bottom Atomic Power Station uses and treats potable water from the Susquehanna River. The average daily usage is anywhere from 280,000 to 360,000 gallons per day.

The station does not currently use evaporative cooling towers for cooling needs, but evaporates up to 28 million gallons daily (“mgd”) through heat transfer via once-through cooling with water withdrawn from Conowingo Pond. The Peach Bottom Atomic Power Station, located on the west bank of the Conowingo Pond in York County, Pennsylvania and 36 miles from downtown Baltimore- is a two-unit nuclear generating facility that uses water from the Conowingo pond for cooling purposes.

Water shortages on the Lower Susquehanna reached critical levels in the summer of 2002. For the month of August 2002, 66 of 67 Pennsylvania counties had below normal precipitation. On August 9th, 2002, Governor Schweiker extended the drought emergency for 14 counties across Southcentral and Southeast Pennsylvania. Precipitation deficits at or exceeding 10.0 inches were recorded in several counties, included Dauphin County. The greatest deficit of 14.6 inches was in Lancaster County, and departures from normal precipitation range included 0.0 inches in York County. Peach Bottom is located in Lancaster and York Counties while Three Mile Island is situated in Dauphin and Lancaster Counties. (Pennsylvania Department of Environmental Protection, *Drought Report and Drought Conditions Summary*, August-September, 2002).

Ten years later in April 2012, the Susquehanna River reached record seasonal lows matching drought conditions of 1910 and 1946. U.S. Geological Survey analysis showed stream flows at hydrological emergency levels in 42 of the state's 67 counties as of Monday. Another 10 counties were at warning levels, and another 12 at watch level. Only three were normal or above. Groundwater levels are at emergency levels in 13 counties. The SRBC began issuing temporary orders to cease water withdrawals in February, 2012.

The Lower Susquehanna River is impacted abnormal weather conditions. For example, "periods of drought or extended periods of low flow can adversely affect the ability of the dam to meet minimum flow and summertime pond level minimums. In addition, due to high ambient and water temperatures and low flow, maintaining the minimum dissolved oxygen requirement is also challenging. These situations can further be compounded if the flows coming into the pond as measured at the Marietta gage do not equal the flow outfalls. This not only affects the dam, but also the water supply companies and Peach Bottom Atomic Power Station due to the loss of pond level. Additionally, recreational boating and marina operation becomes severely hampered due to low water levels. ("Conowingo Pond Management Plan," *Publication No. 242* , June 2006, p. 71.)

The Susquehanna River Basin is flood prone. "Since record-keeping began 200 years ago, the Susquehanna River has proven one of the most flood-prone watersheds in the nation. The watershed encompasses 27,510 square miles and extends from New York to Pennsylvania to the

Chesapeake Bay in Maryland – where nearly 4 million people live...Of the 1,400 communities in the river basin, 1,160 have residents who live in flood-prone areas.” (7th Annual Susquehanna River Symposium, Bucknell University, October 12-13, 2012)

Extreme weather events occur with more frequency including Tropical Storm Lee in 2011. Additionally, droughts have become more common in the Susquehanna River Basin.

Unlike other consumptive user i n the summer of 2002, Peach Bottom, did not “conserve” water until the plant was forced to close to address a massive fish kill. On August 30, 2002, high differential pressures on the circulating water intake screens forced the manual shut down of Peach Bottom. “The problem was caused by a sudden surge in the amount of fish (Gizzard Shad) that entered the intake canal and clogged the screens. Unit 3 power was returned to 100 percent following cleaning of the circulating water screens and restating of the 3’A’ circulating water pump.” (Nuclear Regulatory Commission, IR-50-277/02-05; 50-278/02- 05).

Five years later in the summer of 2007, Peach Bottom-2 & 3 was detected returning water to the Susquehanna River at temperatures in excess of 110 degrees.

Communities and ecosystems that depend on limited water resources are adversely affected by “normal operating conditions” at nuclear stations.

The Conowingo Pond also plays a cortical role in Peach Bottom's water intake. Declining pond levels threaten Peach Bottom's cooling water intake, recreational use of the Conowingo pond, shore habitat levels, and downstream flows. As drought conditions continue, the operators continue to generate hydroelectricity as much as possible using the water available to them, but it becomes a secondary concern. The primary concern becomes the depletion of storage in the pond and safeguarding the ability of the pond to continue to make adequate releases during low flow events of extended duration." ("Conowingo Pond Management Plan," *Publication No. 242* June 2006 p. 21.)

"The Conowingo pond provides a mixed warm water recreational fishery for largemouth and small mouth bass, channel catfish, white crappie, bluegill, and to lesser degrees, striped bass, walleye and carp. The most abundant fish in the Conowingo pond is the gizzard shad. Bass fishing tournaments are commonplace during the open season. Steep, wooded slopes and railroad postings limit shoreline and boat access. The heated effluent from Peach Bottom Atomic Power Station attracts game fish during the winter and extends the open-water fishing season. ("Conowingo Pond Management Plan," *Publication No. 242*, June 2006, p. 13).

"Millions of fish (game and consumable), fish eggs, shellfish and other organisms are sucked out of the Lower Susquehanna River and killed by nuclear power plants annually. It is hard to know just what the impact on fisheries is, because cool water intakes have been under the radar screen compared to some types of pollution, said Pennsylvania Fish and Boat Commission aquatics resources chief Leroy Young." (Ad Crable, *Intelligencer Journal*, January 15, 2005).

A former Peach Bottom nuclear plant employee said he was "sickened" by the large numbers of sport fish he saw sucked out of the Susquehanna. "When the water comes in, fish would swim in through tunnels and swim into wire baskets," said the man who lives in southern Lancaster County and asked that his name not be used. "There were hundreds and hundreds of fish killed each day. Stripers and bass and walleye and gizzard shad and all kinds of fish. It took a forklift to carry them out" (*Intelligencer Journal*, January 15, 2005).

Water use and water consumption - as well as water supply and water chemistry - have direct and indirect relationships with safety related components, plant cooling, and are intimately connected to the health and safety of the Susquehanna River and the regional community.

IV. Legal Arguments for Revising the Nuclear Regulatory Commission's Draft Safety Evaluation.

The fragmentation of “regulatory oversight” or the segmentation of a large or cumulative project into smaller components in order to avoid designating the project a major federal action has been held to be unlawful. *City of Rochester v. United States Postal Serv.*, 541 F.2d 967, 972 (2d Cir. 1976) .

"To permit non comprehensive consideration of a project divisible into smaller parts, each of which taken alone does not have a significant impact but which taken as a whole has cumulative significant impact, would provide a clear loophole to NEPA."); *Scientists' Inst. for Pub. Information, Inc. v. AEC*, 156 U.S. App. D.C. 395, 481 F.2d 1079, 1086n.29, 1086-89 (D.C.Cir. 1973) (statement required for overall project where individual actions are related logically or geographically). See generally W. Rodgers, *Environmental Law* §§ 7.7, 7.9 (1977) (discussing problems arising from scope and timing of environmental impact statements).

Federal and statewide statutes can not be unilateral exempted or ignored by coordinated inaction.

Regional water coordination was clearly recognized by the Department of Environmental Protection (“DEP”) on June 16, 2007 when the DEP advertised that the Susquehanna River Basin Commission was proposing comprehensive revisions to its regulations governing water withdrawal and consumptive use projects. (Proposed Rules [Federal Register: October 1, 2007 (Volume 72, Number 189) [Page 55711-55712] PART 808.)

The regional changes include a number of markers that the DEP and the NRC must address when consider Exelon's EPU request including a reduce the duration of consumptive use and withdrawal approvals from 25 years to 15; ending the recognition of "pre-compact" or "grandfathered" consumptive uses or withdrawals upon a change of ownership, and no longer allow the transfer of project approvals when a change of ownership occurs; and a require that sponsors of consumptive use projects involving ground or surface water withdrawals request approvals for the consumptive use and the withdrawals.

The SRBC stated, "If additional releases are made from new or existing sources, they will need to be accounted in the monitoring data at the Marietta gage. It will be important to understand how operations of Conowingo Dam will be affected and how existing CU [Consumptive Use] mitigation agreements for Peach Bottom Atomic Power Station and the City of Baltimore could be impacted. Operations of Conowingo Dam are driven by flows at Marietta, as are existing mitigation agreements for the Peach Bottom Atomic Power Station and the City of Baltimore. It will be necessary to specify that those agreements remain in force despite upstream mitigation, and to resolve methodologies for implementing the agreements in instances when upstream mitigation releases are distorting the flow measurements at Marietta. Regardless, Exelon and Baltimore will still be required to mitigate the CU of their projects." (Consumptive Use Mitigation Plan, *Publication No. 253*, March 2008, p. 29)

The Department of Environmental Protection and the Nuclear Regulatory Commission **exempted** Peach Bottom Atomic Power Station from preparing a final Environmental Impact Statement.

The Final Environmental Impact Statement (“EIS”) was concluded by the NRC’s predecessor agency - the Atomic Energy Commission - **in 1973** - prior to the Commonwealth of Pennsylvania enactment of aggressive statutes and regulations. Among the legislation passed were the Radiation Act (1984), Chesapeake Bay Commission Agreement Act (1985), Hazardous Site Cleanup Act (1988), Pennsylvania Environmental Stewardship and Water Protection Act (1999) and Act 129 (2008).

The initial EIS was issued decades prior to the emergence of the Environmental Protection Agency (“EPA”) Section 316(b) of the Clean Water Act. EPA issued regulations on the design and operation of intake structures in order to minimize adverse environmental impacts.

EPA promulgated regulations in 2001, 2003, 2006 and 2014. The requirements are included in the National Pollutant Discharge Elimination System (“NPDES”) permit regulations, 40 CFR Parts 122 and 125 (Subparts I, J, and N).

The NRC must investigate the impact of the Environmental Protection Agency (EPA) 316 (a) and 316 (b) and establish compliance milestones on applications from nuclear power plants.

Additionally, the traditional implications of the Pennsylvania Public Utility Commission (“Pa PUC”) policy and regulations relating to “withdraw and treatment” of water, i.e., referred to as "cost of water" under the Public Utility Code, Title 66, have to be factored in this application absent a PUC proceeding as well as Act 220 water usage guidelines.

Power generation, cooling and safety are inherently connected. There is no imaginary fence between generation and safety. And there should be no regulatory moat created by artificial safety definitions erected by nuclear regulators.

Neither DEP or NRC can bypass Act 220 of 2002 which “establishes the duty of any person to proceed diligently in complying with orders of the DEP.” (Section 3133)

Seasonal flow, Act 220, and the competing demands for limited water resources may make the amount of water available for power generation unreliable. Frequent power decreases and scrams show up as safety indicators and put stress on the nuclear generating stations. The NRC does not compile generation indicators, it analyzes safety indicators, like scrams and power reductions. The uprate clearly has the potential to create safety challenges by abruptly scrambling the plant or forcing power reductions to accommodate a water use budget.

V. The NRC Staff's Draft Safety Evaluation is Replete with Assumptions, Generalizations and Delayed Compliance Deadlines.

The Federal Register Notice ("FR" or "the Notice") is populated with general, unqualified and vague assumptions and statements posited as empirical data.

The plant's cooling towers are not "routinely used" (see "Aquatic Resource Impacts"); and, are not planned to be "routinely used" during and after implementation of the EPU. Therefore, consistent with the discussion in NUREG-1437, Supplement 10, Section 2.2.8.4, "Visual Aesthetics and Noise," there should not be any significant impacts from the EPU, such as icing, fogging, plume, or noise impacts from the operation of cooling towers."

Please define and quantify the terms "plume" and "routinely." (FR, p. 18075)

The Federal Register projected, "Once the EPU has been implemented, water consumption for plant cooling will not significantly change from pre-EPU operation." (FR, p. 18075)

Please define and quantify current and post water consumption levels and define the term "significantly."

"If the proposed EPU is approved and is implemented, PBAPS is predicted to have a slightly larger and hotter mixing zone than pre-uprate conditions during full flow and capacity." (FR, p. 18079)

Please define and quantify “slightly larger” and “hotter mixing zone.”

“The NRC staff anticipates that PBAPS will continue to operate post-EPU in full compliance with the requirements of the PADEP. The PADEP would evaluate PBAPS compliance with its individual wastewater facility permit. “(FR, p. 18079)

How does the NRC measure and verify “anticipation?”

“The potential impacts to aquatic resources from the proposed action could include impingement of aquatic life on barrier nets, trash racks, and traveling screens; entrainment of aquatic life through the cooling water intake structures and into the cooling water systems; and effects from the discharge of chemicals and heated water.” (FR, p. 18075)

The NRC staff concluded in NUREG–1437, Supplement 10, Section 4.1.3, “Impingement of Fish and Shellfish;” that, during the continued operation of PBAPS, the potential impacts caused by the impingement of fish and shellfish on the debris screens of the cooling water intake system would be small (i.e., not detectable or so minor that they will neither destabilize nor noticeably alter any important attribute of the resource) and that impingement losses would not be great enough to adversely affect Susquehanna River aquatic populations.”

The NRC staff also concluded in NUREG–1437, Supplement 10, Section 4.1.3, “that, in the early life stages in the cooling water system, the potential impacts of entrainment of fish and shellfish would be small, and that there are no demonstrated, significant effects to the aquatic environment related to entrainment.”

The NRC provided no empirical data to support environmental impact conclusions, and ignored the aggregate impact of three EPU's implemented since the initial license was granted.

The staff also failed to define and quantify “alter,” “so small, or “significant impact.”

Staff's conclusions relating to “Aquatic Resource Impacts” are based on ongoing studies and appears to co-mingled and mix assumes station conditions under the grandfathered NPDES permit:

However, this conclusion was made assuming station conditions under the previous NPDES permit... After the study is completed and based on the study results, Exelon will submit to PADEP an application to modify the NPDES permit. These modifications may include actions to manage the thermal discharge under EPU conditions. For any such future modifications, the PADEP must, in accordance with Section 316(a) of the Clean Water Act, ensure thermal effluent limitations assure the protection and propagation of a balanced indigenous community of shellfish, fish, and wildlife in and on Conowingo Pond.” (FR, 18706)

The conclusions stated under “Aquatic Resource Impacts” may not be consistent with EPA 316 (b), and are based on a dated NPDES permit, and the NRC is allowing delayed implementation of to Peach Bottom based on pending statutes. (FR, p. 18075).

Why are DEP and the NRC granting waivers based on outdated assumptions, data and studies to be concluded at a later date?

The NRC conclusions are also inconsistent with the historical facts on the ground as enumerated in the discussed under III. Peach Bottom's Environmental Impacts on the Susquehanna River Basin, pp. 6-10.

Regarding the potential impacts of thermal discharges, in NUREG-1437, Supplement 10, Section 4.1.4, "Heat Shock," the NRC staff concluded that the "impacts are small and that the heated water discharged to Conowingo Pond does not change the temperature enough to adversely impact balanced, indigenous populations of fish and wildlife." (FR, pp. 18075-10876).

What are the small impacts and why did the EPA, the NRC and the SRBC accept a generic rather than a site specific evaluation? Has the EPA, the NRC or SRBC anticipated or projected impacts after the "renewed license period..."? If the period is more than 15 years, please explain how this time period has been exempted by SRBC regulations.

Additionally, the NRC failed to explain how the intake structure is designed to reduce the impingement and entrapment of aquatic organisms, and how this design comports with 316 (b).

Moreover, the NRC has "generically" determined that the "effects from discharge of chlorine or other biocides, as well as accumulation of contaminants in sediments or biota, would be small for continued operations during a renewed license period at all plants as discussed in Section 4.5.1.1, "Surface Water Resources, Discharge of Biocides, Sanitary Wastes, and Minor Chemical Spills," of the "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," NUREG-1437, Volume 1, Revision 1, dated June 2013." (ADAMS Accession No. ML 13106A241). (FR, p. 18076)

What and where are the plan(s) to confirm and monitor what and how much “chemical effluents [are] discharged”? How are regulatory agencies going to monitor the changes or quantify or type of discharges?

The DEP and the NRC failed quantify site-specific aquatic challenges, and invasive species challenges based on the documented challenges that currently exist in the Susquehanna River.

The DEP confirmed that zebra mussel adults and juveniles have been found in Goodyear Lake, the first major impoundment on the Susquehanna River’s main stem below Canadarago Lake in New York. Zebra mussels are an invasive species posing a serious ecological and economic threat to the water resources and water users downstream in the river and Chesapeake Bay. On June 19, 2007, zebra mussels were discovered in Cowanesque Lake, Tioga County. This marks the first time zebra mussels have been discovered in the area.

“In 2002, the first report of zebra mussel populations in the Chesapeake Bay Watershed were reported from Eaton Reservoir in the headwaters of the Chenango River, a major tributary to the Susquehanna River in New York. A short time later, zebra mussels also were found in Canadarago Lake, a lake further east in the Susquehanna main stem headwaters. Now, through DEP’s Zebra Mussel Monitoring Network, reports were received that both zebra mussel adults and juveniles, called veligers, have made their way down to the Susquehanna main stem headwaters.”

(Pa DEP, *Update*, July 16, 2004)

Zebra mussels, like Asiatic clams, shad and other biological fouling, can invade the Peach Bottom Atomic Power Station from the Chesapeake Bay or Susquehanna River.

Zebra mussels have been discovered at the Susquehanna Steam Electric Station's fail-safe water supply in Cowanesque Lake and noted: "There is no evidence zebra mussels have been found in anywhere in the vicinity of the SSES..." But the NRC acknowledges the "SRBC requirement that the SSES compensate consumptive water use during river low-flow conditions by sharing the costs of the Cowanesque Lake Reservoir, which provides river flow augmentation source.

In recent years, Algae blooms recently "caused continuous clogging of multiple strainers of all pumps in TMI the intake structure; including: the two safety related DR pumps, all three safety related NR pumps, and all three non-safety related secondary river pumps." (NRC IR 05000289/2006004, p. 7.)

Neither DEP, NRC or SRBC addressed health, safety and structural challenges caused by micro fouling versus macro fouling, micro biologically influenced corrosion, algae blooms, biofilm's disease causing bacteria such as Legionella and listeria, the difficulty in eliminating established biofilms, oxidizing versus non- oxidizing biocides, chlorine versus bleach, alkaline versus non-alkaline environments, possible decomposition into carcinogens, and the eastward migration of Asiatic clams, zebra mussels and the anticipated arrival quagga mussels.

NRC staff noted the limitation of the inspection protocol and "requested that licensees establish a routine inspection and maintenance program to ensure that corrosion, erosion, protective coating failure, silting, and biofouling/tube plugging cannot degrade the performance of the safety-related systems supplied by service water. These issues relate to

the evaluation of safety-related heat exchangers using service water and whether they have the potential for fouling, thereby causing degradation in performance, and the mandate that there exist a permanent plant test and inspection program to accomplish and maintain this evaluation.”

“The regulations in 10 CFR 50.36, set forth NRC requirements related to the content of TSs. Pursuant to 10 CFR 50.36, TSs are required to include items in the following five specific categories: (1) safety limits, limiting safety system settings, and limiting control settings; (2) limiting conditions for operation (LCOs); (3) surveillance requirements (SRs); (4) design features; and (5) administrative controls. **The regulation does not specify the particular requirements to be included in a plant's TSs.** (NRC, “Peach Bottom Atomic Power Station, Unit 2 & 3, Issuance of Amendment Re: Revise Normal Heat Sink Operability Requirement”, Tag Nos. M9805 & M98906, June 5, 2014).

The NRC identified the need for biological and thermal studies. When are the biological and thermal studies going to be completed? Why would the DEP the NRC approve an uprate prior to the completion of the studies? Why is NPDES compliance being delayed until after the uprate is implemented?

VI: Miscellaneous:

The census data - which is 4.5 years old - fails to factor household incomes as it relates to proximate buying power, the Consumer Price Index, commuter times and property taxes. The census data completely ignores fishing and hunting seasons, migrant worker populations and special population including the Amish, Old Order Mennonites and recreational visitors in southern Lancaster and York Counties.

It appears the NRC completely bypassed by the York County Planning Commission. The Commission considers all social, economic, historical, and environmental aspects of projects impact the region.

The U.S. Fish and Wildlife Service has many interests in the relicensing of Conowingo, Muddy Run and Peach Bottom, including the “general health of living resources in the pond and in Conowingo’s tail waters; impacts of Conowingo hydropower generation schedule on downstream resources, anadromous fish restoration and safe upstream and downstream passage of fish (especially diadromous species including eels); and the impact of water development projects on aquatic resources (e.g., egg and larvae impingement at water intakes, stream side development, endangered species issues).” (“Conowingo Pond Management Plan,” *Publication No. 242*, p. 76, June 2006.)

Did the U.S. Fish and Wildlife Service review Exelon's proposed Extended Power Uprate?

The draft SER also assumes the States of Delaware and Maryland do not exist.

There was no discussion of significant historic assets within 50 miles of Peach Bottom including but not limited to: Camp David, the Eisenhower Farm, the First American Capital in York, Gettysburg National Park, Harley-Davidson, Hershey Chocolate, the Pennsylvania Historical and Museum Commission sites and Underground Railroads sites.

No physical changes for radioactive waste disposal were noted which is a strange omission since the NRC approved Peach Bottom as the storage site for Limerick's low-level radioactive waste. Exelon applied to amend Peach Bottom's license in early 2010 to accept low level radioactive waste from Limerick. Exelon can keep the Limerick waste at Peach Bottom for as long as it wants according to NRC spokesman Neil Sheehan sated. "As time goes on, however, the plant may face capacity issues and will need to look for disposal options." (*York Daily Record*, June 1, 2011)

Peach Bottom hosts almost 2,000 tons high level radioactive waste in spent fuel pools and dry casks. The EPU will increase the volume and activity of radioactive solid waste by approximately 14%.

In March 2012, the NRC ordered Peach Bottom Unit 3 to install instrumentation to monitor conditions inside the spent fuel pools also ordered plants owners to develop mitigation strategies to provide assurance of adequate cooling of reactor cores and spent fuel pools when permanent electrical supplies are unavailable for indefinite periods.

VII. Finding of No Significant Impact.

On page 18073, the Summary - which is actually conclusion:

The U.S. Nuclear Regulatory Commission (NRC) is considering issuance of amendments to Renewed Facility Operating License Nos. DPR-44 and DPR-56, issued to Exelon Generation Company, LLC (Exelon, the licensee), for operation of the Peach Bottom Atomic Power Station (PBAPS), Units 2 and 3, located in York and Lancaster Counties, Pennsylvania. The proposed amendments would authorize an increase in the maximum reactor power level from 3514 megawatts thermal (MWt) to 3951 MWt. The NRC staff is issuing a final Environmental Assessment (EA) and final Finding of No Significant Impact (FONSI) associated with the proposed license amendments.

Later on page 18082, the NRC restates its summary in the Findings of No Significant Impact.

The NRC is proposing to amend Renewed Facility Operating License Nos. DPR-44 and DPR-56 for PBAPS, Units 2 and 3. The proposed amendments would authorize an increase in the maximum reactor power level from 3514 MWt to 3951 MWt. The NRC has determined not to prepare an Environmental Impact Statement for the proposed action. The proposed action will not have a significant effect on the quality of the human environment because, amending the licenses with the higher maximum reactor power level, will not result in any significant radiological or non- radiological impacts. Accordingly, the NRC has determined that a Finding of No Significant Impact (FONSI) is appropriate. The NRC's Environmental Assessment (EA), included in Section II above, is incorporated by reference into this finding.

The publication was dated March 31, 2014. Six weeks later, the Peach Bottom nuclear plant was placed on the NRC's priority list of 10 nuclear plants in the Central and Eastern United States that have to do

more detailed risk evaluation from an earthquake. Peach Bottom was chosen for an expedited evaluation based on updated information about the possibility of localized earthquakes. If ground movement from the an earthquake based on the new information exceeds what was used when the plant was designed, Peach Bottom will have to conduct a detailed analysis to determine any changes in accident risk from a quake by December, 2014. Exelon will have to complete an “expedited approach” review to evaluate and reinforce key core cooling equipment to make sure the plant could safely shutdown if a quake hit at the level now considered possible.

Paradoxically, a sliding scale of standards was applied to on June 3, 2014, relating to the relicensing of the Muddy Run is also owned and operated by Exelon. The 800 MWt hydroelectric station is located on the eastern shore of the Conowingo Pond on the Susquehanna River in Lancaster County. The project has operated since 1966.

The Department of Environmental Protection announced that it has issued a water quality (“WQ”) certification for the continued operation and maintenance of Exelon’s Muddy Run hydroelectric project in Martic and Drumore Townships in southern Lancaster County.

Pennsylvania WQ certification is required for relicensing by the Federal Energy Regulatory Commission for projects like the Muddy Run Project under the Federal Power Act. WQ certifications are authorized under the Federal Clean Water Act, the Pennsylvania Dam Safety and Encroachments Act and the Pennsylvania Clean Streams Law.

The hydro plant that is owned by Exelon and produces 22.4% of the electricity of its nuclear sibling agreed to make substantial commitments to mitigating the aquatic resource impacts of the project. While DEP and the NRC gave Exelon a free pass on the EPU at Peach Bottom, the same company acknowledged that in order for the Muddy Run project to continue operation and to minimize the effects of the facility on aquatic resources, Exelon had to agree to:

- Provide \$500,000 per year for 16 years for agricultural pasture and barnyard best management practices to address sediment introduction and other habitat improvement projects, such as stream improvement projects, riparian buffers and small dam removal in Lancaster and York counties.
- Provide a version of Exelon's computer model for evaluating river flows on the Lower Susquehanna River to the Susquehanna River Basin Commission.
- Provide \$8 million over 16 years by Exelon to the Lancaster and York County conservation districts.

In contrast, the NRC is entertaining a request by Exelon's to postpone flood reevaluation for peach Bottom 2 & 3 - due on March 12, 2014 - **until March 12, 2015**. Exelon discussed the milestones for completion of the flooding hazard reevaluation as follows in a letter to the NRC on March 12, 2104.

- a) Complete recalibration of the watershed model by the end of May 2014.
- b) Complete development of the scenarios for the Probable Maximum Flood at PBAPS, Units 2 and 3, by the end of July 2014.

c) Complete the calculations of flood levels and associated effects based on Appendix H to NUREG/CR-7046, "Design-Basis Flood Estimation for Site Characterization at Nuclear Power Plants in the United States of America," by the end of December 2014.

d) Start internal Exelon review of the PBAPS flooding hazard reevaluation in mid-January 2015.

e) Submit PBAPS flooding hazard reevaluation to the NRC by March 12, 2015.

(NRC, Richard B. Ennis, Senior Project Manager Plant Licensing Branch 1-2 Division of Operating Reactor Licensing Office of Nuclear Reactor Regulation, May 21, 2014)

VIII. Conclusions:

Power generation, cooling and safety are inherently connected. There is no fence between generation and safety. And there should be no regulatory moat created by artificial safety definitions erected by nuclear generators. The lack of regulatory coordination establishes a deleterious precedent, and constitutes *de facto* approval of grandfathered and outdated regulations.

Even more baffling are the regulatory moats that federal and state agencies erect to protect rigid and exclusive zones of interest. This type of laissez-faire regulatory behavior gives rise to undesired corporate behaviors such as “grandfathering” and “back fits,” deterioration of monitoring equipment, time delays causing avoidable leaks, and waivers for monitoring wells.”

Populations long the Susquehanna River are potentially impacted by contaminated water, liquid-release exposure pathways, irrigated crops and external exposure during recreational activities.

The Final Safety Evaluation analysis must factor the entire Peach Bottom Region which includes Delaware, Maryland and Pennsylvania and the Chesapeake Bay - largest estuary in North America.

The NRC staff must also review dated and delayed submissions, reconcile “grandfathered” regulations and clarify general and vague assumptions.

The proposed Extended Power Uproot License Amendment for the Peach Bottom Atomic Power Station Units 2 & 3 should be held in abeyance until all the open and unresolved environmental, health and safety issues identified in this Testimony have been addressed and closed out.

Respectfully Submitted,

Eric Epstein, Chairman
Three Mile Island Alert, Inc.
4100 Hillsdale Road
Harrisburg, PA 17112
(717)-541-1101

Service list:

Environmental Protection Agency
Exelon Generation
Pennsylvania Department of Environmental Protection
Pennsylvania Fish and Boat Commission
Pennsylvania Historical and Museum Commission
Pennsylvania Public Utility Commission
Susquehanna River Basin Commission
U.S. Army Corps of Engineers
U.S. Fish and Wildlife Service
U.S. Nuclear Regulatory Commission

Dated: June 10, 2014