



**Idaho  
National  
Engineering  
Laboratory**

*Managed  
by the U.S.  
Department  
of Energy*



*Work performed under  
DOE Contract  
No. DE-AC07-76ID01570*

EGG-NTA-7390  
April 1987

**INFORMAL REPORT**

CONFORMANCE TO GENERIC LETTER 83-28, ITEM 2.2.1--  
EQUIPMENT CLASSIFICATION FOR ALL OTHER SAFETY-  
RELATED COMPONENTS: H. B. ROBINSON-2

Alan C. Udy

Prepared for the  
U.S. NUCLEAR REGULATORY COMMISSION

B706080148 B70417  
PDR ADOCK 05000261  
P PDR

#### DISCLAIMER

This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights. References herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

TECHNICAL EVALUATION REPORT

CONFORMANCE TO GENERIC LETTER 83-28, ITEM 2.2.1--  
EQUIPMENT CLASSIFICATION FOR ALL OTHER SAFETY-RELATED COMPONENTS:  
H. B. ROBINSON-2

Docket No. 50-261

Alan C. Udy

Published April 1987

Idaho National Engineering Laboratory  
EG&G Idaho, Inc.  
Idaho Falls, Idaho 83415

Prepared for the  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555  
Under DOE Contract No. DE-AC07-76ID01570  
FIN No. D6001

ABSTRACT

This EG&G Idaho, Inc., report provides a review of the submittal from the H. B. Robinson Steam Electric Plant, Unit No. 2, regarding conformance to Generic Letter 83-28, Item 2.2.1.

Docket No. 50-261

TAC No. 53710

## FOREWORD

This report is supplied as part of the program for evaluating licensee/applicant conformance to Generic Letter 83-28, "Required Actions Based on Generic Implications of Salem ATWS Events." This work is being conducted for the U.S. Nuclear Regulatory Commission, Office of Nuclear Reactor Regulation, Division of PWR Licensing-A, by EG&G Idaho, Inc., NRR and I&E Support Branch

The U.S. Nuclear Regulatory Commission funded this work under the authorization B&R No. 20-19-10-11-3, FIN No. D6001.

Docket No. 50-261

TAC No. 53710

# CONTENTS

ABSTRACT .....	ii
FOREWORD .....	iii
1. INTRODUCTION .....	1
2. REVIEW CONTENT AND FORMAT .....	2
3. ITEM 2.2.1 - PROGRAM .....	3
3.1 Guideline .....	3
3.2 Evaluation .....	3
3.3 Conclusion .....	3
4. ITEM 2.2.1.1 - IDENTIFICATION CRITERIA .....	4
4.1 Guideline .....	4
4.2 Evaluation .....	4
4.3 Conclusion .....	4
5. ITEM 2.2.1.2 - INFORMATION HANDLING SYSTEM .....	5
5.1 Guideline .....	5
5.2 Evaluation .....	5
5.3 Conclusion .....	5
6. ITEM 2.2.1.3 - USE OF EQUIPMENT CLASSIFICATION LISTING .....	6
6.1 Guideline .....	6
6.2 Evaluation .....	6
6.3 Conclusion .....	6
7. ITEM 2.2.1.4 - MANAGEMENT CONTROLS .....	7
7.1 Guideline .....	7
7.2 Evaluation .....	7
7.3 Conclusion .....	7
8. ITEM 2.2.1.5 - DESIGN VERIFICATION AND PROCUREMENT .....	8
8.1 Guideline .....	8
8.2 Evaluation .....	8
8.3 Conclusion .....	8
9. ITEM 2.2.1.6 - "IMPORTANT TO SAFETY" COMPONENTS .....	9
9.1 Guideline .....	9
10. CONCLUSION .....	10
11. REFERENCES .....	11

EQUIPMENT CLASSIFICATION FOR ALL OTHER SAFETY-RELATED COMPONENTS:

H. B. ROBINSON-2

1. INTRODUCTION

On February 25, 1983, both of the scram circuit breakers at Unit 1 of the Salem Nuclear Power Plant failed to open upon an automatic reactor trip signal from the reactor protection system. This incident was terminated manually by the operator about 30 seconds after the initiation of the automatic trip signal. The failure of the circuit breakers was determined to be related to the sticking of the undervoltage trip attachment. Prior to this incident, on February 22, 1983, at Unit 1 of the Salem Nuclear Power Plant, an automatic trip signal was generated based on steam generator low-low level during plant startup. In this case, the reactor was tripped manually by the operator almost coincidentally with the automatic trip.

Following these incidents, on February 28, 1983, the NRC Executive Director for Operations (EDO), directed the NRC staff to investigate and report on the generic implications of these occurrences at Unit 1 of the Salem Nuclear Power Plant. The results of the staff's inquiry into the generic implications of the Salem unit incidents are reported in NUREG-1000, "Generic Implications of the ATWS Events at the Salem Nuclear Power Plant." As a result of this investigation, the Commission (NRC) requested (by Generic Letter 83-28 dated July 8, 1983<sup>1</sup>) all licensees of operating reactors, applicants for an operating license, and holders of construction permits to respond to the generic issues raised by the analyses of these two ATWS events.

This report is an evaluation of the response submitted by the Carolina Power and Light Company, the licensee for Unit No. 2 of the H. B. Robinson Steam Electric Plant, for Item 2.2.1 of Generic Letter 83-28. The document reviewed as a part of this evaluation is listed in the references at the end of this report.

## 2. REVIEW CONTENT AND FORMAT

Item 2.2.1 of Generic Letter 83-28 requests the licensee or applicant to submit, for the staff review, a description of their programs for safety-related equipment classification including supporting information, in considerable detail, as indicated in the guideline section for each sub-item within this report.

As previously indicated, each of the six sub-items of Item 2.2.1 is evaluated in a separate section in which the guideline is presented; an evaluation of the licensee's/applicant's response is made; and conclusions about the programs of the licensee or applicant for safety-related equipment classification are drawn.

### 3. ITEM 2.2.1 - PROGRAM

#### 3.1 Guideline

Licensees and applicants should confirm that an equipment classification program exists which provides assurance that all safety-related components are designated as safety-related on all plant documents, drawings and procedures and in the information handling system that is used in accomplishing safety-related activities, such as work orders for repair, maintenance and surveillance testing and orders for replacement parts. Licensee and applicant responses which address the features of this program are evaluated in the remainder of this report.

#### 3.2 Evaluation

The licensee for Unit No. 2 of the H. B. Robinson Steam Electric Plant responded to these requirements with a submittal dated November 7, 1983.<sup>2</sup> This submittal includes information that describes their existing safety-related equipment classification program. In the review of the licensee's response to this item, it was assumed that the information and documentation supporting this program is available for audit upon request. We have reviewed this information and note the following general concerns.

The licensee states that they are using the Q-list as the information handling system referred to. The licensee has confirmed that the Q-list is consulted to identify all safety-related components, activities and procedures prior to work being done on safety-related systems.

#### 3.3 Conclusion

We have reviewed the licensee's information and, in general, find that the licensee's response is adequate.

#### 4. ITEM 2.2.1.1 - IDENTIFICATION CRITERIA

##### 4.1 Guideline

The applicant or licensee should confirm that their program used for equipment classification includes criteria used for identifying components as safety-related.

##### 4.2 Evaluation

The licensee's response identified and provided the criteria for determining what plant items are safety-related. The licensee states that Q-list items are those structures, systems and components that are primarily designed to prevent or mitigate the consequences of postulated accidents that could cause undue risk to the health and safety of the public. The definition is further refined by eight qualifying statements. The complete criteria are incorporated into the Plant Operating Manual (POM) Q-List Procedure.

##### 4.3 Conclusion

We find that the criteria used in the identification of safety-related components meet the requirements of Item 2.2.1.1 and are acceptable.

## 5. ITEM 2.2.1.2 - INFORMATION HANDLING SYSTEM

### 5.1 Guideline

The licensee or applicant should confirm that the program for equipment classification includes an information handling system that is used to identify safety-related components. The response should confirm that this information handling system includes a list of safety-related equipment and that procedures exist which govern its development and validation.

### 5.2 Evaluation

The licensee's submittal identifies the Q-list as the information handling system that identifies safety-related components. The licensee states that the Plant Operating Manual (POM) defines the development, validation and control of the Q-list and states that Plant Engineering is responsible for determining the systems and components that are to be included on the Q-list. The POM also guides in the changes to and in the addition of new equipment to the Q-list. These procedures are described.

### 5.3 Conclusion

We find that the information contained in the licensee's submittals is sufficient for us to conclude that the licensee's information handling system for equipment classification meets the guideline requirements. Therefore, the information provided by the licensee for this item is acceptable.

## 6. ITEM 2.2.1.3 - USE OF EQUIPMENT CLASSIFICATION LISTING

### 6.1 Guideline

The licensee's or applicant's description should confirm that their program for equipment classification includes criteria and procedures which govern how station personnel use the equipment classification information handling system to determine that an activity is safety-related and what procedures for maintenance, surveillance, parts replacement and other activities defined in the introduction to 10 CFR 50, Appendix B, apply to safety-related components.

### 6.2 Evaluation

The licensee states all maintenance, surveillance and procurement activities use the Q-list to determine when the activity is safety-related. Reviews and approvals of forms required to perform these tasks refer to the Q-list for equipment classification as part of the review process. Thus, the Q-list is consulted before any maintenance, testing, design changes, engineering support, setpoint changes or special tests or studies are initiated.

### 6.3 Conclusion

We find that the licensee's description of plant administrative controls and procedures meets the requirements of this item and is, therefore, acceptable.

## 7. ITEM 2.2.1.4 - MANAGEMENT CONTROLS

### 7.1 Guideline

The applicant or licensee should confirm that the management controls used to verify that the procedures for preparation, validation and routine utilization of the information handling system have been followed.

### 7.2 Evaluation

The licensee states that the controls described in response to Section 2.2.1.2 (i.e., the Plant Operating Manual) assure the proper additions and changes to the Q-list. Quality assurance surveillance and audits are used to verify the routine utilization of the Q-list.

### 7.3 Conclusion

We find that the management controls used by the licensee assure that the information handling system is maintained, is current and is used as intended. Therefore, the licensee's response for this item is acceptable.

## 8. ITEM 2.2.1.5 - DESIGN VERIFICATION AND PROCUREMENT

### 8.1 Guideline

The applicant's or licensee's submittal should document that past usage demonstrates that appropriate design verification and qualification testing is specified for the procurement of safety-related components and parts. The specifications should include qualification testing for expected safety service conditions and provide support for the applicant's/licensee's receipt of testing documentation to support the limits of life recommended by the supplier. If such documentation is not available, confirmation that the present program meets these requirements should be provided.

### 8.2 Evaluation

The licensee's submittal states that specifications for safety-related components include qualification testing and analysis for environmental conditions. The Q-list is used to identify a part as safety-related. Procurement procedures insure that the procurement specifications for safety-related parts and components include the expected service conditions, design verification, qualification testing and documentation that supports this information. Additionally, the licensee has a program for approval of suppliers of safety-related components and parts.

### 8.3 Conclusions

The licensee's response for this item is considered to be complete. The information provided addresses the concerns of this item and is acceptable.

9. ITEM 2.2.1.6 - "IMPORTANT TO SAFETY" COMPONENTS

9.1 Guideline

Generic Letter 83-28 states that the licensee's equipment classification program should include (in addition to the safety-related components) a broader class of components designated as "Important to Safety." However, since the generic letter does not require the licensee to furnish this information as part of their response, review of this item will not be performed.

## 10. CONCLUSION

Based on our review of the licensee's response to the specific requirements of Item 2.2.1, we find that the information provided by the licensee to resolve the concerns of Items 2.2.1.1, 2.2.1.2, 2.2.1.3, 2.2.1.4 and 2.2.1.5 meet the requirements of Generic Letter 83-28 and is acceptable. Item 2.2.1.6 was not reviewed as noted in Section 9.1.

## 11. REFERENCES

1. NRC letter, D. G. Eisenhut to all Licensees of Operating Reactors, Applicants for Operating License, and Holders of Construction Permits, "Required Actions Based on Generic Implications of Salem ATWS Events (Generic Letter 83-28)," July 8, 1983.
2. Carolina Power and Light Company letter, A. B. Cutter to D. G. Eisenhut, NRC, "Generic Implications of Salem ATWS Events," November 7, 1983, Serial: LAP-83-517.

<p>NRC FORM 335 (2-84) NRCM 1102, 3201, 3202</p> <p style="text-align: center;"><b>BIBLIOGRAPHIC DATA SHEET</b></p> <p>SEE INSTRUCTIONS ON THE REVERSE</p>	<p style="text-align: center;">U.S. NUCLEAR REGULATORY COMMISSION</p> <p>1. REPORT NUMBER (Assigned by TIDC, add Vol. No., if any)</p> <p style="text-align: center;">EGG-NTA-7390</p>								
<p>2. TITLE AND SUBTITLE</p> <p>CONFORMANCE TO GENERIC LETTER 83-28, ITEM 2.2.1-- EQUIPMENT CLASSIFICATION FOR ALL OTHER SAFETY-RELATED COMPONENTS: H. B. ROBINSON-2</p>	<p>3. LEAVE BLANK</p>								
<p>5. AUTHOR(S)</p> <p>Alan C. Udy</p>	<p>4. DATE REPORT COMPLETED</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">MONTH</td> <td style="text-align: center;">YEAR</td> </tr> <tr> <td style="text-align: center;">April</td> <td style="text-align: center;">1987</td> </tr> </table> <p>6. DATE REPORT ISSUED</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">MONTH</td> <td style="text-align: center;">YEAR</td> </tr> <tr> <td style="text-align: center;">April</td> <td style="text-align: center;">1987</td> </tr> </table>	MONTH	YEAR	April	1987	MONTH	YEAR	April	1987
MONTH	YEAR								
April	1987								
MONTH	YEAR								
April	1987								
<p>7. PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)</p> <p>EG&amp;G Idaho, Inc. P. O. Box 1625 Idaho Falls, ID 83415</p>	<p>8. PROJECT/TASK/WORK UNIT NUMBER</p> <p>9. FIN OR GRANT NUMBER</p> <p style="text-align: center;">D6001</p>								
<p>10. SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)</p> <p>Division of PWR Licensing - A Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, DC 20555</p>	<p>11a. TYPE OF REPORT</p> <p>b. PERIOD COVERED (Inclusive dates)</p>								
<p>12 SUPPLEMENTARY NOTES</p>									
<p>13. ABSTRACT (200 words or less)</p> <p style="text-align: center;">This EG&amp;G Idaho, Inc., report provides a review of the submittals from the Carolina Power and Light Company regarding conformance to Generic Letter 83-28, Item 2.2.1 for H. B. Robinson-2.</p>									
<p>14 DOCUMENT ANALYSIS • KEYWORDS/DESCRIPTORS</p> <p>b. IDENTIFIERS/OPEN-ENDED TERMS</p>	<p>15 AVAILABILITY STATEMENT</p> <p style="text-align: center;">Unlimited Distribution</p> <p>16 SECURITY CLASSIFICATION</p> <p style="text-align: center;">(This page) Unclassified (This report) Unclassified</p> <p>17. NUMBER OF PAGES</p> <p>18. PRICE</p>								