

Letter to N. C. Moseley from Carolina Power and Light Company dated May 27, 1975.

DISTRIBUTION:

50-261

H. D. Thornburg, IE

IE:HQS (4)

Office of Standards Development

Central Files

Division of Reactor Licensing (4)

PDR

Local PDR

NSIC

TIC

STATE

Ao
(4)



Carolina Power & Light Company

H. B. ROBINSON STEAM ELECTRIC PLANT
Post Office Box 790
Hartsville, South Carolina

May 27, 1975

Robinson File No. 2-0-1-s-1

Mr. Norman C. Moseley, Director
Directorate of Regulatory Operations
U. S. Nuclear Regulatory Commission
Region II, Suite 818
40 Peachtree Street, N.W.
Atlanta, Georgia 30303

Mr. Donald Knuth, Director
Directorate of Regulatory Operations
U. S. Nuclear Regulatory Commission
Washington, D. C. 20545

Dear Sirs:

In accordance with Section 6.6.2 of the Technical Specifications, the following Abnormal Occurrence is reported:

On 0930, May 27, 1975, with the reactor at 33% power and increasing following a maintenance outage, a reactor coolant system sample indicated 16 ppm oxygen. This constitutes a violation of Technical Specification 1.6.1 which limits RCS oxygen to 0.1 ppm above 250°F. Immediate corrective action was taken to reduce the oxygen concentration, and, by 1115, the reactor coolant system oxygen concentration had been reduced to within specifications.

This incident constitutes an Abnormal Occurrence as defined in Technical Specification 1.8.b and was reported by telephone to Mr. Marvin Sincule of CP&L, Atlanta, on May 27, 1975.

Yours very truly,

J. B. McGirt, Manager
H. B. Robinson SEQ Plant

W:ala