

A002

REGULATORY INFORMATION DISTRIBUTION SYSTEM

DOCKET NBR: 050-261 H.B. Robinson 2  
RECIPIENT: O'Reilly, J.P.  
ORIGINATOR: Banks, H.R.  
COMPANY NAME: Carolina Pwr & Light  
SUBJECT:

DOC DATE: 781023  
ACCESSION NBR: 7810310143  
COPIES RECEIVED:  
LTR 1 ENCL 1  
SIZE: 1+2

LER#78-023/03L-0 on 780922: while proceeding from Hot to Cold Shutdown the concentration of boric acid storage tank B was 22796 ppm, due to insufficient sampling during batching, & tank A level was low as a result of borating the RCS.

DISTRIBUTION CODE: A002  
DISTRIBUTION TITLE:  
INCIDENT REPORTS

NOTARIZED

NAME	ENCL?
BR CHIEF	W/4 ENCL
<u>REG FILE</u>	W/ENCL
NRC PDR	W/ENCL
I & E	W/2 ENCL
MIPC	W/3 ENCL
I & C SYSTEMS BR	W/ENCL
NOVAK/CHECK	W/ENCL
EEB	W/ENCL
AD FOR ENG	W/ENCL
PLANT SYSTEMS BR	W/ENCL
HANAUER	W/ENCL
AD FOR PLANT SYSTEMS	W/ENCL
AD FOR SYS & PROJ	W/ENCL
REACTOR SAFETY BR	W/ENCL
ENGINEERING BR	W/ENCL
KREGER/J. COLLINS	W/ENCL
POWER SYS BR	W/ENCL
K SEYFRIT/IE	W/ENCL
LPDR	W/ENCL
NSIC	W/ENCL
ACRS	W/16 ENCL

FOR ACTION

ORB#1 BC  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

TOTAL NUMBER OF COPIES REQUIRED:  
LTR 42  
ENCL 42

NOTES:

NOV 1 1978



Carolina Power & Light Company

October 23, 1978

FILE: NG-3516 (R)

SERIAL: GD-78-2819

Mr. James P. O'Reilly, Director  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

REGULATORY DOCKET FILE COPY

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET 50-261  
LICENSE NO. DPR-23  
LICENSEE EVENT REPORT 78-23

Dear Mr. O'Reilly:

In accordance with Section 6.9.2.b of the Technical Specifications for the H. B. Robinson Steam Electric Plant, Unit 2, the attached Licensee Event Report is submitted. This report fulfills the requirement for a written report within thirty (30) days of a reportable occurrence and is in accordance with the format set forth in NUREG-0161, July, 1977.

Yours very truly,

H. R. Banks  
Manager  
Nuclear Generation

DCS:jpw\*

Attachment

cc: Messrs. R. A. Hartfield  
J. G. Davis

781031.0143

A002  
S/11