



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

CAROLINA POWER AND LIGHT COMPANY

DOCKET NO. 50-261

H. B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 37
License No. DPR-23

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Carolina Power and Light Company (the licensee) dated October 4, 1977, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

7906040130

ATTACHMENT TO LICENSE AMENDMENT NO. 37

FACILITY OPERATING LICENSE NO. DPR-23

DOCKET NO. 50-261

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the area of change.

Remove

6.3-1

Insert

6.3-1

ATTACHMENT TO LICENSE AMENDMENT NO. 37

FACILITY OPERATING LICENSE NO. DPR-23

DOCKET NO. 50-261

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the area of change.

Remove

6.3-1

Insert

6.3-1

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of facility Operating License No. DPR-23 is hereby amended to read as follows:

"3.B Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 37, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications."

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



A. Schwencer, Chief
Operating Reactors Branch
Division of Operating Reactors

Attachment:
Changes to the Technical
Specifications

Date of Issuance: April 30, 1979

6.3

FACILITY STAFF QUALIFICATIONS

6.3.1 Each member of the facility staff shall meet or exceed ANSI N19.1-1971 with regard to the minimum qualifications for comparable positions

6.3.2 The Environmental and Radiation Control Supervisor shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975. The Guide says that he shall have a bachelor's degree or equivalent in a science or engineering subject. Equivalent in this case is defined as follows:

- (a) 4 years of formal schooling in science or engineering,
- (b) 4 years of applied radiation protection experience at a nuclear facility,
- (c) 4 years of operational or technical experience/training in nuclear power, or
- (d) Any combination of the above totaling 4 years.

This requirement is in addition to the requirement for five years of professional experience in applied radiation protection.