



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

CAROLINA POWER AND LIGHT COMPANY

DOCKET NO. 50-261

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 56
License No. DPR-23

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Carolina Power and Light Company (the licensee) dated May 5, 1981, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8105260 263

P


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-23 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 56, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Yarga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 14, 1981

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 56 TO FACILITY OPERATING LICENSE NO. DPR-23

DOCKET NO. 50-261

Revise Appendix A as follows:

Remove Pages

3.1-16

3.1-19a

4.1-10

Insert Pages

3.1-16

3.1-19a

4.1-10

3.1.5 Leakage

- 3.1.5.1 If the primary system leakage exceeds 1 gpm and the source of leakage is not identified within 12 hours, the reactor shall be placed in the hot shutdown condition utilizing normal operating procedures. If the source of leakage exceeds 1 gpm and is not identified within 24 hours, the reactor shall be placed in the cold shutdown condition utilizing normal operating procedures.
- 3.1.5.2 If the sources of leakage have been identified and it is evaluated that continued operation is safe, operation of the reactor with a total leakage rate not exceeding 10 gpm shall be permitted. If leakage exceeds 10 gpm, the reactor shall be placed in the hot shutdown condition within 12 hours utilizing normal operating procedures. If the leakage exceeds 10 gpm for 24 hours, the reactor shall be placed in the cold shutdown condition utilizing normal operating procedures.
- 3.1.5.3 If the leakage is determined to be primary to secondary steam generator leakage in excess of 0.35 gpm in any steam generator, or in excess of 1 gpm total for all three steam generators, the reactor shall be shutdown and the plant placed in the cold shutdown condition utilizing normal procedures within 30 hours after detection.
- 3.1.5.4 a. During reactor operation and hot shutdown conditions, all pressure isolation valves listed in Table 3.1-1 shall be functional as a pressure isolation device, except as specified in 3.1.5.4.b. Valve leakage shall not exceed the amounts indicated.
- b. In the event that integrity of any pressure isolation valve specified in Table 3.1-1 cannot be demonstrated, reactor operation may continue, provided that at least two valves in each high pressure line having a non-functional valve are in, and remain in, the mode corresponding to the isolated condition. (Manual valves shall be locked in the closed position; motor operated valves shall be placed in the closed position and power supplies deenergized).
- c. If Specifications 3.1.5.4a or b cannot be met, an orderly shutdown shall be initiated and the reactor shall be in hot shutdown within 6 hours and in the cold shutdown condition within the following 30 hours.

TABLE 3.1-1

PRIMARY COOLANT SYSTEM PRESSURE ISOLATION VALVES

<u>System</u>	<u>Valve No.</u>	Maximum (a) <u>Allowable Leakage</u>
Low-Pressure Safety Injection/Residual Heat Removal		≤ 5.0 GPM for each (b) valve
Loop 1, cold leg	875A 876A	
Loop 2, cold leg	875B 876B	
Loop 3, cold leg	875C 876C	
High-Pressure Injection		
Loop 2, hot leg	874B	
Loop 3, hot leg	874A	

- (a)
1. Leakage rates less than or equal to 1.0 gpm are considered acceptable.
 2. Leakage rates greater than 1.0 gpm but less than or equal to 5.0 gpm are considered acceptable if the latest measured rate has not exceeded the rate determined by the previous test by an amount that reduces the margin between measured leakage rate and the maximum permissible rate of 5.0 gpm by 50% or greater.
 3. Leakage rates greater than 1.0 gpm but less than or equal to 5.0 gpm are considered unacceptable if the latest measured rate exceeded the rate determined by the previous test by an amount that reduces the margin between measured leakage rate and the maximum permissible rate of 5.0 gpm by 50% or greater.
 4. Leakage rates greater than 5.0 gpm are considered unacceptable.
- (b) More than one valve may be tested in parallel. The combined leakage shall not exceed 5.0 gpm. Redundant valves in each line shall not be tested in series.

TABLE 4.1-3 (Continued)

	<u>Check</u>	<u>Frequency</u>	<u>Maximum Time Between Tests</u>
13. Turbine Inspection	Visual, Magnaflex and Die Penetrant	Every five years	6 years
14. Fans and Associated Charcoal and Absolute Filters for Control Room and Residual Heat Removal Compartments (HVE-19, HVE-5a and 5b respectively)	Fans functioning, Laboratory tests on charcoal must show $\geq 99\%$ iodine removal. In-place test must show $> 99\%$ removal of polydispersed DOP particles by the HEPA filters and Freon by the charcoal filters.	Once per operating cycle	NA
15. Isolation Seal Water System	Functioning	Each refueling shutdown	NA
16. Overpressure Protection System	Functioning	Each refueling shutdown	NA
17. Primary Coolant System check valves	Functioning	1. Periodic leakage testing on each ^(c) valve listed in Table 3.1-1 shall be accomplished prior to entering reactor operation condition (1) after every time the plant is placed in the cold shutdown condition for refueling, (2) after each time the plant is placed in a cold shutdown condition for 72 hours if testing has not been accomplished in the <u>pre-</u> ceding 9 months, (3) after maintenance, repair or replacement work is performed.	(a) (b)

(a) To satisfy ALARA requirements, leakage may be measured indirectly (as from the performance of pressure indicators) if accomplished in accordance with approved procedures and supported by computations showing that the method is capable of demonstrating valve compliance with the leakage criteria.

(b) Minimum test differential pressure shall not be less than 150 psid.

(c) More than one valve may be tested in parallel. The combined leakage shall not exceed 5.0 gpm. Redundant valves in each line shall not be tested in series.