

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-261CAROLINA POWER AND LIGHT COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 71 to Facility Operating License No. DPR-23 issued to Carolina Power and Light Company (the licensee), which revised Technical Specifications for operation of the H. B. Robinson Steam Electric Plant, Unit No. 2, (the facility) located in Darlington County, South Carolina. The amendment is effective as of the date of issuance.

The amendment authorizes Cycle 9 operation at a reduced power level; revises the Appendix A Technical Specifications to: (a) incorporate changes resulting from the Cycle 9 reload core analysis, including administrative changes, and (b) incorporates changes to include specific surveillance of the emergency core cooling system motor operated valves; and revises the Operating License Condition 3.I.a, b, c & d to include a steam generator inspection and steam generator tube leakage criterion.

The applications for amendment comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since this amendment does not involve a significant hazards consideration.


- 2 -

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the applications for amendment dated April 30, 1981, April 30, 1982, and July 13, 1982 (as supplemented April 20, 1982 and June 24, 1982), (2) Amendment No. 71 to License No. DPR-23, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. and at the Hartsville Memorial Library, Home and Fifth Avenues, Hartsville, South Carolina 29550. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 23rd of July 1982.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing