

September 20, 1989

Docket No. 50-261

MEMORANDUM FOR: Elinor G. Adensam, Director
Project Directorate II-1
Division of Reactor Projects - I/II

FROM: Ronnie H. Lo, Senior Project Manager
Project Directorate II-1
Division of Reactor Projects - I/II

SUBJECT: FORTHCOMING MEETING WITH CAROLINA POWER AND LIGHT
COMPANY (CP&L) REGARDING H. B. ROBINSON STEAM ELECTRIC
PLANT, UNIT NO. 2 (HBR-2)

DATE & TIME: Thursday, September 28, 1989
1:00 P.M.

LOCATION: One White Flint North
11555 Rockville Pike
Rockville, Maryland
14/B/11

PURPOSE: To discuss Auxiliary Feedwater System Operability Issues
and Restart of HBR-2 (Agenda enclosed).

*PARTICIPANTS:

NRC

G. Lainas
E. Adensam
R. Lo
L. Garner
J. Wermiel
W. Lefave
A. Thadani

W. Hehl
P. Kellogg
L. Garner
S. Varga
T. Sullivan

CP&LC

T. Watson
C. Dietz
R. Morgan
L. Loflin
R. Prunty
J. Shepard
C. Crawford
J. Koosterman, et.al.

Original Signed By:

Ronnie H. Lo, Senior Project Manager
Project Directorate II-1
Division of Reactor Projects - I/II

Enclosure: As stated

cc w/enclosure:
See next page

*Meetings between NRC technical staff and applicants or licensees are open for interested members of the public, petitioners, intervenors, or other parties to attend as observers pursuant to "Open Meeting Statement of NRC Staff Policy," 43 Federal Register 28058, 6/28/78.

DF01
41

OFC : LA: [signature] : PM: PDII-1 : D: PDII-1 :
NAME : P. Anderson : RLo: bld [signature] : EAdensam [signature] :
DATE : 09/20/89 : 09/20/89 : 09/20/89 :

OFFICIAL RECORD COPY

Document Name: ROBINSON MEETING NOTICE

8909260334 890920
PDR ADOCK 05000261
P PNU

H. B. Robinson Steam Electric
Plant, Unit No. 2

cc:

Mr. R. E. Jones, General Counsel
Carolina Power & Light Company
P. O. Box 1551
Raleigh, North Carolina 27602

Mr. H. A. Cole
Special Deputy Attorney General
State of North Carolina
P. O. Box 629
Raleigh, North Carolina 27602

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
H. B. Robinson Steam Electric Plant
Route 5, Box 413
Hartsville, South Carolina 29550

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street
Suite 2900
Atlanta, Georgia 30323

Mr. R. Morgan
General Manager
H. B. Robinson Steam Electric Plant
P. O. Box 790
Hartsville, South Carolina 29550

Mr. Dayne H. Brown, Chief
Radiation Protection Branch
Division of Facility Services
Department of Human Resources
701 Barbour Drive
Raleigh, North Carolina 27603-2008

Mr. Robert P. Gruber
Executive Director
Public Staff - NCUC
P. O. Box 29520
Raleigh, North Carolina 27626-0520

Mr. C. R. Dietz
Manager, Robinson Nuclear Project
Department
H. B. Robinson Steam Electric Plant
P. O. Box 790
Hartsville, South Carolina 29550

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Mr. Lynn W. Eury
Executive Vice President
Power Supply
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

DISTRIBUTION FOR MEETING NOTICE DATED: September 20, 1989

~~Docket File~~

NRC & Local PDRs

PDII-1 Reading

T. Murley/J. Snizek

J. Partlow

S. Varga

G. Lainas

R. Lo

C. Haughney

OGC

E. Jordan

B. Grimes

Receptionist (WFN)

NRC Participants

ACRS (10)

GPA/PA

V. Wilson

L. Thomas

R. Borchardt, (17/G/21)

K. Clark, Region II

P. Anderson

R. Lobel, (11/E/22)

E. Imbro

C. McCracken

T. Marsh

J. Huang

cc: Licensee/Applicant & Service List

DFol
1/1

AGENDA

H. B. ROBINSON STARTUP CONFERENCE

- I. Introduction
 - A. Participant Introduction
 - B. Description of Condition
 - C. Agenda Review
- II. Brief History of Auxiliary Feedwater System (including Condensate Storage Tank)
 - A. Major System Configuration Stages
 - 1. Initial Plant Startup
 - 2. Post-TMI
 - 3. Present (pre-shutdown)
 - B. Design Basis
 - 1. Technical Specifications
 - 2. Configurations/Modifications
 - C. Operations
 - 1. Procedures
 - 2. Surveillance/Performance
 - 3. Maintenance
- III. Summary of CP&L Investigations
 - A. Inadequate NPSH
 - B. Seismic Qualification of Condensate Storage Tank
 - C. Physical Damage/Status of AFW Pumps and Motors
 - D. Other Systems
 - 1. NPSH
 - 2. Surveillance Testing
 - 3. Preventative Maintenance
 - E. Independent Evaluation of Previously Identified Issues
 - F. Internal Investigation

IV. Corrective Actions

- A. Conformance with Design Basis
- B. Suction Piping Modification
- C. Post-MOD Acceptance Testing
- D. Procedure Changes
- E. Problem Identification/Followup
- F. DBD Program Review

V. Summary