

APPENDIX A

NOTICE OF VIOLATION

Carolina Power and Light Company
H. B. Robinson 2

Docket No. 50-261
License No. DPR-23

As a result of the inspection conducted on January 5-9, 1981, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violations were identified.

- A. Technical Specification 6.8.1 requires written administrative policies to be established that meet or exceed the requirements and recommendations of Appendix A to Regulatory Guide 1.33, dated November 3, 1972. The Guide endorses ANSI Standard N45.2-1971. Section 16 of the standard requires measures to be established to control items which do not conform to requirements.

Contrary to the above, as of January 7, 1981, measures were not established to control nonconforming Containment Pressure Indicator PI-951 and its associated containment isolation engineered safety feature. PI-951 performance indicated the possibility that its associated engineered safety feature would actuate nonconservatively, yet the channel was allowed to continue in service.

This is a Severity Level V Violation (Supplement I.E.).

- B. Technical Specification 6.8.1 requires written administrative policies to be established that meet or exceed the requirements and recommendations of Appendix A to Regulatory Guide 1.33, dated November 3, 1972. The Guide endorses ANSI Standard N45.2-1971. Section 2 of the standard requires the Quality Assurance program to identify the items and services to which quality standards apply.

Contrary to the above, as of January 9, 1981, written administrative policies did not identify the instrumentation to which quality standards apply (Nuclear Instrumentation System excepted).

This is a Severity Level V Violation (Supplement I.E.).

Pursuant to the provisions of 10 CFR 2.201, Carolina Power and Light Company is hereby required to submit to this office within twenty-five days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

FEB 05 1981

Date: _____

810 3310 641