

APPENDIX B

NOTICE OF DEVIATION

Carolina Power and Light Company

License No. DPR-23

Based on the results of the NRC inspection conducted on April 11, - May 10, 1981, certain of your activities appear to deviate from your commitments to the Commission as indicated below.

CP&L letter GD-79-3306, Lessons Learned Short Term Requirements, dated December 31, 1979, reported CP&L implementation of Requirement 2.1.6.a as clarified in enclosure 1 of NRR letter dated October 30, 1979, Discussions of Lessons Learned Short Term Requirements. This letter committed the licensee to a leak reduction program as a periodic test with an annual frequency. Periodic Test 2.12, Safety Injection System (Boron Injection Tank) Integrity Test was established to satisfy this commitment.

Contrary to the above, as of April 13, 1981, Periodic Test 2.12 had not been performed annually. This test was overdue as of March, 1981.

8107240243 810707
PDR ADOCK 05000261
Q PDR