

APPENDIX A

NOTICE OF VIOLATION

Carolina Power and Light Company
H. B. Robinson

Docket No. 50-261
License No. DPR-23

As a result of the inspection conducted on December 15-18, 1981, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violation was identified.

10 CFR 50.55a(g) requires that inservice inspection of Class 1, 2, and 3 piping systems be conducted in accordance with ASME B&PV Code Section XI. ASME Section XI requires that boundaries of Class 1, 2 and 3 systems be established in accordance with Regulatory Guide 1.26.

Contrary to the above, establishing of piping class boundaries in accordance with Regulatory Guide 1.26 was not done in that the feedwater piping system inspection isometrics show a check valve as the Class 2/Class 3 boundary when in fact the boundary valve is a motor operated isolation valve upstream of the check valve.

This is a Severity Level VI Violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

Date: JAN 07 1982

8203080489 820302
PDR ADDCK 05000261
Q PDR