



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION II  
101 MARIETTA STREET, N.W.  
ATLANTA, GEORGIA 30323

U. S. NUCLEAR REGULATORY COMMISSION

REGION II

AUGMENTED INSPECTION TEAM

Report No.: 50-261/89-20

Licensee: Carolina Power and Light Company  
P. O. Box 1551  
Raleigh, NC 27602

Docket No.: 50-261

License No.: DPR-23

Facility Name: H. B. Robinson 2

Inspection Conducted: August 27 - September 1, 1989

Team Leader:

*Paul J. Kellogg*  
Paul J. Kellogg, Chief  
Operational Programs Section

*9/14/89*  
Date Signed

Team Members: R. Azua, Reactor Engineer, RIV  
B. Bonser, McGuire Project Engineer, RII  
W. Lefave, Plant Systems Engineer, NRR  
W. Levis, Brunswick Resident Inspector, RII  
R. Lo, Robinson Project Manager, NRR

Approved by:

*E. W. Merschoff*  
for E. W. Merschoff, Deputy Director  
Division of Reactor Safety  
Region II

*9-14-89*  
Date Signed

8909270149 890915  
PDR ADOCK 05000261  
Q FDC

## TABLE OF CONTENTS

### I. INTRODUCTION - FORMATION AND INITIATION OF AUGMENTED INSPECTION TEAM (AIT)

- A. Background
- B. Formation of AIT
- C. AIT Charter - Initiation of Inspection
- D. Persons Contacted are listed in Appendix A.
- E. Abbreviations and acronyms are listed in Appendix B.

### II. BRIEF DESCRIPTION OF IDENTIFICATION OPPORTUNITIES

### III. SAFETY SYSTEM FUNCTIONAL INSPECTION

- A. Licensee Initiative
- B. Corrective Action Systems

### IV. DESIGN BASIS DOCUMENTATION REVIEW PROCESS

- A. Purpose of the DBD Process
- B. Identification and Resolution of AFW NPSH Discrepancy
- C. Conclusions

### V. OPERABILITY DEFINITION

### VI. COMMUNICATIONS

### VII. ROOT CAUSE DETERMINATION

### VIII.EXIT INTERVIEW

## REPORT DETAILS

### I. INTRODUCTION - FORMATION AND INITIATION OF AIT

#### A. Background

H.B. Robinson Unit 2 is a Westinghouse three loop pressurized water reactor. The Unit is located five miles North West of Hartsville, SC in Darlington County. Initial criticality was achieved in September 1970, and commercial operation began in March 1971.

On August 16, 1989, the licensee reported to the NRC that NPSHa was inadequate for all combinations of AFW pumps running and various CST levels. The SDAFW pump was declared inoperable and a seven day LCO was entered. On August 22, 1989, the licensee informed the NRC that inadequate NPSHa existed for two MDAFW pumps at rated flow. On August 22, 1989, the licensee reported that the unit was being shutdown due to NPSHa problems in the AFW system.

#### B. Formation of Augmented Inspection Team

On the morning of Thursday, August 24, 1989, the Regional Administrator, after further briefing by the Regional and Resident staff and consultation with senior NRC management, directed the dispatch of an Augmented Inspection Team headed by the Section Chief of the Region II Operational Programs Section. The team included participation by NRR.

#### C. AIT Charter - Initiation of Inspection

The Charter for the AIT was prepared on August 25, 1989, and the AIT members arrived at the Robinson site on August 28, 1989. The special inspection commenced with an Entrance Meeting and briefing by licensee management at 1000 hours on August 28, 1989. The Charter for the AIT specified that the following tasks be completed:

1. Develop and validate a detailed sequence of actions associated with the design basis reconstitution of the Auxiliary Feedwater System at the H. B. Robinson Plant. This sequence should include the design process inputs, calculations, verification, findings, and disposition of deficiencies.
2. Evaluate the significance of the NPSH deficiency on safety system performance. Review AFW events where the system response was not as expected.
3. Evaluate the accuracy, timeliness and effectiveness with which identified deficiencies were reported to Plant and Corporate management and their prioritization and disposition of each.

Review the opportunities the licensee had to identify and correct this problem, i.e., post trip reviews, SSFI, and design basis documentation, and determine why the problem was not fully scoped, root cause, and adequate timely corrective action implemented.

4. Evaluate the licensee's actions taken including engineering interface to verify equipment operability when degraded system performance was evident. Determine what actions the licensee took regarding any problems identified with AFW performance.

D. Persons contacted are listed in Appendix A.

E. Abbreviations and Acronyms used are listed in Appendix B.

## II. BRIEF DESCRIPTION OF IDENTIFICATION OPPORTUNITIES

In October 1986, the licensee commenced data collection for a self initiated SSFI on the AFW system. This information was collected by December 10, 1986. On December 22, 1986, a reactor trip occurred during which a member of the SSFI team was in the control room and noted reduced AFW flow with all three pumps running. This observation was turned over to the Technical Support Group for follow-up. A special project was completed by ONS in January of 1987, at the request of Technical Support. The results of this special project were that NPSHa was not the problem but additional testing should be performed to make an exhaustive conclusion. This testing was incorporated into a plant problem identification report which was subsequently scheduled to be completed in 1988. Additionally the SSFI identified a significant finding with respect to NPSHa. This finding was placed into the RAIL system for completion by the DBD process. At least two more plant trips occurred during which low flow conditions were noted in the AFW system with three pumps operating. Since this had been previously identified and turned over to Technical Support for resolution, operations considered it as a non-problem. In July 1989, the licensee's NED completed a design hydraulic calculation which indicated NPSHa problems with the SDAFW pump. This calculation was forwarded to the Modifications and Projects Manager and Technical Support personnel on July 21, 1989. The Technical Support discounted the calculation as being flawed and asked NED to perform the work again. On July 27, 1989, the ONS informed NED of actual test results collected on June 20, 1989, and attempted to explain the flaws in the original calculation. On August 16, 1989, NED provided Revision 1 of their calculation to the plant. This was again reviewed both by Technical Support and ONS, the results were still considered to be non-conservative. On August 21, 1989, NED and ONS met to discuss the calculation and the actual plant data. Based on this review the AFW pumps were declared inoperable.

### III. SAFETY SYSTEM FUNCTIONAL INSPECTION

#### A. Licensee Initiative

Beginning in October 1987, the licensee conducted a self-initiated SSFI on the AFW system to assess the ability of the AFW system to perform its safety function. The assessment reviewed the functional areas of system design, testing, maintenance, training and operations. The areas were examined in accordance with functional area work plans which provided the necessary guidance for how the functional areas were to be reviewed. The inspection was conducted from October 17, 1986, until December 10, 1986. The site was briefed on the team's findings on February 3, 1987. A draft report was issued in March 1987, and the final report issued August 27, 1987.

The AFW SSFI report concluded that the operational readiness was "reasonably adequate." There were, however, problems identified which had a "significant negative impact on operational readiness and require near-term attention." The specific findings were classified by the team into one of three levels. The first of these classifications included those areas that represented the most significant concerns and which needed timely attention. The second classification included those areas for which increased attention to detail would contribute to a higher state of operational readiness. The third area was one in which no problems were found and strengths were identified.

The specific findings and recommendations were summarized by functional area as an attachment to the SSFI report. In all, approximately 82 items were identified for action. Sixteen of the items were classified as significant concerns. These specific items were assigned as RAIL items by the Regulatory Compliance Organization on site for tracking and assignment of responsibilities to close. However, when the RAIL numbers were assigned, no priority system was used to ensure that those items which represented the most significant concerns were resolved first and in a timely manner as recommended by the report. In addition, since the RAIL items were not a Regulatory or other agency commitment the due dates could be extended by mutual agreement between the responsible individual assigned to the task and the responsible regulatory Compliance individual assigned to track the item. No management approval is required for an extension request for a RAIL item of this priority. There is also no limit to the number of times that the item can be extended. Responsible managers do get a weekly printout of outstanding RAIL items in their area. This document provides the RAIL number, initiating documentation, responsible individual, short description of the item, status of corrective action, due date, the number of times that the item has been extended, and the priority.

The priority does not refer to the safety significance of the item but rather indicates whether or not a report is required to an outside agency. A Priority one RAIL item signifies the requirements to provide a report or response to an outside agency. The Priority two item is one which only HBR2 action is required and no report or response to an outside agency is necessary. A Priority three item is one which the closeout action is to be taken by an outside agency and no further HBR2 action is required.

The question of adequate NPSHa was addressed in Section 5.1.4 of the SSFI report beginning on page 60. The report states that the suction pressure criteria was met for each of the AFW pumps at the 35,000 gallon CST level. The report further notes that there was very little margin available for the steam driven pump and that although the case of simultaneous operation of all three pumps was not investigated it would appear that if the flow rate were doubled the corresponding pressure drop would increase by a factor of four which would lead to NPSH problems on the steam driven pump before the 35,000 gallon CST level was met. Some of the assumptions noted by the inspector in the calculations provided in the report include the following:

1. 100 degrees F water temperature
2. 6" pipe (approximately 1' of head added to compensate for some reducers gates valves and 4' inch pipe)
3. 35,000 gallons on CST corresponded to 4.7'
4. pumps delivered rated flow (300 gpm for MDAFW Pump, 600 gpm for SDAFW Pump)

The deficiency regarding the NPSHa concern during three pump operation was classified as a significant concern in Section 3 of the report and assigned a RAIL number for tracking purposes and assignment of responsibility to close. RAIL item 87R779 was assigned to Technical Support for resolution on August 26, 1987. The priority listed is two since no response was required to an outside agency. No due date is listed for resolution of the item. The item was updated on December 22, 1987, to reflect a due date of March 15, 1988. In all, the item was extended six times with a present due date of September 26, 1989. The resolution of the item was ultimately turned over in August 1987, to NED for inclusion in the DBD for the AFW system.

The SSFI team left the site on December 10, 1986. On December 22, 1986 a member of the SSFI team was in the control room at the time of the Reactor trip and noted the degraded AFW flow conditions during the three pump operation.

On December 29, 1986, a calculation was provided to a Technical Support member from an NSSS engineer (both of whom were also on the SSFI team) which concluded that the steam driven pump would not operate correctly ( $NPSHa < NPSHr$ ) if the CST level were below approximately 20 feet which corresponds to 76% or 145,000 gallons in the CST. This information was not included in the SSFI report which was issued after this date. A stronger statement in the report including this additional information would have underlined the significance of the problem.

The AFW SSFI was a missed opportunity to identify the NPSHa problems associated with the AFW pumps. Although the report lists the NPSHa concern as significant, the wording was not strong enough to indicate the potential of the problem.

The licensee's lack of aggressiveness in resolving non-regulatory commitment issues is considered to be a significant weakness. Of the 82 AFW SSFI items identified, 19 are still open with seven of these included in the significant category.

#### B. Corrective Action Systems

The inspector also reviewed the licensee's corrective action program as outlined in procedure PLP 26 R2. The program as defined in PLP 26 began in August 1988. Since its inception 22 Significant Condition Reports were initiated in 1988 and 65 Significant Condition Reports were initiated thus far in 1989. Thirteen of the 22 SCRs from 1988 are still open with four of the 13 classified as nuclear safety related. Fifty-three of the 65 SCRs generated in 1989 are still open with 21 of the 53 classified as nuclear safety related. Plant management has recognized that the SCRs are not being closed in a timely manner. One of the SCRs generated in 1989 involves the program itself to provide better methods for tracking and resolving identified significant conditions. Included in the closeout of this SCR will be the requirement to prioritize the SCRs such that those that are nuclear safety related receive attention first.

### IV. THE SYSTEM DESIGN BASIS DOCUMENT REVIEW PROCESS

#### A. Purpose of the DBD Process

The objective of the DBD process is to establish the current design basis and calculations/analyses of records applicable to HBR2 and control them for future use. The DBD process is divided into three basic phases: a documentation collection phase, a validation phase, and a discrepancy resolution phase. The first three DBDs at HBR2 were pilot projects. They included the Safety Injection System, AFW System, and Reactor Safeguards System.

The licensee defines the design basis for a system as a system's functional and regulatory requirements and the codes and standards of records that govern its design as modified by post operating license regulatory commitments. System calculations/analyses of records demonstrate that a system complies with its design bases and dictates the system and component performance parameters. The DBD process is intended to verify that the system design basis, the calculations/analyses of record and the as-constructed system are consistent.

The HBR2 system DBDs are prepared in accordance with "Design Basis Reconstitution Project Guideline for Preparation of System Design Basis Documents." This guideline provides background information on the original HBR2 design evolution and explains how available design information is to be evaluated and integrated into a set of DBDs in a common format.

The HBR2 system DBD guideline contains several general and specific requirements. These requirements include supplying sufficient information to satisfy the applicable design input requirements of ANSI N45.2.11; design basis information as defined in the general DBD guidelines; and reference to applicable FSAR transient analyses and other FSAR sections which define the systems functional requirements. To assure incorporation of those requirements, the DBD follows a specific format. This format addresses system functional requirements, regulatory imposed design requirements, system design requirements, component design requirements and design margins. To meet all the objectives of the guidelines the DBD generally includes only summary level information/statements with appropriate references.

After the system DBD is approved for preliminary use, it is used as the inspection standard for field validation of plant procedures and hardware. The guideline states that a field validation will be performed of the system's critical design basis parameters that are contained in the system DBD as they relate to the system hardware and its performance and configuration. The validation guideline was implemented by extracting design basis statements from the DBD for validation. The validation process for the AFW system reviewed 174 design basis statements, of these 117 were validated/exempted and one was determined to be out of scope. The remaining 56 items could not be validated and were referred to the Discrepancy Resolution Coordinator for follow-up action. These 56 items were grouped into 26 discrepancies and entered into the Discrepancy Resolution Information Program. A discrepancy resolution coordinator was in charge of getting resolution of the identified discrepancies.



## B. Identification and Resolution of AFW NPSH Discrepancy

On July 11, 1988, the site requested the DBD project to address concerns related to AFW performance capability. The site was specifically concerned about the motor driven and steam driven AFW pump suction piping size and the minimum NPSHa required for continuous multiple pump operation. This site concern resulted from plant investigation into items covered by the SSFI on the AFW system conducted in 1987 by the licensee's Corporate Nuclear Safety Group. The memo requested an analysis be performed during the DBD process to fully address the plant concerns. There was no priority attached to this memo, nor was the memo worded to indicate that anything other than routine work was involved.

On December 30, 1988, the preliminary DBD was approved. It contained AFW system performance requirements. These included the following system requirements:

1. The head generated by the AFW pumps shall be sufficient to ensure that feedwater can be pumped into the SGs when the MS safety valves are discharging.
2. The relative pressures associated with the various SG conditions that could exist when AFW is required must be considered when designing the system to supply the required flow to the SGs.
3. The minimum required flow to be delivered to the operable SGs against a SG pressure must be equivalent to the maximum accumulation pressure of the SG safety valves that must be opened to pass the decay heat load.
4. Each AFW pump shall have sufficient head to deliver its rated capacity to the SGs at the safety valve set pressure (with three percent accumulation).

Following completion of the AFW system preliminary DBD and prior to beginning the validation phase it was identified that no calculations were found in the documentation search to support the AFW pump suction line sizing. On March 20, 1989, implementation of the validation plan started. The licensee determined that validating the specific AFW system performance requirements in the DBD would require the preparation of an AFW system hydraulic calculation. An Interdiscipline Review Request (IRR DBD2-MAK-002) was submitted to the NED Mechanical/Nuclear Unit requesting preparation of an AFW system hydraulic calculation. The IRR requested completion of the calculation by May 26, 1989, to support the AFW DBD validation schedule.

On July 20, 1989, the Mechanical/Nuclear Unit responded to IRR DBD2-MAK-002 with Revision 0 of the AFW system hydraulic calculation.

This calculation determined that NPSHa could be a problem when all three AFW pumps are operating at a 1200 gpm flow rate. To support pump operation at this flow rate, level in the CST would have to be greater than 76.7 percent. Below this level, flowrates would not be adequate to assure that the steam driven AFW pump would have sufficient NPSH.

The following day, in accordance with procedure DBD.PII.1, "Discrepancy Resolution", a SAP form was completed. The SAP form provides a systematic approach to determine the prioritization of discrepancies and is used to determine the frequency of core damage based upon a particular initiating event (discrepancy). The conclusion of the SAP was that: "insufficient NPSHa to the SDAFW pump will result in a reduction of flexibility to supply secondary coolant." The PRA analysis determined that assuming failure of the SDAFW pump this discrepancy constituted a high risk potential to the frequency of core damage and required immediate evaluation. NED contacted the site and notified site management of a potential significant deficiency that could affect operability.

On August 16, 1989, NED completed Revision 1 of the AFW system hydraulic calculation. It included analyses of additional scenarios as requested by the site system engineer. That same day, the site was notified again of an operability issue on the SDAFW pump.

### C. Conclusions

1. There was not a common understanding of the DBD process and what it was to accomplish. In this case, the questions surrounding the AFW pump suction piping size and minimum NPSHa were not answered by the DBD process but resulted only in the generation of hydraulic calculations based on design data. The DBD process did not verify field data and operational experience.
2. There was a lack of design basis information on the AFW system which led to a poor comprehension of AFW system operation. Specifically with three pumps operating simultaneously.
3. When NED recognized a significant deficiency with the AFW system and reported it to site management. Site management failed to respond aggressively and accepted it as an old problem.

### V. SYSTEM / COMPONENT DEFINITION OF OPERABILITY

Operability is one of the issues that is being addressed as a result of the recent events at HBR2. The failure by plant personnel to attach any significant safety concerns to the reduced auxiliary feedwater flows, has raised questions as to how the plant identified operability problems and more importantly how the plant personnel define operability.

In response to the first question HBR2 utilizes several methods which include a surveillance test program, preventive maintenance program, post trip review program and a trip reduction assessment program. These programs were reviewed only with respect to the AFW system.

The surveillance program for the AFW pumps was found to be consistent. The pumps were tested periodically as required, and the data obtained met the acceptance criteria set forth in the test. Based on the lack of any trending data, it is apparent from interviews that the data taken was not routinely correlated with any previous test data in an effort to verify that the pumps were operating in a consistent manner. With respect to a preventive maintenance the licensee's program is performance based, which means that if a pump is performing its function, it is considered operable and thus it is not scheduled for maintenance. The MDAFW pumps had not been overhauled since the plant began operation approximately seventeen years ago. The SPAFW pump had undergone some repair approximately ten years ago and was scheduled for maintenance during the upcoming planned outage.

The post trip review program and the trip reduction assessment program are both identified in the following two procedures; PLP-035, "Plant Operating Experience Report, Revision 0," dated April 2, 1986, and PLP-036, "Trip Reduction Assessment Program (TRAP)", Revision 0, dated April 8, 1986. The purpose of these procedures is to identify those items or pieces of equipment that have failed to perform their function and have (a) caused a plant trip, (b) may cause a plant trip or (c) make it more difficult for the plant operators to recover from a plant trip. These guidelines were found to be narrow in scope and have excluded the operator from identifying that piece of equipment that may be performing its function, thus not meeting the criteria set forth above, but operating below design.

How the licensee defines operability is closely related to the paragraph described above. It has been noted that the operators determine that equipment that is found to perform its function is considered to be operable even though it may be operating in a degraded condition, i.e., operating below design. This was demonstrated during past events where the control room operators noted that the AFW pumps did not achieve their total design flow of 1200 GPM when all three pumps were operating. The operators determined that as long as the pumps produced a total flow in excess of 300 GPM (identified in plant FSAR), the pumps were operational. With this conclusion the operators never addressed this item in either the control room logs, the post trip review report or the TRAP, and thus was never identified as a possible concern. This definition of operability is shared by plant operators and other plant personnel. Their may cause the plant staff to be unaware of equipment degradation trends as long as a piece of equipment is performing its function.

## VI. COMMUNICATIONS

Throughout this entire event, communications remained at the lowest levels in the organization. The Tech. Support Manager and ONS Manager were the highest levels that the December 22, 1986, reduced flow observation reached. The SSFI findings were transmitted to the manager of Technical Support for resolution. The Manager of Modification Projects received the NED notification of the hydraulic calculation problem and passed it on to Technical Support. The concerns of the reduced flow events and the more conservative calculations were carried out at the engineering level. This persisted until ONS became aware of the request for Technical Specifications and JCO preparation based on the less conservative Revision 1 calculation. When that concern was finally raised to the correct levels of plant management, aggressive action was carried out to define the problem and the necessary corrective actions.

## VII. ROOT CAUSES

The AIT team considered there to be four root causes for the slow recognition of the AFW NPSH problem. These root causes are:

1. Lack of Design information for the case of three pump operation. This lack of information coupled with the licensee's definition of operability led the operators/engineers to consider the AFW system operational and the DBD process to be in error.
2. Lack of priority assigned to the licensee's internal SSFI findings. The initial priority assigned to the SSFI findings was lost when they were entered into the RAIL system for action.
3. System Operability Attitude. The licensee's attitude of equipment being operable if it functions when called on and passes its surveillance tests led to a false conclusion about the calculations performed by NED and ONS.
4. Communications at too low a level without management involvement. Throughout this event, communications were carried out at the engineer to engineer level until the discussions concerning the JCO and Technical Specification changes were started. Management was unaware of the existence of more conservative calculations.

## VIII. EXIT INTERVIEW

The preliminary findings of this special inspection were discussed on September 1, 1989, with those persons indicated in Appendix A. No dissenting comments were received.

## APPENDIX A

### Persons Contacted

<u>Name</u>	<u>Title Work Group</u>
J. Baruch	Technical Representative Dresser Industries
P. Bauer	Engineer - NSSS
* G. Chappell	Principal Engineer - NED
* S. Clark	Project Engineer On-Site NED
C. Coffman	Engineer, ONS
S. Cracker	Regulatory Compliance Senior Specialist
* R. Crook	Senior Specialist - Regulatory Compliance
* J. Curley	Director Regulatory Compliance CP&L
* C. Dietz	Manager - RNP
* J. Eads	Project Engineer - Nuclear Licensing NSD
* W. Flanagan	Manager Outage/Modifications
* S. Griggs	Technical Aide - Regulatory Compliance
* W. Gainey, Jr.	OPS Support Supervisor
* E. Harris, Jr.	Director, ONS
J. Hauck	Corporate Quality Assurance
* J. Kloosterman	Project Engineer - Nuclear Licensing CP&L
* A. Lucas	Manager - NED
* W. Martin	Principal Engineer - BNP ONS
A. McCauley	Onsite Nuclear Safety
C. Moon	System Engineer - Tech Support
* R. Morgan	Plant General Manager
* M. Page	Manager Tech Support
* R. Pranity	Principal Engineer - Nuclear Licensing
* D. Quick	Manager, Maintenance
* D. Stadler	Onsite Licensing Engineer
B. Waldsmith	Reactor Operator
* R. Watson	Senior Vice President Nuclear General CP&L
* K. Williams	Senior Engineer - Onsite NED
* H. Young	Manager QA/QC

### NRC Personnel

*E. Adensam	Project Director - NRR
*L. Garner	NRC Senior Resident Inspector
*K. Jury	Resident Inspector
*E. Merschhoff	Deputy Director, Division of Reactor Safety, RII
*D. Verrelli	Chief, Projects Branch 1, RII

\* Attended Exit Meeting

## APPENDIX B

### ACRONYMS AND ABBREVIATIONS

AFW	AUXILIARY FEEDWATER
ANSI	AMERICAN NATIONAL STANDARD INSTITUTE
AIT	AUGMENTED INSPECTION TEAM
CST	CONDENSATE STORAGE TANK
DBD	DESIGN BASES DOCUMENT
FSAR	FINAL SAFETY ANALYSIS REPORT
HBR2	H. B. ROBINSON UNIT 2
JCO	JUSTIFICATION FOR CONTINUED OPERATION
LCO	LIMITING CONDITION FOR OPERATION
MS	MAIN STEAM
MDAFW	MOTOR DRIVEN AUXILIARY FEEDWATER
NED	NUCLEAR ENGINEERING DEPARTMENT
NPSHa	NET POSITIVE SUCTION HEAD available
NPSHr	NET POSITIVE SUCTION HEAD required by the pumps
NRC	NUCLEAR REGULATORY COMMISSION
NSSS	NUCLEAR STEAM SUPPLY SYSTEM
PIR	PROBLEM IDENTIFICATION REPORT
PRA	PROBABILISTIC RISK ASSESSMENT
RAIL	REGULATORY ACTION ITEM LIST
SAP	SCREENING AND PRIORITIZATION
SCR	SIGNIFICANT CONDITION REPORT
SDAFW	STEAM DRIVEN AUXILIARY FEEDWATER
SG	STEAM GENERATOR
SSFI	SAFETY SYSTEM FUNCTIONAL INSPECTION
TRAP	TRIP REDUCTION ASSESSMENT PROGRAM