

ENCLOSURE 1

NOTICE OF VIOLATION

Carolina Power and Light Company
H.B. Robinson

Docket No. 50-261
License No. DPR-23

During the NRC inspection conducted on January 14 - February 7, 1992, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure For NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1991), the violation is listed below:

10 CFR 50 Appendix B, Criterion V, requires in part that activities affecting quality be accomplished in accordance with procedures. Operations surveillance test procedure, OST-701, Inservice Inspection Valve Test, revision 16, section 6.3 requires that valve stroke times be measured from the time the control switch is actuated to the time the valve reaches the required position as determined by the valve position indicating lights.

Contrary to the above, activities affecting quality were not accomplished in accordance with procedure OST-701 on December 17, 1991, in that valves PS-956F and G, primary sampling system containment isolation valves, were not timed from control switch actuation to light indication as required. The failure to time the valves in the specified manner resulted in the valves not being declared inoperable as required by the procedure.

This is a Severity Level IV violation (Supplement 1).

Pursuant to the provisions of 10 CFR 2.201, Carolina Power and Light Company is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

THE NUCLEAR REGULATORY COMMISSION

Dated at Atlanta, Georgia
this 25 February 1992

9203100029 920225
PDR ADDCK 05000261
Q PDR