

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9308050064 DOC.DATE: 93/07/23 NOTARIZED: NO DOCKET #
 FACIL:50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH.NAME AUTHOR AFFILIATION
 ERRELLI,D.M. Region 2 (Post 820201)
 RECIPIENT NAME RECIPIENT AFFILIATION
 DIETZ,C.R. Carolina Power & Light Co.

SUBJECT: Forwards insp rept 50-261/93-15 on 930612-0709.Weaknesses in calibration of heat trace recorder & calibration errors, noted.

DISTRIBUTION CODE: IE01D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 3+8
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 PD	1 1	MOZAFARI,B	1 1
INTERNAL:	AEOD/DEIB	1 1	AEOD/DSP/ROAB	1 1
	AEOD/DSP/TPAB	1 1	AEOD/TTC	1 1
	DEDRO	1 1	NRR/DORS/OEAB	1 1
	NRR/DRCH/HHFB	1 1	NRR/DRIL/RPEB	1 1
	NRR/DRSS/PEPB	1 1	NRR/PMAS/ILPB1	1 1
	NRR/PMAS/ILPB2	1 1	NUDOCS-ABSTRACT	1 1
	OE DIR	1 1	OGC/HDS2	1 1
	REG FILE 02	1 1	RES/HFB	1 1
	RGN2 FILE 01	1 1		
EXTERNAL:	EG&G/BRYCE,J.H.	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 22

JUL 23 1993

Docket No.: 50-261
License No.: DPR-23

Carolina Power and Light Company
ATTN: Mr. C. R. Dietz
Vice President
H. B. Robinson Steam Electric Plant,
Unit 2
P. O. Box 790
Hartsville, SC 29550-0790

Gentlemen:

SUBJECT: NRC INSPECTION REPORT NO. 50-261/93-15

This refers to the inspection conducted by W. T. Orders of this office on June 12 - July 9, 1993. The inspection included a review of activities authorized for your H. B. Robinson facility. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed inspection report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress.

Within the scope of the inspection, there were no violations or deviations identified. However, the enclosed report documents weaknesses in the calibration of a heat trace recorder and calibration errors introduced in the Boric Acid Storage Tank temperature controller from a mis-positioned adjusting link. These observations are of concern, in as much, as they are similar to problems with calibration and control of instrumentation and control equipment discussed in Inspection Reports 92-27, 92-34, and 93-11. Collectively, these observations could be indicative of a programmatic deficiency warranting your increased attention.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be placed in the NRC Public Document Room.

9308050064 930723
PDR ADOCK 05000261
Q PDR

IE01

JUL 23 1993

Carolina Power and Light Company 2

Should you have any questions concerning this letter, please contact us.

Sincerely,

ORIGINAL SIGNED BY
DAVID M. VERRELLI

David M. Verrelli, Chief
Reactor Projects Branch 1
Division of Reactor Projects

Enclosure:
NRC Inspection Report

cc w/encl:
W. T. Flanagan
Plant General Manager
H. B. Robinson Steam Electric Plant
P. O. Box 790
Hartsville, SC 29550

Mr. W. S. Orser
Executive Vice President
Nuclear Generation
Carolina Power & Light Company
P. O. Box 1551 Mail Code - CPB 12
Raleigh, NC 27602

Mr. H. W. Habermeyer, Jr.
Vice President
Nuclear Services Department
Carolina Power & Light Company
P. O. Box 1551 - Mail OHS7
Raleigh, NC 27602

Heyward G. Shealy, Chief
Bureau of Radiological Health
Dept. of Health and Environmental
Control
2600 Bull Street
Columbia, SC 29201

Dayne H. Brown, Director
Division of Radiation Protection
N. C. Department of Environment,
Health & Natural Resources
P. O. Box 27687
Raleigh, NC 27611-7687

(cc w/encl cont'd - See page 3)

Carolina Power and Light Company 3

JUL 23 1993

(cc w/encl cont'd)
McCuen Morrell, Chairman
Darlington County Board of Supervisor
County Courthouse
Darlington, SC 29535

H. Ray Starling
Vice President - Legal Department
Carolina Power and Light Co.
P. O. Box 1551
Raleigh, NC 27602

H. A. Cole
Special Deputy Attorney General
State of North Carolina
P. O. Box 629
Raleigh, NC 27602

Robert Gruber
Executive Director
Public Staff - NCUC
P. O. Box 29520
Raleigh, NC 27626-0520

J. L. Harrison, Manager
Regulatory Compliance
H. B. Robinson Steam Electric Plant
P. O. Box 790
Hartsville, SC 29550

Ms. Gayle B. Nichols
Staff Counsel
SC Public Service Commission
P. O. Box 11649
Columbia, SC 29211

bcc w/encl:
H. Christensen, RII
B. Mozafari, NRR
Document Control Desk

NRC Resident Inspector
U. S. Nuclear Regulatory Commission
Route 5, Box 413
Hartsville, SC 29550

RII:DRP

HChristensen:tj
07/23/93