

ENCLOSURE 2

NOTICE OF DEVIATION

Carolina Power and Light Company
H. B. Robinson Unit 2

Docket No.: 50-261
License No.: DPR-23

During an NRC inspection conducted on November 21 - December 25, 1993, a deviation from a written commitment was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the deviation is listed below:

Licensee letter dated February 1, 1989, RESPONSE TO GENERIC LETTER 88-17, LOSS OF DECAY HEAT REMOVAL, committed to installation of a suction pressure indicator and associated low pressure alarm for each RHR pump.

The licensee deviated from the above commitment in that, this instrumentation was not installed. Alternate indications were installed, however, no documentation to revise the original commitment was made.

Please provide to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region II, and if applicable, a copy to the NRC resident Inspector, in writing within 30 days of the date of this Notice, the reasons for the deviation, the corrective steps which have been taken and the results achieved, the corrective steps which will be taken to avoid further deviations, and the date when your corrective action will be completed. Where good cause is shown, consideration will be given to extending the response time.

Dated at Atlanta, Georgia
this 20th of January 1994