





Carolina Power & Light Company  
Robinson Nuclear Plant  
PO Box 790  
Hartsville SC 29550

Robinson File No.: 13510I  
Serial: RNP/94-0103

**JAN 19 1994**

United States Nuclear Regulatory Commission  
ATTENTION: Document Control Desk  
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261/LICENSE NO. DPR-23  
CORRECTION TO GENERIC LETTER 88-17, LOSS OF DECAY HEAT REMOVAL  
RESPONSE

Gentlemen:

The purpose of this letter is to inform you of a deviation (RHR suction pressure parameter) from information that was provided in a Carolina Power & Light Company (CP&L) letter dated February 1, 1989, concerning actions in response to Generic Letter 88-17. The February 1, 1989, letter stated that CP&L would provide monitoring for RHR suction pressure (Item 1 Instrumentation Response (c)) as a means to monitor the Decay Heat Removal (DHR) System performance. However, the evaluation performed for Modification 1011, "Instrumentation for Mid-Loop Operation", determined that monitoring of RHR pump discharge pressure would be more appropriate. The monitoring was implemented as required during Refueling Outage 13 (Spring, 1991) but inadvertently not communicated to the NRC.

Questions regarding this matter may be referred to Mr. Jan S. Kozyra at (803) 383-1872.

Very truly yours,

Warren J. Dorman  
Acting Manager - Regulatory Affairs

250086

JSK:lst

c: Mr. S. D. Ebnetter  
Ms. B. L. Mozafari  
Mr. W. T. Orders

9401310409 940119  
PDR ADOCK 05000261  
P PDR

Highway 151 and SC 23 Hartsville SC

A001  
1/0

bc: T. A. Baxter, Esq.  
Mr. R. S. Beverage  
Mr. R. K. Buckles (LIS)  
Mr. W. R. Campbell  
Mr. J. M. Curley  
Mr. C. R. Dietz  
Mr. W. J. Dorman  
Mr. D. T. Gudger  
Mr. H. W. Habermeyer, Jr.  
Mr. E. M. Harris  
Mr. J. D. Heidt

Mr. J. S. Kozyra  
Mr. R. E. Morgan  
Mr. F. A. Murray  
Mr. C. S. Olexik, Jr.  
Mr. W. S. Orser  
Mr. M. P. Pearson  
Mr. H. A. Pollock  
Mr. R. S. Stancil  
Mr. R. B. Van Metre  
Siemens Pwr. Corp. c/o T. Dresser  
File: RC/A-2