

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9403150397 DOC. DATE: 94/03/07 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH. NAME AUTHOR AFFILIATION
 KRICH, R.M. Carolina Power & Light Co.
 RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: "1993 Annual Rept - Primary Coolant Iodine Spikes."

DISTRIBUTION CODE: IE47D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: 50.59 Annual Report of Changes, Tests or Experiments Made W/out Approv.

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME	LTR	ENCL		
	PD2-1 PD	1	0		
INTERNAL:	AEOD/DOA	1	1		
	AEOD/DSP/TPAB	1	1		
	<u>REG FILE</u> 02	1	1		
EXTERNAL:	NRC PDR	1	1		
	MOZAFARI, B	2	2		
	AEOD/DSP/ROAB	1	1		
	NRR/DRCH/HHFB	1	1		
	RGN2 FILE 01	1	1		
	NSIC	1	1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 11 ENCL ~~10~~ 0

R
I
D
S
/
A
D
D
S
/
A
D
D
S



TS 6.9.1.2

Carolina Power & Light Company
Robinson Nuclear Plant
PO Box 790
Hartsville SC 29550

Robinson File No.: 13510C
Serial: RNP/94-0439

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

MAR 07 1994

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23
1993 ANNUAL REPORT - PRIMARY COOLANT IODINE SPIKES

Dear Sir:


Carolina Power and Light Company submits the 1993 Annual Report on Primary Coolant Iodine Spikes. This annual report is submitted as required by Technical Specification 6.9.1.2, Item 2.

During 1993, the primary coolant did not exceed 1.0 $\mu\text{Ci}/\text{gram}$ dose equivalent I-131, nor did the Gross Activity exceed 100/E-Bar $\mu\text{Ci}/\text{gram}$ as set forth in Technical Specification 3.1.4.

This report is being submitted six days late due to an oversight within the organization. Changes are being considered which should preclude this from occurring in the future.

If you have any questions concerning this report, please contact me or my staff.

Very truly yours,


R. M. Krich - Manager
Regulatory Affairs Section

MLM:lst
c: S. D. Ebnetter
W. T. Orders

9403150397 940307
PDR ADOCK 05000261
R PDR

Highway 151 and SC 23 Hartsville SC

JEH 1/0