

# FORD 1

## REGULARY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9404110151      DOC. DATE: 94/03/10      NOTARIZED: NO      DOCKET #  
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C      05000261  
 AUTH. NAME      AUTHOR AFFILIATION  
 CLINE, W.E.      Region 2 (Post 820201)  
 RECIP. NAME      RECIPIENT AFFILIATION  
 DIETZ, C.R.      Carolina Power & Light Co.

SUBJECT: Ack receipt of 940204 response to 931221 ltr identifying certain changes made in rev 24 to emergency plan that decreased effectiveness of plan. Corrective action appears to resolve identified emergency planning discrepancies.

DISTRIBUTION CODE: IE35D      COPIES RECEIVED: LTR 1 ENCL 0      SIZE: 3  
 TITLE: Emergency Preparedness-Appraisal/Confirmatory Action Ltr/Exercise Rep

### NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME		LTR	ENCL	
	PD2-1 PD		1		
INTERNAL:	AEOD/DOA/IRB		1		
	NRR/PMAS/ILRB12		1		
	OC/LEDCB		1		
	<u>REG FILE</u> 02		1		
EXTERNAL:	NRC PDR		1		
		MOZAFARI, B	1		
		NRR/DRSS/PEPB9D	1		
		NUDOCS-ABSTRACT	1		
		OE DIR	1		
		RGN2 FILE 01	1		
		NSIC	1		

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK. ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 12 ENCL 11

R  
I  
D  
S  
/  
F  
O  
R  
D  
D  
O  
C  
U  
M  
E  
N  
T

ORIGINAL RECORD COPY

MAR 10 1994

Docket No. 50-261  
License No. DPR-23

Carolina Power and Light Company  
ATTN: Mr. C. R. Dietz  
Vice President  
H. B. Robinson Steam Electric Plant  
Unit 2  
P. O. Box 790  
Hartsville, SC 29550-0790

Gentlemen:

SUBJECT: REVISION 24 TO EMERGENCY PLAN FOR H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT 2, DOCKET NO. 50-261

Thank you for your response of February 4, 1994 to our letter of December 21, 1993, identifying certain changes made in Revision 24 to your Emergency Plan that decreased the effectiveness of the Plan. We acknowledge earlier receipt by facsimile transmission of applicable portions of the Emergency Action Level (EAL) Flowcharts indicating that you have reverted to the previously approved versions of the EALs in question. This corrective action appears to resolve the identified emergency planning discrepancies.

We also acknowledge your discussion of corrective actions in response to our expressed concern regarding the adequacy of your review process to assure compliance with 10 CFR 50.54(q). The effectiveness of those actions will be evaluated during licensing reviews of Emergency Plan revisions and inspections of your emergency preparedness program.

Please be reminded that 10 CFR 50.54(q) requires that proposed changes which decrease the effectiveness of your Emergency Plan shall not be implemented without application to and approval by the Commission. However, changes may be made without Commission approval if such changes do not decrease the effectiveness of the Plan, and the Plan, as changed, continues to meet the standards of 10 CFR 50.47(b) and the requirements of Appendix E to 10 CFR Part 50. If a change is made without approval, you should furnish copies in accordance with 10 CFR 50.54(q). Also, any changes to the Emergency Plan Implementing Procedures should be made in accordance with the requirements of Appendix E to 10 CFR Part 50.

9404110151 940310  
PDR ADOCK 05000261  
F PDR

1/0  
JES

Carolina Power and Light Company 2

Should you have any questions regarding this letter, please contact Mr. Kenneth P. Barr of our staff on 404-331-0335.

Sincerely,

ORIGINAL SIGNED BY  
WILLIAM E. CLINE

William E. Cline, Chief  
Radiological Protection and  
Emergency Preparedness Branch  
Division of Radiation Safety  
and Safeguards

cc: M. P. Pearson  
Plant Manager  
H. B. Robinson Steam Electric Plant  
P. O. Box 790  
Hartsville, SC 29550

H. W. Habermeyer, Jr.  
Vice President  
Nuclear Services Department  
Carolina Power & Light Company  
P. O. Box 1551 - Mail OHS7  
Raleigh, NC 27602

W. Dorman, Acting Manager  
Regulatory Compliance  
H. B. Robinson Steam Electric Plant  
P. O. Box 790  
Hartsville, SC 29550

Max Batavia, Chief  
Bureau of Radiological Health  
Dept. of Health and Environmental  
Control  
2600 Bull Street  
Columbia, SC 29201

Dayne H. Brown, Director  
Division of Radiation Protection  
N. C. Department of Environment,  
Commerce & Natural Resources  
P. O. Box 27687  
Raleigh, NC 27611-7687

cc: (cont'd on page 3)

cc: (cont'd)  
H. Ray Starling  
Manager - Legal Department  
Carolina Power and Light Co.  
P. O. Box 1551  
Raleigh, NC 27602

Karen E. Long  
Assistant Attorney General  
State of North Carolina  
P. O. Box 629  
Raleigh, NC 27602

Robert P. Gruber  
Executive Director  
Public Staff - NCUC  
P. O. Box 29520  
Raleigh, NC 27626-0520

Public Service Commission  
State of South Carolina  
P. O. Box 11649  
Columbia, SC 29211

bcc: H. Christensen, RII  
B. Mozafari, NRR  
Document Control Desk

NRC Resident Inspector  
U. S. Nuclear Regulatory Commission  
Route 5, Box 413  
Hartsville, SC 29550

RII:DRSS

*JRK*  
JKreh  
2/24/94

RII:DRSS

*KB*  
KBarr  
2/25/94

RII:DRP

*H*  
HChristensen  
3/2/94