

PRIORITY 1
(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9407120022 DOC. DATE: 94/06/20 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light Co 05000261
 AUTH. NAME AUTHOR AFFILIATION
 KRICH, R.M. Carolina Power & Light Co.
 RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Requests NRC review & approval of equivalent margins analysis for beltline mats per GL 92-01, rev 1.

DISTRIBUTION CODE: A028D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Generic Letter 92-01 Responses (Reactor Vessel Structural Integrity 1

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD2-1 PD	1	MOZAFARI, B	2
INTERNAL:	NRR/DE/EMCB	2	NRR/DORS/OGCB	1
	NRR/DRPE/PDI-1	1	NRR/DRPW	1
	NUDOCS-ABSTRACT	1	OC/LFDCB	1
	OGC/HDS3	1	<u>REG FILE</u> 01	1
	RES/DE/MEB	1		
EXTERNAL:	NRC PDR	1	NSIC	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 15 ENCL ~~15~~ 0

MAY

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



Carolina Power & Light Company
 Robinson Nuclear Plant
 PO Box 790
 Hartsville SC 29551
 Robinson File No.: 13510I
 Serial: RNP/94-1238

United States Nuclear Regulatory Commission
 Attention: Document Control Desk
 Washington, DC 20555

JUN 20 1994

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
 DOCKET NO. 50-261/LICENSE NO. DPR-23
RESPONSE TO GENERIC LETTER 92-01, REVISION 1, "REACTOR VESSEL
 STRUCTURAL INTEGRITY," FOR THE H. B. ROBINSON STEAM ELECTRIC
 PLANT, UNIT NO. 2

Gentlemen:

The purpose of this letter is to request NRC review and approval of the equivalent margins analyses performed for the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, beltline materials in accordance with 10 CFR 50, Appendix G, as submitted to the NRC via letters dated July 6, 1992, August 19, 1993, October 27, 1993, November 29, 1993, December 21, 1993, and June 13, 1994. This letter is in response to the May 9, 1994 NRC letter requesting that we submit a request for NRC review and approval of the equivalent margins analysis for the HBRSEP, Unit No. 2 reactor vessel beltline materials. In our letter dated June 13, 1994, we requested a delay until June 20, 1994, to respond to the NRC's May 9, 1994 letter.

Carolina Power & Light Company (CP&L) has reviewed and concurs in the findings and conclusions of the Westinghouse Owners' Group Report WCAP-13587, Revision 1. CP&L confirms that all beltline materials within the HBRSEP, Unit No. 2 reactor vessel meet or have a higher J-R curve than the bounding plate for three loop plants, as analyzed in WCAP-13587, Revision 1. Accordingly, CP&L requests the NRC review and approve WCAP-13587, Revision 1, as amended by the enclosure to CP&L letter to the NRC dated December 21, 1993, as they apply to HBRSEP, Unit No. 2. We are identifiable as Plant 7 within the report.

Questions regarding this matter may be referred to Mr. K. R. Jury at (803) 383-1363.

Very truly yours,

R. M. Krich
 Manager - Regulatory Affairs

120018

- c: Mr. S. D. Ebnetter, Regional Administrator, USNRC, Region II
- Ms. B. L. Mozafari, USNRC Project Manager, HBRSEP
- Mr. W. T. Orders, USNRC Senior Resident Inspector, HBRSEP

9407120022 Highway 151 and SC 23 Hartsville SC

MAY
 1028 1/0