

CATEGORY 1

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NRR:9702200339 DOC.DATE: 97/02/13 NOTARIZED: NO DOCKET #
 FACIL:50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH.NAME AUTHOR AFFILIATION
 CHERNOFF,H.K. Carolina Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Informs that mod to spent fuel pool drain line to provide anti-siphon protection will be completed by 970918.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: General Distribution

NOTES:

RECIPIENT ID CODE/NAME	COPIES	LTTR	ENCL	RECIPIENT ID CODE/NAME	COPIES	LTTR	ENCL
PD2-1 LA	1			PD2-1 PD	1		
MOZAFARI, B	1						
INTERNAL: FILE CENTER-01	1			NRR/DE/ECGB/A	1		
NRR/DE/EMCB	1			NRR/DRCH/HICB	1		
NRR/DSSA/SPLB	1			NRR/DSSA/SRXB	1		
NUDOCS-ABSTRACT	1			OGC/HDS3	1		
EXTERNAL: NOAC	1			NRC PDR	1		

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN 5D-5(EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 0

MA



Carolina Power & Light Company

Robinson Nuclear Plant
3581 West Entrance Road
Hartsville SC 29550

Robinson File No: 13510

Serial: RNP-RA/97-0015

FEB 13 1997

United States Nuclear Regulatory Commission

Attn: Document Control Desk

Washington, D.C. 20555-0001

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

DOCKET NO. 50-261/LICENSE NO. DPR-23

ANTI-SIPHON PROTECTION FOR THE SPENT FUEL POOL DRAIN LINE

Gentlemen:

NRC letter dated October 10, 1996, transmitted a report that discussed spent fuel storage pool concerns that were identified by the NRC. The letter noted that the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No 2 had piping that extends to near the bottom of the spent fuel pool and that lacks passive anti-siphon protection. The letter further stated that the NRC intends to initiate activities to evaluate the potential for a safety enhancement backfit.

As discussed with the NRC Project Manager in late 1996, Carolina Power & Light (CP&L) Company is developing a modification to the spent fuel pool drain line to provide anti-siphon protection. The modification is currently expected to be completed by September 18, 1997.

Questions regarding this matter may be referred to me at (803) 857-1437.

Very truly yours,

H. K. Chernoff

Supervisor - Licensing/Regulatory Programs

200055

JSK/klb

c: Mr. L. A. Reyes, Regional Administrator, USNRC, Region II

Ms. B. L. Mozafari, USNRC Project Manager, HBRSEP

Mr. B. B. Desai, USNRC Senior Resident Inspector, HBRSEP

9702200339 970213
PDR ADOCK 05000261
P PDR

40011/0