

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9801130100 DOC.DATE: 98/01/07 NOTARIZED: NO DOCKET #
 FACIL:50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH.NAME AUTHOR AFFILIATION
 WILKERSON,T.M. Carolina Power & Light Co.
 RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards replacement page that updates info in SBRSEP,Unit
 2 Emergency Response Data Sys Data Point Library.Change
 implemented on 971208 & reflects mod of info used to
 calculate volume weighted containment average temperature.

DISTRIBUTION CODE: A026D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2
 TITLE: Emergency Response Data System (ERDS)

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTR	ENCL		ID	CODE/NAME	LTR	ENCL
	AEOD/IRB	01	1	1		TRIMBLE,D	1	1	
INTERNAL:	AEOD		1	1		AEOD/DOA/IRB	1	1	
	FILE CENTER		1	1		RGN2 ERC	1	1	
	RGN2	FILE	1	1					
EXTERNAL:	NRC	PDR	1	1					

TOTAL NUMBER OF COPIES REQUIRED: LTR 8 ENCL 8



Carolina Power & Light Company
Robinson Nuclear Plant
3581 West Entrance Road
Hartsville SC 29550

Robinson File No: 13510
Serial: RNP-RA/98-0006

JAN 07 1998

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23
EMERGENCY RESPONSE DATA SYSTEM - DATA POINT LIBRARY REVISION

Gentlemen:

In accordance with 10 CFR 50, Appendix E, Paragraph VI, section 3.a, the attachment to this letter provides a replacement page that updates information in the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2 Emergency Response Data System Data Point Library. This change was implemented on December 8, 1997, and reflects a modification of the information used to calculate the volume weighted containment average temperature.

If you have any questions concerning this matter, you may contact me or Mr. H. K. Chernoff of my staff.

Very truly yours,

T. M. Wilkerson
Manager - Regulatory Affairs

JSK/jk

Attachment

c: Mr. B. B. Desai, USNRC Senior Resident Inspector, HBRSEP
Mr. J. W. Shea, USNRC Project Manager, HBRSEP
Mr. L. A. Reyes, Regional Administrator, USNRC, Region II

9801130100 980107
PDR ADOCK 05000261
F PDR



Handwritten initials/signature

DATA POINT LIBRARY REFERENCE FILE

Date:	<u>12/08/97</u>
Reactor Unit:	<u>R02</u>
Data Feeder:	<u>ERFIS</u>
NRC ERDS Parameter:	<u>CTMNT TEMP</u>
Point ID:	<u>CVT0001</u>
Plant Spec Point Desc.:	<u>VOLUME WEIGHTED AVE CV AIR TEMP</u>
Generic/Cond Desc.:	<u>CONTAINMENT TEMPERATURE</u>
Analog/Digital:	<u>A</u>
Engr Units/Dig States:	<u>DEGF</u>
Engr Units Conversion:	<u>N/A</u>
Minimum Instr Range:	<u>0.0</u>
Maximum Instr Range:	<u>600.0</u>
Zero Point Reference:	<u>N/A</u>
Reference Point Notes:	<u>N/A</u>
PROC or SENS:	<u>P</u>
Numbers of Sensors:	<u>5</u>
How Processed:	<u>SUM</u>
Sensor Locations:	<u>70 FT ABOVE FLOOR, NT SIDE OF</u> <u>HVH-2, BEHIND RCP C, NEAR RCP B</u> <u>LADDER, BEHIND RCP A</u>
Alarm/Trip Set Points:	<u>N/A</u>
NI Detector Power Supply	
Cut-off Power Level:	<u>N/A</u>
NI Detector Power Supply	
Turn-on Power Level:	<u>N/A</u>
Instrument Failure Mode:	<u>QUALITY -NCAL</u>
Temperature Compensation	
For DP Transmitters:	<u>N/A</u>
Level Reference Leg:	<u>N/A</u>
Unique System Desc.:	<u></u>