



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

CAROLINA POWER & LIGHT COMPANY

DOCKET NO. 50-261

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 161  
License No. DPR-23

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Carolina Power & Light Company (the licensee), dated August 23, 1994, as supplemented March 2, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications, as indicated in the attachment to this license amendment; and paragraph 3.B. of Facility Operating License No. DPR-23 is hereby amended to read as follows:

**B. Technical Specifications**

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 161, are hereby incorporated in the license. Carolina Power & Light Company shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director  
Project Directorate II-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: April 14, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 161

FACILITY OPERATING LICENSE NO. DPR-23

DOCKET NO. 50-261

Replace the following page of the Appendix A Technical Specifications with the enclosed page. The revised areas are indicated by marginal lines.

Remove Page

3.5-11

Insert Page

3.5-11

TABLE 3.5-1 (Continued)

ENGINEERED SAFETY FEATURE SYSTEM INITIATION INSTRUMENT SETTING LIMITS

<u>NO.</u>	<u>FUNCTIONAL UNIT</u>	<u>CHANNEL ACTION</u>	<u>SETTING LIMIT</u>
6. (Cont'd)	b. 480V Emerg. Bus Undervoltage (Degraded Voltage) Time Delay	Trip Normal Supply Breaker	430 Volts $\pm$ 4 Volts 10.0 Second Delay $\pm$ 0.5 sec.
7.	Containment Radioactivity High	Ventilation Isolation	The alarm is set with a method described in the ODCM.

- 
- Initiates also containment isolation (Phase A), feedwater line isolation and starting of all containment fans.
  - .. Initiates also containment isolation (Phase B).
  - ... Derived from equivalent WP measurements.