

6.13 HIGH RADIATION AREA

6.13.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.1601(a) of 10 CFR 20, each High Radiation Area in which the intensity of radiation is 1000 mRem/hr or less shall be barricaded and conspicuously posted as a High Radiation Area and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit (RWP).^{*} Any individual or group of individuals permitted to enter such areas shall be provided with or accompanied by one or more of the following:

- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area.
- b. A radiation monitoring device provided for each individual which continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate levels in the area have been established and personnel have been made knowledgeable of them.
- c. An individual qualified in radiation protection procedures who is equipped with a radiation dose rate monitoring device. This individual shall be responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance at the frequency specified by the Radiation Control Supervisor in the Radiation Work Permit.

6.13.2 The requirements of 6.13.1 above shall also apply to each high radiation area in which the intensity of radiation is greater than 1000 mRem/hr at 30 centimeters (12 inches) from the radiation source or from any surface penetrated by the radiation, but less than 500 rads/hour at 1 meter from the radiation source or from any surface penetrated by the radiation. In addition, locked doors shall be provided to prevent unauthorized entry into such areas and the keys shall be maintained under the administrative control of the Operations Shift Supervisor on duty and/or the Radiation Control Supervisor. Entrance there to shall also be controlled by requiring issuance of a Radiation Work Permit. The footnote for Section 6.13.1 is not applicable to each high radiation area in which the intensity of radiation is greater than 1000 mRem/hr.

* Health Physics personnel or personnel escorted by Health Physics personnel shall be exempt from the RWP issuance requirement during the performance of their assigned duties within the RCA, provided they comply with approved radiation protection procedures for entry into high radiation areas.

November 21, 1994

Mr. C. S. Hinnant, Vice President
Carolina Power & Light Company
H. B. Robinson Steam Electric Plant,
Unit No. 2
Post Office Box 790
Hartsville, South Carolina 29551-0790

Dear Mr. Hinnant:

SUBJECT: ISSUANCE OF AMENDMENT NO. 153 TO FACILITY OPERATING LICENSE NO. DPR-23 REGARDING OPPOSITE TRAIN SURVEILLANCE TESTING REQUIREMENTS - H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2 (TAC NO. M89842)

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 153 to Facility Operating License No. DPR-23 for the H. B. Robinson Steam Electric Plant, Unit No. 2. This amendment changes the Technical Specifications in response to your request dated June 29, 1994.

The amendment deletes the requirement to perform alternate train testing to demonstrate that other, similar, safety-related components are operable when components are found, or made, inoperable in the safety injection, residual heat removal, and containment spray systems. The surveillance requirements, which the licensee refers to as accelerated testing requirements, affect the safety injection (SI) pumps, residual heat removal (RHR) pumps, containment spray (CS), SI, RHR and CS flow paths.

A copy of the related Safety Evaluation is enclosed. Notice of Issuance will be included in the Commission's bi-weekly Federal Register notice.

Sincerely,

Original signed by:

Brenda L. Mozafari, Project Manager
Project Directorate II-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-261

Enclosures:

1. Amendment No. 153 to DPR-23
2. Safety Evaluation

cc w/enclosures:
See next page

DOCUMENT NAME: G:\ROBINSON\ROB89842.AMD

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	LA:PD21:DRPE	E	PM:PD21:DRPE	E	NRR:DOPS 94-235	E	D:PD21:DRPE	OGC	
NAME	PDAnderson		BMozafari/rsl		CGrimes		MBoyle:Acting		
DATE	10/1/94		10/20/94		10/2/94		10/2/94		

OFFICIAL RECORD COPY

~~941128017A~~

Mr. C. S. Hinnant
Carolina Power & Light Company

H. B. Robinson Steam Electric
Plant, Unit No. 2

cc:

Mr. R. E. Jones
General Counsel - Legal Department
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Mr. Dayne H. Brown, Director
Department of Environmental,
Health and Natural Resources
Division of Radiation Protection
Post Office Box 27687
Raleigh, North Carolina 27611-7687

Karen E. Long
Assistant Attorney General
State of North Carolina
Post Office Box 629
Raleigh, North Carolina 27602

Mr. Robert P. Gruber
Executive Director
Public Staff - NCUC
Post Office Box 29520
Raleigh, North Carolina 27626-0520

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
H. B. Robinson Steam Electric Plant
2112 Old Camden Road
Hartsville, South Carolina 29550

Mr. Max Batavia, Chief
South Carolina Department of Health
Bureau of Radiological Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta St., N.W., Ste. 2900
Atlanta, Georgia 30323

Mr. H. W. Habermeyer, Jr.
Vice President
Nuclear Services Department
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Mr. Dale E. Young
Plant General Manager
Carolina Power & Light Company
H. B. Robinson Steam Electric Plant
3581 West Entrance Road
Hartsville, South Carolina 29550

Hartsville Memorial Library
147 West College Avenue
Hartsville, South Carolina 29550

Public Service Commission
State of South Carolina
Post Office Drawer 11649
Columbia, South Carolina 29211

Mr. R. M. Krich
Manager - Regulatory Affairs
Carolina Power & Light Company
H. B. Robinson Steam Electric Plant,
Unit No. 2
Post Office Box 790
Hartsville, South Carolina 29551-0790