

- j. If any of the specified limiting conditions for refueling are not met, refueling of the reactor shall cease; work shall be initiated to correct the conditions so that the specified limits are met; and no operations which may increase the reactivity of the core shall be made.
- k. The reactor shall be subcritical as required by 3.10.8.3.

3.8.2 The Spent Fuel Building Filter system and the Containment Purge filter system shall satisfy the following conditions:

- a. The results of the in-place cold DOP and halogenated hydrocarbon tests at greater than 20 percent design flows on HEPA filters and charcoal adsorber banks shall show ≥ 99 percent DOP removal and ≥ 99 percent halogenated hydrocarbon removal.
- b. Verification by way of laboratory carbon sample analysis from the Spent Fuel Building filter system carbon and the Containment Purge filter system carbon to show ≥ 90 percent radioactive methyl iodide removal in accordance with test 5.b of Table 5-1 of ANSI/ASME N509-1976 except that ≥ 70 percent relative humidity air is required.
- c.
 - 1. The Spent Fuel Building refueling filter fan shall be shown to operate within $\pm 10\%$ of the design flow.
 - 2. At least one Containment purge filter fan shall be shown to operate within $\pm 10\%$ of the design flow and must be operable during core alterations or movement of irradiated fuel assemblies, or at least one automatic containment isolation valve in each line penetrating the containment which provides a direct path from the containment atmosphere to the outside atmosphere shall be securely closed.
- d. During fuel handling operations, the relative humidity (R.H.) of the air processed by the refueling filter systems shall be ≤ 70 percent.
- e. From and after the date that the Spent Fuel Building filter system is made or found to be inoperable for any reason, fuel handling operations in the Spent Fuel Building shall be terminated immediately.