

February 14, 1997

Mr. C. S. Hinnant, Vice President
Carolina Power & Light Company
H. B. Robinson Steam Electric Plant,
Unit No. 2
3581 West Entrance Road
Hartsville, South Carolina 29550

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING THE ADEQUACY OF DELAYED
OFFSITE POWER CIRCUIT FOR THE H. B. ROBINSON STEAM ELECTRIC PLANT,
UNIT NO. 2 (TAC M97957)

Dear Mr. Hinnant:

The NRC has recently reviewed offsite power system designs for older operating plants as a result of lessons learned from the Maine Yankee Independent Safety Assessment. The review was conducted to verify the adequacy of delayed offsite power circuits. In particular, the staff was concerned with plants that rely upon main and unit auxiliary transformers to backfeed power to the onsite distribution system by removing the disconnect links between the main generator and the main transformer. Before we can conclude that the offsite power system design at the H. B. Robinson Steam Electric Plant, Unit No. 2 (HBR) meets its design licensing basis, additional information is needed regarding the delayed offsite power circuit at HBR. The response to the enclosed request for additional information is expected within 30 days.

Please contact me at (301) 415-2020 if you have any questions concerning this request.

Sincerely,

/ s /

Brenda Mozafari, Project Manager
Project Directorate II-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-261

Enclosure: Request for Additional Information

cc w/enclosure: See next page
FILENAME - G:\ROBINSON\ROB97957.RAI

Distribution:

Docket File OGC
PUBLIC ACRS
PD II-1 Rdg SVarga
JJohnson, RII PKang
JZwolinski JCalvo

OFFICE	LA:PDII-1	PM:PDII-1	D:PDII-1
NAME	Dunnington	BMozafari	MReinhart
DATE	2/14/96 ^{ETD}	2/14/96	2/14/96
COPY	Yes/No	Yes/No	Yes/No

OFFICIAL RECORD COPY

NRC FILE CENTER COPY

210047

9702240287 970214
PDR ADOCK 05000261
P PDR

Mr. C. S. Hinnant
Carolina Power & Light Company

cc:

Mr. William D. Johnson
Vice President and Senior Counsel
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Ms. Karen E. Long
Assistant Attorney General
State of North Carolina
Post Office Box 629
Raleigh, North Carolina 27602

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
H. B. Robinson Steam Electric Plant
2112 Old Camden Road
Hartsville, South Carolina 29550

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta St., N.W., Ste. 2900
Atlanta, Georgia 30323

Mr. Dale E. Young
Plant General Manager
~~Carolina Power & Light Company~~
H. B. Robinson Steam Electric Plant
Unit No. 2
3581 West Entrance Road
Hartsville, South Carolina 29550

Public Service Commission
State of South Carolina
Post Office Drawer 11649
Columbia, South Carolina 29211

H. B. Robinson Steam Electric
Plant, Unit No. 2

Mr. Dayne H. Brown, Director
Department of Environmental,
Health and Natural Resources
Division of Radiation Protection
Post Office Box 27687
Raleigh, North Carolina 27611-7687

Mr. Robert P. Gruber
Executive Director
Public Staff - NCUC
Post Office Box 29520
Raleigh, North Carolina 27626-0520

Mr. Max Batavia, Chief
South Carolina Department of Health
Bureau of Radiological Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Mr. J. Cowan
Vice President
Nuclear Services and Environmental
Support Department
Carolina Power & Light Company
Post Office Box 1551 - Mail OHS7
Raleigh, North Carolina 27602

Mr. Milton Shymlock
U. S. Nuclear Regulatory Commission
101 Marietta Street, N.W. Suite 2900
Atlanta, Ga. 3023-0199

REQUEST FOR ADDITIONAL INFORMATION
REGARDING THE ADEQUACY OF THE DELAYED OFFSITE POWER CIRCUIT
FOR THE
H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

The NRC recently performed a review of offsite power system designs for older operating plants as a result of lessons learned from the Maine Yankee Independent Safety Assessment. The review was conducted to verify the adequacy of delayed offsite power circuits. In particular, the staff was concerned with plants that rely upon main and unit auxiliary transformers to backfeed power to the onsite distribution system by removing the disconnect links between the main generator and the main transformer. This review noted this feature in the design of the H. B. Robinson Steam Electric Plant, Unit No. 2 (HBR).

HBR was licensed with only one immediately available offsite power circuit and a delayed offsite power circuit that relies on a backfeed through the main and unit auxiliary transformers. To establish this backfeed the main generator disconnect links must be removed. For a delayed offsite power circuit to be considered an acceptable source of offsite power, it must be shown that power can be reestablished in sufficient time to prevent fuel design limits and design conditions of the reactor coolant pressure boundary from being exceeded. The HBR Updated Final Safety Analysis Report (UFSAR) states that removal of the main generator disconnect links in order to establish offsite power is expected to take a minimum of four hours. The UFSAR does not state, however, the maximum expected time needed to establish this backfeed source of power. The staff could not find any documentation to indicate that an analysis has been done to demonstrate the adequacy of this delayed offsite power circuit.

The staff is concerned that Carolina Power & Light Company (CP&L) may not have performed an analysis to demonstrate the adequacy of its delayed offsite power circuit. To resolve this concern, we request that you provide the information requested below.

1. State whether you have performed an analysis to demonstrate that the delayed offsite power circuit can be established in sufficient time to prevent fuel design limits and design conditions of the reactor coolant pressure boundary from being exceeded. If such analysis was performed, provide a summary of the analysis and any conclusions (e.g., adequacy of time limits and voltages, etc.).

ENCLOSURE

2. Describe any procedures in place for implementing the delayed offsite power circuit when needed, and state whether CP&L has tested its capability to backfeed power within an allowable time limit. If so, state how often operators are trained on using the procedures and how long it takes to establish the backfeed.
3. The staff noted that HBR's Technical Specifications do not contain surveillance requirements regarding the delayed offsite power circuit. Explain how HBR periodically verifies its ability to establish offsite power within a specified time limit using the main and unit auxiliary transformers.