

United States Nuclear Regulatory Commission

Attachment to Serial: RNP-RA/99-0076

2 Pages

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
REQUEST FOR TECHNICAL SPECIFICATIONS CHANGE
RESIDUAL HEAT REMOVAL ISOLATION VALVE INTERLOCK

CORRECTED RETYPED TECHNICAL SPECIFICATIONS PAGE

9904160169 990409
PDR ADOCK 05000261
P PDR

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.14.1 (continued)	Within 24 hours following valve actuation due to automatic or manual action or flow through the valve
SR 3.4.14.2 Verify RHR System interlock prevents the valves from being opened with a simulated or actual RCS pressure signal > 474 psig.	18 months