

In Reply Refer To:
RII:PJK
50-261

July 19, 1979
SSINS 50-261

Carolina Power and Light Company
Attn: J. A. Jones, Executive
Vice President and Chief
Operating Officer
411 Fayetteville Street
Raleigh, North Carolina 27602

Gentlemen:

Subject: Confirmation of Action

This refers to our telephone conversation of July 19, 1979, regarding the requirements for testing of anchor bolts on safety-related systems at the Robinson facility as contained in NRC Bulletin 79-02.

With regard to the matters discussed, it is our understanding that your Robinson Nuclear Plant will not be returned to power operation without the concurrence of this office. Our concurrence will be based on the results of your technical discussions with this office of the results of the anchor bolt testing program, the bases for operability of safety-related systems and your proposed schedule for further testing if required to assure operability.

Please inform us immediately if your understanding of these items is different from that stated above.

Sincerely,

*7/19 Discussed contents with
E. Jordan IE:HQ.*

James P. O'Reilly
Director

*May
CCP*

cc: H. R. Banks
Manager, Nuclear Operations
411 Fayetteville Street
Raleigh, North Carolina 27602

bcc: Local Public Document Room
Washington Public Document Room
Central Files
Nuclear Safety Information Center
Technical Information Center
IE Mail and File
Region II Reading Room
State of North Carolina

R. B. Starkey, Plant Manager
P. O. Box 790
Hartsville, South Carolina 29550

Principal Staff
N. C. Moseley, ROI
G. Gower, X005

| | | |
|---------|-----------|------------|
| OFFICE | RII:RONS | |
| SURNAME | PJK | |
| DATE | CMUpright | PJK/ogg:cb |