

FEB 11 1983

IE HQ FILE COPY

Carolina Power and Light Company
 ATTN: Mr. E. E. Utley
 Executive Vice President
 411 Fayetteville Street
 Raleigh, NC 27602

Gentlemen:

SUBJECT: APPROVAL OF EXTENDED MAINTENANCE REQUEST FOR H. B. ROBINSON
 DN: 50-261

This letter confirms the telephone discussion of February 8, 1983, between Mr. S. R. Zimmerman, Manager of Licensing and Permits, and Mr. R. C. Lewis of this office, in which, after consultation with NRR, we concurred with your request of a 24 hour extension to the maintenance period in accordance with Technical Specification 3.3.7. The extension permitted the plant to remain in a power operation mode while repairs to the "B" Service Water Booster Pump were completed.

Should you have any questions concerning this letter, please contact this office.

Sincerely,

James P. O'Reilly
 Regional Administrator

cc:

R. B. Starkey, Jr., Plant General Manager

bcc:

H. R. Denton, NRR
 S. A. Varga, NRR
 NRC Resident Inspector
 Document Management Branch
 State of South Carolina

RII <i>CWH</i> CWHel:caw 2/10/83	RII <i>CWH for</i> PRBemis 2/10/83	RII <i>DMV</i> DMVerrelli 2/10/83	RII <i>HCD</i> RCLewis 2/10/83
---	---	--	---

DMV ok to cut 3 posts

8307140207 830211
 PDR ADOCK 05000261
 P PDR

1/0 IE31