REGULATORY NFORMATION DISTRIBUTION SYMEM (RIDS)

•*	-	-				
ACCESSION NBR: 8708				NOTARIZEI		DOCKET #
FACIL: 50-261 H. B.	Robinson	Plant, Un	it 2, Car	olina Power	∿ & Light C	05000261
AUTH. NAME	AUTHOR A	FILIATION				• .
ZIMMERMAN, S. R.	Carolina	Power & Li	ght Co.			
RECIP. NAME	RECIPIEN	T AFFILIAT	ION			
	Docume	nt Control	Branch ()	Document Co	ontrol Desk)

SUBJECT: Forwards cost estimate for installation of radio communications control circuit for NRC in facilty,per 870629 request.

DISTRIBUTION CODE: A045D COPIES RECEIVED: LTR $\frac{1}{2}$ ENCL $\frac{1}{2}$ SIZE: $\frac{2}{2}$ TITLE: OR Submittal: Emergency Preparedness Plans, Implement'g Procedures, C

NOTES:

--- •

	RECIPIENT ID CODE/NAU PD2-1 PD	ME	COPIE LTTR 1		RECIPIENT ID CODE/NAME ECCLESTON,K	COPI LTTR 1	
INTERNAL:	AEOD/DOA/IRB	01	1 1	1 1	NRR/DREP/EPB	1	1
EXTERNAL:	LPDR NSIC		1 1	1 1	NRC PDR	i	1



AUG 13 1987

SERIAL: NLS-87-168

United States Nuclear Regulatory Commission ATTENTION: Document Control Desk Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2 DOCKET NO. 50-261/LICENSE NO. DPR-23 BIFC RADIO COMMUNICATIONS RECOMMENDATION ESTIMATE

Gentlemen:

Carolina Power & Light Company provides the enclosed cost estimate for installation of a radio communications control circuit for the NRC in the Robinson Plant Emergency Operations Facility, as requested by your June 29, 1987 letter. We understand that NRC Region II may request installation of the system in the near future.

If you have any questions concerning this submittal, please contact my staff.

Yours very truly,

Mauran

S. R. Zimherman Manager Nuclear Licensing Section

JSK/ppo (5257JSK)

Enclosure

cc: Mr. D. M. Collins Mr. T. R. Decker Dr. J. Nelson Grace Mr. K. Eccleston Mr. H. Krug



411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

HBR CONTROL CIRCUIT FOR RADIO COMMUNICATIONS IN EOF FOR NRC

Total Estimated Cost:	\$6,539.00
Cost Summary:	
Construction Labor/Direct Materials Overhead	\$4,624.00 (Estimated Man-hours: 289) 990.00 925.00

Project Scope:

Install two twin lead, direct current, control circuits from the NRC areas in the EOF to the outside/roof of the building. Both ends of the control circuits should be terminated with WE-742 wire junctions and labeled for NRC emergency use only. The outside termination should be housed in a waterproof container to protect it from the elements. The exact placement of these terminal blocks are to be determined by the licensee. The wire for the control circuits should be at least equal in quality and size to those installed by a telephone company for voice quality telephone circuits.