

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8903080158 DOC.DATE: 89/02/27 NOTARIZED: NO DOCKET #  
 FACIL:50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261  
 AUTH.NAME AUTHOR AFFILIATION  
 MORGAN,R.E. Carolina Power & Light Co.  
 RECIP.NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Submits 1988 annual rept on primary coolant iodine spikes.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 1  
 TITLE: OR Submittal: General Distribution

### NOTES:

|           | RECIPIENT              |      | COPIES |  |  |
|-----------|------------------------|------|--------|--|--|
|           | ID CODE/NAME           | LTTR | ENCL   |  |  |
|           | PD2-1 LA               | 1    | 0      |  |  |
|           | LO,R                   | 1    | 1      |  |  |
| INTERNAL: | ARM/DAF/LFMB           | 1    | 0      |  |  |
|           | NRR/DEST/CEB 8H        | 1    | 1      |  |  |
|           | NRR/DEST/MTB 9H        | 1    | 1      |  |  |
|           | NRR/DEST/SICB          | 1    | 1      |  |  |
|           | <u>NUDOCS-ABSTRACT</u> | 1    | 1      |  |  |
|           | <u>REG FILE 01</u>     | 1    | 1      |  |  |
| EXTERNAL: | LPDR                   | 1    | 1      |  |  |
|           | NSIC                   | 1    | 1      |  |  |
|           | PD2-1 PD               | 2    | 2      |  |  |
|           | NRR/DEST/ADS 7E        | 1    | 1      |  |  |
|           | NRR/DEST/ESB 8D        | 1    | 1      |  |  |
|           | NRR/DEST/RSB 8E        | 1    | 1      |  |  |
|           | NRR/DOEA/TSB 11        | 1    | 1      |  |  |
|           | OGC/HDS1               | 1    | 0      |  |  |
|           | RES/DSIR/EIB           | 1    | 1      |  |  |
|           | NRC PDR                | 1    | 1      |  |  |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 16

m/A-4

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S



Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT  
POST OFFICE BOX 790  
HARTSVILLE, SOUTH CAROLINA 29550  
FEB. 27 1989

Robinson File No: 13510C

Serial: RNP/89-0814

United States Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261  
LICENSE NO. DPR-23  
1988 ANNUAL REPORT - PRIMARY COOLANT IODINE SPIKES

Dear Sir:

Carolina Power and Light Company submits the 1988 Annual Report on Primary Coolant Iodine Spikes. This annual report is submitted as required by Technical Specification 6.9.1.b.

During 1988, the primary coolant did not exceed 1.0  $\mu\text{Ci}/\text{gram}$  dose equivalent I-131 nor did the Gross Activity exceed 100/E-Bar  $\mu\text{Ci}/\text{gram}$  as set forth in Technical Specification 3.1.4.

If you have any questions concerning this report, please contact my staff or me.

Very truly yours,

R. E. Morgan  
General Manager  
H. B. Robinson S. E. Plant

SAG:bah

cc: M. L. Ernst  
L. W. Garner

8903080158 890227  
PDR ADOCK 05000261  
R PDC

A001  
1/0