

## REGULATORY DOCKET FILE COPY

R. Diggs

B. Jones (4)

B. Scharf (10) ACRS (16)

C. Miles

DISTRIBUTION
Docket File 50-261
NRC PDR
Local PDR
TERA
NSIC
NRR Reading
ORB1 Reading
H. Denton
D. Eisenhut
R. Tedesco
W. Gammill
A. Schwencer
D. Neighbors
C. Parrish

Docket No. 50-261

Mr. J. A. Jones Senior Executive Vice President Carolina Power and Light Company 336 Fayetteville Street Raleigh, North Carolina 27602

Dear Mr. Jones:

On December 5, 1979, the Commission issued Amendment No. 45 to Facility Operating License No. DPR-23 for the H. B. Robinson Steam Electric Plant, Unit No. 2. Item 16 of Table 4.1-3, page 4.1-10 in the Technical Specifications was inadvertently removed.

Enclosed is a corrected page 4.1-10 which restores item 16.

Sincerely,

I&E (5)

Attorney, OELD

Original Signed By

A. Schwencer, Chief Operating Reactors Branch #1 Division of Operating Reactors

Enclosure: As Stated

cc: w/enclosure
See next page





DOR:ORB DOR:OF

JDNe hbors:jbCSPar

DOR: ORB 1 (p) bCSParrish () 01/10/80

DOR: ORB

8002280





## UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

January 10, 1980

Docket No. 50-261

Mr. J. A. Jones Senior Executive Vice President Carolina Power and Light Company 336 Fayetteville Street Raleigh, North Carolina 27602

Dear Mr. Jones:

On December 5, 1979, the Commission issued Amendment No. 45 to Facility Operating License No. DPR-23 for the H. B. Robinson Steam Electric Plant, Unit No. 2. Item 16 of Table 4.1-3, page 4.1-10 in the Technical Specifications was inadvertently removed.

Enclosed is a corrected page 4.1-10 which restores item 16.

t X Cliv

Sincerely,

A. Schwencer, Chief Operating Reactors Branch #1 Division of Operating Reactors

Enclosure: As Stated

cc: w/enclosure

See next page

cc: G. F. Trowbridge, Esquire Shaw, Pittman, Potts and Trowbridge 1800 M Street, N.W. Washington, D. C. 20036

> Hartsville Memorial Library Home and Fifth Avenues Hartsville, South Carolina 29550

Michael C. Farrar, Chairman Atomic Safety and Licensing Appeal Board Panel U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Richard S. Salzman Atomic Safety and Licensing Appeal Board Panel U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Dr. W. Reed Johnson
Atomic Lafety and Licensing
Appeal Board Panel
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

		<u>Check</u>	<u>Preouency</u>	Time Betwee Tests
13.	Turbine Inspection	Visual, Magnaflux and Die Penetrant	Every five years	6 year
14.	Fans and Associated Char- coal and Absolute Filters for Con- trol Room and Residual Heat Removal Compartments (HVE-19, HVE-5a and 5b respec- tively)	Fans functioning. Laboratory tests on charcoal must show > 99% iodine removal. In-place test must show > 99% removal of polydispersed DOP particles by the HEPA filters and Freon by the charcoal filters.	Once per operating cycle.	NA
25.	Isolation Seal Water System	Functioning	Each refueling shutdown	NA
16.	Overpressure Protection System	Functioning	Each refueling shutdown	NA

NA - Not applicable