

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8012080479 DOC. DATE: 80/12/03 NOTARIZED: YES DOCKET #
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power and Light 05000261
 AUTH. NAME: AUTHOR AFFILIATION
 UTLEY, E. E. Carolina Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION
 VARGA, S. A. Operating Reactors Branch 1

SUBJECT: Requests revision to Tech Specs reflecting changes &
 additions to plant as result of NRC required fire protection
 sys mods. Proposed revisions encl.

DISTRIBUTION CODE: A006S COPIES RECEIVED: LTR 3 ENCL 3 SIZE: 2 + 13
 TITLE: Fire Protection Information (After Issuance of OP. Lic.)

NOTES:

	RECIPIENT ID CODE/NAME		COPIES LTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTR ENCL
ACTION:	VARGA, S.	04	7	7			
INTERNAL:	CHEM ENG BR-A	7	5	5	I&E	06	2 2
	NRC PDR	02	1	1	OELD		1 0
	REG FILE	01	1	1	WAMBACH, T.	10	1 1
EXTERNAL:	ACRS	09	16	16	LPDR	03	1 1
	NSIC	05	1	1			

DEC 9 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 36 ENCL 35

SL



Carolina Power & Light Company

December 3, 1980

File No: NG-3514 (R)

Serial No: NO-80-1794

1980 DEC 8 AM 9 35

Office of Nuclear Reactor Regulation
Attention: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
United States Nuclear Regulatory Commission
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

DOCKET NO. 50-261

LICENSE NO. DPR-23

REVISION OF TECHNICAL SPECIFICATIONS - FIRE PROTECTION

Dear Mr. Varga:

In accordance with the Code of Federal Regulations, Title 10, Part 50.90 and Part 2.101, Carolina Power and Light Company (CP&L) hereby requests a revision to the Technical Specifications for its H. B. Robinson Steam Electric Plant, Unit No. 2. This request reflects changes and additions to the plant as a result of the fire protection system modifications required by the NRC. This revision changes the proposed Fire Protection Technical Specifications submitted to the NRC on May 17, 1979, and a proposed amendment to those Specifications submitted on June 7, 1979.

Enclosed are replacement pages for the H. B. Robinson Steam Electric Plant, Unit No. 2 Technical Specifications which reflect these revisions. Changes are indicated by the vertical lines in the right hand margin of the affected pages. For your convenience, we have also enclosed the entire proposed Fire Protection Technical Specifications.

Because these modifications and changes were required by your staff, it is CP&L's understanding that no license fee is required.


We are currently developing plant procedures to ensure compliance with these proposed Technical Specifications. Due to the massive effort and long implementation time involved with these procedure preparations, we do not intend to implement the new procedures until final NRC approval of this proposed revision to the Technical Specifications has been received. Until such time as approval and issuance takes place we will maintain a fire protection program which complies with the original Fire Protection Technical Specifications, except for the propane engine-driven fire pump, which were issued on February 28, 1978 and which became effective March 30, 1978. Since the propane engine-driven fire pump was replaced by a diesel engine-driven fire pump, surveillance testing formerly required of the propane engine-driven pump will be performed on the diesel engine-driven pump in the interim until the new fire protection Technical Specifications are issued.

A006
5
3/3

8012080479

If you have any questions concerning this matter, please contact our staff.

Very truly yours,




E. E. Utley

Executive Vice President
Power Supply and Engineering & Construction

SBC/t1
Enclosure

Sworn to and subscribed before me this 3rd day of December 1980


Notary Public

My Commission Expires: October 4, 1981

cc: Mr. J. D. Neighbors (NRC)
Mr. J. P. O'Reilly (NRC-I&E)

