

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8202010195 DOC. DATE: 82/01/27 NOTARIZED: YES DOCKET #
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power and Light 05000261
 AUTH. NAME AUTHOR AFFILIATION
 HOWE, P.W. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 VARGA, S.A. Operating Reactors Branch 1

SUBJECT: Requests amend to License DPR-23, adding three safety-related hydraulic snubbers.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 24
 TITLE: General Distribution for after Issuance of Operating License

NOTES: w/Check \$200.00

ACTION:	RECIPIENT		COPIES		RECIPIENT	COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME	LTTR
	ORB #1 BC	01	13	13			
INTERNAL:	ELD		1	0	IE	06	2 2
	NRR/DHFS DEPY08		1	1	NRR/DL DIR		1 1
	NRR/DL/ORAB		1	0	NRR/DSI/RAB		1 1
	<u>REG FILE</u>	04	1	1			
EXTERNAL:	ACRS	09	10	10	LPDR	03	1 1
	NRC PDR	02	1	1	NSIC	05	1 1
	NTIS		1	1			



Carolina Power & Light Company

January 27, 1982

File: NG-3514(R)

Office of Nuclear Reactor Regulation
ATTN: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
United States Nuclear Regulatory Commission
Washington, D.C. 20555



H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
REQUEST FOR LICENSE AMENDMENT -
SAFETY-RELATED HYDRAULIC SNUBBERS

Dear Mr. Varga:

Summary

In accordance with the Code of Federal Regulations, Title 10, Part 50.90 and Part 2.101, Carolina Power & Light Company (CP&L) hereby requests revisions to the Technical Specifications for the H. B. Robinson Steam Electric Plant (HBR) Unit 2. These revisions involve the addition of three safety related hydraulic snubbers to Table 3.13-1 as required by Technical Specification 3.13.1.d.

Details

Three existing hydraulic snubbers, Nos. 28, 29 and 30, installed on the feedwater system piping have been reclassified as safety-related and should be added to Table 3.13-1 of HBR's Technical Specifications. These snubbers have been routinely tested as part of our hydraulic snubber surveillance program.

The affected page is enclosed for your review.

The requested change to the Technical Specifications constitutes one Class II amendment in accordance with 10CFR170.22. Accordingly, our check for \$1,200.00 is enclosed.

8202010195 820127
PDR ADOCK 05000261
PDR

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

A001
s/
1/1
w/cheat!
\$ 1200.00

Mr. Steven A. Varga

-2-

January 27, 1982

Should you have any questions regarding this matter, please contact my staff.

Yours very truly,




P. W. Howe
Vice President
Technical Services

DCW/lr (2790)

Enclosures

cc: Mr. J. P. O'Reilly
Mr. W. J. Ross

Sworn to and subscribed before me this 27th day of January, 1982.



My commission expires: Oct. 4, 1986